

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

Washington 25, D. C.

July 25, 1960

Honorable John A. McCone
Chairman
U. S. Atomic Energy Commission
Washington 25, D. C.

Subject: HUMBOLDT BAY POWER PLANT - PACIFIC GAS AND
ELECTRIC COMPANY

Dear Mr. McCone:

At its twenty-seventh meeting, in Washington, D. C., on July 20-22, 1960, the Advisory Committee on Reactor Safeguards met with and was advised by the applicant of its proposals to resolve the recommendations made in our letter of June 27, 1960.

As indicated in General Luedecke's letter to me dated July 21, 1960, the applicant proposed to install double isolation valves welded in tandem outside the dry well. These valves will be located immediately outside the dry well and the first valve will connect with a shroud tube which is an extension of the dry well.

It is the opinion of the Advisory Committee on Reactor Safeguards that this proposed arrangement will meet the recommendations contained in the next to last paragraph in our letter dated June 27, 1960.

Sincerely yours,

/s/ Leslie Silverman
Chairman

Reference:

Letter from A. R. Luedecke to L. Silverman dated July 21, 1960

C O P Y