



50-298

UNITED STATES  
**NUCLEAR REGULATORY COMMISSION**  
 WASHINGTON, D.C. 20555-0001

May 9, 1997

Mr. G. R. Horn  
 Sr. Vice President of Energy Supply  
 Nebraska Public Power District  
 1414 15th Street  
 Columbus, NE 68601

SUBJECT: COOPER NUCLEAR STATION - EVALUATION OF CORE SPRAY PIPING INDICATIONS  
 DURING REFUELING OUTAGE 17 (TAC NO. M95141)

Dear Mr. Horn:

By letter dated May 7, 1997, the Nebraska Public Power District (NPPD) provided the staff with the results of your re-examination of three indications on the core spray piping at the Cooper Nuclear Station (CNS). The three indications had been previously identified during the 1995 refueling outage. By letter dated December 21, 1995, the Nuclear Regulatory Commission (NRC) staff approved your flaw evaluations of those indications, and also approved plant operation for one fuel cycle without repair of the subject flaws. In that letter, the staff stipulated that continued operation beyond one cycle should be supported by re-inspection and re-evaluation of the indications in accordance with the requirements of American Society of Mechanical Engineers (ASME) Code, Section XI, 1989 Edition.

By letter dated November 27, 1996, NPPD notified the NRC that future inspections of the core spray spargers and piping would be performed in accordance with the Boiling Water Reactor Vessel Internals Project guidelines contained in EPRI Report TR-106740, dated July 1996, "BWR Vessel and Internals Project, Core Spray Internals Inspection and Flaw Evaluation Guidelines (BWRVIP-18)." The visual and ultrasonic (UT) re-examinations of the previously identified flaws were performed in accordance with this guidance during the current refueling outage (RFO-17).

In your letter of May 7, 1997, you reported the following results:

Weld Number	Length - 1995 results (in.)	Length - 1997 results (in.)	Projected length at end of next cycle (in.)	Maximum Allowable flaw size
A1	8.9	9.1	10.3	11.8
A21	5.5	5.6	6.8	11.8
B12	1.5	NA	NA	10.7

1/0  
 PFO

150058

9705130181 970509  
 PDR ADOCK 05000298  
 G PDR

**NRC FILE CENTER COPY**

In 1995, the apparent indication in the area of the B12 weld was based on a visual examination, which could not be confirmed by UT examination at the time. Your re-examination of that area during RFO-17 failed to identify any flaws, and you have concluded that the previously identified indication in that area is non-relevant. You further concluded that the slight increases reported in the lengths of the indications seen in the areas of the A1 and A21 welds may have resulted from differences in UT examination methods, or from crack growth. If the increases are attributed to crack growth, you concluded that the actual growth rate has been significantly less than the bounding rate assumed in your previous analyses provided in your letters of November 22 and December 18, 1995. You further concluded that the fracture mechanics evaluation submitted in those letters is still applicable, based on the absence of significant growth in the indications, and that the Code allowable flaw sizes will not be exceeded during an additional cycle of operation. You also committed to re-examine the two relevant indications using the BWRVIP-18 guidance at the next refueling outage.

The NRC staff has reviewed your letter of May 7, 1997, and concludes that the previous analyses and assumptions accepted in our letter dated December 21, 1995, are applicable to the current indications, due to the limited crack growth observed over the past cycle. Therefore, we conclude that the flaw sizes at the end of the next fuel cycle will not exceed the critical flaw sizes calculated using the methodologies and the acceptance criteria provided in IWB-3640 and Appendix C of the ASME Boiler and Pressure Vessel Code, Section XI, and that CNS can be safely operated for an additional fuel cycle without repair of the flaws in the areas of the A1 and A21 welds. Plant operation beyond the next fuel cycle should again be supported by the results of re-inspection and re-evaluation of the indications, consistent with the commitments in your May 7, 1997, letter.


In our letter of December 21, 1995, the staff requested you to provide an evaluation of the potential effects of reduced core spray flow due to leakage through the identified cracks, which were conservatively assumed to be through-wall. In addition, you were requested to evaluate the potential impact of loose parts resulting from a break of the core spray line at the identified crack locations. The staff has reviewed your evaluation of those potential effects, provided by letter dated March 29, 1996, and has concluded that these effects would result in a negligible increase in the peak cladding temperature calculated for the Cooper Nuclear Station. However, this review was based on the crack lengths reported in 1995 and on the Maximum Average Planar Linear Heat Generation Rates for the past fuel cycle. You are therefore requested to submit for staff review an updated analysis to confirm that these conclusions are valid for the next fuel cycle. This submittal is requested within 3 months of plant restart from the current refueling outage.

Mr. G. R. Horn

- 3 -

This completes the NRC staff review for TAC No. M95141. If you have any questions regarding this issue, please contact me at (301) 415-1336.

Sincerely,

A handwritten signature in cursive script that reads "James R. Hall". The signature is written in dark ink and is positioned above the typed name and title.

James R. Hall, Senior Project Manager  
Project Directorate IV-1  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

Docket No. 50-298

cc: See next page

Mr. G. R. Horn

- 3 -

This completes the NRC staff review for TAC No. M95i41. If you have any questions regarding this issue, please contact me at (301) 415-1330.

Sincerely,

ORIGINAL SIGNED BY:

James R. Hall, Senior Project Manager  
Project Directorate IV-1  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

Docket No. 50-298

cc: See next page

DISTRIBUTION:

Docket File	PUBLIC	PD4-1 r/f
J. Roe	C. Hawes	ACRS
OGC (15B18)	T. Gwynn, RIV	J. Hall
E. Adensam (EGA1)	J. Strosnider	K. Wichman

Document Name: CO095141.LTR

OFC	PM/PD4-1	LA/PD4-1	EMCB
NAME	JHall/vw <i>JH</i>	CHawes <i>cmh</i>	<i>BJE</i>
DATE	5/9/97	5/9/97	5/9/97

OFFICIAL RECORD COPY

Mr. G. R. Horn  
Nebraska Public Power Company

Cooper Nuclear Station

cc:

Mr. John R McPhail, General Counsel  
Nebraska Public Power District  
P. O. Box 499  
Columbus, NE 68602-0499

Lincoln Electric System  
ATTN: Mr. Ron Stoddard  
11th & O Streets  
Lincoln, NE 68508

Nebraska Public Power District  
ATTN: Mr. P. D. Graham  
Vice President of Nuclear Energy  
P. O. Box 98  
Brownville, NE 68321

Midwest Power  
ATTN: Richard J. Singer, Manager-Nuclear  
907 Walnut Street  
P. O. Box 657  
Des Moines, IA 50303

Randolph Wood, Director  
Nebraska Department of Environmental  
Control  
P. O. Box 98922  
Lincoln, NE 68509-8922

Nebraska Public Power District  
ATTN: Mr. B. L. Houston, Nuclear  
Licensing & Safety Manager  
P. O. Box 98  
Brownville, NE 68321

Mr. Larry Bohlken, Chairman  
Nemaha County Board of Commissioners  
Nemaha County Courthouse  
1824 N Street  
Auburn, NE 68305

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
P. O. Box 218  
Brownville, NE 68321

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, TX 76011

Ms. Cheryl Rogers, LLRW Program Manager  
Division of Radiological Health  
Nebraska Department of Health  
301 Centennial Mall, South  
P. O. Box 95007  
Lincoln, NE 68509-5007

Mr. Ronald A. Kucera, Department Director  
of Intergovernmental Cooperation  
Department of Natural Resources  
P.O. Box 176  
Jefferson City, MO 65102