

Douglas R. Gipson  
Senior Vice President, Nuclear Generation

Fermi 2  
6400 North Dixie Hwy., Newport, Michigan 48166  
Tel: 313.586.5201 Fax: 313.586.4172

10CFR50.73

May 8, 1997  
NRC-97-0052

**Detroit Edison**



U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

- Reference: 1) Fermi 2  
NRC Docket No. 50-341  
NRC License No. NPF-43
- 2) Detroit Edison Letter to NRC, NRC-97-0021, "Licensee Event Report (LER) 97-003," dated April 2, 1997

Subject: Licensee Event Report (LER) No. 97-003, Revision 1

Pursuant to 10CFR50.73, Detroit Edison is submitting the enclosed LER No. 97-003, Revision 1 documenting a condition outside the design basis related to the Emergency Equipment Cooling Water System (EECWS) containment isolation function and the subsequent identification of several bypass leakage paths which were not previously recognized.

The diverse power modification of the EECWS primary containment penetrations identified as a commitment in the original submittal of this LER has been completed. There are no new commitments made in this LER.

If you have any questions, please contact Andrew V. Antrassian, Compliance Engineer, at (313) 586-1856.

Sincerely,

*Le 22 1/1*

130194  
cc: A. B. Beach  
G. A. Harris  
M. J. Jordan  
A. J. Kugler  
Region III  
M. V. Yudas, Jr.  
Wayne County Emergency Management Division



9705150035 970508  
PDR ADOCK 05000341  
S FDR