

Mr. George A. Hunger, Jr.
Director-Licensing, MC 52A-5
PECO Energy Company
Nuclear Group Headquarters
Correspondence Control Desk
P.O. Box No. 195
Wayne, PA 19087-0195

June 18, 1997

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION (RAI) RELATED TO PROPOSED
EXTENSION OF SURVEILLANCE INTERVAL FOR REPLACEMENT OF PRIMARY
CONTAINMENT PURGE AND EXHAUST VALVE INFLATABLE SEALS, PEACH BOTTOM
ATOMIC POWER STATION, UNITS 2 AND 3 (TAC NOS. M98730 AND M98731)

Dear Mr. Hunger:

By letter dated May 9, 1997, PECO Energy Company (PECO) submitted a proposed change to Peach Bottom Atomic Power Station (PBAPS), Units 2 and 3. Technical Specifications to extend the surveillance interval for replacement of the Primary Containment purge and exhaust valve inflatable seals from 48 months to 96 months. PECO requested NRC approval of the requested changes by August 1, 1997.

The NRC staff has initiated a review of the proposed changes and determined that additional information is needed to complete the review. The staff's RAI is included as an enclosure. The staff's RAI requests that PECO provide information to support statements regarding PBAPS purge and exhaust valve performance history.

If you have any questions regarding the RAI, please do not hesitate to contact me at (301) 415-1428.

Sincerely,
/s/

Joseph W. Shea, Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-277\278

Enclosure: RAI

cc w/encl: See next page

NRC FILE CENTER COPY

DISTRIBUTION

Docket File
PUBLIC
PDI-2 Reading
SVarga

OGC
JStolz
JShea
MO'Brien

MHart
ACRS
MModes, RGN-I

OFFICE	PDI-2/PM	PDI-2/PA	PDI-2/PD	PDI-2	
NAME	JShea	MO'Brien	JStolz	MHart <i>mlh</i>	
DATE	6/17/97	6/18/97	6/18/97	6/17/97	

OFFICIAL RECORD COPY

DOCUMENT NAME: G:\HART\PB98730.RAI

230088

9706230238 970618
PDR ADOCK 05000277
P PDR



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

June 18, 1997

Mr. George A. Hunger, Jr.
Director-Licensing, MC 52A-5
PECO Energy Company
Nuclear Group Headquarters
Correspondence Control Desk
P.O. Box No. 195
Wayne, PA 19087-0195

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION (RAI) RELATED TO PROPOSED
EXTENSION OF SURVEILLANCE INTERVAL FOR REPLACEMENT OF PRIMARY
CONTAINMENT PURGE AND EXHAUST VALVE INFLATABLE SEALS, PEACH BOTTOM
ATOMIC POWER STATION, UNITS 2 AND 3 (TAC NOS. M98730 AND M98731)

Dear Mr. Hunger:

By letter dated May 9, 1997, PECO Energy Company (PECO) submitted a proposed change to Peach Bottom Atomic Power Station (PBAPS), Units 2 and 3, Technical Specifications to extend the surveillance interval for replacement of the Primary Containment purge and exhaust valve inflatable seals from 48 months to 96 months. PECO requested NRC approval of the requested changes by August 1, 1997.

The NRC staff has initiated a review of the proposed changes and determined that additional information is needed to complete the review. The staff's RAI is included as an enclosure. The staff's RAI requests that PECO provide information to support statements regarding PBAPS purge and exhaust valve performance history.

If you have any questions regarding the RAI, please do not hesitate to contact me at (301) 415-1428.

Sincerely,

A handwritten signature in cursive script, appearing to read "Joseph W. Shea".

Joseph W. Shea, Project Manager
Project Directorate I-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-277/278

Enclosure: RAI

cc w/encl: See next page

Mr. George A. Hunger, Jr.
PECO Energy Company

Peach Bottom Atomic Power Station,
Units 2 and 3

cc:

J. W. Durham, Sr., Esquire
Sr. V.P. & General Counsel
PECO Energy Company
2301 Market Street, S26-1
Philadelphia, PA 19101

Chief-Division of Nuclear Safety
PA Dept. of
Environmental Resources
P.O. Box 8469
Harrisburg, PA 17105-8469

PECO Energy Company
ATTN: Mr. T. N. Mitchell, Vice President
Peach Bottom Atomic Power Station
1848 Lay Road
Delta, PA 17314

Board of Supervisors
Peach Bottom Township
R. D. #1
Delta, PA 17314

PECO Energy Company
ATTN: Regulatory Engineer, A4-5S
Peach Bottom Atomic Power Station
1848 Lay Road
Delta, PA 17314

Public Service Commission of Maryland
Engineering Division
Chief Engineer
6 St. Paul Centre
Baltimore, MD 21202-6806

Resident Inspector
U.S. Nuclear Regulatory Commission
Peach Bottom Atomic Power Station
P.O. Box 399
Delta, PA 17314

Mr. Richard McLean
Power Plant and Environmental
Review Division
Department of Natural Resources
B-3, Tawes State Office Building
Annapolis, MD 21401

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Dr. Judith Johnsrud
National Energy Committee
Sierra Club
433 Orlando Avenue
State College, PA 16803

Mr. Roland Fletcher
Department of Environment
201 West Preston Street
Baltimore, MD 21201

Manager-Business & Co-owner Affairs
Public Service Electric and Gas
Company
P.O. Box 236
Hancocks Bridge, NJ 08038-0236

A. F. Kirby, III
External Operations - Nuclear
Delmarva Power & Light Company
P.O. Box 231
Wilmington, DE 19899

Manager-Peach Bottom Licensing
PECO Energy Company
Nuclear Group Headquarters
Correspondence Control Desk
P.O. Box No. 195
Wayne, PA 19087-0195

PECO Energy Company
Plant Manager
Peach Bottom Atomic Power Station
1848 Lay Road
Delta, PA 17314

REQUEST FOR ADDITIONAL INFORMATION

PEACH BOTTOM ATOMIC POWER STATION, UNITS 2 AND 3

PRIMARY CONTAINMENT PURGE AND EXHAUST VALVE
REPLACEMENT INTERVAL EXTENSION

In the May 9, 1997 submittal PECO made the following statements:

- (1) "T-ring seal performance reviews since 1986 indicate that documented failures were not due to material condition, but were mainly the result of improper installation."
- (2) "Review of the PBAPS purge and exhaust valve performance history has determined that these valves are relatively free of valve leakage problems. Review of valve leakage test data supports this assessment."

The Torus to Reactor Building vacuum breaker isolation valve leakage test results were also stated as supporting the extension request.

Please provide the purge and exhaust valve and Torus to Reactor Building vacuum breaker valve performance data used to support these statements.

Enclosure