UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

OCT 1 3 1983

Référence (68:

PDR: per R. Emit

RES-2D-3

NOTE TO:

W_ Kane, Senior Program Manager Deputy Executive Director for Regional Operations and Generic Requirements, EDO

FROM:

G. M. Holahan, Chief Operating Reactors Assessment Branch Division of Licensing, NRR

SUBJECT:

BACKGROUND INFORMATION RELATING TO THE ASSESSMENT OF THE OFFSITE CONSEQUENCES OF NON-CORE MELT, STEAM GENERATOR TUBE RUPTURE EVENTS

The purpose of this note is to provide backgound information on the subject of the assessment of the offsite consequences of non-core melt, steam generator tube rupture events. NRR will be prepared to discuss this subject in more detail at the October 24, 1983 CRGR meeting on this subject.

In response to CRGR's request for additional information and sensitivity analysis on the non-core melt SGTR events, we have studied several potential sources of conservatism in the analysis of SGTR following by SG overfill and failure of an SG Safety Valve.

For each class of event we reconsidered: the source of radioactive iodine (initial coolant activity and iodine spiking); primary to secondary transport; partition and water transport after leaving the secondary system; and meteorology. Table I (enclosed) summarizes the range of values and best estimate value for each of these items. The following sections discuss the bases for the values presented in Table I.

Initial Iodine Activity

2.5 1

The maximum and minimum values of initial primary coolant activity were chosen as 1% and 100% of the current Standard Technical Specifications (T/S) value of 1 μ Ci/gm. Although some plants have higher T/S limit and some exceed the T/S value for a short period of time, the I μ Ci/gm appears to be a reasonable upper limit for an initial value. The most recently published NRC report or fuel performance, Fuel Performance Annual Report for 1981, NUREG/CR 3001, PNL 4342, December 1982, was consulted to determine how frequently the 1 μ Ci/gm value was exceeded. We found that 9 PWRs exceeded the limit on one or more occasions for a total of 33 times. However, in every case the limit was only exceeded for a short period of time. The highest steady state operating value was approximately .5 μ Ci/gm. The best estimate value of .1 μ Ci/gm was chosen as representative of a plant operating with several failed fuel rods. While many plants run with lower coolant activity, some operate with values 2 to 5 times the best estimate value.

9705190255 831024 PDR NUREG 0933 C PDR

Iodina Spiking

The range of iodine spiking assumption was chosen from no spiking to the Design Basis Spike of 50C times the steady state iodine production rate for two hours following a reactor trip. To establish a best estimate value, primary coolant activity values were calculated as a function of time following a reactor trip using various assumptions about the size of the iodine spike. The calculated increase in iodine concentration was then compared to the iodine spikes reported in the Fuel Performance Annual Report for 1981 (NUREG/CR-3001). Although there is considerable variation from event to event and some uncertainty about exactly when the post trip samples were taken, it appears that ar iodine spike of 10% to 20% of the design basis spike is consistent with operating experience.

Primary to Secondary Iodine Transport

The transport of iodine from the primary system to the steam generator was calculated with a best estimate time dependent (finite difference) code which accounts for dilution by ECCS, mixing in the RCS, leakage to the SG, radioactive decay, cleanup (letdown and SG blowdown), partition, carryover to the condenser, feedwater addition and release to atmosphere.

Partition (and Plate-out) in the Steam Generator

The range of values presented in Table 1 actually represents best estimate values for different conditions in the steam generators. With the SG water level below the dryers and separators, the dryers and separator would be effective in capturing most of the droplets carrying the iodine. The value of .001 has been taken from "Iodine Transport Predicted for a Postulated Steam Line Break with Concurrent Rupture of Steam Generator Tubes," NUREG/CR 2659, PNL 3794, February 1983. The assumption of no partitioning (i.e., PF=I.0) for the case with the dryers and separators flooded is also taken from the above report, and represents a best estimate for these conditions.

Partition and Water Transport After Leaving the Steam Generators

The blowdown of a steam generator through a stuck open safety/relief valve will be in the form of a two phase mixture of steam and water droplets. The size of the water droplets during a high pressure blowdown is expected to be small (10 µm) based on drop size predictions made for LOCA blowdown conditions (Reference 3). A mixture with such small droplets resembles a fog or mist. For the expected range of weather conditions, droplets of such a small size would be expected to stay in suspension in the atmosphere and be carried away from the point of release. A recent analysis of iodine relased during a steam line break with a concurrent steam generator tube rupture supports this conclusion (Reference 2). In that analysis the retention on-site of liquid W. Kane

released from the sceam generator was neglected partially based on containment system experiments. These experiments showed that only approximately 20% of the mass of water exiting from the break into the atmosphere was retained close to the point of discharge.

- 3 -

Meteorology

The range of X/Q values in Table I, which were used to calculate site boundary doses, represent the range from favorable conditions to typical FSAR 95% meteorology. The best estimate value was chosen to represent average condition for a typical site. The crisite health effects (mean, latent deaths), were calculated with the CRAC cide. These were best contate calculations for the Byron site and were uone in the same manner as for Final Environmental Statement reports.

Results

Table 2 (Enclosure 2) presents the calculated primary iodine inventory (RCI in curies), SG iodine inventory (SCI in curies), inventory of iodine released to atmosphere (ACI in curies) and the approximate dose for the case of a single SGTR followed by SG overfill and a stuck open SG safety valve (at 3600 seconds), with the best estimate assumptions from Table 1. Table 2 shows a total release of 105.6 curies over 6 hours with an estimated total dose of approximately 11 rem at the site boundary. Similar calculations were performed with other assumptions within the ranges shown in Table I. The overall results are presented in Table 3 (Enclosure 3).

Gary M. Holahan, Chief Operating Reactors Assessment Branch Division of Licensing, NRR

Enclosures: 1. Table 1 2. Table 2 3. Table 3 4. References

DISTRIBUTION FMiraglia ORAB Rdg S. Stern GHolahan WSchwink (CRGR) MCaruso MTaylor (CRGR) ORABHU CLORAD DL MCaruso:dm GHolahan 10/11/83 10/15/83

LHulman, AEB TMarsh EMurphy

ENCLOSURE 1

TABLE I

	RANGE		
	Least Conservative	Most Conservative	Best Estimate Value
Initial Coolant Activity	.01 µCi/gm	1 ºCi/gm	.1 ^{µµ} Ci/gm
Iodine Spiking	none	Design Basis (500x for 2 hrs)	10 to 20% of Design Basis
Primary to Secondary Iodine Transport	E		best estimate calculations
Partition (and Plate-out) in SG	1.0	.001	.001 when SG level below separators 1.0 when separators flooded
Partition and Water Transport after leaving SG	.8	1.0	1.0 (iodine held in water, water transported in small droplets
Meteorology (X/Q) for Site Dose Calculations	1x10 ⁻⁵	1×10 ⁻³	2x10 ⁻⁴ average meteorology
Meteorology for Estimating Health Effects		dir Firelia an	Best estimate CRAC Code Calculations

ODE VERSION = DOSE102C

ENGLOSURE 2

tTABLE 2

DT == 100 T END= 21700 5C= 4.5E-0601 MICRO CI/CC im O LMS6= 165000 PFaz 1E-03 WBD= O LAM= 9E-07 REM/CI= .1 ZRCSC= 4.5E-051 MICRO CI/CC ALFIA- 100 20 % OF DESIGN DASIS SPIKE T SPIKE= 7200 LDOWN= 3 MRCS= 550000 SOURCE CI/SEC= 1.572755-04 T RCI SCI ACI DOSE 0 24.75 .7425 0 0 500 31.32 1.944 0 0 1000 38.144 2.87 0 0 3.979 0 0 1500 44.764 . 2000 51.184 0 0 5.264 0 57.411 0 2500 6-723 0 0 2000 63.45 8.349 3500 69.307 10.137 0 0 .089 .893 73.421 4000 12.802 76.298 .268 4500 15.823 2.681 78.989 . 482 5000 18.66 4.825 500 81.505 21.325 7.304 .73 .000 10.097 1.009 63.857 25.827 1.318 6500 86.057 26-173 13.184 16.548 1.654 7000 88.113 28.375 83.932 20.166 2.016 7500 30.326 8000 78.546 31-727 23.983 2.378 2.793 27.935 8500 73.511 32.646 31.969 3.196 9000 68.804 33.162 33.34 36.042 3.604 9500 64.403 4.011 60.288 33.237 40.115 10000 32.903 44.158 4.415 10500 56.441 48-146 4.814 52.844 32.382 11000 49.479 31-71 52.059 5.205 11500 30.917 55.879 5.587 12000 46.335 5.959 59.596 12500 43.395 30.033 13000 40.646 29.078 63.199 6.319 28.073 13500 38.076 66.682 6.668 7.003 35.673 27.033 70.039 14000 33.428 25.974 73.267 7.326 14500 7.636 31.328 24.906 76.365 15000 29.365 23.84 79.332 7.933 15500 22.783 82.169 8.216 16000 27.55 21.741 84.879 8.487 25-813 16500 87.464 24.208 20.721 8.746 17000 8.992 7500 22.708 19.726 89.924 92.265 9.226 3000 21.305 18.757 94.489 9.448 17.819 18500 19.994 19000 16.914 . 96.6 9.66 18.767 98.603 9.86 16.042 19500 17.621 15.204 100.503 10.05 20000 16.349 14.401 102.303 10.23 20500 15.547 10.4 21000 13.633 104.006 14.61

ť

ENCLOSURE 3

TABLE 3

SUMMARY OF ESTIMATED RELEASES AND DOSES FOR THE CASE OF AN SGTR PLUS STUCK OPENED SG SAFETY VALVE

FOR BEST ESTIMATE METEOROLOGY:

	.01 µCi/gm	.1 µCi/gm	<u>1</u> μCi/gm
No Iodine Spike	2 Ci/.2 rem	22 Ci/2 rem	220 Ci/22 rem
20% Iodine Spike	11 Ci/1 rem	106 Ci/10.6 rem	1058 Ci/106 rem
100% Iodine Spike	44 Ci/4 rem	444 Ci/44 rem	4445 Ci/445 rem
FOR CONSERVATIVE METEOROL	.OGY		
	.01 µCi/gm	.1 µCi/gm	1 μCi/gm
No Iodine Spike	2 Ci/l rem	22 Ci/11 rem	220 Ci/110 rem
20% Iodine Spike	11 Ci/5 rem	106 Ci/53 rem	1058 Ci/500 rem
100% Iodine Spike	44 Ci/20 rem	444 Ci/200 rem	4445 Ci/2223 rem
FOR FAVORABLE METEOROLOG	4		
	.01 µCi/gm	.1 uCi/gm	1 µCi/gm
No Iodine Spike	2 Ci/.01 rem	22 Ci/1 rem	220 Ci/1 rem
20% Iodine Spike	10 Ci/.05 rem	106 Ci/.5 rem	1000 Ci/5 rem
100% Iodine Spike	44 Ci/.2 rem	444 Ci/2 rem	4445 Ci/20 rem

ENCLOSURE 4

REFERENCES

 Bailey, W. J.; Tokar, M.; Fuel Performance Annual Report for 1981, NUREG/CR-3001, December 1982.

S. S. Arr.

in the second

and a the states

Sec. A.

- Postma, A. K.; Hesson, G. M.; Faletti, D. W.; Iodine Transport Predicted for a Postulated Steam Line Break with Concurrent Ruptures of Steam Steam Generator Tubes, NUREG/CR-2659, February 1983.
- Gido, R. G., and A. Koestal 1978. "LOCA-Generated Drop Size Prediction -A Thermal Fragmentation Model, Trans. Amer. Nucl. Soc., 30. 371-372.

1.18