

GPU Nuclear Corporation
Post Office Box 480
Route 441 South
Middletown, Pennsylvania 17057-0191
717 944-7621
TELEX 84-2386
Writer's Direct Dial Number:

April 2, 1986

5211-86-2049

Office of Nuclear Reactor Regulation
Attn. John F. Stolz, Director
PWR Project Directorate No. 6
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555


Dear Mr. Stolz:

Three Mile Island Nuclear Station Unit 1 TMI-1)
Operating License No. DPR-50
Docket No. 50-289
Technical Specification Change Request No. 116, Rev. 1, Supplement II
Additional Information on Debris Screens

On December 3, 1984, GPUN submitted Supplement II to Technical Specification Change Request No. 116, Rev. 1. We committed to submit a Tech. Spec. Change Request, if necessary, to revise the purge isolation valve open position limits within a year after issuance of the amendment associated with Tech. Spec. Change Request No. 116, Rev. 1, Amendment 108, issued May 8, 1985, approved Tech. Spec. Change Request No. 116, Rev. 1.

We have determined that a Tech. Spec. Change Request will not be necessary. The debris screen that is presently being designed and scheduled for installation during the Cycle 6 outage will not affect the open position limits of the containment purge isolation valve. The flow area of the screen is such that during LOCA conditions, the air velocity through the screen is still well below critical limits.

Sincerely,


H. D. Huk III
Director, TMI-1

HDH/SMO/spb

cc: R. Conte
J. Thoma

0531A

8604080264 860402
PDR ADOCK 05000289
P PDR

Acc 11/0