

yellow

April 9, 1986

Tennessee Valley Authority  
ATTN: Mr. S. A. White  
Manager of Nuclear Power  
6N 38A Lookout Place  
1101 Market Street  
Chattanooga, TN 37402-2801

Gentlemen:

SUBJECT: REPORT NOS. 50-327/86-18 AND 50-328/86-18

On February 24-28, 1986, NRC inspected activities authorized by NRC Operating License No. DPR-77 and DPR-79 for your Sequoyah facility. At the conclusion of the inspection, the findings were discussed with those members of your staff identified in the enclosed inspection report.

Areas examined during the inspection are identified in the report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observation of activities in progress.

Within the scope of the inspection, no violations or deviations were identified.

Your attention is invited to unresolved items identified in the inspection report. These matters will be pursued during future inspections.

Your attention is also invited to paragraph 2 of the enclosed report which addresses the status of previous actions requiring completion prior to unit restart. One new action involving the determination and correction of unreliable Barton 288A differential pressure switch applications at your Sequoyah facility has been added to those actions requiring completion prior to unit restart.

Should you have any questions concerning this letter, please contact us.

Sincerely,

(original signed by) Verrilli

John A. Olshinski  
Deputy Regional Administrator for TVA

Enclosure:  
Inspection Report Nos. 50-327/86-18  
and 50-328/86-10

cc w/encl: (See page 2)

8604220370 860409  
PDR ADDCK 05000327  
G PDR

IEOI  
1/1

cc w/encl:

- ✓ H. L. Abercrombie, Sequoyah Nuclear Plant  
Site Director
- ✓ P. R. Wallace, Plant Manager
- ✓ K. W. Whitt, Chief, Nuclear  
Safety Review Staff
- ✓ D. L. Williams, Jr., Supervisor  
Licensing Section
- ✓ G. B. Kirk, Compliance Staff Supervisor
- ✓ J. E. Wills, Project Engineer

bcc w/encl:

- ✓ J. N. Grace, RII
- ✓ H. R. Denton, NRR
- ✓ H. L. Thompson, NRR
- ✓ J. M. Taylor, IE
- ✓ B. B. Hayes, OI
- ✓ S. R. Connelly, OIA
- ✓ NRC Resident Inspector  
Document Control Desk  
State of Tennessee

RII

DFalconer:cdg

03/08/86

4-02

RII *W**BW*  
BWB

03/08/86

4

RII

CJulian

03/08/86

4/7

RII

AGibson

03/08/86

4/7

RII

SWeise

03/08/86

4

RII

DVerrelli

03/08/86

4