

Mr. John R. McGaha, Jr.  
Vice President - Operations  
Entergy Operations, Inc.  
River Bend Station  
P. O. Box 220  
St. Francisville, LA 70775

June 26, 1997

SUBJECT: RIVER BEND STATION, UNIT 1 - REQUEST FOR ADDITIONAL INFORMATION ON  
MAXIMUM EXTENDED LOAD LINE LIMIT IMPLEMENTATION (TAC NO. M97835)

Dear Mr. McGaha:

By letter dated January 20, 1997, Entergy Operations, Inc. requested a change to the technical specifications (TSs) for the River Bend Station (RBS) Facility Operating License No. NPF-47. The change would implement the maximum extended load line limit analysis (MELLLA) for RBS operation.

In our review of the proposed change, we have identified additional information enclosed, which we need in order to complete the review. It is requested that Entergy provide a response within 30 days so that we can complete the review. If you have any questions on our request, please let me know.

Sincerely,

ORIGINAL SIGNED BY:

David L. Wigginton, Senior Project Manager  
Project Directorate IV-1  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

Docket No. 50-458

Enclosure: Request for Additional Information

cc w/encl: See next page

DISTRIBUTION

Docket File	PUBLIC
J. Roe	PD4-1 r/f
E. Adensam, (EGAL)	OGC (15B18)
D. Wigginton	ACRS
C. Hawes	T. Gwynn, RIV

Document Name: RB97835.RAI

OFC	PM/PD4-1	LA/PD4-1
NAME	DWigginton:sp	CHawes CMH
DATE	6/29/97	6/26/97
COPY	YES/NO	YES/NO

OFFICIAL RECORD COPY

NRC FILE CENTER COPY

9707010217 970626  
PDR ADOCK 05000458  
P FDR

010000



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

June 26, 1997

Mr. John R. McGaha, Jr.  
Vice President - Operations  
Entergy Operations, Inc.  
River Bend Station  
P. O. Box 220  
St. Francisville, LA 70775

SUBJECT: RIVER BEND STATION, UNIT 1 - REQUEST FOR ADDITIONAL INFORMATION ON  
MAXIMUM EXTENDED LOAD LINE LIMIT IMPLEMENTATION (TAC NO. M97835)

Dear Mr. McGaha:

By letter dated January 20, 1997, Entergy Operations, Inc. requested a change to the technical specifications (TSs) for the River Bend Station (RBS) Facility Operating License No. NPF-47. The change would implement the maximum extended load line limit analysis (MELLLA) for RBS operation.

In our review of the proposed change, we have identified additional information enclosed, which we need in order to complete the review. It is requested that Entergy provide a response within 30 days so that we can complete the review. If you have any questions on our request, please let me know.

Sincerely,

A handwritten signature in black ink, appearing to read "D. Wigginton".

David L. Wigginton, Senior Project Manager  
Project Directorate IV-1  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

Docket No. 50-458

Enclosure: Request for Additional Information

cc w/encl: See next page

Mr. John R. McGaha  
Entergy Operations, Inc.

cc:

Winston & Strawn  
1400 L Street, N.W.  
Washington, DC 20005-3502

Manager - Licensing  
Entergy Operations, Inc.  
River Bend Station  
P. O. Box 220  
St. Francisville, LA 70775

Director  
Joint Operations Cajun  
10719 Airline Highway  
P. O. Box 15540  
Baton Rouge, LA 70895

Senior Resident Inspector  
P. O. Box 1050  
St. Francisville, LA 70775

President of West Feliciana  
Police Jury  
P. O. Box 1921  
St. Francisville, LA 70775

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, TX 76011

Ms. H. Anne Plettinger  
3456 Villa Rose Drive  
Baton Rouge, LA 70806

Administrator  
Louisiana Radiation Protection Division  
P. O. Box 82135  
Baton Rouge, LA 70884-2135

River Bend Station

Executive Vice President and  
Chief Operating Officer  
Entergy Operations, Inc.  
P. O. Box 31995  
Jackson, MS 39286

General Manager - Plant Operations  
Entergy Operations, Inc.  
River Bend Station  
P. O. Box 220  
St. Francisville, LA 70775

Director - Nuclear Safety  
Entergy Operations, Inc.  
River Bend Station  
P. O. Box 220  
St. Francisville, LA 70775

Vice President - Operations Support  
Entergy Operations, Inc.  
P. O. Box 31995  
Jackson, MS 39286-1995

Attorney General  
State of Louisiana  
P. O. Box 94095  
Baton Rouge, LA 70804-9095

Wiso, Carter, Child & Caraway  
P. O. Box 651  
Jackson, MS 39205

Vice President & Controller  
Cajun Electric Power Cooperative  
10719 Airline Highway  
P.O. Box 15540  
Baton Rouge, LA 70895

REQUEST FOR ADDITIONAL INFORMATION  
TECHNICAL SPECIFICATIONS CHANGES FOR  
MAXIMUM EXTENDED LOAD LINE LIMIT (MELLL) IMPLEMENTATION  
ENERGY OPERATIONS, INC.  
RIVER BEND STATION (RBS)  
OPERATING LICENSE NUMBER NPF-47  
DOCKET NO. 50-458

Explain the basis for the values for the revised average power range monitor (APRM) flow-biased scram and rod-block setpoints. What is the analysis methodology used for determining the new nominal setpoint vs. the allowable value, and has the methodology changed from that used to determine the original setpoints? What was the original design basis for including the flow-biased setpoints and how has the design basis changed such that the setpoints are no longer necessary?

Explain the statement on pg. 3-1 of General Electric (GE) report, "The power/flow state points chosen for analyses of AOOs [anticipated operational occurrences] bound the current licensed operating domain for RBS up to the Increased Core Flow (ICF) region and the MELLL region"? It appears that the 100% power / 75% flow state point was used as a bounding point for the AOOs analyzed in report. For the AOOs reviewed in the report, explain why this point is bounding for flow and power.

Was the turbine trip without bypass event analyzed for MELLL operation? What are the results and is the transient bounded by another transient?

Explain the conservative adder discussed on page 7-3 of GE report for the loss of feedwater heater event, and explain how the adder bounds the event down to 75% core flow?

Explain why the recirculation pump runout is the limiting event for Reactor Internal Pressure Differences as discussed on page 6-1 of the GE report.

ENCLOSURE