

Lawrence D. Low, Director  
Division of Compliance

Robert Lowenstein, Director  
Division of Licensing and Regulation

PACIFIC GAS AND ELECTRIC COMPANY  
DOCKET NO. 50-133

LR:BJR

Reference is made to the memorandum dated June 27, 1963, subject as above, from P. A. Morris to E. R. Price, which noted the seismic condition of the Eureka site, and the fact that a seismic trip is not included in the Humboldt Bay Reactor design.

As you know the seismic condition of the Eureka site was specifically considered on page 8 of our Hazards Analysis for the Humboldt Bay Unit No. 3 facility. In addition, the public hearings held on August 24 and 25, 1960, included testimony on this aspect of the Eureka site.

Based on our review of the seismic characteristics of newly proposed reactor plant sites within the same general California fault areas, and the results thereof, we plan to reconsider whether a seismic trip for the Humboldt Bay Reactor System may be appropriate.

bcc: Facilities Licensing Group  
OGC (2)  
Facility File

8602250457 851212  
PDR FOIA  
FIREST085-665 PDR

OFFICE ▶	LR:EB	LR:R&PRSB	LR:FL	OGC	LR	LR
SURNAME ▶	BJR:1 <i>BJR</i>	Boyd/Bryan	EGCase		ERPrice	RLowenstein
DATE ▶	7-18-63	7/25/63	7/24			