UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH OCTOBER, 1985

DOCKET NO. 50 - 352

UNIT NAME LIMERICK UNIT 1

DATE NOVEMBER 15, 1985

COMPLETED BY PHILADELPHIA ELECTRIC COMPANY

W.M. ALDEN

ENGINEER-IN-CHARGE

LICENSING SECTION

NUCLEAR GENERATION DIVISION

TELEPHONE (215) 841-5022

1		1		1		1		I METHOD	OF I	LICENSEE	1	SYSTEM	COMPONEN	TI	CAUSE AND CORRECTIVE
- 1		1	TYPE	10	URATION	IR	EASON	SHUTTING	DOWN	EVENT	1	CODE	I CODE	1	ACTION TO
1.04	DATE	1	(1)	3	(HOURS)	1	(2)	I REACTOR	(3) 1	REPORT #	1	(4)	1 (5)	1	PREVENT RECURRENCE
1		1		1		1		1	1		1		1	,	
9	851008	1	5	1	156.5	į.	В	1 4	- 1	NA	-	ZZ	ZZZZZZ	1	PLANNED TURBINE TRIP FOR STP27.3. MAIN TURBINE
		1		1		1		1	- 1		1		1	1	TRIP FOR TC-3 BY ACTUATING THE MANUAL TURBINE
		1		1		1		1	1		1		1	1	TRIP PUSHBUTTON FOLLOWED BY REACTOR SCRAM AND
		1		1		1		1	- 1		1		1	1	CLOSURE OF 4 MAIN TURBINE STOP VALVES.
		1		1		1		1	- 1		1		1	1	
10	851015	1	F	1	021.3	1	н	1 3	1	85-83	-1	НН	PUMPXX	1	LOW LEVEL REACTOR SCRAM CAUSED BY REACTOR
		1		1		1		1	1		1		1	1	PRESSURE INCREASING BEYOND THE CAPABILITY OF
		1		ı		1		1	1		- 1		1	1	THE CONDENSATE PUMPS PRIOR TO REACTOR FEEDPUMPS
		1		ı		1		1	- 1		1		1	1	BEING PLACED IN SERVICE.
		1		1		1		1	1		- 1		1	1	
11	851031	1	F	ı	000.0	1	н	1 4	- 1	NA	1	EB	I ELECON	1	LOAD REDUCTION FROM 68% TO 43% DUE TO RECIRC
		i		1		ĩ		1	- 1		- 1		1	1	RUNBACK CAUSED BY LOOSE CONNECTION AT PIN 3
		i		1		i		1	- 1		- 1		1	1	ON POWER SUPPLY C-32-K163.
		i		i		i		1	- 1		- 1		1	1	
		1		*	177.8	1		1	- 1		1		1	1	

(1)

(2)

(3)

(4)

F - FORCED S - SCHEDULED REASON

A - EQUIPMENT FAILURE (EXPLAIN)

B - MAINTENANCE OR TEST

C - REFUELING

D - REGULATORY RESTRICTION

E - OPERATOR TRAINING + LICENSE EXAMINATION

F - ADMINISTRATIVE

G - OPERATIONAL ERROR (EXPLAIN)

METHOD

1 - MANUAL

2 - MANUAL SCRAM.

4 - OTHER (EXPLAIN)

EXHIBIT G - INSTRUCTIONS FOR PREPARATION OF DATA ENTRY SHEETS FOR ! CENSEE 3 - AUTOMATIC SCRAM. EVENT REPORT (LER,

(5)

FILE (NUREG-0161)

8601090088 851122 PDR ADOCK 05000352 PDR