Mr. J. E. Cross President-Generation Group Duquesne Light Company Post Office Box 4 Shippingport, PA 15077

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION (RAI) REGARDING BEAVER VALLEY POWER STATION, UNIT NO. 1 (BVPS-1), REQUEST FOR EXEMPTION FROM THE REQUIREMENTS OF 10 CFR 70.24 FOR AN ACCIDENTAL CRITICALITY MONITOR (TAC NO. M97469)

Dear Mr. Cross:

By letter dated December 18, 1996, Duquesne Light Company (DLC) submitted a request for an exemption om the requirements of 10 CFR 70.24 for an accidental criticality monitor for the BPVS-1. The NRC staff is reviewing DLC's request; however, before we can complete our review we will require DLC to specifically respond to the criteria in the enclosed RAI. DLC is requested to respond to this RAI within 30 days of receipt of this letter to enable us to complete our review of DLC's exemption request within a timely manner.

Please contact me at (301) 415-1409 if you have any questions regarding this issue.

Sincerely

181

Donald S. Brinkman, Senior Project Manager Project Directorate I-2 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Docket No. 50-334

Enclosure: RAI

cc w/encl: See next page

DISTRIBUTION:

Docket File

ACRS. TWF

PUBLIC PDI-2 r/f

SVarga

MO'Brien

PEselgroth, RI

DBrinkman

GWunder

OGC, 0-15B18

| OFFICE | PDI-2/PM/ | PD1-2/LA | PDJ-2/D | |
|--------|---------------|----------|---------|--|
| NAME | DBrinkman: cw | MO'Brien | JSTOTZ | |
| DATE | 5116197 | 6/197 | 5/6/97 | |

OFFICIAL RECORD COPY

DOCUMENT NAME: BV97469.RAI



UNITED STATES **NUCLEAR REGULATORY COMMISSION**

WASHING ON, D.C. 20555-0001

May 19, 1997

Mr. J. E. Cross President-Generation Group Duquesne Light Company Post Office Box 4 Shippingport, PA 15077

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION (RAI) REGARDING BEAVER VALLEY POWER STATION, UNIT NO. 1 (BVPS-1), REQUEST FOR EXEMPTION FROM THE REQUIREMENTS OF 10 CFR 70.24 FOR AN ACCIDENTAL CRITICALITY MONITOR (TAC NO. M97469)

Dear Mr. Cross:

By letter dated December 18, 1996, Duquesne Light Company (DLC) submitted a request for an exemption from the requirements of 10 CFR 70.24 for an accidental criticality monitor for the BPVS-1. The NRC staff is reviewing DLC's request; however, before we can complete our review we will require DLC to specifically respond to the criteria in the c closed RAI. DLC is requested to respond to this RAI within 30 days of receipt of this letter to enable us to complete our review of DLC's exemption request within a timely manner.

Please contact me at (301) 415-1409 if you have any questions regarding this issue.

Sincerely

Donald & Builana Donald S. Brinkman, Senior Project Manager

Project Directorate I-2

Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Docket No. 50-334

Enclosure: RAI

cc w/encl: See next page

J. E. Cross Duquesne Light Company

cc:

Jay E. Silberg, Esquire Shaw, Pittman, Potts & Trowbridge 2300 N Street, NW. Washington, DC 20037

Director-Safety and Licensing Department (BV-A) Duquesne Light Company Beaver Valley Power Station PO Box 4 Shippingport, PA 15077

Commissioner Roy M. Smith West Virginia Department of Labor Building 3, Room 319 Capitol Complex Charleston, WVA 25305

Director, Utilities Department Public Utilities Commission 180 East Broad Street Columbus, OH 43266-0573

Director, Pennsylvania Emergency Management Agency Post Office Bo: 3321 Harrisburg, PA 17105-3321

Ohio EPA-DERR ATTN: Zack A. Clayton Post Office Box 1049 Columbus. OH 43266-0149

Dr. Judith Johnsrud National Energy Committee Sierra Club 433 Orlando Avenue State College, PA 16803

Duquesne Light Company
Beaver Valley Power Station
PO Box 4
Shippingport, PA 150/7
ATTN: R. L. Grand, Division Vice
President, Nuclear Operations Group
and Plant Manager (BV-SOSB-7)

Beaver Valley Power Station Units 1 & 2

Bureau of Radiation Protection Pennsylvania Department of Environmental Resources ATTN: Michael P. Murphy Post Office Box 2063 Harrisburg. PA 17120

Mayor of the Borrough of Shippingport Post Office Box 3 Shippingport, PA 15077

Regional Administrator, Region I U.S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, PA 19406

Resident Inspector U.S. Nuclear Regulatory Commission Post Office Box 298 Shippingport, PA 15077

Duquesne Light Company Beaver Valley Power Station PO Box 4 Shippingport, PA 15077 ATTN: S. C. Jain, Vice President Nuclear Services (BV-A)

REQUEST FOR ADDITIONAL INFORMATION REGARDING

PROPOSED EXEMPTION TO ACCIDENTAL CRITICALITY MONITOR REQUIREMENTS OF 10 CFR 70.24

BEAVER VALLEY POWER STATION, UNIT NO. 1 (BVPS-1)

DOCKET NO. 50-334

Please provide responses to the following criteria for granting exemptions to 10 CFR 70.24 requirements.

- Only 1 pressurized water reactor fuel assembly is allowed out of a shipping cask or storage rack at one time.
- With the fresh fuel storage racks filled with fuel of the maximum permissible U-235 enrichment and flooded with pure water, the maximum k-effective shall not exceed 0.95, at a 95% probability, 95% confidence level.
- 3. With the fresh fuel storage racks filled with fuel of the maximum permissible U-235 enrichment and flooded with moderator at the (low) density corresponding to optimum moderation, the maximum k-effective shall not exceed 0.98, at a 95% probability, 95% confidence level.
- 4. With the spent fuel storage racks filled with fuel of the maximum permissible U-235 enrichment and flooded with pure water, the maximum k-effective shall not exceed 0.95, at a 95% probability, 95% confidence level.
- 5. The quantity of other forms of special nuclear material, such as sources, detectors, etc., that are stored on site is small enough to preclude achieving a critical mass.
- Radiation monitors, as required by General Design Criterion 63, are provided in fuel storage and handling areas to detect excessive radiation levels and to initiate appropriate safety actions.
- 7. The maximum nominal U-235 enrichment is limited to 5 weight percent.