

Mr. Neil S. Carns
 Senior Vice President
 and Chief Nuclear Officer
 Northeast Nuclear Energy Company
 c/o Ms. Patricia A. Loftus
 Director - Regulatory Affairs
 P.O. Box 128
 Waterford, CT 06385

July 30, 1997

SUBJECT: MILLSTONE NUCLEAR POWER STATION, UNIT 3 - CHANGE TO TECHNICAL SPECIFICATION BASES SECTION 3/4.9.7 (TAC NO. M99262)

Dear Mr. Carns:

By letter dated July 14, 1997, Northeast Nuclear Energy Company submitted changes to Technical Specification (TS) Bases Section 3/4.9.7, Crane Travel - Spent Fuel Storage Areas. The change modifies TS Bases Section 3/4.9.7 to be consistent with the revised impact load analysis for the spent fuel racks. The change to the Bases, along with the July 1, 1997, revision to the Millstone Unit 3 Final Safety Analysis Report (FSAR), removes inconsistencies between the TS and the FSAR regarding load limits.

The NRC staff has reviewed the changes and has no objection to the wording. A copy of revised Bases page B 3/4 9-2 is enclosed.

Sincerely,

Original signed by:
 James W. Andersen, Project Manager
 Special Projects Office - Licensing
 Office of Nuclear Reactor Regulation

Docket No. 50-423

Enclosure: Revised Bases page B 3/4 9-2

cc w/encl: See next page

DISTRIBUTION:

Docket File
 PUBLIC
 SPO-L Reading
 SPO Reading
 WTravers
 PMcKee
 LBerry
 JAndersen
 OGC
 ACRS
 JDurr, RI

DWol
 |
 |

DOCUMENT NAME: G:\ANDERSEN\M99262.LTR

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

NRC FILE CENTER COPY

OFFICE	SPO-L:PM	SPO-L:LA	SPO-L:DD					
NAME	JAndersen	LBerry	PMcKee					
DATE	07/30/97	07/27/97	07/19/97					

OFFICIAL RECORD COPY

9708010248 970730
 PDR ADOCK 05000423
 P PDR

010073



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

July 30, 1997

Mr. Neil S. Carns
Senior Vice President
and Chief Nuclear Officer
Northeast Nuclear Energy Company
c/o Ms. Patricia A. Loftus
Director - Regulatory Affairs
P.O. Box 128
Waterford, CT 06385

SUBJECT: MILLSTONE NUCLEAR POWER STATION, UNIT 3 - CHANGE TO TECHNICAL
SPECIFICATION BASES SECTION 3/4.9.7 (TAC NO. M99262)

Dear Mr. Carns:

By letter dated July 14, 1997, Northeast Nuclear Energy Company submitted changes to Technical Specification (TS) Bases Section 3/4.9.7, Crane Travel - Spent Fuel Storage Areas. The change modifies TS Bases Section 3/4.9.7 to be consistent with the revised impact load analysis for the spent fuel racks. The change to the Bases, along with the July 1, 1997, revision to the Millstone Unit 3 Final Safety Analysis Report (FSAR), removes inconsistencies between the TS and the FSAR regarding load limits.

The NRC staff has reviewed the changes and has no objection to the wording. A copy of revised Bases page B 3/4 9-2 is enclosed.

Sincerely,

A handwritten signature in black ink, appearing to be "JW Andersen", written over a faint circular stamp.

James W. Andersen, Project Manager
Special Projects Office - Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-423

Enclosure: Revised Bases page B 3/4 9-2

cc w/encl: See next page

Northeast Nuclear Energy Company

Millstone Nuclear Power Station
Unit 3

cc:

Lillian M. Cuoco, Esquire
Senior Nuclear Counsel
Northeast Utilities Service Company
P. O. Box 270
Hartford, CT 06141-0270

Mr. Kevin T. A. McCarthy, Director
Monitoring and Radiation Division
Department of Environmental Protection
79 Elm Street
Hartford, CT 06106-5127

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

First Selectmen
Town of Waterford
Hall of Records
200 Boston Post Road
Waterford, CT 06385

Mr. Wayne D. Lanning
Deputy Director of Inspections
Special Projects Office
475 Allendale Road
King of Prussia, PA 19406-1415

Michael H. Brothers
Vice President - Millstone Unit 3
Northeast Nuclear Energy Company
P. O. Box 128
Waterford, CT 06385

Mr. M. R. Scully, Executive Director
Connecticut Municipal Electric
Energy Cooperative
30 Stott Avenue
Norwich, CT 06360

Mr. Mr. K. Thayer
Recovery Officer - Nuclear Engineering
and Support
Northeast Nuclear Energy Company
P. O. Box 128
Waterford, Connecticut 06385

Mr. William D. Meinert
Nuclear Engineer
Massachusetts Municipal Wholesale
Electric Company
P. O. Box 426
Ludlow, MA 01056

Joseph R. Egan, Esquire
Egan & Associates, P.C.
2300 N Street, NW
Washington, D.C. 20037

Mr. F. C. Rothen
Vice President - Nuclear Work Services
Northeast Nuclear Energy Company
P. O. Box 128
Waterford, CT 06385

Ernest C. Hadley, Esquire
1040 B Main Street
P. O. Box 549
West Wareham, MA 02576

Mr. John Buckingham
Department of Public Utility Control
Electric Unit
10 Liberty Square
New Britain, CT 06051

Mr. James S. Robinson
Manager, Nuclear Investments and
Administration
New England Power Company
25 Research Drive
Westborough, MA 01582

Mr. D. M. Goebel
Vice President - Nuclear Oversight
Northeast Nuclear Energy Company
P. O. Box 128
Waterford, CT 06385

Northeast Nuclear Energy Company

Millstone Nuclear Power Station
Unit 3

cc:

Deborah Katz, President
Citizens Awareness Network
P. O. Box 83
Shelburne Falls, MA 03170

Mr. Daniel L. Curry
Project Director
Parsons Power Group Inc.
2675 Morgantown Road
Reading, Pennsylvania 19607

Senior Resident Inspector
Millstone Nuclear Power Station
c/o U.S. Nuclear Regulatory
Commission
P. O. Box 513
Niantic, CT 06357

Mr. Don Schopfer
Verification Team Manager
Sagent & Lundy
55 E. Monroe Street
Chicago, Illinois 60603

Mr. Allan Johanson, Assistant Director
Office of Policy and Management
Policy Development and Planning Division
450 Capitol Avenue - MS# 52ERN
P. O. Box 341441
Hartford, CT 06134-1441

Citizens Regulatory Commission
ATTN: Ms. Susan Perry Luxton
180 Great Neck Road
Waterford, Connecticut 06385

The Honorable Terry Concannon
Co-Chair
Nuclear Energy Advisory Council
Room 4035
Legislative Office Building
Capitol Avenue
Hartford, Connecticut 06106

Mr. Evan W. Wocllacott
Co-Chair
Nuclear Energy Advisory Council
128 Terry's Plain Road
Simsbury, Connecticut 06070

Little Harbor Consultants, Inc.
Millstone - ITPOP Project Office
P. O. Box 0630
Niantic, Connecticut 06357-0630

Mr. B. D. Kenyon
President and Chief Executive Officer
Northeast Nuclear Energy Company
P. O. Box 128
Waterford, CT 06385

REFUELING OPERATIONS

BASES

3/4.9.6 REFUELING MACHINE

The OPERABILITY requirements for the refueling machine ensure that: (1) refueling machines will be used for movement of drive rods and fuel assemblies, (2) each crane has sufficient load capacity to lift a drive rod or fuel assembly, and (3) the core internals and reactor vessel are protected from excessive lifting force in the event they are inadvertently engaged during lifting operations.

3/4.9.7 CRANE TRAVEL - SPENT FUEL STORAGE AREAS

The restriction on movement of loads over fuel assemblies in the storage pool ensures that in the event the load is dropped: (1) the activity release will be less than the activity release assumed in the design basis fuel handling accident, and (2) the resulting geometry will not result in a critical array.

3/4.9.8 RESIDUAL HEAT REMOVAL AND COOLANT CIRCULATION

3/4.9.8.1 HIGH WATER LEVEL

BACKGROUND

The purpose of the Residual Heat Removal (RHR) System in MODE 6 is to remove decay heat and sensible heat from the Reactor Coolant System (RCS), as required by GDC 34, to provide mixing of borated coolant and to prevent boron stratification. Heat is removed from the RCS by circulating reactor coolant through the RHR heat exchanger(s), where the heat is transferred to the Reactor Plant Component Cooling Water System. The coolant is then returned to the RCS via the RCS cold leg(s). Operation of the RHR system for normal cooldown or decay heat removal is manually accomplished from the control room. The heat removal is manually accomplished from the control room. The heat removal rate is adjusted by controlling the flow of reactor coolant through the RHR heat exchanger(s) and the bypass. Mixing of the reactor coolant is maintained by this continuous circulation of reactor coolant through the RHR system.

APPLICABLE SAFETY ANALYSES

If the reactor coolant temperature is not maintained below 200°F, boiling of the reactor coolant could result. This could lead to a loss of coolant in the reactor vessel. Additionally, boiling of the reactor coolant could lead to a reduction in boron concentration in the coolant due to boron plating out on components near the areas of the boiling activity. The loss of reactor coolant and the reduction of boron concentration in the reactor coolant would eventually challenge the integrity of the fuel cladding, which is fission product barrier. One train of the RHR system is required to be operational in MODE 6, with the water level \geq 23 ft above the top of the reactor vessel to prevent this challenge. The LCO does permit deenergizing the RHR pump for short durations,