



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39215-1640

April 22, 1986

O. D. KINGSLEY, JR.
VICE PRESIDENT - NUCLEAR OPERATIONS

U. S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Washington, D. C. 20555

Attention: Mr. Harold R. Denton, Director

Dear Mr. Denton:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-29
Technical Specification Amendment
Effective Dates
AECM-86/0102

Reference: Letter from Elinor G. Adensam to Mr. J. B. Richard dated
September 18, 1985

Mississippi Power & Light (MP&L) was requested by the referenced letter to notify the Nuclear Regulatory Commission (NRC) of the effective date of certain technical specification changes.

Amendment 4 changes to the Fire Detection Instrumentation Table 3.3.7.9-1.c.16 have been administratively implemented but could not be made effective in the technical specifications until work was completed to change smoke detectors to flame detectors in the corridor between the diesel generator building and the auxiliary building (Table 3.3.7.9-1.d.1). Both of these fire detection instrumentation changes affect page 3/4 3-87 of the technical specifications. Work has been completed and both changes have been entered in the technical specifications with an effective date of April 4, 1986. With this notification, Amendment 4 has been completely implemented into the Grand Gulf Nuclear Station (GGNS) Unit 1 Technical Specifications.

If you have any questions, please contact this office.

Yours truly,

8604280143 860422
PDR ADOCK 05000416
P PDR

ODK:vog

cc: (See Next Page)

J13AECM86041001 - 1

Member Middle South Utilities System

A001
1/0

cc: Mr. T. H. Cloninger
Mr. R. B. McGehee
Mr. N. S. Reynolds
Mr. H. L. Thomas
Mr. R. C. Butcher

Mr. James M. Taylor, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dr. J. Nelson Grace, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N. W., Suite 2900
Atlanta, Georgia 30323

Dr. Alton B. Cobb
State Health Officer
State Board of Health
Box 1700
Jackson, Mississippi 39205