



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

May 22, 1997

50-366

Mr. H. L. Sumner, Jr.
Vice President
Southern Nuclear Operating
Company, Inc.
Post Office Box 1295
Birmingham, Alabama 35201-1295

SUBJECT: ASSESSMENT OF FEEDWATER SPARGER INSERVICE INSPECTION - EDWIN I.
HATCH NUCLEAR PLANT, UNIT 2 (TAC NO. M98386)

Dear Mr. Sumner:

By letter dated April 4, 1997, and supplemented May 7, 1997, you submitted a description of the indications associated with the "A" feedwater sparger thermal sleeve to the tee weld, and with tack welds on two bolt locations on one of the end brackets at Hatch Unit 2.

The indications on the "A" sparger thermal sleeve are located on the bottom of the pipe and are predominately axial in orientation. They are characterized as four primary indications with minor branching. One of the indications is approximately 4 inches long and appears to traverse the sleeve to the tee weld. Another indication is approximately 2 inches long within the sparger tee next to the tee weld. The two remaining indications are approximately 1.5 inches long within the thermal sleeve next to the tee weld.

The indications on one of the end brackets are located on the tack welds of the nut to the end bracket at each of the two bolt locations.

Your evaluation of the flaw indications concluded that the feedwater spargers do not provide a safety-related function. However, you indicated that leakage from sparger cracks could cause thermal cycling in the feedwater nozzle blend radius and potentially cause cracking. Furthermore, you stated that the Hatch Unit 2 feedwater nozzles have been inspected and no cracking has been observed. Even if one considers the potential thermal cycling, there are no safety consequences since the feedwater nozzle has been analyzed with a 1/4-inch crack and found to be acceptable. The leakage from the indications in the thermal sleeve to the tee weld would not result in an adverse impact to safety-related equipment. The presence of the cracked tack welds on the end bracket does not adversely affect the function or the structural integrity of the feedwater sparger. Therefore, Hatch Unit 2 operation for one cycle is acceptable. Also, your April 4, 1997, letter provided your commitment to perform additional inspections of the affected areas during the next Unit 2 refueling outage currently scheduled for the fall of 1998. The affected areas should include the feedwater nozzle blend radius, and all the cracked components.

9705280165 970522
PDR ADOCK 05000366
G PDR

NRC FILE CENTER COPY


H. L. Sumner, Jr.

- 2 -

Based on its review of your submittals, the staff is in general agreement with your evaluation, and has concluded that the flaw indications in the feedwater sparger and the tack welds are acceptable for Hatch Unit 2 operation for one cycle. If concerns arise during the NRC staff's review of other plants, they will be promptly communicated to you. Subsequently, if the staff determines that the flaw and the piping integrity evaluations are unacceptable, you will be expected to take prompt action to place the facility in a safe configuration, consistent with the requirements of NRC regulations and the Hatch technical specifications.

If you have any questions in this matter, please contact me at (301) 415-1496.

Sincerely,



Kahtan N. Jabbour, Project Manager
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-366

cc: See next page

Based on its review of your submittals, the staff is in general agreement with your evaluation, and has concluded that the flaw indications in the feedwater sparger and the tack welds are acceptable for Hatch Unit 2 operation for one cycle. If concerns arise during the NRC staff's review of other plants, they will be promptly communicated to you. Subsequently, if the staff determines that the flaw and the piping integrity evaluations are unacceptable, you will be expected to take prompt action to place the facility in a safe configuration, consistent with the requirements of NRC regulations and the Hatch technical specifications.

If you have any questions in this matter, please contact me at (301) 415-1496.

Sincerely,

ORIGINAL SIGNED BY:

Kahtan N. Jabbour, Project Manager
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket No. 50-366

cc: See next page

Distribution

Docket File	KJabbour	SVarga
PUBLIC	OGC	JJohnson, RII
PDII-2 RF	ACRS	PSkinner, RII
JZwolinski	WKoo	
HBerkow	LBerry	

DFC 10

DOCUMENT NAME: G:\HATCH\FLAW.LET

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM:PDII-2 <input checked="" type="checkbox"/>	LA:PDII-2 <input checked="" type="checkbox"/>	EMCB <input checked="" type="checkbox"/>	D:PDII-2 <input checked="" type="checkbox"/>
NAME	KJabbour:cn	LBerry	JStrogonder	HBerkow
DATE	05/12/97 <i>KJS</i>	05/12/97	05/16/97	05/22/97

OFFICIAL RECORD COPY

Edwin I. Hatch Nuclear Plant
Units 1 and 2

cc:

Mr. Ernest L. Blake, Jr.
Shaw, Pittman, Potts and Trowbridge
2300 N Street, NW.
Washington, DC 20037

Mr. D. M. Crowe
Manager, Licensing
Southern Nuclear Operating
Company, Inc.
P. O. Box 1295
Birmingham, Alabama 35201-1295

Resident Inspector
U.S. Nuclear Regulatory Commission
11030 Hatch Parkway North
Baxley, Georgia 31513

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. Charles H. Badger
Office of Planning and Budget
Room 610
270 Washington Street, SW.
Atlanta, Georgia 30334

Harold Reheis, Director
Department of Natural Resources
205 Butler Street, SE., Suite 1252
Atlanta, Georgia 30334

Steven M. Jackson
Senior Engineer - Power Supply
Municipal Electric Authority
of Georgia
1470 Riveredge Parkway, NW
Atlanta, Georgia 30328-4684

Mr. Thomas P. Mozingo
Program Manager
Nuclear Operations
Oglethorpe Power Corporation
2100 East Exchange Place
P. O. Box 1349
Tucker, Georgia 30085-1349

Charles A. Patrizia, Esquire
Paul, Hastings, Janofsky & Walker
10th Floor
1299 Pennsylvania Avenue
Washington, DC 20004-9500

Chairman
Appling County Commissioners
County Courthouse
Baxley, Georgia 31513

Mr. W. G. Harriston, III
President and Chief Executive
Officer
Southern Nuclear Operating
Company, Inc.
P. O. Box 1295
Birmingham, Alabama 35201-1295

Mr. J. D. Woodard
Executive Vice President
Southern Nuclear Operating
Company, Inc.
P. O. Box 1295
Birmingham, Alabama 35201-1295

Mr. P. W. Wells
General Manager, Edwin I. Hatch
Nuclear Plant
Southern Nuclear Operating
Company, Inc.
11030 Hatch Parkway North
Baxley, Georgia 31513