



Westinghouse  
Electric Corporation

Energy Systems

Rockville Nuclear Licensing Center  
Nuclear and Advanced Technology Division

One Montrose Metro  
11921 Rockville Pike Suite 450  
Rockville Maryland 20852

NSD-NRC-97-5262  
DCP/NRC0980  
Docket No.: STN-52-003

August 7, 1997

Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

ATTENTION: T. R. QUAY

SUBJECT: RESOLUTION OF CHAPTER 2 OPEN ITEMS

Dear Mr. Quay:


The attached SSAR markup of Chapter 2 provides changes to the SSAR to address open items. These markups were discussed and agreed to during a meeting with the NRC on August 6, 1997.

The changes included to address each of the remaining open items are identified below.

RAI #	OITS #	SSAR Change
231.37	5231	Changes in subsections 2.5.4.5.3 and 2.5.4.5.3.1 have been included to address NRC comments.
231.39	5233	The criteria in subsection 2.5.2.1 have been revised to address NRC comments about site specific soil amplification.
231.40	5234	Two response spectra have been added to the list in subsection 2.5.2.2 at the request of the NRC staff.
231.41	5234	The criteria in subsection 2.5.2.1 have been revised to address NRC comments about site specific soil amplification.

E0041


9708200104 970807  
PDR ADDCK 05200003  
E PDR



August 7, 1997

Other changes are included in the markup to address questions and comments raised during the review meeting. The changes to criteria in 2.5.2.1 reference figures in 3.7.1 to be added for evaluation of site specific spectra at the foundation level. These figures will include one that is the lower value at each frequency of the two upper bound envelope spectrum for the horizontal motion and a second figure that is the envelope of the vertical motion spectra at the foundation level. These changes will be included in SSAR revision 16. The figures are not included in this transmittal.

Please contact Donald A. Lindgren at (412) 374-4856 with any questions.



Brian A. McIntyre, Manager  
Advanced Plant Safety and Licensing

/dlj

cc: J. Sebrosky, NRC w/attachment  
N. Liarulo, Westinghouse w/o attachment



## CHAPTER 2

### SITE CHARACTERISTICS

This chapter defines the site-related parameters for which the AP600 plant is designed. The site parameters are in Table 2-1. These parameters envelope most potential sites in the United States. The sections of this chapter follow the standard format and discuss how the specific parameters are used in the AP600 design and how the Combined License applicant is to demonstrate that the site meets the design parameters.

The site is acceptable if the site characteristics fall within the AP600 plant site design parameters in Table 2-1. Should specific site parameters or characteristics be outside the envelope of assumptions established by Table 2-1, the Combined License applicant referencing the AP600 will demonstrate that the design satisfies the requirements imposed by the specific site parameters and conforms to the design commitments and acceptance criteria described in the AP600 Standard Safety Analysis Report.

#### 2.1 Geography and Demography

The geography and demography are site specific and will be defined by the Combined License applicant.

##### 2.1.1 Combined License Information for Geography and Demography

Combined License applicants referencing the AP600 certified design will provide site-specific information related to site location and description, exclusion area authority and control, and population distribution.

**Site Information** – Site-specific information on the site and its location will include political subdivisions, natural and man-made features, population, highways, railways, waterways, and other significant features of the area.

**Exclusion Area** – Site-specific information on the exclusion area will include the size of the area and the exclusion area authority and control. Activity that may be permitted within the exclusion area will be included in the discussion.

**Population Distribution** – Site-specific information will be included on population distribution.

#### 2.2 Nearby Industrial, Transportation, and Military Facilities

The plant has inherent capability to withstand certain types of external accidents due to the specified design conditions associated with earthquakes, wind loading, and radiation shielding. Acceptability for external accidents associated with a given site will be covered in the Combined License application.



Each Combined License applicant referencing the AP600 will provide analyses of accidents external to the nuclear plant. The determination of the probability of occurrence of potential accidents which could have severe consequences will be based on analyses of available statistical data on the occurrence of the accident together with analyses of the effects of the accident on the plant's safety-related structures and components. If an accident is identified for which the probability of severe consequences is unacceptable, specific changes to the AP600 will be identified in the Combined License safety analysis report. The criteria for not requiring changes to the AP600 design is that the total annual frequency of occurrence is less than  $10^{-6}$  per year for an external accident leading to severe consequences. The following accident categories will be considered in determining the frequency of occurrence, as appropriate:

**Explosions** – Accidents involving detonations of high explosives; munitions, chemicals, or liquid and gaseous fuels will be considered for facilities and activities in the vicinity of the plant where such materials are processed, stored, used, or transported in quantity.

**Flammable Vapor Clouds (Delayed Ignition)** – Accidental releases of flammable liquids or vapors that result in the formation of unconfined vapor clouds in the vicinity of the plant.

**Toxic Chemicals** – Accidents involving the release of toxic chemicals from nearby mobile and stationary sources.

**Fires** – Accidents leading to high heat fluxes or smoke, and to nonflammable gas or chemical-bearing clouds from the release of materials as the consequence of fires in the vicinity of the plant.

**Airplane Crashes** – Accidents involving aircraft crashes leading to missile impact or fire in the vicinity of the plant.

#### 2.2.1 Combined License Information for Identification of Site-specific Potential Hazards

Combined License applicants referencing the AP600 certified design will provide site-specific information related to the identification of potential hazards within the site vicinity, including an evaluation of potential accidents and verify that the frequency of site-specific potential hazards is consistent with the criteria outlined in Section 2.2. The site-specific information will provide a review of aircraft hazards, information on nearby transportation routes, and information on potential industrial and military hazards.

#### 2.3 Meteorology

The AP600 is designed for air temperatures, humidity, precipitation, snow, wind, and tornado conditions as specified in Table 2-1. The Combined License applicant must provide information to demonstrate that the site parameters are within the limits specified for the standard design.





### 2.3.1 Regional Climatology

The regional climatology is site specific and will be defined by the Combined License applicant.

### 2.3.2 Local Meteorology

The local meteorology is site specific and will be defined by the Combined License applicant.

### 2.3.3 Onsite Meteorological Measurement Programs

The onsite meteorological measurement program is site specific and will be defined by the Combined License applicant. The number and location of meteorological instrument towers are determined by actual site parameters.

### 2.3.4 Short-Term Diffusion Estimates

In the absence of a specific site for use in determining values for short-term diffusion, a study was performed to determine the atmospheric dispersion factors (X/Q values) that would envelope most current plant sites and that could be used to calculate the radiological consequences of design basis accidents. The X/Q values thus derived are provided in Table 2-1.

This set of X/Q values is representative of potential sites for construction of the AP600. These values are appropriate for analyses to determine the radiological consequences of accidents. These values were determined using meteorological data representative of an 80-90th percentile U.S. site. The values were calculated following guidance in Regulatory Guide 1.145 considering ground release, building wake (building area of 33,800 ft<sup>2</sup>), and lateral plume meander under stable atmospheric conditions. Site selection is not restricted to those sites bounded by these X/Q values. If a selected site has X/Q values that exceed the reference site values, the accident doses reported in Chapter 15 would be adjusted to reflect the change in X/Q values.

### 2.3.5 Long-Term Diffusion Estimates

The long-term diffusion estimates are site specific and will be provided by the Combined License applicant. The site boundary annual average X/Q shown in Table 2-1 is used to calculate release concentrations at the site boundary for comparison with the activity release limits defined in 10 CFR 20. The value specified is expected to bound atmospheric conditions at most U.S. sites. If a selected site has a X/Q value that exceeds this reference site value, the release concentrations reported in Section 11.3 would be adjusted proportionate to the change in X/Q.





### **2.3.6 Combined License Information**

#### **2.3.6.1 Regional Climatology**

Combined License applicants referencing the AP600 certified design will address site-specific information related to regional climatology.

#### **2.3.6.2 Local Meteorology**

Combined License applicants referencing the AP600 certified design will address site-specific local meteorology information.

#### **2.3.6.3 Onsite Meteorological Measurements Program**

Combined License applicants referencing the AP600 certified design will address the site-specific onsite meteorological measurements program.

#### **2.3.6.4 Short-Term Diffusion Estimates**

Combined License applicants referencing the AP600 certified design will address the site-specific X/Q values specified in Subsection 2.3.4. For a site selected that exceeds the bounding X/Q values, the Combined License applicant will address how the radiological consequences associated with the controlling design basis accident continue to meet the dose reference values given in 10 CFR Part 100 and control room operator dose limits given in General Design Criteria 19 using site-specific X/Q values. No further action is required for sites within the bounds of the site interface criteria.

#### **2.3.6.5 Long-Term Diffusion Estimates**

Combined License applicants referencing the AP600 certified design will address long-term diffusion estimates and X/Q values specified in subsection 2.3.5. No further action is required for sites within the bounds of the site interface criteria.

### **2.4 Hydrologic Engineering**

The AP600 is designed for a normal groundwater elevation up to plant elevation 98' and for a flood level up to plant elevation 100'. For structural analysis purposes, grade elevation is also established as plant elevation 100'. Actual grade will be a few inches lower to prevent surface water from entering doorways.

For a portion of the annex building the site grade will be 107 feet to permit truck access at the elevation of the floor in the annex building and inside containment. Subsection 3.4.1 describes design provisions for groundwater and flooding.

The Combined License applicant will evaluate events leading to potential flooding to demonstrate that the site meets the interface requirements. As necessary, the Combined



License applicant may propose measures to protect the plant according to the Standard Review Plan, Section 2.4.10. Events to be considered are those identified in Standard Review Plan, Section 2.4.2.

Adverse effects of flooding due to high water or ice effects do not have to be considered for site-specific nonsafety-related structures and water sources outside the scope of the certified design. Flooding of water intake structures, cooling canals, or reservoirs or channel diversions would not prevent safe operation of the plant.

#### 2.4.1 Combined License Information

##### 2.4.1.1 Hydrological Description

Combined License applicants referencing the AP600 certified design will describe major hydrologic features on or in the vicinity of the site including critical elevations of the nuclear island and access routes to the plant.

##### 2.4.1.2 Floods

Combined License applicants referencing the AP600 certified design will address the following site-specific information on historical flooding and potential flooding factors, including the effects of local intense precipitation.

- Probable Maximum Flood on Stream and Rivers – Site-specific information that will be used to determine the design basis flooding at the site. This information will include the probable maximum flood on streams and rivers.
- Dam Failures – Site-specific information on potential dam failures.
- Probable Maximum Dam Surge and Seiche Flooding – Site-specific information on probable maximum dam surge and seiche flooding.
- Probable Maximum Tsunami Loading – Site-specific information on probable maximum tsunami loading.
- Flood Protection Requirements – Site-specific information on flood protection requirements or verification that flood protection is not required to meet the site flood level interface.

No further action is required for sites within the bounds of the site interface criteria.

##### 2.4.1.3 Cooling Water Supply

Combined License applicants will address the water supply sources to provide makeup water to the service water system cooling tower.







**2.4.1.4 Groundwater**

Combined License applicants referencing the AP600 certified design will address site-specific information on groundwater. No further action is required for sites within the bounds of the site interface criteria.

**2.4.1.5 Accidental Release of Liquid Effluents in Ground and Surface Water**

Combined License applicants referencing the AP600 certified design will address site-specific information on the ability of the ground and surface water to disperse, dilute, or concentrate accidental releases of liquid effluents. Effects of these releases on existing and known future use of surface water resources will also be addressed.

**2.4.1.6 Emergency Operation Requirement**

Combined License applicants referencing the AP600 certified design will address any flood protection emergency procedures required to meet the site flood level interface.

**2.5 Geology, Seismology, and Geotechnical Engineering**

Combined License applicants referencing the AP600 certified design will address site specific information related to basic geological, seismological, and geotechnical engineering of the site and the region, as discussed in the following subsections.

**2.5.1 Basic Geological and Seismic Combined License Information**

Combined License applicants referencing the AP600 certified design will address the following site-specific geologic and seismic information:

- Regional and site physiography
- Geomorphology
- Stratigraphy
- Lithography
- Structural geology
- Tectonics
- Seismicity

**2.5.2 Vibratory Ground Motion**

The AP600 is designed for a safe shutdown earthquake (SSE) defined by a peak ground acceleration (PGA) of 0.30g and the design response spectra specified in subsection 3.7.1.1, Figures 3.7.1-1 and 3.7.1-2. The AP600 design response spectra were developed using the Regulatory Guide 1.60 response spectra as the base and modified to address high frequency amplification effects observed in eastern North America earthquakes. The peak ground accelerations in the two horizontal and the vertical directions are equal.







The AP600 has been designed using a set of four design soil profiles described in subsection 3.7.1.4.

#### 2.5.2.1 Combined License Seismic and Tectonic Characteristics Information

Combined License applicants referencing the AP600 certified design will address the following site-specific information related to seismic and tectonic characteristics of the site and region:

- Correlation of earthquake activity with geologic structure or tectonic provinces
- Maximum earthquake potential
- Seismic wave transmission characteristics of the site
- Safe shutdown earthquake (SSE) ground response spectra

The Combined License applicant must demonstrate that the proposed site meets the following requirements:

- The free field peak ground acceleration at the finished grade level is less than or equal to a 0.30g safe shutdown earthquake.
- The site design response spectra at the finished grade level in the free-field are less than or equal to those given in Figures 3.7.1-1 and 3.7.1-2. The site specific design-response spectra must be developed at the finished grade elevation considering site specific soil amplification.
- The site specific response spectra at the foundation level in the free field are less than or equal to those given in Figures 3.7.1-18 and 3.7.1-19 ground motion must have a horizontal component with a peak ground acceleration of at least 0.1 g at the AP600 foundation level as required by 10 CFR Part 52 Appendix S IV(a)(1)(i).
- Foundation material layers are approximately horizontal (dip less than 20 degrees) and the shear wave velocity of the soil is greater than or equal to 1000 feet per second.

#### 2.5.2.2 Sites With Geoscience Parameters Outside the Certified Design

If the site specific spectra at plant grade exceed the response spectra in Figures 3.7.1-1 and 3.7.1-2 at any frequency, if the site specific spectra at foundation level exceed the response spectra in Figures 3.7.1-18 and 3.7.1-19 at any frequency, or if soil conditions are outside the range evaluated for AP600 design certification, a site specific evaluation can be performed. This evaluation will consist of a site-specific dynamic analysis and generation of in-structure response spectra to be compared with the floor response spectra of the certified design at 5 percent damping. The site design response spectra at the finished grade level in the free-field given in Figures 3.7.1-1 and 3.7.1-2 were used to develop the floor response spectra. The site is acceptable for construction of the AP600 if of the floor response spectra from the site-specific evaluation do not exceed the AP600 spectra for each of the locations identified below.



• Reactor vessel support	Figure 3.7.2-17, Sheets 1-3
• Containment operating floor	Figure 3.7.2-17, Sheets 4-6
• Shield building roof	Figure 3.7.2-15, Sheets 7-9
• Control room floor	Figure 3.7.2-15, Sheets 1-3
• Coupled auxiliary <del>roof</del> and shield building	Figure 3.7.2-9, Sheets 10-12
• Steel containment vessel at polar crane support	Figure 3.7.2-15, Sheets 1-3

Lateral earth pressures for a site evaluated using site specific spectra are acceptable if the lateral earth pressures from the site-specific analyses do not exceed the AP600 design values at any location. Lateral earth pressure design values are given in Table 2C-1 through 2C-4.

Site-specific soil structure interaction analyses must be performed by the Combined License applicant to demonstrate acceptability of sites that have seismic and soil characteristics outside of the site parameters in Table 2-1. These analyses would use the site specific soil conditions (including variation in soil properties in accordance with Standard Review Plan 3.7.2). The three components of the site specific ground motion time history must satisfy the enveloping criteria of Standard Review Plan 3.7.1 for the response spectrum for damping values of 2, 3, 4, 5 and 7 percent and the enveloping criterion for power spectral density function. Floor response spectra and lateral earth pressures determined from the site specific analyses should be compared against the design basis of the AP600 described above. These evaluations and comparisons will be provided and reviewed as part of the Combined License application.

### 2.5.2.3 Site-Specific Seismic Structures

The AP600 includes all seismic Category I structures, systems and components in the scope of the design certification. ~~Provisions are not required for site-specific design of seismic Category I structures, systems and components.~~

### 2.5.3 Surface Faulting Combined License Information

Combined License applicants referencing the AP600 certified design will address surface and subsurface geological and geophysical information including the potential for surface or near-surface faulting affecting the site.

### 2.5.4 Stability and Uniformity of Subsurface Materials and Foundations

#### 2.5.4.1 Excavation

Excavation in soil for the nuclear island structures below grade will establish a vertical face with lateral support of the adjoining undisturbed soil or rock. One alternative is to use a soil nailing method. Soil nailing is a method of retaining earth in-situ. As the nuclear island excavation progresses vertically downward, holes are drilled horizontally into the adjoining undisturbed soil, a metal rod is inserted into the hole, and grout is pumped into each hole to fill the hole and to anchor the "nail" rod.



As each increment of the nuclear island excavation is completed, nominal eight to ten inch diameter holes are drilled horizontally through the vertical face of the excavation into adjacent undisturbed soil. These "nail" holes, spaced horizontally and vertically on five to six feet centers, are drilled slightly downward to the horizontal. A "nail", normally a metal bar/rod, is center located for the full length of the hole. The nominal length of soil nails are 60 percent to 70 percent of the wall height, depending upon soil conditions. The hole is filled with grout to anchor the rod to the soil. A metal face plate is installed on the exposed end of the rod at the excavated wall vertical surface. Welded wire mesh is hung on the wall surface for wall reinforcement and secured to the soil nail face plates for anchorage. A 4,000 psi to 5,000 psi non-expansive pea gravel shotcrete mix is blown onto the wire mesh to form a nominal four to six inch thick soil retaining wall. Installation of the soil retaining wall closely follows the progress of the excavation and is from the top down, with each wire mesh-reinforced, shotcreted wall section being supported by the soil "nails" and the preceding elevations of soil nailed wall placements. The shotcrete contains a crystalline waterproofing material as described in subsection 3.4.1.1.1.

Soil nailing as a method of soil retention has been successfully used on excavations up to 55 feet deep on projects in the U.S. Soils have been retained for up to 90 feet in Europe. The state of California CALTRANS uses soil nailing extensively for excavations and soil retention installations. Soil nailing design and installation has a successful history of application which is evidenced by its excellent safety record.

The soil nailing method produces a vertical surface down to the bottom of the excavation and is used as the outside forms for the exterior walls below grade of the nuclear island. Concrete is placed directly against the vertical concrete surface of the excavation.

For excavation in rock and for methods of soil retention other than soil nailing, four to six inches of shotcrete are blown on to the vertical surface. The concrete for the exterior walls is placed against the shotcrete. The shotcrete contains a crystalline waterproofing material as described in subsection 3.4.1.1.1.

#### 2.5.4.2 Bearing Capacity

The average bearing reaction of the AP600 is about 8,000 pounds per square foot. The minimum average allowable static soil bearing capacity is 8,000 pounds per square foot over the footprint of the nuclear island at its excavation depth (see Table 2-1). Net allowable static bearing capacities have been computed for the design soil profiles as shown in Table 2-2. Capacities are calculated using bearing capacity equations in Terzaghi and Peck (Reference 1), for both cohesive and cohesionless soils (both dry and saturated cases).

For cohesive soils, an estimate for undrained shear strength ( $S_u$ ) was made by using the relationship between low strain shear modulus ( $G_{max}$ ) and undrained shear strengths. The shear modulus was obtained from the shear wave velocity profiles at a depth of approximately 90 feet. This corresponds to a depth of  $D+B/2$  (Depth,  $D = 40$  feet; Width,  $B = 104$  feet, average) which accounts for the zone of influence under the nuclear island basemat. The water table has been shown to have no effect on the bearing capacity of mats on cohesive





soils. For cohesionless soils, relative density and friction angle were calculated from their relationships with shear wave velocity and low strain shear modulus. Location of the ground water table significantly influences the bearing strength of cohesionless soils. In determining the bearing strengths, the ground water table was assumed to be at grade. For the rock profiles, the bearing strengths shown are based on the rock quality designation in accordance with Peck et al. (Reference 2).

In general, higher bearing capacities are associated with more competent soil profiles. The bearing capacities provided in Table 2-2 are preliminary estimates for static loading conditions only. The Combined License applicant will perform field and laboratory investigations to establish the material type and the associated strength parameters in order to determine the site-specific bearing capacity value.

Generally, once the static bearing capacity at a given site is adequate, the dynamic bearing demand will also be satisfied.

#### 2.5.4.3 Settlement

Short-term (elastic) and long-term (heave and consolidation) settlement for limiting cases of deep soft soil sites are evaluated for the history of loads imposed on the foundation consistent with the construction sequence. The resulting time-history of settlements includes construction activities such as dewatering, excavation, bearing surface preparation, placement of the basemat and construction of the superstructure. The settlement under the nuclear island footprint is represented in the distribution of subgrade stiffness. The basemat and structure are analyzed at various stages of construction as described in subsection 3.8.5.

The settlement analysis utilizes the one-dimensional consolidation theory in which excess pore pressure is dissipated consistent with the site consolidation parameters such as the initial void ratio, compression and recompression index and the coefficient of consolidation. The limiting cases of deep soft soil sites comprised of compressible soils are represented by subsurface profiles consisting of compressible clay deposits extending down to a depth of 360 feet underlying a 40-foot layer of sand at the surface. The evaluation considers two profiles. One profile has alternate layers of sand and clay and the second profile consists of only clay. Profile 1 maximizes settlements in the early stages of construction while profile 2 maximizes settlement during the later stages of construction and during the operational period of the plant. The elastic properties for the soils are consistent with the minimum shear wave velocity of Table 2-1 and the expected soil strains due to construction loads. The clay is assumed to be normally consolidated and the water table is assumed to be at grade.

The analysis considers the effects of dewatering and excavation, the history of construction loading, elastic deformation and consolidation of the subsurface soils, and the effect of the progressive stiffness of the structure. For the limiting deep soft soil sites examined, the maximum estimated settlement after placement of first concrete for the basemat is 4.5 inches for the postulated alternating sand and clay site and 14 inches for the all clay site.





The AP600 does not rely on structures, systems, or components located outside the nuclear island to provide safety-related functions. Differential settlement between the nuclear island foundation and the foundations of adjacent buildings does not have an adverse effect on the safety-related functions of structures, systems, and components. Differential settlement under the nuclear island foundation could cause the basemat and buildings to tilt. Much of this settlement occurs during civil construction prior to final installation of the equipment. Differential settlement of a few inches across the width of the nuclear island would not have an adverse effect on the safety-related functions of structures, systems, and components.

#### 2.5.4.4 Liquefaction

The potential for liquefaction was evaluated for the soft soil and the soft-to-medium parabolic soil profiles. In this evaluation, the profiles were assumed to be of clean sand deposits with the water table at ground level. The cyclic shear stresses generated by the safe shutdown earthquake were evaluated against the cyclic shear strengths calculated in accordance with Seed's liquefaction chart (Reference 4). These strengths were estimated using normalized blow count values representative of the shear wave velocities. The evaluation indicated that the soft profile with clean sand deposits may be susceptible to liquefaction under the generic safe shutdown earthquake. However, other factors, such as the age of the deposit or the silt and clay content, can significantly increase the resistance to liquefaction. Such sites would require detailed site-specific investigation. The soft-to-medium parabolic soil profile and any firmer soil profiles are not susceptible to liquefaction.

#### 2.5.4.5 Subsurface Uniformity

Soil structure interaction and foundation design are a function of the uniformity of the soil or rock below foundation. Although the AP600 design and analysis of the AP600 is based on soil or rock conditions with uniform properties within horizontal layers, it includes provisions and design margins to accommodate many non-uniform sites. This subsection identifies the requirements for site investigation that may be used to demonstrate that:

- A site is "uniform" based on the criteria outlined in subsection 2.5.4.5.3. If the site can be demonstrated to be "uniform" no further site specific analysis is required to qualify the site for the AP600.
- A "non-uniform" site is acceptable to locate the AP600 based on the criteria for acceptability outlined in subsection 2.5.4.5.3. Some non-uniform sites are acceptable as described in subsection 2.5.4.5.3 based on evaluation performed as part of design certification. Other non-uniform sites may be shown to be acceptable as described in subsection 2.5.4.5.3.1 using site specific evaluation as part of the Combined License application.

Considerations with respect to the materials underlying the nuclear island are the type of site, such as rock or soil, and whether the site can be considered uniform. If the site is nonuniform, the nonuniform soil characteristics such as the location and profiles of soft and hard spots should be considered. These considerations can be assessed with the information



developed in response to Regulatory Guides 1.132 and 1.138. The geological investigations of subsections 2.5.1 and 2.5.4.6.1 provide information on the uniformity of the site, whether it may be geologically impacted, and whether the bedrock may be sloping or undulatory.

Appendix 2A presents a survey of 22 commercial nuclear power plant sites in the United States. This survey focused on site parameters that affect the seismic response such as the depth to bedrock, type and characteristic of the soil layers, including the variation of shear wave velocities, the depth to the ground water level, and the embedment depth of the plant structures. Of the 22 sites, 11 are rock sites where competent rock exists at relatively shallow depths. At the other sites, the depth to bedrock varies from about 50 feet (Callaway) to well in excess of 4,000 feet (South Texas). A review of these 11 soil sites, all of which are marine, deltaic, or lacustrine deposits, did not reveal any significant variation of soil characteristics below the nuclear island footprint. There was one possible nonuniform site, Monticello, which is underlain by glacial deposits; the geologic description is such that there might be lateral variability in the foundation parameters within the plan dimension of the plant. The review of the 22 commercial nuclear power plant sites in the United States suggests that the majority of AP600 sites exhibit "uniform" soil properties within the nuclear island footprint.

#### 2.5.4.5.1 Site investigation for Uniform Sites

For sites that are expected to be uniform, based on the geologic investigation outlined in subsections 2.5.1 and 2.5.4.6.2, Appendix C to Regulatory Guide 1.132 provides guidance on the spacing and depth of borings of the geotechnical investigation for safety-related structures. Specific language in the Regulatory Guide suggests a spacing of 100 feet supplemented with borings on the periphery and at the corners for favorable, uniform geologic conditions.

For foundation engineering purposes, a series of primary borings should be drilled on a grid pattern that encompasses the nuclear island footprint and 40 feet beyond the boundaries of the nuclear island footprint. The 40-foot extension for the grid of borings is established from a Boussinesq analysis of the zone of influence of the foundation mat which shows that the net change in the effective vertical overburden stress is less than seven percent at a distance of 40 feet from the edge of the foundation mat. The grid need not be of equal spacing in the two orthogonal directions, but it should be oriented in accordance with the true dip and strike of the rock in the immediate area of the nuclear island footprint. If geologic conditions are such that true dip and strike are not obvious, or if the dip is practically flat, then the orientation of the grid can be consistent with the major orthogonal lines of the nuclear island. The spacing of the borings on the grid should be on the order of 50 to 60 feet. For example, an acceptable grid could have 5 borings in the short direction and 7 borings in the long direction, resulting in 35 primary borings to cover the nuclear island footprint and 40 feet beyond. The depth of borings should be determined on the basis of the geologic conditions. Borings should be extended to a depth sufficient to define the site geology and to sample materials that may swell during excavation, may consolidate subsequent to construction, may be unstable under earthquake loading, or whose physical properties would affect foundation behavior or stability. At least one-fourth of the primary borings should penetrate sound rock or, for a deep soil site, to a maximum depth of 250 feet below the foundation mat. At this



depth of 250 feet the change in the vertical stress during or after construction for the combined foundation loading is less than 10 percent of the in-situ effective overburden stress. Other primary borings may terminate at a depth of 160 feet below the foundation (equal to the width of the structure).

#### 2.5.4.5.2 Site investigation for Non-uniform sites

At sites that are determined to be non-uniform or potentially non-uniform during the course of the geological investigations outlined in subsections 2.5.1 and 2.5.4.6.2, the investigation effort is extended to determine if the site is acceptable for an AP600. The following paragraphs identify the site geotechnical investigations required to demonstrate that the site is acceptable.

As the AP600 foundation/structural system is robust, the probability of being able to show compliance for all but the worst of sites is high, unless liquefaction or faulting is prevalent on the site. As stated in Regulatory Guide 1.132, where variable conditions are found, spacing of boreholes should be smaller, as needed, to obtain a clear picture of soil or rock properties and their variability. Where cavities or other discontinuities of engineering significance may occur, the normal exploratory work should be supplemented by secondary borings or soundings at a spacing small enough to detect such features. The depth of the secondary borings is 160 feet below the foundation mat. At this depth, the maximum change in vertical stress during or after construction is about 11 percent of the in-situ effective overburden stress. The depth of borings should be extended beyond 160 feet if the geologic investigation indicates the possible presence of karst conditions, under-consolidated clays, loose sands, intrusive dikes or other forms of geologic impacts at depth greater than 160 feet.

To provide guidance for the site investigation of non-uniform sites, three non-uniform cases are described that might occur for nuclear plants. For each of these cases, the type of site investigation is described.

##### Sloping Bedrock Site

The sloping bedrock site as shown on Figure 2.5-2 is typical for a river front site where in the geologic past the bedrock has been eroded to a valley slope and then the valley was subsequently filled with alluvium. The bedding in the rock is nearly horizontal, but the surface of the rock is sloping on a strike parallel to the direction of the river. The shear wave velocity of the uniform soil layer overlying rock may vary between 1,000 and 2,500 feet per second. The shear wave velocity of 3,500 feet per second for the bedrock is representative of sites with a sloping rock surface. Sites where the bedrock has much higher shear wave velocities are not likely to exhibit such conditions.

Investigations for a site with a sloping bedrock surface must define the depth to bedrock as a function of plan location and the shear wave velocity of the overlying soil and bedrock. More borings may be necessary than required for a uniform site in order to establish the variation in depth to bedrock within the nuclear island footprint.





### Undulatory Bedrock Site

An undulatory bedrock site as shown in Figure 2.5-3 is one where the bedding planes in the bedrock are (or nearly) horizontal but the surface is undulatory. Such a situation may occur if the bedrock surface is an erosion surface in a marine or lake environment. Another example might be a limestone site overlain by saprolite as in the southeast United States. The undulations could be the result of differential weathering or by soft zones associated with solution activity in the limestone.

Investigations for a site with an undulatory bedrock surface associated with weathering or karst condition must define the depth to bedrock as a function of plan location and the shear wave velocity of the overlying soil and bedrock. For cases with the overlying soil layer between the foundation level and the bedrock less than 40 feet, the pattern dimensions of the undulations must be defined with borings, specifically the width and depth of the undulations. Boring spacing on the order of 10 feet may be required for undulations having dimensions on the order of 20 feet in order to establish the variation in depth to bedrock within the nuclear island footprint.

### Geologically Impacted Site

A geologically impacted site as shown on Figure 2.5-4 is one where the bedrock has abrupt facies change or has been interrupted either by a fault (shear zone) or by an intrusive such as a dike. This leads to the possibility of lateral variation in the bedrock properties affecting soil structure interaction and bearing pressure. Three subcases are identified. The first type includes an abrupt facies change. The second type has a shear zone of varying width and position. The third case is an intrusive dike of very competent rock compared to the surrounding rock.

Investigations for a geologically impacted site must define the width of the zone of the higher (or lower) shear wave velocity. The location of the zone of higher (or lower) shear wave velocity must be determined in relation to the center of containment. The azimuths of the bounding postulated vertical planes of the higher (or lower) shear wave velocity must be determined.

The zone of the higher (or lower) shear wave velocity is shown in Figure 2.5-4 bounded by non-curvilinear vertical parallel planes. It is recognized that such a situation is highly unlikely in nature. In order to define the width and location of the zone of higher (or lower) shear wave velocity, the spacing of the borings will have to be on the order of 10 feet for a zone with a width of 20 feet. It may be more practical to trench the site to locate and define the dimensions and locations of the intrusive or shear zone, thus eliminating many of the borings that would otherwise be required.





#### 2.5.4.5.3 Site Foundation Material Evaluation Criteria

The AP600 is designed for application at a site where the foundation conditions do not have extreme variation within the nuclear island footprint. This subsection provides criteria for evaluation of soil variability.

The subsurface may consist of layers and these layers may dip with respect to the horizontal. If the dip is less than 20 degrees, the generic analysis using horizontal layers is applicable as described in NUREG CR-0693 (Reference 6). The physical properties of the foundation medium may or may not vary systematically across a horizontal plane. The recommended methodology for checking uniformity is to calculate from the boring logs a series of "best estimate" planes beneath the nuclear island footprint that define the top (and bottom) of each layer. The planes could represent stratigraphic boundaries, lithologic changes, unconformities, but most important, they should represent boundaries between layers having different shear wave velocities. Shear wave velocity is the primary property used for defining uniformity of a site.

The distribution of bearing reactions under the basemat is a function of the subgrade modulus which in turn is a function of the shear wave velocity. The Combined License applicant shall demonstrate that the variation of subgrade modulus or shear wave velocity across the footprint is within the range considered for design of the nuclear island basemat. The farther the non-uniform layer is located below the foundation, the less influence it has on the bearing pressures at the basemat. Lateral variability of the shear wave velocity at depths greater than 120 feet below grade (80 feet below the foundation) do not significantly affect the subgrade modulus.

If a site can be classified as uniform, it qualifies for the AP600 based on analyses and evaluations performed to support design certification without additional site specific analyses. For a site to be considered uniform, the variation of shear wave velocity in the material below the foundation to a depth of 120 feet below finished grade within the nuclear island footprint shall meet the criteria outlined below:

- The depth to a given layer indicated on each boring log may not fall precisely on the postulated "best estimate" plane. The deviation of the observed layers from the "best estimate" planes should not exceed 5 percent of the observed depths from the ground surface to the plane. If the deviation is greater than 5 percent, additional planes may be appropriate or additional borings may be required, thereby diminishing the spacing.
- For a layer with a low strain shear wave velocity greater than or equal to 2500 feet per second ~~at the ground surface~~, the layers should ~~have be~~ approximately uniform ~~equal~~ thickness, should have a dip no greater than 20 degrees, ~~and the shear wave velocity at any location within any layer should not vary from the average velocity within the layer by more than 20 percent.~~



- For a layer with a low strain shear wave velocity less than 2500 feet per second ~~at the ground surface~~, the layers should ~~have be~~ approximately uniform equal thickness, should have a dip no greater than 20 degrees and the shear wave velocity at any location within any layer should not vary from the average velocity within the layer by more than 10 percent.

#### 2.5.4.5.3.1 Site-Specific Subsurface Uniformity Design Basis

Many sites that do not meet the above criteria for a uniform site are acceptable for the AP600. The key attribute for acceptability of the site for an AP600 is the bearing pressure on the underside of the basemat. ~~This is a function of the subgrade modulus at the elevation of the foundation. The lateral variability of this subgrade modulus is acceptable if the layers satisfy the criteria for uniform soils given above. A site having local soft or hard spots within a layer or layers does not meet the criteria for a uniform site. Non-uniform soil conditions may also require evaluation of the AP600 seismic response as described in subsection 2.5.2.2. The subgrade modulus is a function of the properties of the layers below the foundation and failure of one layer to meet the uniform criterion may not make the overall foundation unacceptable.~~

~~The design of As described in subsection 3.8.5 the nuclear island foundation outlined in subsection 3.8.5 includes sufficient margin is designed specifically to include bearing pressures of 120 percent of those of the uniform soil properties case. Evaluation criteria are defined to evaluate sites that do not satisfy the site parameters directly. The design basis provided below is included to provide a clear specification of the design commitment and evaluation criteria required to demonstrate that a site specific application satisfies AP600 requirements. Application of the AP600 to sites using this site-specific evaluation is not approved as part of the AP600 design certification and the evaluation should be provided and reviewed as part of the Combined License application.~~

#### Rigid Basemat Evaluation

A site with nonuniform soil properties may be demonstrated to be acceptable by evaluation of the bearing pressures on the underside of a rigid rectangular basemat equivalent to the nuclear island. Bearing pressures are calculated for dead and safe shutdown earthquake loads. The safe shutdown earthquake loads used for the evaluation are associated with one of the AP600 design soil cases evaluated for design certification. The soil case representative of the site-specific soil is used. For the site to be acceptable, the bearing pressures from this analysis need to be less than or equal to 120 percent of the bearing pressures calculated in similar analyses for a site having uniform soil properties.

Alternatively, the safe shutdown earthquake loads may be determined from a site-specific seismic analysis of the nuclear island using site specific inputs as described in subsection 2.5.2.2. For the site to be acceptable, the bearing pressures from the site-specific analyses need to be less than or equal to 120 percent of the bearing pressures calculated in rigid basemat analyses using the AP600 design ground motion at a site having uniform soil properties.



This evaluation method shows acceptability for geologically impacted sites where there is a sufficient soil layer between the foundation level and the abrupt stiffness change of the bedrock.

#### Flexible Basemat Evaluation

For sites having bedrock close to the foundation level the assumption of a rigid basemat may be overly conservative because local deformation of the basemat will reduce the effect of local soil variability. For such sites, a site-specific analysis may be performed using the AP600 basemat model and methodology described in subsection 3.8.5. The safe shutdown earthquake loads are those from the AP600 design soil case representative of the site-specific soil. Alternatively, bearing pressures may be determined from a site-specific soil structure interaction analysis using site specific inputs as described in subsection 2.5.2.2. For the site to be acceptable the bearing pressures from the site-specific analyses including static and dynamic loads need to be less than the capacity of each portion of the basemat.

#### 2.5.4.6 Combined License Information

Combined License applicants referencing the AP600 design will address the following site specific information related to the geotechnical engineering aspects of the site. No further action is required for sites within the bounds of the site parameters.

2.5.4.6.1 Site and Structures – Site-specific information regarding the underlying site conditions and geologic features will be addressed. This information will include site topographical features, as well as the locations of seismic Category I structures.

2.5.4.6.2 The Combined License applicant will demonstrate that the foundation soils are within the range considered for design of the nuclear island basemat. The design basis for sites that require a site specific analysis is defined in subsection 2.5.2.2.

Properties of Underlying Materials – A determination of the static and dynamic engineering properties of foundation soils and rocks in the site area will be addressed. This information will include a discussion of the type, quantity, extent, and purpose of field explorations, as well as logs of borings and test pits. Results of field plate load tests, field permeability tests, and other special field tests (e.g., bore-hole extensometer or pressuremeter tests) will also be provided. Results of geophysical surveys will be presented in tables and profiles. Data will be provided pertaining to site-specific soil layers (including their thicknesses, densities, moduli, and Poisson's ratios) between the basemat and the underlying rock stratum. Plot plans and profiles of site explorations will be provided.

Laboratory Investigations of Underlying Materials – Information about the number and type of laboratory tests and the location of samples used to investigate underlying materials will be provided. Discussion of the results of laboratory tests on disturbed and undisturbed soil and rock samples obtained from field investigations will be provided.





- 2.5.4.6.3** Excavation and Backfill – Information concerning the extent (horizontal and vertical) of seismic Category I excavations, fills, and slopes, if any will be addressed. The sources, quantities, and static and dynamic engineering properties of borrow materials will be described in the site-specific application. The compaction requirements, results of field compaction tests, and fill material properties (such as moisture content, density, permeability, compressibility, and gradation) will also be provided. Information will be provided concerning the specific soil retention system, for example, the soil nailing system, including the length and size of the soil nails, which is based on actual soil conditions and applied construction surcharge loads. Information will also be provided on the waterproofing system along the vertical face and the mudmat.
- 2.5.4.6.4** Ground Water Conditions – Groundwater conditions will be described relative to the foundation stability of the safety-related structures at the site. The soil properties of the various layers under possible groundwater conditions during the life of the plant will be compared to the range of values assumed in the standard design in Table 2-1.
- 2.5.4.6.5** Response of Soil and Rock to Dynamic Loading – The dynamic characteristics of the soil and rock will be compared to the assumptions made in the standard design regarding the variation of shear wave velocity and material damping. The parametric analyses described in Appendices 2A and 2B cover a broad range of dynamic characteristics appropriate for most soil types (sand, silts, clays, gravels, and various combinations). The shear wave velocity (based on low strain best estimate soil properties) must be greater than or equal to 1000 feet per second.
- 2.5.4.6.6** Liquefaction Potential – Soils under and around seismic Category I structures will be evaluated for liquefaction potential for the site specific SSE ground motion. This should include justification of the selection of the soil properties, as well as the magnitude, duration, and number of excitation cycles of the earthquake used in the liquefaction potential evaluation (e.g., laboratory tests, field tests, and published data). Liquefaction potential will also be evaluated to address seismic margin.
- 2.5.4.6.7** Bearing Capacity – The Combined License applicant will verify that the site-specific soil bearing capacity is equal to or greater than the value documented in Table 2-1 of the SSAR.
- 2.5.4.6.8** Earth Pressures – The AP600 is designed for static and dynamic lateral earth pressures and hydrostatic groundwater pressures acting on plant safety-related facilities using soil parameters as evaluated in previous subsections. No additional information is required on earth pressures.
- 2.5.4.6.9** Soil Properties for Seismic Analysis of Buried Pipes – The AP600 does not utilize safety related buried piping. No additional information is required on soil properties.
- 2.5.4.6.10** Static and Dynamic Stability of Facilities – Soil characteristics affecting the stability of the nuclear island will be addressed including foundation rebound, settlement, and differential settlement.





- 2.5.4.6.11 Subsurface Instrumentation** – Data will be provided on instrumentation, if any, proposed for monitoring the performance of the foundations of the nuclear island. This will specify the type, location, and purpose of each instrument, as well as significant details of installation methods. The location and installation procedures for permanent benchmarks and markers for monitoring the settlement will be addressed.

### **2.5.5 Combined License Information for Stability of Slopes**

Combined License applicants referencing the AP600 design will address site-specific information about the static and dynamic stability of soil and rock slopes, the failure of which could adversely affect the Nuclear Island.

### **2.5.6 Combined License Information for Embankments and Dams**

Combined License applicants referencing the AP600 design will address site-specific information about the static and dynamic stability of embankments and dams, the failure of which could adversely affect the Nuclear Island.

### **2.5.7 References**

1. Terzaghi, K. and Peck, R.B., "Soil Mechanics in Engineering Practice," 2nd Edition, John Wiley & Sons, New York, 1967.
2. Peck, R.B., Hanson, W.E., and Thornburn, T.H., "Foundation Engineering," John Wiley & Sons, New York, 1974.
3. Harr, M.E., "Foundations of Theoretical Soil Mechanics," McGraw-Hill Book Co., New York, 1966.
4. Seed, H.B., "Soil Liquefaction and Cyclic Mobility Evaluation for Level Ground During Earthquakes," Journal of Geotechnical Engineering Division, ASCE, Vol. 105, GT2, February 1979.
5. NUREG/CR-5956, "Consideration of Uncertainties in Soil-Structure Interaction Computations," December 1992
6. NUREG/CR-0693, "Seismic Input and Soil Structure Interaction," February, 1979.





Table 2-1 (Sheet 1 of 2)

## SITE PARAMETERS

## Air Temperature

Maximum Safety <sup>(a)</sup>	115°F dry bulb/80°F coincident wet bulb 81°F wet bulb (noncoincident)
Minimum Safety <sup>(a)</sup>	-40°F
Maximum Normal <sup>(b)</sup>	100°F dry bulb/77°F coincident wet bulb 80°F wet bulb (noncoincident) <sup>(d)</sup>
Minimum Normal <sup>(b)</sup>	-10°F

## Wind Speed

Operating Basis	110 mph; importance factor 1.11 (safety), 1.0 (nonsafety)
Tornado	300 mph

## Seismic

SSE	0.30g peak ground acceleration <sup>(c)</sup>
Fault Displacement Potential	None

## Soil

Average allowable static soil bearing capacity	Greater than or equal to 8,000 pounds per square foot over the footprint of the nuclear island at its excavation depth.
Lateral variability	Soils supporting the nuclear island should not have extreme variations in subgrade stiffness (see subsection 2.5.4.5)
Shear Wave Velocity	Greater than or equal to 1000 ft/sec based on low strain best estimate soil properties
Liquefaction Potential	None





Table 2-1 (Sheet 2 of 2)

**SITE PARAMETERS****Missiles**

Tornado	4000 - lb automobile at 105 mph horizontal, 74 mph vertical 275 - lb, 8 in. shell at 105 mph horizontal, 74 mph vertical 1 inch diameter steel ball at 105 mph horizontal and vertical
---------	--

**Flood Level**

Less than plant elevation 100'

**Ground Water Level**

Less than plant elevation 98'

**Plant Grade Elevation**

Less than plant elevation 100' except for portion at a higher elevation adjacent to the annex building

**Precipitation**

Rain	19.4 in./hr (6.3 in./5 min)
Snow/Ice	75 pounds per square foot on ground with exposure factor of 1.0 and importance factors of 1.2 (safety) and 1.0 (non-safety)

**Atmospheric Dispersion Values - X/Q**

Site boundary (0-2 hr)	$\leq 1.0 \times 10^{-3} \text{ sec/m}^3$
Site boundary (annual average)	$\leq 2.0 \times 10^{-5} \text{ sec/m}^3$
Low population zone boundary	
0 - 8 hr	$\leq 1.35 \times 10^{-4} \text{ sec/m}^3$
8 - 24 hr	$\leq 1.0 \times 10^{-4} \text{ sec/m}^3$
24 - 96 hr	$\leq 5.4 \times 10^{-5} \text{ sec/m}^3$
96 - 720 hr	$\leq 2.2 \times 10^{-5} \text{ sec/m}^3$

**Population Distribution**

Exclusion area (site)	0.5 mi
-----------------------	--------

**Notes:**

- Maximum and minimum safety values are based on historical data and exclude peaks of less than 2 hours duration.
- Maximum and minimum normal values are the 1 percent exceedance magnitudes.
- With response spectra at plant grade as given in Figures 3.7.1-1 and 3.7.1-2
- The noncoincident wet bulb temperature is applicable to the cooling tower only.



Table 2-2

**NET ALLOWABLE STATIC BEARING CAPACITIES  
(KIPS PER SQUARE FOOT)**

Soil Shear Wave Velocity Profile	Cohesive Soil		Cohesionless Soil			
	40 feet below grade	At grade	40 feet below grade		At grade	
			Dry	Submerged	Dry	Submerged
Soft Soil	7	6.8	70.3	32.2	35.1	16.1
Soft to Medium - Linear	18.9	12	102	46.6	55.8	25.6
Soft to Medium - Parabolic	32	24	139	63.8	79.7	36.5
Upper Bound, Soft to Medium - Parabolic	60	50	265	121.3	159.3	73
Soft Rock	>220					
Hard Rock	>450					







Figure 2.5-1 DELETED




Figure 2.5-2

Sloping Bedrock Site




Figure 2.5-3

Undulating Bedrock Site




Figure 2.5-4

Geologically Impacted Site