

June 4, 1971

W. R. Stratton, Chairman  
Oyster Creek Subcommittee

C. P. Siess, Vice Chairman, ACRS

CATEGORY B REPORTS - OYSTER CREEK - JERSEY CENTRAL POWER AND LIGHT  
COMPANY LETTER DATED MAY 20, 1971

Attached is a brief summary of the information presented in the  
subject correspondence. No ACRS action appears warranted.

This item should be incorporated in your set of project documents  
to maintain an up-to-date description of the plant, organization,  
procedures, etc.

Original Signed by  
J. C. McKinley  
J. C. McKinley  
Staff Assistant

Attachments:

- 1) Summary
- 2) Jersey Central Power & Light  
Co ltr dtd 5/20/71

OFFICE ▶	ACRS				
SURNAME ▶	JCM:bjw				
DATE ▶	6/4/71				

3/24/11

A194

OYSTER CREEK

Jersey Central Power and Light Company letter dated May 20, 1971 attempts to clarify the reliability of the diesel generators. A number of operational problems have been reported but only four could have affected the diesel generators' ability to perform in an emergency; all of the others have related to parallel operation which would not occur under emergency conditions. At no time did both generators fail simultaneously. There have been no failures to start since October 1970.

No ACRE action required.

OFFICE ▶							
SURNAME ▶							
DATE ▶							