



UNITED STATES
ATOMIC ENERGY COMMISSION
WASHINGTON, D.C. 20545

JCM

February 25, 1972

RECEIVED

Docket No. 50-219

1972 MAR 2 AM 8 56

U.S. ATOMIC ENERGY COMM.
ADVISORY COMMITTEE ON
REACTOR SAFEGUARDS

Dr. Chester P. Siess
Chairman, Advisory Committee
on Reactor Safeguards
U. S. Atomic Energy Commission
Washington, D. C. 20545

Dear Dr. Siess:

Sixteen (16) copies of the following are transmitted for the
Committee's information:

Letter from Jersey Central Power & Light Company
dated February 22, 1972, advising of coincident out
of service No. 2 Diesel Generator and No. 1 Contain-
ment Spray System that occurred at Oyster Creek.

Sincerely,

Donald J. Skovholt
Assistant Director
for Reactor Operations
Division of Reactor Licensing

Enclosures:
As stated

9203250295 910807
PDR FOIA
DEKOK91-282 PDR

ACRS OFFICE COPY Category "B"
3/26/295

SUPPLEMENT NO. 152

CATEGORY B

Oyster Creek

March 28, 1972

WRS
&
ACRS

Coincident "Out of Service" Condition for Both No. 1
Spray and No. 2 Diesel Generator

Jersey Central Power & Light Company letter dated
February 22, 1972 reports a case where an engineered
safety feature was out of service and at the same time
the diesel generator drive for the alternate system
was also out of service. The No. 1 Containment Spray
System was taken out of service for surveillance
testing and the No. 2 Diesel Generator was out of service
for addition of crank case oil. This was an error by
the Shift Foreman in allowing both systems to be
taken out of service at the same time.

No ACRS action is recommended.

The enclosed material should be retained as part of
the permanent record.

(JCM)

File: Oyster Creek

OFFICE ▶	ACRS				
SURNAME ▶	JCM:bae				
DATE ▶	3/28/72				

A/112