



SEABROOK STATION  
Engineering Office

Public Service of New Hampshire

February 24, 1986

New Hampshire Yankee Division

SBN- 950  
T.F. B7.1.2

United States Nuclear Regulatory Commission  
Washington, DC 20555

Attention: Mr. Vincent S. Noonan, Project Director  
PWR Project Directorate No. 5

References: (a) Construction Permits CPPR-135 and CPPR-136, Docket  
Nos. 50-443 and 50-444  
(b) PSNH Letter SBN-903, dated November 27, 1985, "Resolution  
of Power System Branch Confirmatory Items," J. DeVincentis  
to G. W. Knighton  
(c) PSNH Letter SBN-899, dated November 21, 1985, "Seabrook  
Station Voltage Regulation Study," J. DeVincentis to  
G. W. Knighton

Subject: Resolution of Power System Branch Confirmatory Item; SER  
Section 8.3.1.1.3, Item (2) (SER Confirmatory Issue No. 22)

Dear Sir:

SER Section 8.3.1.1.3, Item (2), regarding compliance with Position B3 of  
Branch Technical Position (BTP) PSB-1, requires confirmation that the starting  
and running of Non-Class 1E loads coincident with the start of accident loads  
have been considered in the Voltage Regulation Study [Reference (c)] and are  
reflected in Table 3 of the same study.

The running of Non-Class 1E loads coincident with the start of accident  
loads has been addressed in a previous response [Reference (b)]. To address  
the concern regarding the starting of Non-Class 1E loads during accident  
conditions, we have performed a review to determine the potential for these  
loads to randomly start coincident with accident loads and any subsequent  
effects on the Class 1E bus voltages. The results of our evaluation indicate  
that the consideration of the random start loads coincident with accident  
loading does not reduce the Class 1E bus voltages, as presented in Table 3 of  
the Voltage Study, to unacceptable levels.

In the course of this review, we identified some additional loads which  
receive a start signal during accident conditions via the Containment  
Isolation (T) Signal. Previously, only those starts initiated by a Safety  
Injection (SI) Signal were considered. Table 3 of the Voltage Regulation  
Study has been revised to incorporate the simultaneous start of these loads  
during accident conditions. A copy of the revised Table 3 is attached.

8603030082 860224  
PDR ADOCK 05000443  
E PDR


3001  
11

As can be seen in the enclosed table, all voltages are above the 80% required for starting except the voltages at the terminals of fans EAH-FM-4A and 4B. This condition is determined to be acceptable based on the following reasons:

1. Adequate voltage exists for the acceleration of all 4kV safeguards motors, and as these large motors accelerate (typically one to two seconds), voltage at the 480V buses will recover within two seconds such that the voltage at the terminals of the subject 460V motors will exceed the required 80%.
2. Discussions with the fan vendor indicate that there would be no problem in starting and accelerating the subject fans with terminal voltages as low as 75% from zero to two seconds, followed by voltage recovery above 80% after two seconds. Vendor's reasons for justification include: a) subject motors are only 72% loaded, b) motors utilize Class H insulation, and 3) motors are only 7.5 hp but have frame size comparable to 20 hp motor.
3. It should also be noted that during PSB-1 verification testing, it was identified that the computer model used to simulate motor start conditions yielded conservative results.

Based on the results of our evaluation which considers the starting and running of Non-Class 1E loads coincident with the start of accident loads, we believe that this submittal resolves that portion of SER Confirmatory Issue No.22 involving SER Section 8.3.1.1.3, Item (2); and we request that the resolution of this item be reflected in the next supplement to Seabrook Station's SER.

Very truly yours,



John DeVincentis, Director  
Engineering and Licensing

cc: Atomic Safety and Licensing Board Service List

William S. Jordan, III  
Diane Curran  
Harmon, Weiss & Jordan  
20001 S. Street, N.W.  
Suite 430  
Washington, D.C. 20009

Robert G. Perlis  
Office of the Executive Legal Director  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Robert A. Backus, Esquire  
116 Lowell Street  
P.O. Box 516  
Manchester, NH 03105

Philip Ahrens, Esquire  
Assistant Attorney General  
Augusta, ME 04333

Mr. John B. Tanzer  
Designated Representative of  
the Town of Hampton  
5 Morningside Drive  
Hampton, NH 03842

Roberta C. Pevear  
Designated Representative of  
the Town of Hampton Falls  
Drinkwater Road  
Hampton Falls, NH 03844

Mrs. Sandra Gavutis  
Designated Representative of  
the Town of Kensington  
RFD 1  
East Kingston, NH 03827

Jo Ann Shotwell, Esquire  
Assistant Attorney General  
Environmental Protection Bureau  
Department of the Attorney General  
One Ashburton Place, 19th Floor  
Boston, MA 02108

Senator Gordon J. Humphrey  
U.S. Senate  
Washington, DC 20510  
(ATTN: Tom Burack)

Diana P. Randall  
70 Collins Street  
Seabrook, NH 03874

Richard A. Hampe  
Hampe and McNicholas  
35 Pleasant Street  
Concord, NH 03301

Donald E. Chick  
Town Manager  
Town of Exeter  
10 Front Street  
Exeter, NH 03833

Brentwood Board of Selectmen  
RED Dalton Road  
Brentwood, NH 03833

Richard E. Sullivan, Mayor  
City Hall  
Newburyport, MA 01950

Calvin A. Canney  
City Manager  
City Hall  
126 Daniel Street  
Portsmouth, NH 03801

Stephen E. Merrill  
Attorney General  
Dana Bisbee, Esquire  
Assistant Attorney General  
Office of the Attorney General  
25 Capitol Street  
Concord, NH 03301-6397

Anne Verge, Chairperson  
Board of Selectmen  
Town Hall  
South Hampton, NH 03827

Patrick J. McKeon  
Selectmen's Office  
10 Central Road  
Rye, NH 03870

Carole F. Kagan, Esquire  
Atomic Safety and Licensing Board Panel  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Mr. Angi Machiros  
Chairman of the Board of Selectmen  
Town of Newbury  
Newbury, MA 01950

Town Manager's Office  
Town Hall - Friend Street  
Amesbury, MA 01913

Senator Gordon J. Humphrey  
1 Pillsbury Street  
Concord, NH 03301  
(ATTN: Herb Boynton)

H. Joseph Flynn  
Office of General Counsel  
Federal Emergency Management Agency  
500 C Street, SW  
Washington, DC 20472

TABLE 3

BUS AND MOTOR TERMINAL VOLTAGES  
WHEN STARTING ALL ACCIDENT LOADS SIMULTANEOUSLY  
UNIT RUNNING AT FULL LOAD  
UTILITY GRID AT MINIMUM ANTICIPATED VOLTAGE  
(ALL VOLTAGES ARE ON MOTOR VOLTAGE BASE)

<u>BUS OR</u> <u>MOTOR TAG NO.</u>	<u>HP</u>	<u>NOMINAL</u> <u>VOLTAGE, V</u>	<u>SOURCE</u>	
			<u>FROM UAT, pu</u>	<u>FROM RAT, pu</u>
EDE-SWG-5	---	4160	0.9208	0.9344
* SI-P-6A	450	4000	0.9183	0.9318
* RH-P-8A	400	4000	0.9190	0.9325
* CS-P-2A	600	4000	0.9171	0.9306
EDE-US-51	---	480	0.8789	0.8936
EDE-MCC-512	---	460	0.8751	0.8898
* EAH-FN-4A	7.5	460	0.7971	0.8105
* CS-V-142	1.9	460	0.8404	0.8545
* CS-LCV-112B	1.9	460	0.8279	0.8418
* CS-LCV-112D	0.7	460	0.8497	0.8640
* CS-V-196	0.7	460	0.8579	0.8724
EDE-US-52	---	480	0.8868	0.9016
EDE-MCC-521	---	460	0.8852	0.9000
* CBA-FN-16A	15	460	0.8398	0.8538
CBA-FN-19	40	460	0.8781	0.8930
EDE-US-53	---	480	0.8879	0.9029
EDE-SWG-6	---	4160	0.8986	0.9145
* SI-P-6B	450	4000	0.8966	0.9126
* RH-P-8B	400	4000	0.8971	0.9130
* CS-P-2B	600	4000	0.8952	0.9111
* FW-P-37B	900	4000	0.8924	0.9083
EDE-US-61	---	480	0.8506	0.8672
EDE-MCC-612	---	460	0.8466	0.8632
* EAH-FN-4B	7.5	460	0.7728	0.7880
* SW-V-5	0.33	460	0.8396	0.8561
* CS-LCV-112C	1.9	460	0.8007	0.8165
* CS-LCV-112E	0.7	460	0.8295	0.8458
* CS-V-197	0.7	460	0.8317	0.8480
EDE-US-62	---	480	0.8693	0.8866
EDE-MCC-621	---	460	0.8674	0.8848
CBA-FN-32	40	460	0.8611	0.8786
* CBA-FN-16B	15	460	0.8367	0.8534

NOTES: \* SIMULTANEOUS STARTING LOAD

- 1) OTHER SAFETY AND NON SAFETY LOADS ARE RUNNING
- 2) THE FOLLOWING LOADS ARE LUMPED TOGETHER AS BULK STARTING LOAD ON RESPECTIVE BUSES:

<u>LOAD</u>	<u>HP</u>	<u>MCC</u>	<u>LOAD</u>	<u>HP</u>	<u>MCC</u>
CS-V-167	0.7	EDE-MCC-512	CS-V-143	1.9	EDE-MCC-612
CC-V-145	0.33	EDE-MCC-512	CS-V-168	1.0	EDE-MCC-612
CS-V-149	0.7	EDE-MCC-512	CC-V-272	0.33	EDE-MCC-612
SW-V-4	0.33	EDE-MCC-512			
CGC-V-14	0.33	EDE-MCC-521	CGC-V-28	0.33	EDE-MCC-621

TERMINAL VOLTAGES FOR THESE LOADS ARE NOT LISTED IN THE TABLE BECAUSE THE LOADS IN THE TABLE REPRESENT THE WORST CASE VOLTAGE DROPS.