



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

BALTIMORE GAS AND ELECTRIC COMPANY

COCKET NO. 50-317

CALVERT CLIFFS NUCLEAR POWER PLANT UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 115
License No. DPR-53

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The applications for amendment by Baltimore Gas & Electric Company (the licensee) dated December 22, 1983 and March 26, 1984 as supplemented by letters dated March 21, 1985 and August 9, 1985, comply with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the applications, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8603030601 860220
PDR ADOCK 05000317
P PDR


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-53 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 115, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Ashok C. Thadani, Director
PWR Project Directorate #8
Division of PWR Licensing-B

Attachment:
Changes to the Technical
Specifications

Date of Issuance: February 20, 1986

ATTACHMENT TO LICENSE AMENDMENT NO. 115

FACILITY OPERATING LICENSE NO. DPR-53

DOCKET NO. 50-317

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by amendment number and contain vertical lines indicating the areas of change. The corresponding overleaf pages are provided to maintain document completeness.

Remove Pages

3/4 6-9e
3/4 6-23
3/4 6-25

Insert Pages

3/4 6-9e
3/4 6-23
3/4 6-25

CONTAINMENT SYSTEMS

CONTAINMENT PURGE SYSTEM

LIMITING CONDITION FOR OPERATION

3.6.1.7 The containment purge supply and exhaust isolation valves shall be closed by isolating air to the air operator and maintaining the solenoid air supply valve deenergized.

APPLICABILITY: MODES 1, 2, 3 and 4

ACTION:

- a. With one containment purge supply and/or one exhaust isolation valve open, close the open valve(s) within one hour or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With one containment purge supply and/or one exhaust isolation valve inoperable due to high leakage, repair the valve(s) within 24 hours or be in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.6.1.7 The 48-inch containment purge supply and exhaust isolation valves shall be determined closed at least once per 31 days, by verifying that power to the solenoid valve is removed.

CONTAINMENT SYSTEMS

CONTAINMENT VENT SYSTEM

LIMITING CONDITION FOR OPERATION

3.6.1.8 The containment vent isolation valves MOV 6900 and MOV 6901 shall be maintained closed by tagging the motor power supply breakers open and maintaining the keyed hand switches locked in the closed position.*

APPLICABILITY: MODES 1, 2, 3 and 4

ACTION:

With one or both containment vent isolation valves open, close the open valve(s) within one hour or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.6.1.8 The containment vent isolation valves shall be determined closed at least once per 31 days by verifying that power to the motor operators is removed and the valves indicate shut.*

*These requirements shall be deleted upon initial operability of the CRS isolation signal input to MOV 6900 and MOV 6901.

TABLE 3.6-1 (Continued)

CONTAINMENT ISOLATION VALVES

| <u>PENETRATION NO.</u> | <u>ISOLATION CHANNEL</u> | <u>ISOLATION VALVE IDENTIFICATION NO.</u> | <u>FUNCTION</u> | <u>ISOLATION TIME (SECONDS)</u> |
|------------------------|--------------------------|---|----------------------------|---------------------------------|
| 44 | NA NA NA | FP-141-A FP-141-B FP-6200-MOV* | Fire Protection | NA NA NA |
| 47A | NA NA | PS-6540A-SV* PS-6507A-SV* | Hydrogen Sample Outlet | NA NA |
| 47B | NA NA | PS-6540E-SV* PS-6507E-SV* | Hydrogen Sample Outlet | NA NA |
| 47C | NA NA | PS-6540F-SV* PS-6507F-SV* | Hydrogen Sample Outlet | NA NA |
| 47D | NA NA | PS-6540G-SV* PS-6507G-SV* | Hydrogen Sample Return | NA NA |
| 48A | SIAS-B SIAS-A | HP-6900-MOV(4) HP-6901-MOV(4) | Containment Vent Isolation | < 15 < 15 |

CALVERT CLIFFS - UNIT 1

3/4 6-24

Amendment No. 8/8, 8/2, 103

TABLE 3.6-1 (Continued)

CONTAINMENT ISOLATION VALVES

| <u>PENETRATION NO.</u> | <u>ISOLATION CHANNEL</u> | <u>ISOLATION VALVE IDENTIFICATION NO.</u> | <u>FUNCTION</u> | <u>ISOLATION TIME (SECONDS)</u> |
|------------------------|--------------------------|---|-------------------------------|---------------------------------|
| 48B | NA NA | HP-104 HP-6903-MOV | Hydrogen Purge Inlet | NA NA |
| 49A | NA NA | PS-6540B-SV* PS-6507B-SV* | Hydrogen Sample | NA NA |
| 49B | NA NA | PS-6540C-SV* PS-6507C-SV* | Hydrogen Sample | NA NA |
| 49C | NA NA | PS-6540D-SV* PS-6507D-SV* | Hydrogen Sample | NA NA |
| 50 | NA NA | Blind Flange Blind Flange | ILRT | NA NA |
| 59 | NA NA | SFP-170 SFP-171 | Refueling Pool Inlet | NA NA |
| 60 | NA NA | ES-144 ES-142 | Steam to Reactor Head Laydown | NA NA |

TABLE 3.6-1 (Continued)
CONTAINMENT ISOLATION VALVES

| <u>PENETRATION NO.</u> | <u>ISOLATION CHANNEL</u> | <u>ISOLATION VALVE IDENTIFICATION NO.</u> | <u>FUNCTION</u> | <u>ISOLATION TIME (SECONDS)</u> |
|------------------------|--------------------------|---|----------------------------|---------------------------------|
| 61 | NA | SFP-176 | Refueling Pool Outlet | NA |
| | NA | SFP-174 | | NA |
| | NA | SFP-172 | | NA |
| | NA | SFP-189 | | NA |
| 62 | SIAS A | PH-6579-MOV | Containment Heating Outlet | ≤ 13 |
| 64 | NA | PH-376 | Containment Heating Outlet | NA |

(1) Manual or remote manual valve which is closed during plant operation.

(2) May be opened below 300°F to establish shutdown cooling flow.

(3) Containment purge valves will be shut in MODES 1, 2, 3, and 4 per TS 3/4 6.1.7.

* May be open on an intermittent basis under administrative control.

** Containment purge isolation valves isolation times will only apply in MODE 6 when the valves are required to be OPERABLE and they are open. Isolation time for containment purge isolation valves is NA for MODES 1, 2, 3 and 4 per TS 3/4 6.1.7, during which time these valves must remain closed.

(4) Containment vent isolation valves shall be opened for containment pressure control, airborne radioactivity control, and surveillance testing purposes only.

CONTAINMENT SYSTEMS

3/4.6.5 COMBUSTIBLE GAS CONTROL

HYDROGEN ANALYZERS

LIMITING CONDITION FOR OPERATION

3.6.5.1 Two independent containment hydrogen analyzers shall be OPERABLE.

APPLICABILITY: MODES 1 and 2.

ACTION:

- a. With one hydrogen analyzer inoperable, restore the inoperable analyzer to OPERABLE status within 30 days or be in at least HOT STANDBY within the next 6 hours.
- b. With both hydrogen analyzers inoperable, restore at least one inoperable analyzer to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours.

SURVEILLANCE REQUIREMENTS

4.6.5.1 Each hydrogen analyzer shall be demonstrated OPERABLE at least bi-weekly on a STAGGERED TEST BASIS by drawing a sample from the waste gas system through the hydrogen analyzer.

4.6.5.2 Each hydrogen analyzer shall be demonstrated OPERABLE at least once per 92 days on a STAGGERED TEST BASIS by performing a CHANNEL CALIBRATION using sample gases in accordance with manufacturers' recommendations.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

BALTIMORE GAS AND ELECTRIC COMPANY

DOCKET NO. 50-318

CALVERT CLIFFS NUCLEAR POWER PLANT UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 98
License No. DPR-69

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The applications for amendment by Baltimore Gas & Electric Company (the licensee) dated December 22, 1983 and March 26, 1984 as supplemented by letters dated March 21, 1985 and August 9, 1985, comply with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the applications, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.2 of Facility Operating License No. DPR-69 is hereby amended to read as follows:

2. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 98, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Ashok C. Thadani, Director
PWR Project Directorate #8
Division of PWR Licensing-B

Attachment:
Changes to the Technical
Specifications

Date of Issuance: February 20, 1986

ATTACHMENT TO LICENSE AMENDMENT NO. 98

FACILITY OPERATING LICENSE NO. DPR-69

DOCKET NO. 50-318

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by amendment number and contain vertical lines indicating the areas of change. The corresponding overleaf pages are provided to maintain document completeness.

Remove Pages

3/4 6-9b
3/4 6-23
3/4 6-25

Insert Pages

3/4 6-9b
3/4 6-23
3/4 6-25

CONTAINMENT SYSTEMS

CONTAINMENT VENT SYSTEM

LIMITING CONDITION FOR OPERATION

3.6.1.8 The containment vent isolation valves MOV 6900 and MOV 6901 shall be maintained closed by tagging the motor power supply breakers open and maintaining the keyed hand switches locked in the closed position.*

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With one or both containment vent isolation valves open, close the open valve(s) within one hour or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.6.1.8 The containment vent isolation valves shall be determined closed at least once per 31 days by verifying that power to the motor operators is removed and the valves indicate shut.*

* These requirements shall be deleted upon initial operability of the CRS isolation signal input to MOV 6900 and MOV 6901.

CALVERT CLIFFS - UNIT 2

3/4 6-23

Amendment No. 17, 18, 45, 88, 98

TABLE 3.6-1 (Continued)

CONTAINMENT ISOLATION VALVES

| <u>PENETRATION NO.</u> | <u>ISOLATION CHANNEL</u> | <u>ISOLATION VALVE IDENTIFICATION NO.</u> | <u>FUNCTION</u> | <u>ISOLATION TIME (SECONDS)</u> |
|------------------------|--------------------------|---|----------------------------|---------------------------------|
| 44 | NA | FP-145-A | Fire Protection | NA |
| | NA | FP-145-B | | NA |
| | NA | FP-6200-MOV* | | NA |
| 47A | NA | PS-6540A-SV* | Hydrogen Sample Outlet | NA |
| | NA | PS-6507A-SV* | | NA |
| 47B | NA | PS-6540E-SV* | Hydrogen Sample Outlet | NA |
| | NA | PS-6507E-SV* | | NA |
| 47C | NA | PS-6540F-SV* | Hydrogen Sample Outlet | NA |
| | NA | PS-6507F-SV* | | NA |
| 47D | NA | PS-6540G-SV* | Hydrogen Sample Return | NA |
| | NA | PS-6507G-SV* | | NA |
| 48A | SIAS A | HP-6900-MOV (4) | Containment Vent Isolation | ≤ 15 |
| | SIAS B | HP-6901-MOV (4) | | ≤ 15 |

TABLE 3.6-1 (Continued)

CONTAINMENT ISOLATION VALVES

| <u>PENETRATION NO.</u> | <u>ISOLATION CHANNEL</u> | <u>ISOLATION VALVE IDENTIFICATION NO.</u> | <u>FUNCTION</u> | <u>ISOLATION TIME (SECONDS)</u> |
|------------------------|--------------------------|---|-------------------------------|---------------------------------|
| 48B | NA NA | HP-104 HP-6903-MOV | Hydrogen Purge Inlet | NA NA |
| 49A | NA NA | PS-6540B-SV* PS-6507B-SV* | Hydrogen Sample | NA NA |
| 49B | NA NA | PS-6540C-SV* PS-6507C-SV* | Hydrogen Sample | NA NA |
| 49C | NA NA | PS-6540D-SV* PS-6507D-SV* | Hydrogen Sample | NA NA |
| 50 | NA NA | Blind Flange Blind Flange | ILRT | NA NA |
| 59 | NA NA | SFP-178 SFP-179 | Refueling Pool Inlet | NA NA |
| 60 | NA NA | ES-144 ES-142 | Steam to Reactor Head Laydown | NA NA |

TABLE 3.6-1 (Continued)

CONTAINMENT ISOLATION VALVES

| <u>PENETRATION NO.</u> | <u>ISOLATION CHANNEL</u> | <u>ISOLATION VALVE IDENTIFICATION NO.</u> | <u>FUNCTION</u> | <u>ISOLATION TIME (SECONDS)</u> |
|------------------------|--------------------------|---|----------------------------|---------------------------------|
| 61 | NA | SFP-184 | Refueling Pool Outlet | NA |
| | NA | SFP-182 | | NA |
| | NA | SFP-180 | | NA |
| | NA | SFP-186 | | NA |
| 62 | SIAS A | PH-6579-MOV | Containment Heating Outlet | <13 |
| 64 | NA | PH-387 | Containment Heating Inlet | NA |

- (1) Manual or remote manual valve which is closed during plant operation.
- (2) May be opened below 300°F to establish shutdown cooling flow.
- (3) Containment purge valves will be shut in MODES 1, 2, 3 and 4 per TS 3/4 6.1.7.

* May be open on an intermittent basis under administrative control.

** Containment purge isolation valves isolation times will only apply in MODE 6 when the valves are required to be OPERABLE and they are open. Isolation time for containment purge isolation valves is NA for MODES 1, 2, 3 and 4 per TS 3/4 6.1.7, during which time these valves must remain closed.

- (4) Containment vent isolation valves shall be opened for containment pressure control, airborne radioactivity control, and surveillance testing purposes only.

CALVERT CLIFFS - UNIT 2

3/4 6-25

Amendment No. 47/1, 7/4, 8/9, 6/1 98

CONTAINMENT SYSTEMS

3/4.6.5 COMBUSTIBLE GAS CONTROL

HYDROGEN ANALYZERS

LIMITING CONDITION FOR OPERATION

3.6.5.1 Two independent containment hydrogen analyzers shall be OPERABLE.

APPLICABILITY: MODES 1 and 2.

ACTION:

- a. With one hydrogen analyzer inoperable, restore the inoperable analyzer to OPERABLE status within 30 days or be in at least HOT STANDBY within the next 6 hours.
- b. With both hydrogen analyzers inoperable, restore at least one inoperable analyzer to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours.

SURVEILLANCE REQUIREMENTS

4.6.5.1 Each hydrogen analyzer shall be demonstrated OPERABLE at least biweekly on a STAGGERED TEST BASIS by drawing a sample from the Waste Gas System through the hydrogen analyzer indicator.

4.6.5.2 Each hydrogen analyzer shall be demonstrated OPERABLE at least once per 92 days on a STAGGERED TEST BASIS by performing a CHANNEL CALIBRATION using sample gases in accordance with manufacturers' recommendations.