

## LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) Millstone Nuclear Power Station Unit 3										DOCKET NUMBER (2) 0 5 0 0 0 4 2 3										PAGE (3) 1 OF 2	
TITLE (4) Area Temperature Monitoring - CS-01																					
EVENT DATE (5)			LER NUMBER (6)				REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)											
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES					DOCKET NUMBER(S)							
02	08	86	86	016	00	03	10	86						0 5 0 0 0							
OPERATING MODE (9) 3			THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5. (Check one or more of the following) (11)																		
POWER LEVEL (10) 0.00			20.405(b)				20.405(c)				50.73(a)(2)(iv)				73.71(b)						
			20.405(a)(1)(i)				50.36(a)(1)				50.73(a)(2)(v)				73.71(c)						
			20.405(a)(1)(ii)				50.36(a)(2)				50.73(a)(2)(vi)				<input checked="" type="checkbox"/> OTHER (Specify in Abstract below and in Text, NRC Form 366A)						
			20.405(a)(1)(iii)				50.73(a)(2)(i)				50.73(a)(2)(vii)(A)				SPECIAL REPORT						
			20.405(a)(1)(iv)				50.73(a)(2)(ii)				50.73(a)(2)(viii)(B)										
			20.405(a)(1)(v)				50.73(a)(2)(iii)				50.73(a)(2)(ix)										
LICENSEE CONTACT FOR THIS LER (12)												TELEPHONE NUMBER									
NAME Thomas Cleary, Associate Engineer												AREA CODE 203 444-5571									
COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)																					
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC	CAUSE							SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC						
B	I	M	S 4 2 0	N																	
SUPPLEMENTAL REPORT EXPECTED (14)												EXPECTED SUBMISSION DATE (15)				MONTH	DAY	YEAR			
<input type="checkbox"/> YES (If yes, complete EXPECTED SUBMISSION DATE)												<input checked="" type="checkbox"/> NO									

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

This Special Report is being submitted within thirty days pursuant to Plant Technical Specifications 3.7.14b and 6.9.2. Plant Technical Specification 3.7.14b requires that a Special Report be submitted to the Nuclear Regulatory Commission if one or more areas exceeds the specified temperature limit by less than 20 degrees Fahrenheit for more than 8 hours. Containment Area CS-01 (inside crane wall) has exceeded the 120 degrees Fahrenheit specified limit. Subsequent investigation reveals that the pressurizer cubicle is the only area exceeding the limits.

On 2/7/86 the pressurizer cubicle reached a temperature of 121.2 degrees Fahrenheit and the plant entered the Action Statement at 0224 hours on 2/8/86. All environmentally qualified equipment was verified to be operable.

This Special Report is being submitted pursuant to Plant Technical Specifications 3.7.14b and 6.9.2.

8603170406 860310  
PDR ADDOCK 05000423  
S PDR

IE22  
111

## LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

U.S. NUCLEAR REGULATORY COMMISSION

APPROVED OMB NO 3150-0104

EXPIRES 8/31/86

FACILITY NAME (1)

DOCKET NUMBER (2)

LER NUMBER (6)

PAGE (3)

Millstone Nuclear Power Station  
Unit 3

YEAR

SEQUENTIAL  
NUMBERREVISION  
NUMBER

0 5 0 0 0 4 2 3 8 6 - 0 1 6 - 0 0 0 2 OF 2

TEXT (If more space is required, use additional NRC Form 366A's) (17)

This Special Report is being submitted within thirty days pursuant to Plant Technical Specifications 3.7.14b and 6.9.2. Plant Technical Specification 3.7.14b requires that a Special Report be submitted to the NRC if one or more areas exceeds the specified temperature limit by less than 20 degrees Fahrenheit for more than 8 hours. Containment Area CS-01 (inside crane wall) has exceeded the 120 degrees Fahrenheit specified limit. Subsequent investigation reveals that the pressurizer cubicle is the only area exceeding the limits.

On 2/7/86 the pressurizer cubicle reached a temperature of 121.2 degrees Fahrenheit and the plant entered the Action Statement at 0224 hours on 2/8/86. Further investigation reveals that the pressurizer cubicle temperature has been varying between approximately 119 degrees Fahrenheit to 125 degrees Fahrenheit consistently since 2/7/86. Therefore, an analysis has been performed for continued operability for a sustained temperature of 125 degrees Fahrenheit within the pressurizer cubicle. The following is a list of affected equipment.

3RCS\*MV8000A - Pressurizer Relief Isolation Valve  
3RCS\*MV8000B - Pressurizer Relief Isolation Valve  
3RCS\*PCV455A - Pressurizer Pressure Control Valve  
3RCS\*PCV456 - Pressurizer Power Relief Valve  
3RCS\*SV8095A - Reactor Vessel Head Vent Isolation Valve  
3RCS\*SV8095B - Reactor Vessel Head Vent Isolation Valve  
3RCS\*SV8096A - Reactor Vessel Head Vent Isolation Valve  
3RCS\*SV8096B - Reactor Vessel Head Vent Isolation Valve

Calculations have been performed for all affected equipment. Review of these calculations demonstrate continued operability of this equipment. The thermal life characteristics for each component has been adjusted accordingly.

This Special Report is being submitted pursuant to Plant Technical Specifications 3.7.14b and 6.9.2.

# NORTHEAST UTILITIES



THE CONNECTICUT LIGHT AND POWER COMPANY  
WESTERN MASSACHUSETTS ELECTRIC COMPANY  
HOLYOKE WATER POWER COMPANY  
NORTHEAST UTILITIES SERVICE COMPANY  
NORTHEAST NUCLEAR ENERGY COMPANY

General Offices • Selden Street, Berlin, Connecticut

P.O. BOX 270  
HARTFORD, CONNECTICUT 06141-0270  
(203) 666-6911

March 10, 1986  
MP-8804

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D. C. 20555

Reference: Facility Operating License No. NPF-49  
Docket No. 50-423  
Licensee Event Report 50-423/86-016-00

Gentlemen:

This letter forwards Licensee Event Report 86-016-00, a Special Report required to be submitted within thirty days pursuant to Plant Technical Specifications 3.7.14b and 6.9.2. The plant entered the Action Statement for area temperature monitoring on February 8, 1986.

Yours truly,

NORTHEAST NUCLEAR ENERGY COMPANY

*Wayne D. Romberg*  
Wayne D. Romberg

Station Superintendent  
Millstone Nuclear Power Station

WDR/TC:se

Attachment: LER 86-016-00

cc: Dr. T. E. Murley, Region I

*IEU  
11*