

Docket No.: 50-298

Mr. J. M. Pilant, Technical  
Staff Manager  
Nuclear Power Group  
Nebraska Public Power District  
Post Office Box 499  
Columbus, Nebraska 68601

MAR 13 1986

Dear Mr. Pilant:

SUBJECT: EMERGENCY TECHNICAL SPECIFICATION CHANGE MAIN STEAM LINE HIGH FLOW ISOLATION SETPOINT

Re: Cooper Nuclear Station

Your letter dated March 11, 1986 requests an emergency amendment to Technical Specification 3.2.A. The proposed amendment would change the main steam line high flow isolation setpoint limit from 140% rated steam flow to 150% rated steam flow as indicated in the enclosures.

We have reviewed your evaluation (letter from W. Yee, General Electric, to G. Horn (NPPC) dated March 6, 1986) and find it acceptable. This letter will confirm the verbal granting of a temporary waiver of compliance as recorded by the NRC Operations Center on March 10, 1986. This waiver of compliance will be in effect until March 17, 1986.

Sincerely,

Original signed by  
Daniel R. Muller

Daniel R. Muller, Director  
BWR Project Directorate #2  
Division of BWR Licensing

Enclosures:  
Proposed amended Cooper Technical Specifications pages 50 and 84

cc w/enclosure  
See next page

DISTRIBUTION:

- ~~Docket File~~
- NRC PDR
- Local PDR
- RBernero
- SNorris
- WLong
- QELD
- LHarmon
- EJordan
- BGrines
- JPartow
- TBernhart (4 cys for each docket No.)
- WJones
- DVassallo
- ACRS (10)
- OPA
- LFMB
- Gray File

8603180462 860313  
PDR ADOCK 05000298  
P PDR

OFFICIAL RECORD COPY  
\*Previously concurred

See previous concurrence

DBL:PD#2	DBL:PD#2	QELD	<del>DBL:AD:BWR</del>	DBL:PD#2:D
SNorris:nc	*WLong	*JScinto	<del>GLatous</del>	DMcLary
3/13/86	3/12/86	3/13/86	3/13/86	3/13/86
		w/comments		

Mr. J. M. Pilant  
Nebraska Public Power District

Cooper Nuclear Station

cc:

Mr. G. D. Watson, General Counsel  
Nebraska Public Power District  
P. O. Box 4999  
Columbus, Nebraska 68601

Mr. Arthur C. Gehr, Attorney  
Snell & Wilmer  
3100 Valley Center  
Phoenix, Arizona 85073

Cooper Nuclear Station  
ATTN: Mr. Paul Thomason, Division  
Manager of Nuclear Operations  
P. O. Box 98  
Brownville, Nebraska 68321

Director  
Nebraska Department of Environmental  
Control  
P. O. Box 94877  
State House Station  
Lincoln, Nebraska 68509

Mr. William Siebert, Commissioner  
Nemaha County Board of Commissioners  
Nemaha County Courthouse  
Auburn, Nebraska 68305

Resident Inspector  
U.S. Nuclear Regulatory Commission  
P. O. Box 218  
Brownville, Nebraska 68321

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

H. Ellis Simmons, Director  
Division of Radiological Health  
Department of Health  
301 Centennial Mall, South  
P. O. Box 95007  
Lincoln, Nebraska 68509

COOPER NUCLEAR STATION  
TABLE 3.2.A (Page 1)  
PRIMARY CONTAINMENT AND REACTOR VESSEL ISOLATION INSTRUMENTATION

Instrument	Instrument I.D. No.	Setting Limit	Minimum Number of Operable Components Per Trip System (1)	Action Required When Component Operability is Not Assured (2)
Main Steam Line High Rad.	RMP-RM-251, A,B,C,&D	$\leq$ 3 Times Full Power	2	A or B
Reactor Low Water Level	NBI-LIS-101, A,B,C,&D	$\geq$ +12.5" Indicated Level	2(4)	A or B
Reactor Low Low Water Level	NBI-LIS-57 A & B #2 NBI-LIS-58 A & B #2	$\geq$ -37" Indicated Level	2	A or B
Reactor Low Low Low Water Level	NBI-LIS-57 A & B #1 NBI-LIS-58 A & B #1	$\geq$ -145.5" Indicated Level	2	A or B
Main Steam Line Leak Detection	MS-TS-121, A,B,C,&D 122, 123, 124, 143, 144, 145, 146, 147, 148, 149, 150	$\leq$ 200°F	2(6)	B
Main Steam Line High Flow	MS-dPIS-116 A,B,C,&D 117, 118, 119	$<$ 150% of Rated Steam Flow	2(3)	B
Main Steam Line Low Pressure	MS-PS-134, A,B,C,&D	$\geq$ 825 psig	2(5)	B
High Drywell Pressure	PC-PS-12, A,B,C,&D	$\leq$ 2 psig	2(4)	A or B
High Reactor Pressure	RR-PS-128 A & B	$\leq$ 75 psig	1	D
Main Condenser Low Vacuum	MS-PS-103, A,B,C,&D	$\geq$ 7" Hg (7)	2	A or B
Reactor Water Cleanup System High Flow	RWCU-dPIS-170 A & B	$\leq$ 200% of System Flow	1	C

03/11/86

14:56

NPPD COLUMBUS GO

NC. 003

008

867917427

299

250

XXXX

### 3.2 BASES: (Cont'd)

and the guidelines of 10CFR100 will not be exceeded. For large breaks up to the complete circumferential break of a 28-inch recirculation line and with the trip setting given above, CSCS initiation and primary system isolation are initiated in time to meet the above criteria. Reference Paragraph VI.5.3.1 USAR.

The high drywell pressure instrumentation is a diverse signal for malfunctions to the water level instrumentation and in addition to initiating CSCS, it causes isolation of Group 2 and 6 isolation valves. For the breaks discussed above, this instrumentation will generally initiate CSCS operation before the low-low-low water level instrumentation; thus the results given above are applicable here also. The water level instrumentation initiates protection for the full spectrum of loss-of-coolant accidents and causes isolation of all isolation valves except Groups 4 and 5.

Venturis are provided in the main steam lines as a means of measuring steam flow and also limiting the loss of mass inventory from the vessel during a steam line break accident. The primary function of the instrumentation is to detect a break in the main steam line. For the worst case of accident, main steam line break outside the drywell, a trip setting of 150% of rated steam flow in conjunction with the flow limiters and main steam line valve closure, limits the mass inventory loss such that fuel is not uncovered, fuel clad temperatures peak at approximately 1000°F and release of radioactivity to the environs is below 10CFR100 guidelines. Reference Section XIV.6.5 USAR.

Temperature monitoring instrumentation is provided in the main steam tunnel and along the steam line in the turbine building to detect leaks in these areas. Trips are provided on this instrumentation and when exceeded, cause closure of isolation valves. See Spec. 3.7 for Valve Group. The setting is 200°F for the main steam leak detection system. For large breaks, the high steam flow instrumentation is a backup to the temp. instrumentation.

High radiation monitors in the main steam tunnel have been provided to detect gross fuel failure as in the control rod drop accident. With the established setting of 3 times normal background, and main steam line isolation valve closure, fission product release is limited so that 10CFR100 guidelines are not exceeded for this accident. Reference Section XIV.6.2 USAR.

Pressure instrumentation is provided to close the main steam isolation valves in RUN Mode when the main steam line pressure drops below Specification 2.1.A.6. The Reactor Pressure Vessel thermal transient due to an inadvertent opening of the turbine bypass valves when not in the RUN Mode is less severe than the loss of feedwater analyzed in Section XIV.5 of the USAR, therefore, closure of the Main Steam Isolation valves for thermal transient protection when not in RUN mode is not required.

The Reactor Water Cleanup System high flow and temperature instrumentation are arranged similar to that for the HCCI. The trip settings are such that core uncover is prevented and fission product release is within limits.