

LICENSEE EVENT REPORT

CONTROL BLOCK:

--	--	--	--	--	--

1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 I L D R S 1 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 14 15 25 26 30 37 CAT 38

LICENSEE CODE LICENSE NUMBER LICENSE TYPE

CON'T.

REPORT SOURCE L 6 0 5 0 0 0 0 1 0 7 0 8 1 5 7 8 8 0 9 1 4 7 8 9

60 61 2 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During high system load conditions, dispatcher requested postponement of weekly reactor
0 3 | protection system functional operability test DOS 500-6 to off peak time within
0 4 | interval. Need to reschedule test subsequently inadvertently overlooked. Safety
0 5 | significance minimal because both safety systems were operable. Similar events in
0 6 | R.O. #'s 50-010/1977-16, 50-010/1976-19.
0 7 |
0 8 |

SYSTEM CODE I A 11		CAUSE CODE A 12		CAUSE SUBCODE A 13		COMPONENT CODE Z Z Z Z Z 14		COMP. SUBCODE Z 15		VALVE SUBCODE Z 16	
EVENT YEAR 7 8		SEQUENTIAL REPORT NO. 2 8		OCCURRENCE CODE 0 3		REPORT TYPE L		REVISION NO. 0			
ACTION TAKEN H 18		FUTURE ACTION Z 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 0 22		ATTACHMENT SUBMITTED N 23	
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27		NPRD-4 FORM SUB. N 24		PRIME COMP. SUPPLIER Z 25		COMPONENT MANUFACTURER Z 9 9 9 26					

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Shift personnel failed to inform subsequent shifts about postponement. Shift

1 1 personnel have been reinstructed about significance of completing scheduled

1 2 surveillances. In addition, surveillances that could not be completed will be logged

1 3 to ensure they will be rescheduled.

1 4

8 9 FACILITY STATUS (28) 10 11 12 13 OTHER STATUS (30) 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

1 5 E (28) 0 7 0 (29) NA (30) B (31) Surveillance Program (32)

8 9 ACTIVITY CONTENT 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

1 6 Z (33) Z (34) NA (35) NA (36)

PERSONNEL EXPOSURES									
NUMBER			TYPE		DESCRIPTION (39)				
1	7	0	0	0	(37)	Z	(38)	NA	

PERSONNEL INJURIES	
NUMBER	DESCRIPTION
41	

8	0	0	0	(40)	NA	80
8	9	11	12			
LOSS OF OR DAMAGE TO FACILITY				(43)		
TYPE OF DAMAGE						

TYPE		DESCRIPTION	
1	g	2	42 NA

7 8 9 10 80

ISSUED DESCRIPTION (45) 78092600 65 NA

NRC USE ONLY

NAME OF PREPARER

J. Phelan

PHONE: 263