

## NRC PUBLIC DOCUMENT ROOM

RELATED CORRESPONDENCE

## PACIFIC GAS AND ELECTRIC COMPANY

PG&amp;E +

77 BEALE STREET, 31ST FLOOR • SAN FRANCISCO, CALIFORNIA 94106 • (415) 781-4211

JOHN C. MORRISSEY  
VICE PRESIDENT AND GENERAL COUNSELMALCOLM H. FURBUSH  
ASSOCIATE GENERAL COUNSELCHARLES T. VAN DEUSEN  
PHILIP A. CRANE, JR.  
HENRY J. LAPLANTE  
RICHARD A. CLARKE  
JOHN B. GIBSON  
ARTHUR L. MILLMAN, JR.  
ROBERT OHLBACH  
CHARLES W. THISSLER  
ASSISTANT GENERAL COUNSEL

September 22, 1978

THIS DOCUMENT CONTAINS  
POOR QUALITY PAGESGILBERT L. HARRICK  
DAN HAYASHI  
DAN CHAYKIN-LUBROOK  
JACK F. FALLIN, JR.  
BERNARD J. DELASANTAEDWARD J. McDANIELY  
DAN H. MCGOWAN  
JOSEPH I. KELLY  
HOWARD V. GULIS  
JAMES G. LOUDON

SENIOR COUNSEL

JOSHUA BARLEV  
ROBERT L. BORGON  
LEIGH B. CASSIDY  
GEORGE DODSON  
GARY P. EICHEN  
DONALD ERICKSON  
DAVID C. GILBERT  
ANNETTE GOODMAN  
ROBERT L. HARRIS  
KERNIT R. KURTIS  
THEODORE L. LINDBERG, JR.  
RICHARD A. LINDNER  
ROBERT B. McLENNAN  
RICHARD H. MOSS  
ROGER J. PETERS  
ROBERT A. SCOTT  
SHIRLEY A. SODERSON  
JACK W. SHUCK  
SHIRLEY A. WOOJ. PETER BAUMGARTNER  
STEVEN P. BURKLE  
PAMELA CHAPILLE  
WILLIAM H. EDWARDS  
JOHN F. EUGLEN, JR.  
JOHN N. FRY  
PATRICK G. GOLDEN  
PETER W. HANSEN  
SUSAN J. HARRIS  
F. RONALD LAUFHEIMER  
MEREDITH LIPSON  
MARK W. LOUDON  
RICHARD L. MILES  
DOUGLAS A. OGLEBY  
V. MICHAEL REICHENBACH  
TOMMY RAMSDALE  
SUZANNE SCHIFF  
DAVID J. WILLIAMSON  
BRUCE R. WORTHINGTON

ATTORNEYS

Mr. John F. Stolz, Chief  
 Light Water Reactors Branch No. 1  
 Division of Project Management  
 U. S. Nuclear Regulatory Commission  
 Washington, D. C. 20555

Re: Docket No. 50-275-OL  
 Docket No. 50-323-OL  
 Diablo Canyon Units 1 & 2



Dear Mr. Stolz:

Enclosed in support of our operating license application are responses to informal questions 1 through 10 transmitted to PG&E in an August 4, 1978 memorandum on the subject of seismic qualifications.

Because portions of the responses are Westinghouse proprietary information, enclosed are 30 copies of the proprietary responses and 30 copies of the non-proprietary version of the same responses. Also enclosed are an application for Withholding Proprietary Information From Public Disclosure and supporting letters from Westinghouse.

Five copies of these reports have been sent directly to Mr. Dennis Allison.

Kindly acknowledge receipt of the above material on the enclosed copy of this letter and return it to me in the enclosed addressed envelope.

Very truly yours,

Philip A. Crane, Jr.

Enclosures

CC w/encs.: Mr. Dennis Allison  
Service List w/non-proprietary enclosure

7810130058

NON-PROPRIETARY

This package contains non-proprietary responses to informal questions 1 through 10 transmitted to PGandE in an August 4, 1978 memorandum on the subject of Seismic Qualifications.

Question 1 Seismic Qualification: Auxiliary Safeguards Cabinet

The Auxiliary Safeguards Cabinet contains relays that receive signals from the Solid State Protection System and upon actuation, close or open contacts that operate safeguards devices, mostly valves.

Information in regard to the electrical operability during seismic tests of the Auxiliary Safeguards Cabinet and associated relays has not been described in Section 10.3.2 of the FSAR amendment 50 or in Section 3.10 of the FSAR. The Auxiliary Safeguards Cabinet may be structurally identical to the safeguard test cabinet; however, they are not electrically identical. Provide information in regard to the electrical functions monitored during seismic shaking in order to demonstrate the seismic adequacy of the Auxiliary Safeguards Cabinet.

RESPONSE

1. Auxiliary Safeguards Cabinet

The Auxiliary Safeguards Cabinet contains rotary relays that are used to provide the same electrical function, i.e., safeguard actuation, as the relays contained in the output bay of the three-bay Solid State Protection System. WCAP-8694 describes the seismic qualification of the rotary relays, and concludes that no contact bounce occurred and that the relays operated properly before, during and after the simulated seismic event. WCAP-8941 describes the seismic qualification of these rotary relays in the Auxiliary Safeguards Cabinet, stating that the seismic levels tested in WCAP-8694 are 2 to 3 times greater than those required for this cabinet at the Diablo Canyon site.

QUESTION 2Seismic Qualification: Instrument AC Inverter (Static  
Inverter)

The static inverters' function is to supply uninterrupted 118-volt, 60 Hz power to the vital AC instrument bus. The inverter operates from two power sources: a DC voltage source or a 480 volt AC source. In normal operation, the 480 volt AC source supplies power to the inverter. In the event of an AC power failure, the DC voltage source supplies power to the inverter.

It appears from the information in the FSAR that the power source's to the inverter were not changed from the AC source to the DC source during seismic shaking. Provide justification that the tests performed demonstrate the seismic adequacy of the static inverter.

RESPONSE

The inverter is designed such that during normal operation, the inverter power is derived from the AC source with the DC source assuming the load upon loss of AC voltage. The only difference in the system between the two(2) inputs is a diode, used primarily as a blocking diode. The battery supply (normal DC source) is not in the Westinghouse scope of supply and was not tested as part of the system. The diode (solid state) used is a JEDEC device and is used in many military and industrial applications. The military qualification requires that the device be subjected to G-levels much greater than required in this application and therefore the complete function of this one(1) diode was not tested. However, the blocking capability was observed during the seismic test and its integrity was maintained throughout the testing and was therefore acceptable.

During the seismic test, a small DC power supply was used in place of the normal DC power source to verify the blocking capability of the blocking diode. Had the diode shorted during the test, a protective device would have isolated the small DC power supply, thus indicating diode failure. No such indications were observed. Examination of the diode following the test indicated that no loss of integrity (open circuit) resulted. Therefore, functional operability of the diode during and after the test was demonstrated.

QUESTION 4

Seismic Qualification: Nuclear Instrumentation System

The Nuclear Instrumentation System monitors the neutron flux level and provides reactor trip signals if certain power limits are exceeded.

- a) Only the power range channel was energized and monitored during seismic testing. Therefore, it appears that the source range and intermediate range channels, required for reactor start-up and shutdown protection, have not been seismically qualified. Provide justification.

Section 7.5 of the FSAR indicates that the occurrences of a seismic event does not render the source and intermediate range channels inoperative. However, Section 3.10.2 of the FSAR (page 3.10-4) indicates that the source and intermediate range channels are not required to be seismically qualified since any design basis accident described in the FSAR can be terminated within acceptable limits by the power range channels. Provide justification for this apparent inconsistency.

- b) Section 3.10.2 of the FSAR (page 3.10-4) indicates that neutron detectors for the nuclear instrumentation system power range channel are seismically qualified. However, the seismic information for neutron detectors does not appear to be in WCAP-7821, WCAP-8021, or the seismic evaluation for postulated 7.5M Hosgri earthquake. (Amendment 50 to the FSAR). Provide the seismic qualification test information for neutron detectors associated with the power range channel as well as those detectors associated with the source and intermediate range channels.
- c) Westinghouse committed to retesting an entire typical channel of the nuclear instrumentation system (including signal conditioning circuits and bistables) to verify that the bistables have the capability to change state during a seismic event. Section 10.3.16.2 of the FSAR amendment 50 implies that only bistables have undergone additional testing versus an entire typical channel. Justify the retesting of only the bistables.
- d) Two tests were performed to demonstrate the functional operability of bistables as documented in WCAP-8831, Seismic operability demonstration testing of the Nuclear Instrumentation System Bistable Amplifiers. Test 1 (referenced as test 2 in WCAP-8831 Section 5-15) indicates all bistables tripped as

required except for the negative rate bistable. The negative bistable was not tested during the seismic shaking. Test 2 (referenced as test 5 in WCAP-8831 section 5-18) indicates 5 of 6 bistables operated as required during the test; however, it appears that the bistables were not tripped and therefore not tested during the seismic shaking as required. The overpower-high range bistable experienced an unexplained trip. And the negative rate bistables was (again as in test 1) not tested. Provide justification that these two tests demonstrate the seismic adequacy of the Nuclear Instrumentation System.

RESPONSE

(a) as stated in FSAR 3.10.2, all design basis accidents discussed in the FSAR can be terminated within acceptable limits by the power range channels. The source and intermediate channels therefore do not require seismic qualification and have not been qualified.

Shutdown procedures will contain the following provisions in the event that the source range channels are rendered inoperative due to a seismic event:

- (1) the operator will take appropriate action to preclude boron dilution
- (2) prior to cooldown, boric acid will be added to the reactor coolant to ensure that the concentration is sufficient to maintain the reactor in a subcritical state.

(b) The power range neutron detectors at Diablo Canyon are of the integral mineral insulated cable design, Model Number

] b,c

Shock and vibration tests have been performed, in the past, on this type of design by the Westinghouse Electronic Tube Division.

The integral cable design was subjected to a vibration test with constant sinusoidal acceleration of 1g in the horizontal and vertical planes. A constant sweep of 2.5 minutes duration was performed from 6 to 20 Hz in the horizontal plane. Following this, another constant sweep of 2.5 minutes duration was performed from 10 to 40 Hz in the vertical direction. In addition, the design was subjected to a sinusoidal acceleration of 1g amplitude for 20 seconds, in the horizontal plane, at frequencies of 6.5 and 7.4 Hz. The performance of the detector was evaluated by checking the resistance, capacitance, and neutron sensitivity before and after the test.

Also, a shock test was performed for this design. The shock input provided a 0.15 second duration pulse which produced an acceleration with a 0.8g radial component and a 0.14g longitudinal component. The performance of the detector was evaluated as before and no detectable damage was observed.

The upper support for the neutron detectors at Diablo Canyon is approximately at elevation 96 feet of the containment interior structure. The zero period acceleration at elevation 102ft. is approximately 0.7g's. This value is less than the test accelerations achieved during the shock and vibration tests discussed previously.

Additional multifrequency and multiaxis test have been performed on a single NIS power range detector (Model ) mounted in a support assembly which simulated a lower bound or worst case detector holder. The multifrequency inputs were developed in accordance with the guidelines set forth in WCAP-8624 IEEE-344-1975. The attached figure presents a comparison between the multifrequency and multi-axis test spectrum and the required Hosgri spectrum at elevation 102.0 feet of the containment interior. As can be seen in the figure, the test spectrum envelopes the required spectrum.

] b,c

During the test, the detector was energized from a high voltage power supply, and an a-c signal was imposed on the high voltage electrode. This a-c signal as well as d-c leakage currents were monitored on each of the two signal electrodes to determine proper electrical operability.

At the completion of the seismic test, there was no observable mechanical damage and the electrical recordings revealed only a transient type electrical disturbance on one of the two signal electrodes. This electrical disturbance was most likely generated by electrode displacement produced by the detector assembly impacting with the holder assembly. The signal perturbations were small in amplitude (less than  $10^{-8}$  amperes) and would not cause any loss of protection capability of the NI System during normal operation in the presence of a normal detector signal (greater than  $10^{-4}$


amperes) in an operating plant. Subsequent detector acceptance tests performed by the detector manufacturer did not disclose any abnormal permanent change in the electrical or neutron sensitivity characteristics. Thus it is concluded that the NIS Power Range Detector will operate as required during and after a seismic event.

It is therefore concluded that this equipment is qualified for the Hosgri 7.5M event.

(c) The purpose of the demonstration test program was to show electrical & operability. The electrical operability was verified during Tests 2 (d) and 5 as described in WCAP-8830 for the high seismic OBE and SSE conditions respectively. As a result of the test configuration (single rack in lieu of four) and the frame and rack damage incurred by the seismic test fixture malfunction; mechanical failures prevented the complete test run. As indicated in Section 7 of WCAP-8830, the drawer securing method is being revised for high seismic plants and the details were indicated in Westinghouse letter NS-CE-1609 dated 11/22/77.

Test 2 performed a functional operability test of the bistables by introducing manually adjustable signal into the complete instrumentation channel as indicated in Figure 2-3 of WCAP-8830. The signal profile is shown in Figure 5-8. The negative rate bistables was not exercised during this test; however, the signal conditioning equipment (same as that for positive rate bistable input) and six other bistables units with the same electrical and mechanical design performed as required.

Test 5 was performed under extremely adverse conditions with the failed drawer latches. Recordings (Figures 5-12 through 5-16) indicate that five of the six bistable units performed their required function during the simulated seismic event. The only bistable function not tested was the negative rate trip function. Post seismic test electrical evaluation indicated that all electrical functions performed as required. Further testing was not possible because of the structural damage.



QUESTION 5

Seismic Qualification: Pressure and Differential Pressure Transmitters

Pressure and Differential Pressure Transmitters sense the pressurizer level and pressure, and the steam generator feedwater/system level, pressure, and flow. The output from these transmitters are sent to the process control system equipment which generates the various reactor trips and safeguards actuation signals.

- a) PG&E's response dated October 3, 1977 to an NRC Question Number 3.104 states that certain instruments are to be replaced, Steam Generator Narrow Range Level and Pressurizer Level. Confirm that these instruments are in fact the Pressures and Differential Pressure Transmitters being replaced. Provide the seismic qualification information for the replacement instruments, Steam Generator Narrow Range Level, Pressure Level, Reactor Coolant System Pressure, and Containment Sump Level.
- b) The electric test results for the transmitters, described in Section 10.3.17.2 of the FSAR Amendment, 50, demonstrated that the output oscillated around the normal signal level. These oscillations could cause trips depending on the monitored variables and the trip point. The tests do not demonstrate that the equipment is capable of meeting its performance specifications under service conditions (during seismic shaking). Provide justification that the tests performed demonstrate the seismic adequacy of the transmitters.
- c) The Fischer and Porter transmitter, No. 13D2495 measures Steam Generator Level, was not tested, but was qualified by comparison to the Steam Generator Flow transmitter No. 10B2496, that was tested. Justify the assumption, made on page 4-7 of WCAP-8021, Seismic Testing and Electrical and Control Equipment (PG&E plants), that the output of 13D2495 would offset in a similar fashion under seismic excitation as 10B2496.
- d) The transmitter were only tested at some normal value as indicated in Section 10.3.17.2 of the FSAR Amendment 50. Define normal value and justify not testing over the full range of pressures, levels, or flows that these transmitters would be expected to operate.

RESPONSE

(a) The following transmitters are being replaced at Diablo Canyon:

Steam Generator Narrow Range Level  
Pressurizer Level  
Reactor Coolant System Pressure  
Containment Sump Level

Replacement

b,c

The seismic tests of the pressure and differential pressure transmitters was performed using multifrequency triaxial inputs which conform to the requirements of standard IEEE-344-1975.

b,c

The multifrequency inputs were developed in accordance with the guidelines for frequency content and phasing set forth in WCAP-8624; "General method of developing multifrequency biaxial test inputs for bistables."

The transmitters were mounted to a test fixture in a manner which simulated actual field mounting. A schematic of the triaxial test setup is shown in attached Figure 1.

b,c

b,c

QUESTION 3 Seismic Qualification: Main Control Board

Provide information in regard to the seismic qualification of individual Class 1E instruments and/or controls mounted on the Main Control board.

RESPONSE

The qualifications of individual instruments and controls mounted on the Main Control board are contained in Paragraph 10.3.15.2 of the Hosgri Report.

A summary of the seismic electrical errors are presented in Table 1.

RESPONSE

- 5(b) Signal level oscillations associated with seismic events were considered in the selection of system setpoints in order that the oscillations would not cause an invalid trip. An amendment in Section 10.3.17.2 of the Hosgri Report is being prepared to clarify that issue.

RESPONSE

- 5(c) The Fisher and Porter transmitters No. 13D2495 (Narrow Range Steam Generator Level) are being replaced. The Fisher and Porter transmitters No. 13D2495 (Wide Range Steam Generator Level) are not safety related and do not require qualification.

RESPONSE

- 5(d) The meaning of normal value, as used in Section 10.3.17.2, refers to a transmitter output between the zero and full scale operating range.

A transmitter tested for a seismic event at any given level would be representative of all other levels on the scale as long as the value selected was not so close to either end of the scale that the transmitter would be constrained, preventing the mechanical system from floating freely during the seismic event. It should be noted that the effects of the seismic forces on the transmitter do not vary according to where the scale is reading during a seismic event.

Any pressure transmitter converts pressure to forces. It then measures these forces to determine the pressure. The methods of measurement vary with design but force is always the quantity measured.

A seismic acceleration also imparts a force. This force is a function of the mass of the device and its acceleration. It will be added (or subtracted) from the other forces on the device and will thus provide a pressure deviation in the readout. This force is not a function of the other forces on the device and is therefore not a function of the scale reading before it was applied. Therefore, the deviation that it provides is not a function of the scale reading.

RESPONSE

5(d) Continued

At low pressures, the pressure forces can be small compared to the seismic forces and the relative deviation due to seismic forces will be larger than at high pressures. If, for example, the seismic forces caused a deviation equivalent to 5% of the total range of the device, the relative deviation when the reading was 5% of range would be 100% of reading. If the reading was 90% of range, the relative deviation would be only 6% of reading. For this reason, all seismic errors are considered as a percentage of span, not reading.

Thus, determination of the seismic error is independent of the instrument reading.

POSITION ON SENSITIVE TEST STAND  
No. 1 No. 2 No. 3 -C.A.P.

No. 2

No. 3

-C.A.P.

OBE

b,c


## PRELIMINARY

NOTE: VALUES GIVEN ARE WORST ERRORS FOUND IN 3 BINS  
AT EACH POSITION. PERCENT ERRORS ARE PERCENT OF SPAN.

10.361-4

b,c

Figure 2 Schematic of Biaxial Test Setup




Control Accelerometer

Position \_\_\_\_\_ Run \_\_\_\_\_

FIGURE 2

## INPUT B (OBE)




Control Accelerometer  
SPAN #2 - 5.0  
6-3-78

Position 1 Run 1  
0° DAMPING 5%

Fig. 3

## INPUT B (OBE)



Control Accelerometer

SPAN #2 - 5.0


6-3-78

Position 1 Run 4

0° DAMPING 5%

Fig. 4

INPUT B (OBE)




Control Accelerometer  
SPAN #2 - 5.0  
6-3-78

Position 1 Run 5  
0° DAMPING <5%

Fig. 5

INPUT B (OBE)




Control Accelerometer  
SPAN #2 .. 5.0 ..  
6-5-78

Position  $\gamma$  Run 6  
 $0^\circ$  DAMPING 5%

Fig. 6

INPUT B (OBE)

ACCEPTABLE OBE #5




Control Accelerometer  
6-5-78  
SPAN #2 - 5.0

Position 1 Run 7  
0° DAMPING 5%

Fig. T

## INPUT A (SSE)




Control Accelerometer  
6-5-78  
SPAN #2 - .9.5

Position  $\gamma$  Run 70  
0° DAMPING 5%

Fig. 8

## INPUT B (SSE)



Control Accelerometer


6-5-78

SPAN 0.0

Position 1 Run 8  
0° DAMPING 5%

Fig. 29

## INPUT C (SSE)



Control Accelerometer


6-5-78  
SPAN #2 - 9.0

Position 1 Run 9

0° DAMPING 5%

Fig. 910

INPUT A (SSE)



Control Accelerometer

6-5-78


SPAN - 9.5

Position 2 Run 11

270° DAMPING 5%

Fig. 11

INPUT B (SSE)



Control Accelerometer


6-5-78

SPAN - 9.9

Position 2 Run 12  
270° DAMPING 5%

Fig. 12

## INPUT C (SSE)




Control Accelerometer  
6-5-78  
SPAN #2 - 9.0

Position 2 Run 13  
270°  
DAMPING 5%

Fig. 13

INPUT A (SSE)



Control Accelerometer


6-5-78

SPAN #2 - 9.5

Position 3 Run 17  
180°  
DAMPING 5%

Fig. 14

## INPUT B (SSE)




Control Accelerometer

6-5-78

SPAN #2 - 9.9

Position 3 Run 18  
180°  
DAMPING 5%

## INPUT C (SSE)



Control Accelerometer


6-5-78  
SPAN #2 - 9.0Position 3 Run 20

180°

DAMPING 5%

Fig. 15

INPUT A (SSE)



Control Accelerometer


6-5-78  
SPAN #2 - 9.5

Position 4 Run 16

90°  
DAMPING 5%

FIG. 10

## INPUT B (SSE)



Control Accelerometer

6-5-78

SPAN #2 - 9.9


Position 4 Run 15

90°

DAMPING 5%

Fig. 18


INPUT C (SSE)



Control Accelerometer  
6-5-78  
SPAN #2 - 9.0

Position 4 Run 14  
90°  
DAMPING 5%


Fig. E-19



REQUIRED RESPONSE SPECTRUM (RRS)

OPERATING BASIS EARTHQUAKE (OBE)

Fig. 20



REQUIRED RESPONSE SPECTRUM (RRS)

SAFE SHUTDOWN EARTHQUAKE (SSE)

Fig. 21

QUESTION 6 Seismic Qualification: Process Control and Protection Equipment

The Process Control and Protection equipment contains signal conditioning equipment for monitoring pressurizer water level and pressure, containment pressure, reactor coolant flow and temperature, and steam generator water level and pressure, etc.

- a) Confirm that the process control and protection equipment referenced in Section 10.3.9 of the FSAR Amendment 50, and page 3.10-6 of the FSAR is the same as Westinghouse CID Process Equipment referenced in WCAP-8021 Section 2-4.
- b) Westinghouse committed to retesting entire typical channels of the process control and protection equipment (including signal conditioning circuits and bistables) to verify that the bistables have the capability to change state during a seismic event. Section 10.3.19.1 of the FSAR Amendment 50 implies that only bistablers have undergone additional testing versus an entire typical channel. Justify that the retesting of only bistables demonstrates the seismic adequacy of the process control and protection equipment.

RESPONSE

- a) The process control and protection equipment used in the Diablo Canyon plant is the Westinghouse CID 7100 Process Equipment. This is the same equipment discussed in Section 10.3.9 of the FSAR Amendment 50 and page 3.10-6 of the FSAR.
- b) Entire typical channel of the process control and protection equipment were tested. The FSAR will be revised to clarify this.

QUESTION 7 Seismic Qualification: Reactor Trip Switchgear

This equipment consists of two circuit breakers in series which interrupt power to the control rod drives. This interruption of power releases the rods, which fall by gravity to shut down the nuclear reactor.

The basis for determining the functional integrity of the equipment (as indicated in WCAP-7821 supplement #4) was that all breaker outputs, including secondary contact outputs to the various protection systems, electrically maintain proper contact condition of open or closed position. It appears that the capability of the contacts to change position during a seismic event was not tested. Provide justification for monitoring only proper contact conditions of open or closed versus test with contacts open, with contacts closed, and with contacts changing position.

RESPONSE

The primary function of the circuit breakers is to interrupt power and therefore (trip) release the rods. This function was checked during and after the seismic testing, and found to be acceptable. The secondary contacts are used to maintain normal plant control and therefore were monitored during the testing. Once the primary function (trip) was performed, the secondary contacts have no consequence on the operation (trip) of the system. However, the outputs from the breaker's secondary contacts are supplied to various protection systems to provide for safety injection block logic, feedwater isolation logic and turbine trip logic. These inputs and outputs were continuously monitored during the testing sequence and are shown schematically in WCAP-7821 Supplement #4 in figure 4. Therefore, the capability of the contacts to change position during a seismic event was tested.

QUESTION 8Seismic Qualification: Solid State Protection System

The solid state protection system provides reactor trip and/or engineered safety feature action. The equipment tested consists of three cabinets and represent one logic train of the protection system. The input cabinet containing relays, the logic cabinet, and the output cabinet containing master and slave relays.

- a) The solid state protection system also consists of process instrumentations bistables and field contacts that appear not be contained in the three cabinets tested as indicated in Section 10.3.22 of the FSAR Amendment 50. Describe the seismic qualification for the subject process instrumentations bistables and field contacts.
- b) The functional integrity of the solid state protection system was demonstrated, as indicated in Section 10.3.22 of the FSAR Amendment 50, contacts that provide signals for undervoltage trip, train trouble, and safety injection. Justify how the functional integrity of the solid state protection system is demonstrated by only monitoring three relay contacts.
- c) Provide the seismic qualification test results which demonstrates the electrical functionability for the relays located in the input cabinet and for the master relays located in the output cabinet of the solid state protection system.
- d) Provide the seismic qualification test results which demonstrate the electrical functionability of the solid state protection system logic cabinet.

RESPONSE

- a) Not True - Process instrumentation bistables are contained in the Process Control System equipment and have been seismically qualified. See WCAP-8021, Section 2-4 and WCAP-8828.
- b, c, d The functional integrity of the system was demonstrated during the simulated seismic event as follows: Eight simulated input signals were fed into the relays of the four compartments of the input cabinet, four to initiate a reactor trip condition and four to

initiate a safety injection condition. The contacts of the input relays were wired to the Logic Cabinet where one group of four contacts were connected to a 2/4 logic circuit to form a reactor trip signal, and the second group of four contacts were connected to another 2/4 logic circuit to form a safety injection signal. The reactor trip signal coming out of the logic cabinet, was a 48 volt d.c. voltage signal and was connected to an undervoltage coil assembly, identical to one used in the reactor trip switchgear. The reactor trip signal was also connected to a relay, where contacts were recorded. The safety injection signal coming out of the logic cabinet energizes the master relays in the output cabinet, which in turn energizes the slave relays also located in the output cabinet. Contacts from the slave relays were monitored by recorders to ascertain correct action.

Before each test all eight input signals were present, setting the circuitry in a pre-trip condition. During the actual shaking, two input signals, i.e. each group of four, were turned off simulating a 2/4 condition, which were monitored by recorders. Thus, the input relays, logic circuitry, and master and slave relays were demonstrated to function properly before, during, and after each simulated seismic event.

QUESTION 9 Seismic Qualification: Resistance Temperature Detectors

Resistance temperature detectors sense the temperature in the main coolant loops.

- a) Section 3.10 of the FSAR and 10.3.2.8 of the FSAR Amendment 50 do not provide descriptive information as to this safety function of resistance temperature detectors installed at Diablo Canyon. Provide descriptive information.
- b) Identify by manufacturer and model number Class 1E Resistance Temperature Detectors (RTD) being used at Diablo Canyon.
- c) Section 10.3.27 of the FSAR Amendment 50 implies that a much more severe function-verification test was performed on resistance temperature detectors than was reported in WCAP-8234A, Seismic testing and Functional Verification of By-Pass Loop Reactor Coolant RTD's. For this much more severe test, provide the test set up details and test results.
- d) Verify that RTD's at Diablo Canyon are installed in the Reactor Coolant By-Pass Loop.

RESPONSE

- a) The Narrow Range RTD's provide the following safety function trips:

Overtemperature  $\Delta T$

Overpower  $\Delta T$

Lo-Lo  $T_{avg}$  coincident with high steam line flow

The Wide Range RTD's provide Post Accident Monitoring.

- b) Narrow Range RTD's - Sostman Model # 11834B-1

Wide Range RTD's - Sostman Model # 11901B

- c) WCAP-8234A discusses both the seismic test and the more severe functional verification test performed on RTD's. Implication that this second test is in addition to testing discussed in the WCAP is incorrect. The FSAR will be revised for clarity.
- d) At Diablo Canyon the Narrow Range RTD's are installed in the reactor coolant By-Pass Loop; the Wide Range RTD's are installed directly into the main coolant piping through the use of thermal wells.

QUESTION 10 Seismic Qualification: Safeguards Test Cabinet

Selected relays, switches, and components were continuously monitored during seismic testing as indicated in WCAP-8021, Supplement 1 Seismic Testing of Electrical and Control Equipment (Engineered Safeguards test Cabinet for PG&E Plants), May 1977.

Provide electrical schematic diagrams of the test cabinet circuitry, describe the test set up, and identify the selected relays, switches, and components monitored during testing. Justify the seismic adequacy of relays, switches, and components that were not monitored during seismic testing.

RESPONSE

Figure 4 shows the electrical test setup for monitoring selected switches, relays, and resistor-light-diode combinations of the Safeguards Test Cabinet during its seismic test. You will note that normally open and normally closed contacts of switches S804, S807, S818 and S821 were monitored, as were normally open and normally closed contacts of relays K801, K804, K811, K821 and K822. Two light-diode combinations, DS8038 and DS8040 were also monitored for continuity. Component location is shown in Figure 5.

Switches located in the top row (middle and side) and 3rd row (middle) were monitored. Relays located in the top row (side and middle), 2nd row (middle) and bottom row (side) were monitored.

The switches, relays and resistor-light-diode combinations that were not monitored during the seismic tests are identical to the ones that were

monitored, therefore are considered seismically adequate. Note that the locations of the components monitored are in areas of expected highest acceleration, i.e., middle of panel, top of panel.

Schematic diagram 108D415 (Sheets 1-12) is furnished to enhance the understanding of the Safeguards Test Cabinet circuitry.




FIGURE 4 (cont'd)




FIGURE 4 (cont'd)




FIGURE 4 (cont'd)

078001




FIGURE 5

SOLID STATE PROTECTION  
SYSTEM TEST CABINET

COMPONENT LOCATIONS




FIG A TYPICAL PROTECTION ACTUATION CIRCUIT BLOCKING SCHEMES  
 ( CONTACT CLOSURE FOR ACTUATION )




FIG. B TYPICAL D

## TEST LIGHT

DS \*

DEV. B



ILLUMINATED PUSH BUTTON  
SWITCH WITH 28V LAMP  
NO 527  
(EXCEPT AS NOTED)

## REAR OF PANEL



## CONTACT LOCATION SCHEME

## GENERAL NOTES

1. CIRCUITRY AND HARDWARE FOR REDUNDANT PROTECTION TRAINS MAY  
AND THE TEST CABINETS ARE DUPLICATE EXCEPT AS NOTED.

A) TRAIN "A" ONLY

B) TRAIN "B" ONLY

2. FIGURE A & B THE SYMBOL \* REPRESENTS THE SUFFIX NUMBER  
OF THE DEVICE REFERENCED.

EXAMPLE:

- \* SPS RELAY K601 K602 ETC
- \* STC TEST SWITCH S602 S834 ETC
- K8 ETC RELAY K81 K817 ETC
- \* STC LIGHT DS8009 DS8077 ETC

3. FIGURE A & B TYPE CIRCUITS ARE DETAILED ON THE SCHEM-TICS.  
FIGURE A CIRCUITS WILL BE SUBSTITUTED FOR

4. THE OUTPUT RELAYS IN THE SOLID STATE PROTECTION SYSTEM THAT ARE  
LATCH TYPE ARE DESIGNATED BY AN X IN THE L COLUMN ON  
SHEET 2.

5. SW TCHES S801 THRU S848 TO BE EQUIPPED WITH SPRING RETURN FROM  
RIGHT TO LEFT POSITION WHEN DESIGNATED BY AN "X" IN THE SR  
COLUMN ON SHEET 2.

6. UNUSED CIRCUIT DEVICES AND WIRING WILL NOT BE FURNISHED, AND  
BLANK PANEL OPENINGS WILL BE CARVED.

7. MINIMUM TEST CURRENT ON STANDARD FIG. A AND D  
CIRCUITS IS 25 mA.

## LOCATION LEGEND

SPS - SOLID STATE PROTECTION SYSTEM

STC - SAFEGUARDS TEST CABINET

X - SWGR, MCC, AUXILIARY RELAY RACK, ETC.

ASC - AUXILIARY SAFEGUARDS CABINET



PROTECTION ACTUATION CIRCUIT BLOCKING SCHEMES  
(CONTACT OPENING FOR ACTUATION)

FIG. 2 TYPICAL PROTECTION ACTUATION  
CIRCUIT WITHOUT BLOCKING SCHEMES


SHEET	SUB
1	1
2	2
3	3
4	4
5	5
6	6
7	7
8	8
9	9
10	10
11	11
12	12
13	13
14	14
15	15
16	16
17	17
18	18
19	19
20	20
21	21
22	22
23	23
24	24
25	25
26	26
27	27
28	28
29	29
30	30
31	31
32	32
33	33
34	34
35	35
36	36
37	37
38	38
39	39
40	40
41	41
42	42
43	43
44	44
45	45
46	46
47	47
48	48
49	49
50	50
51	51
52	52
53	53
54	54
55	55
56	56
57	57
58	58
59	59
60	60
61	61
62	62
63	63
64	64
65	65
66	66
67	67
68	68
69	69
70	70
71	71
72	72
73	73
74	74
75	75
76	76
77	77
78	78
79	79
80	80
81	81
82	82
83	83
84	84
85	85
86	86
87	87
88	88
89	89
90	90
91	91
92	92
93	93
94	94
95	95
96	96
97	97
98	98
99	99
100	100
101	101
102	102
103	103
104	104
105	105
106	106
107	107
108	108
109	109
110	110
111	111
112	112
113	113
114	114
115	115
116	116
117	117
118	118
119	119
120	120
121	121
122	122
123	123
124	124
125	125
126	126
127	127
128	128
129	129
130	130
131	131
132	132
133	133
134	134
135	135
136	136
137	137
138	138
139	139
140	140
141	141
142	142
143	143
144	144
145	145
146	146
147	147
148	148
149	149
150	150
151	151
152	152
153	153
154	154
155	155
156	156
157	157
158	158
159	159
160	160
161	161
162	162
163	163
164	164
165	165
166	166
167	167
168	168
169	169
170	170
171	171
172	172
173	173
174	174
175	175
176	176
177	177
178	178
179	179
180	180
181	181
182	182
183	183
184	184
185	185
186	186
187	187
188	188
189	189
190	190
191	191
192	192
193	193
194	194
195	195
196	196
197	197
198	198
199	199
200	200
201	201
202	202
203	203
204	204
205	205
206	206
207	207
208	208
209	209
210	210
211	211
212	212
213	213
214	214
215	215
216	216
217	217
218	218
219	219
220	220
221	221
222	222
223	223
224	224
225	225
226	226
227	227
228	228
229	229
230	230
231	231
232	232
233	233
234	234
235	235
236	236
237	237
238	238
239	239
240	240
241	241
242	242
243	243
244	244
245	245
246	246
247	247
248	248
249	249
250	250
251	251
252	252
253	253
254	254
255	255
256	256
257	257
258	258
259	259
260	260
261	261
262	262
263	263
264	264
265	265
266	266
267	267
268	268
269	269
270	270
271	271
272	272
273	273
274	274
275	275
276	276
277	277
278	278
279	279
280	280
281	281
282	282
283	283
284	284
285	285
286	286
287	287
288	288
289	289
290	290
291	291
292	292
293	293
294	294
295	295
296	296
297	297
298	298
299	299
300	300
301	301
302	302
303	303
304	304
305	305
306	306
307	307
308	308
309	309
310	310
311	311
312	312
313	313
314	314
315	315
316	316
317	317
318	318
319	319
320	320
321	321
322	322
323	323
324	324
325	325
326	326
327	327
328	328
329	329
330	330
331	331
332	332
333	333
334	334
335	335
336	336
337	337
338	338
339	339
340	340
341	341
342	342
343	343
344	344
345	345
346	346
347	347
348	348
349	349
350	350
351	351
352	352
353	353
354	354
355	355
356	356
357	357
358	358
359	359
360	360
361	361
362	362
363	363
364	364
365	365
366	366
367	367
368	368
369	369
370	370
371	371
372	372
373	373
374	374
375	375
376	376
377	377
378	378
379	379
380	380
381	381
382	382
383	383
384	384
385	385
386	386
387	387
388	388
389	389
390	390
391	391
392	392
393	393
394	394
395	395
396	396
397	397
398	398
399	399
400	400
401	401
402	402
403	403
404	404
405	405
406	406
407	407
408	408
409	409
410	410
411	411
412	412
413	413
414	414
415	415
416	416
417	417
418	418
419	419
420	420
421	421
422	422
423	423
424	424
425	425
426	426
427	427
428	428
429	429
430	430
431	431
432	432
433	433
434	434
435	435
436	436
437	437
438	438
439	439
440	440
441	441
442	442
443	443
444	444
445	445
446	446
447	447
448	448
449	449
450	450
451	451
452	452
453	453
454	454
455	455
456	456
457	457
458	458
459	459
460	460
461	461
462	462
463	463
464	464
465	465
466	466
467	467
468	468
469	469
470	470
471	471
472	472
473	473
474	474
475	475
476	476
477	477
478	478
479	479
480	480
481	481
48	

SHEET 2		LIST OF MATERIALS	
ITEM	SR	ITEM	SR
SB01		1 * TEST SWITCH X TYPE CTI (DEV 1, SH. 1) (NOTE 5)	SB01
SB02		2 A TEST LIGHT W/W 28V LAMP NO. 327 (DEV 3 SH. 1)	SB02
SB03		3 I RESET SWITCH, 4 TYPE W2 (DEV 2, SH. 1)	SB03
SB04		4 1B RELAY 120VAC PC TTER /BRUMFIELD SERIES MCP	SB04
SB05		5 I RELAY 120VAC C P CLARE NO SP1011AG000	SB05
SB06		6 ■ TAG, FUNCTION	SB06
SB07			SB07
SB08			SB08
SB09			SB09
SB10			SB10
SB11			SB11
SB12			SB12
SB13			SB13
SB14			SB14
SB15	X		SB15
SB16	X		SB16
SB17	X		SB17
SB18	X		SB18
SB19	X		SB19
SB20	X		SB20
SB21	X		SB21
SB22	X		SB22
SB23	X		SB23
SB24	X		SB24
SB25	X		SB25
SB26	X		SB26
SB27	X		SB27
SB28	X		SB28
SB29	X		SB29
SB30	X		SB30
SB31	X		SB31
SB32	X		SB32
SB33	X		SB33
SB34	X		SB34
SB35	X		SB35
SB36	X		SB36
SB37	X		SB37
SB38	X		SB38
SB39	X		SB39
SB40	X		SB40
SB41	X		SB41
SB42	X		SB42
SB43	X		SB43
SB44	X		SB44
SB45	X		SB45
SB46	X		SB46
SB47	X		SB47
SB48	X		SB48
SB49	X		SB49
SB50	X		SB50
SB51	X		SB51
SB52	X		SB52
SB53	X		SB53
SB54	X		SB54
SB55	X		SB55
SB56	X		SB56
SB57	X		SB57
SB58	X		SB58
SB59	X		SB59
SB60	X		SB60
SB61	X		SB61
SB62	X		SB62
SB63	X		SB63
SB64	X		SB64
SB65	X		SB65
SB66	X		SB66
SB67	X		SB67
SB68	X		SB68
SB69	X		SB69
SB70	X		SB70
SB71	X		SB71
SB72	X		SB72
SB73	X		SB73
SB74	X		SB74
SB75	X		SB75
SB76	X		SB76
SB77	X		SB77
SB78	X		SB78
SB79	X		SB79
SB80	X		SB80
SB81	X		SB81
SB82	X		SB82
SB83	X		SB83
SB84	X		SB84
SB85	X		SB85
SB86	X		SB86
SB87	X		SB87
SB88	X		SB88
SB89	X		SB89
SB90	X		SB90
SB91	X		SB91
SB92	X		SB92
SB93	X		SB93
SB94	X		SB94
SB95	X		SB95
SB96	X		SB96
SB97	X		SB97
SB98	X		SB98
SB99	X		SB99
SB100	X		SB100
SB101	X		SB101
SB102	X		SB102
SB103	X		SB103
SB104	X		SB104
SB105	X		SB105
SB106	X		SB106
SB107	X		SB107
SB108	X		SB108
SB109	X		SB109
SB110	X		SB110
SB111	X		SB111
SB112	X		SB112
SB113	X		SB113
SB114	X		SB114
SB115	X		SB115
SB116	X		SB116
SB117	X		SB117
SB118	X		SB118
SB119	X		SB119
SB120	X		SB120
SB121	X		SB121
SB122	X		SB122
SB123	X		SB123
SB124	X		SB124
SB125	X		SB125
SB126	X		SB126
SB127	X		SB127
SB128	X		SB128
SB129	X		SB129
SB130	X		SB130
SB131	X		SB131
SB132	X		SB132
SB133	X		SB133
SB134	X		SB134
SB135	X		SB135
SB136	X		SB136
SB137	X		SB137
SB138	X		SB138
SB139	X		SB139
SB140	X		SB140
SB141	X		SB141
SB142	X		SB142
SB143	X		SB143
SB144	X		SB144
SB145	X		SB145
SB146	X		SB146
SB147	X		SB147
SB148	X		SB148
SB149	X		SB149
SB150	X		SB150
SB151	X		SB151
SB152	X		SB152
SB153	X		SB153
SB154	X		SB154
SB155	X		SB155
SB156	X		SB156
SB157	X		SB157
SB158	X		SB158
SB159	X		SB159
SB160	X		SB160
SB161	X		SB161
SB162	X		SB162
SB163	X		SB163
SB164	X		SB164
SB165	X		SB165
SB166	X		SB166
SB167	X		SB167
SB168	X		SB168
SB169	X		SB169
SB170	X		SB170
SB171	X		SB171
SB172	X		SB172
SB173	X		SB173
SB174	X		SB174
SB175	X		SB175
SB176	X		SB176
SB177	X		SB177
SB178	X		SB178
SB179	X		SB179
SB180	X		SB180
SB181	X		SB181
SB182	X		SB182
SB183	X		SB183
SB184	X		SB184
SB185	X		SB185
SB186	X		SB186
SB187	X		SB187
SB188	X		SB188
SB189	X		SB189
SB190	X		SB190
SB191	X		SB191
SB192	X		SB192
SB193	X		SB193
SB194	X		SB194
SB195	X		SB195
SB196	X		SB196
SB197	X		SB197
SB198	X		SB198
SB199	X		SB199
SB200	X		SB200
SB201	X		SB201
SB202	X		SB202
SB203	X		SB203
SB204	X		SB204
SB205	X		SB205
SB206	X		SB206
SB207	X		SB207
SB208	X		SB208
SB209	X		SB209
SB210	X		SB210
SB211	X		SB211
SB212	X		SB212
SB213	X		SB213
SB214	X		SB214
SB215	X		SB215
SB216	X		SB216
SB217	X		SB217
SB218	X		SB218
SB219	X		SB219
SB220	X		SB220
SB221	X		SB221
SB222	X		SB222
SB223	X		SB223
SB224	X		SB224
SB225	X		SB225
SB226	X		SB226
SB227	X		SB227
SB228	X		SB228
SB229	X		SB229
SB230	X		SB230
SB231	X		SB231
SB232	X		SB232
SB233	X		SB233
SB234	X		SB234
SB235	X		SB235
SB236	X		SB236
SB237	X		SB237
SB238	X		SB238
SB239	X		SB239
SB240	X		SB240
SB241	X		SB241
SB242	X		SB242
SB243	X		SB243
SB244	X		SB244
SB245	X		SB245
SB246	X		SB246
SB247	X		SB247
SB248	X		SB248
SB249	X		SB249
SB250	X		SB250
SB251	X		SB251
SB252	X		SB252
SB253	X		SB253
SB254	X		SB254
SB255	X		SB255
SB256	X		SB256
SB257	X		SB257
SB258	X		SB258
SB259	X		SB259
SB260	X		SB260
SB261	X		SB261
SB262	X		SB262
SB263	X		SB263
SB264	X		SB264
SB265	X		SB265
SB266	X		SB266
SB267	X		SB267
SB268	X		SB268
SB269	X		SB269
SB270	X		SB270
SB271	X		SB271
SB272	X		SB272
SB273	X		SB273
SB274	X		SB274
SB275	X		SB275
SB276	X		SB276
SB277	X		SB277
SB278	X		SB278
SB279	X		SB279
SB280	X		SB280
SB281	X		SB281
SB282	X		SB282
SB283	X		SB283
SB284	X		SB284
SB285	X		SB285
SB286	X		SB286
SB287	X		SB287
SB288	X		SB288
SB289	X		SB289
SB290	X		SB290
SB291	X		SB291
SB292	X		SB292
SB293	X		SB293
SB294	X		SB294
SB295	X		SB295
SB296	X		SB296
SB297	X		SB297
SB298	X		SB298
SB299	X		SB299
SB300	X		SB300
SB301	X		SB301
SB302	X		SB302
SB303	X		SB303
SB304	X		SB304
SB305	X		SB305
SB306	X		SB306
SB307	X		SB307
SB308	X		SB308
SB309	X		SB309
SB310	X		SB310
SB311	X		SB311
SB312	X		SB312
SB313	X		SB313
SB314	X		SB314
SB315	X		SB315
SB316	X		SB316
SB317	X		SB317
SB318	X		SB318
SB319	X		SB319
SB320	X		SB320
SB321	X		SB321
SB322	X		SB322
SB323	X		SB323
SB324	X		SB324
SB325	X		SB325
SB326	X		SB326
SB327	X		SB327
SB328	X		SB328
SB329	X		SB329
SB330	X		SB330
SB331	X		SB331
SB332	X		SB332
SB333	X		SB333
SB334	X		SB334
SB335	X		SB335
SB336	X		SB336
SB337	X		SB337
SB338	X		SB338
SB339	X		SB339
SB340	X		SB340
SB341	X		SB341
SB342	X		SB342
SB343	X		SB343
SB344	X		SB344
SB345	X		SB345
SB346	X		SB346
SB347	X		SB347
SB348	X		SB348
SB349	X		SB349
SB350			

IS ARE TESTED IN CONJUNCTION WITH TEST SWITCH 6380A.

#### PANEL ARRANGEMENT


		Westinghouse Electric Corporation	
		NUCLEAR ENERGY SYSTEMS, PITTSBURGH, PA., U.S.A.	
		TITLE SHEET - 105D415-ELECTRIC CO.	
		DIABLO CANYON INTS142	
		SAFEGUARDS TEST CABINET	
		NTS	
		SCALE	
		DIMENSIONS IN INCHES	
		DO NOT SCALE	
REF. ARI:		105D415	
REF. DRI:		SHEET 2	
REF. G.R.P.V.		SUB F 3A 854	



36 D



4-1984  
G-1280



TO SOLID STATE PROTECTION SYS - J4C2



TO SOLID STATE PROTECT

SO-10-5-1002	1
SO-10-5-1002	2
ECN-B426	3
CHANGES ARE BACKCIRCLED.	
POTOCCELLI 3-7-72	
PGE/FEU 985	
ECN 985B	
CHANGES ARE BACKCIRCLED.	


11

10

9

8

7



IN SYSTEM - J6C1

EPS RELAY ACTUATION

Westinghouse Electric Corporation   
NUCLEAR ENERGY SYSTEMS PITTSBURGH PA U.S.A.  
CALIFORNIA GAS & ELECTRIC CO  
DAGGER CANYON UNITS 1&2  
SAFEGUARDS TEST CABINET  
NTS  
SCALE  
DIMENSIONS IN INCHES  
SHEET 4  
SUB 13845

REF.  
CHAS  
DET ENG  
MFG ENG  
STL ENG  
APP.  
APP.  
APP.  
STL SURV.

3

2


1

6



5

4





STEAM DUMP CKT  
PG&E DIAG NO  
437649



AC/DC TEST CIRCUIT SCHEMATIC - FIGURE A

Westinghouse Electric Corporation	
TYPE PAC ELC GATE-ELECTRIC CO.	
DIABLO CANYON UNIT 142	
SAFEGUARD TEST CABINET	
SCALE	1:1
DIMENSIONS IN INCHES	
EQUIP. SCALE 1:184.667	
PRINT SCALE 1:108.345	

LESS OTHERWISE SPECIFIED.


A i A

B i B

24


D i

36



NOTE:  
ALL RESISTORS 2500 OHM





NOTE :  
ALL RESISTORS 2500

HMS UNLESS OTHERWISE SPECIFIED.

DC TEST CIRCUIT SCHEMATICS - FIGURE B

Westinghouse Electric Corporation

NUCLEAR SYSTEMS DIVISION, PITTSBURGH, PA.

PACIFIC GAS & ELECTRIC  
DIABLO CANYON UNITS 1&2  
SAFEGUARDS TEST CABINET

NTS


SCALE

080415

















SHEET 7

DIMENSIONS IN INCHES

DO NOT SCALE 1/80 x 80' E&G







TEST RELAY CONNECTION DIAG - TRAIN A

Westinghouse Electric Corporation  
NUCLEAR ENERGY SYSTEMS, PITTSBURGH, PA, U.S.A.  
TITLE: D&E - GAS & ELECTRIC CO  
DIABLO CANYON UNITS 1 & 7  
SAFE-GARD TEST CABINET  
NTS SHEET 6  
SCALE 1:250  
DIMENSIONS IN INCHES  
DO NOT SCALE SUB 1385

6 5 4 3 2 1 0 D I










A I ▶

B C i

24

W

36



1

36

100

卷之三

















1

•

6

8

1



TEST RELAY CONNECTION DIAG - TRAIN B

Westinghouse Electric Corporation	
NUCLEAR ENERGY SYSTEMS, PITTSBURGH, PA., U.S.A.	
TITLE: D&C ELEC GAS & ELECTRIC CO	
DIABLO CANYON UNITS 1&2	
SAFEGUARDS TEST CABINET	
NTS	
SCALE	
DIMENSIONS IN INCHES	
DO NOT SCALE	
SUB J Nod 5	

6

5

4

3

2

1

C

A — I — A


B — I — C  
24

D — I  
36





SAFEGUARDS TEST CABINET TRAIN B (VIEWED FROM FRONT)											
LEFT SIDE						RIGHT SIDE					
11	10	9	8	7	6	11	10	9	8	7	6
12	13	14	15	16	17	12	13	14	15	16	17
18	19	20	21	22	23	18	19	20	21	22	23
24	25	26	27	28	29	24	25	26	27	28	29
30	31	32	33	34	35	30	31	32	33	34	35
36	37	38	39	40	41	36	37	38	39	40	41
42	43	44	45	46	47	42	43	44	45	46	47
48	49	50	51	52	53	48	49	50	51	52	53
54	55	56	57	58	59	54	55	56	57	58	59
60	61	62	63	64	65	60	61	62	63	64	65
66	67	68	69	70	71	66	67	68	69	70	71
72	73	74	75	76	77	72	73	74	75	76	77
78	79	80	81	82	83	78	79	80	81	82	83
84	85	86	87	88	89	84	85	86	87	88	89
90	91	92	93	94	95	90	91	92	93	94	95
96	97	98	99	100	101	96	97	98	99	100	101
102	103	104	105	106	107	102	103	104	105	106	107
108	109	110	111	112	113	108	109	110	111	112	113
114	115	116	117	118	119	114	115	116	117	118	119
120	121	122	123	124	125	120	121	122	123	124	125
126	127	128	129	130	131	126	127	128	129	130	131
132	133	134	135	136	137	132	133	134	135	136	137
138	139	140	141	142	143	138	139	140	141	142	143
144	145	146	147	148	149	144	145	146	147	148	149
150	151	152	153	154	155	150	151	152	153	154	155
156	157	158	159	160	161	156	157	158	159	160	161
162	163	164	165	166	167	162	163	164	165	166	167
168	169	170	171	172	173	168	169	170	171	172	173
174	175	176	177	178	179	174	175	176	177	178	179
180	181	182	183	184	185	180	181	182	183	184	185
186	187	188	189	190	191	186	187	188	189	190	191
192	193	194	195	196	197	192	193	194	195	196	197
198	199	200	201	202	203	198	199	200	201	202	203
204	205	206	207	208	209	204	205	206	207	208	209
210	211	212	213	214	215	210	211	212	213	214	215
216	217	218	219	220	221	216	217	218	219	220	221
222	223	224	225	226	227	222	223	224	225	226	227
228	229	230	231	232	233	228	229	230	231	232	233
234	235	236	237	238	239	234	235	236	237	238	239
240	241	242	243	244	245	240	241	242	243	244	245
246	247	248	249	250	251	246	247	248	249	250	251
252	253	254	255	256	257	252	253	254	255	256	257
258	259	260	261	262	263	258	259	260	261	262	263
264	265	266	267	268	269	264	265	266	267	268	269
270	271	272	273	274	275	270	271	272	273	274	275
276	277	278	279	280	281	276	277	278	279	280	281
282	283	284	285	286	287	282	283	284	285	286	287
288	289	290	291	292	293	288	289	290	291	292	293
294	295	296	297	298	299	294	295	296	297	298	299
299	300	301	302	303	304	299	300	301	302	303	304
305	306	307	308	309	310	305	306	307	308	309	310
311	312	313	314	315	316	311	312	313	314	315	316
317	318	319	320	321	322	317	318	319	320	321	322
323	324	325	326	327	328	323	324	325	326	327	328
329	330	331	332	333	334	329	330	331	332	333	334
335	336	337	338	339	340	335	336	337	338	339	340
341	342	343	344	345	346	341	342	343	344	345	346
347	348	349	350	351	352	347	348	349	350	351	352
353	354	355	356	357	358	353	354	355	356	357	358
359	360	361	362	363	364	359	360	361	362	363	364
365	366	367	368	369	370	365	366	367	368	369	370
371	372	373	374	375	376	371	372	373	374	375	376
377	378	379	380	381	382	377	378	379	380	381	382
383	384	385	386	387	388	383	384	385	386	387	388
389	390	391	392	393	394	389	390	391	392	393	394
395	396	397	398	399	400	395	396	397	398	399	400
401	402	403	404	405	406	401	402	403	404	405	406
407	408	409	410	411	412	407	408	409	410	411	412
413	414	415	416	417	418	413	414	415	416	417	418
419	420	421	422	423	424	419	420	421	422	423	424
425	426	427	428	429	430	425	426	427	428	429	430
431	432	433	434	435	436	431	432	433	434	435	436
437	438	439	440	441	442	437	438	439	440	441	442
443	444	445	446	447	448	443	444	445	446	447	448
449	450	451	452	453	454	449	450	451	452	453	454
455	456	457	458	459	460	455	456	457	458	459	460
461	462	463	464	465	466	461	462	463	464	465	466
467	468	469	470	471	472	467	468	469	470	471	472
473	474	475	476	477	478	473	474	475	476	477	478
479	480	481	482	483	484	479	480	481	482	483	484
485	486	487	488	489	490	485	486	487	488	489	490
491	492	493	494	495	496	491	492	493	494	495	496
497	498	499	500	501	502	497	498	499	500	501	502
503	504	505	506	507	508	503	504	505	506	507	508
509	510	511	512	513	514	509	510	511	512	513	514
515	516	517	518	519	520	515	516	517	518	519	520
521	522	523	524	525	526	521	522	523	524	525	526
527	528	529	530	531	532	527	528	529	530	531	532
533	534	535	536	537	538	533	534	535	536	537	538
539	540	541	542	543	544	539	540	541	542	543	544
545	546	547	548	549	550	545	546	547	548	549	550
551	552	553	554	555	556	551	552	553	554	555	556
557	558	559	560	561	562	557	558	559	560	561	562
563	564	565	566	567	568	563	564	565	566	567	568
569	570	571	572	573	574	569	570	571	572	573	574
575	576	577	578	579	580	575	576	577	578	579	580
581	582	583	584	585	586	581	582	583	584	585	586
587	588	589	590	591	592	587	588	589	590	591	592
593	594	595	596	597	598	593	594	595	596	597	598
599	600	601	602	603	604	599	600	601	602	603	604
605	606	607	608	609	610	605	606	607	608	609	610
611	612	613	614	615	616	611	612	613	614	615	616
617	618	619	620	621	622	617	618	619	620	621	622
623	624	625	626	627	628	623	624	625	626	627	628
629	630	631	632	633	634	629	630	631	632	633	634
635	636	637	638	639	640	635	636	637	638	639	640
641	642	643	644	645	646	641	642	643	644	645	646
647	648	649	650	651	652	647	648	649	650	651	652
653	654	655	656	657	658	653	654				



TERMINAL BLOCK CONNECTION DIAG - TRAIN B

2714		Westinghouse Electric Corporation	
CAB		NUCLEAR ENERGY SYSTEMS, PITTSBURGH, PA., U.S.A.	
DRI. END		(W)	
MFG. END		TITLE: PACIFIC GAS & ELECTRIC CO.	
MIDDLE END		DIABLO CANYON UNITS 1 & 2	
ZER.		SAFEGUARDS TEST CABINET	
APP.		NTS	
APP.		SCALE	
GATE SUR.		10BD415	
		DIMENSIONS IN INCHES	
		SHEET 11	
		DO NOT SCALE	
		SUB 1364867	


6 5 4 3 2 1 0 W

A — A


B

C — C  
24

D — D



→ “〇”怎样画？



NOTE 1

SHOWN FOR TRAIN "A" INTERLOCKS. TRAIN "B" INTERLOCKS ARE IN PARENTHESIS.

CONTAINMENT SPRAY TEST  
INTERLOCK CIRCUITRY