



**Commonwealth Edison**

One First National Plaza, Chicago, Illinois  
Address Reply to: Post Office Box 767  
Chicago, Illinois 60690 - 0767

January 12, 1988

Mr. Thomas E. Murley, Director  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Attn: Document Control Desk

Subject: Byron Station Units 1 and 2  
Braidwood Station Units 1 and 2  
Application for Amendment to  
Facility Operating Licenses NPF-37, NPF-66,  
NPF-72, and NPF-75  
Appendix A, Technical Specifications  
NRC Docket Nos. 50-454, 50-455, 50-456 and 50-457

Dear Mr. Murley:

Pursuant to 10 CFR 50.90, Commonwealth Edison proposes to amend Appendix A, Technical Specifications, of Facility Operating Licenses NPF-37, NPF-66, NPF-72, and NPF-75. The proposed amendment requests changes to Technical Specification Tables 3.3-13 and 4.3-9, to separate the Gaseous Waste Management System Oxygen Analyzer into its two major components to describe the two separate oxygen analyzers that make up this system.

The revised Technical Specification pages are contained in Attachment A. The description and summary of the proposed changes is presented in Attachment B.

The proposed changes have been reviewed and approved by both on-site and off-site review in accordance with Commonwealth Edison procedures. Commonwealth Edison has reviewed this proposed amendment in accordance with 10 CFR 50.92(c) and has determined that no significant hazards consideration exists. This evaluation is documented in Attachment C.

Commonwealth Edison is notifying the State of Illinois of our application for this amendment by transmitting a copy of this letter and its attachments to the designated State Official.

BB01210005 BB0112  
PDR ADOCK 05000454  
P PDR

Rec'd w/attach #150.00  
#11701


Adol  
/1

January 12, 1988

In accordance with 10 CFR 170, a fee remittance in the amount of \$150.00 is enclosed.

Please direct any questions you may have concerning this matter to this office.

Very truly yours,

  
S. C. Hunsader  
Nuclear Licensing Administrator

CS

Enclosure: Fee Remittance

Attachments (A): Proposed Technical Specification Changes  
(B): Description and Summary  
(C): Evaluation of Significant Hazards Consideration

cc: Resident Inspector - Byron  
Resident Inspector - Braidwood  
L. N. Olshan - NRR  
S. Sands - NRR  
Region III Office  
M. C. Parker - State of Ill.

4058K