



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

ENERGY GULF STATES, INC. **
CAJUN ELECTRIC POWER COOPERATIVE AND
ENERGY OPERATIONS, INC.
DOCKET NO. 50-458
RIVER BEND STATION, UNIT 1
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 92
License No. NPF-47


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Entergy Gulf States, Inc.* (the licensee) dated August 29, 1996, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, as amended, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and

* EOI is authorized to act as agent for Entergy Gulf States, Inc, which has been authorized to act as agent for Cajun Electric Power Cooperative, and has exclusive responsibility and control over the physical construction, operation and maintenance of the facility.

**Entergy Gulf States, Inc., which owns a 70 percent undivided interest in River Bend, has merged with a wholly owned subsidiary of Entergy Corporation. Entergy Gulf States, Inc. was the surviving company in the merger.

- E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, by Amendment No. 92, the license is amended by changes to the Technical Requirements Manual as indicated in the attachment to this license amendment.
 3. The license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



David L. Wigginton, Senior Project Manager
Project Directorate IV-1
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Requirements Manual

Date of Issuance: February 13, 1997

ATTACHMENT TO LICENSE AMENDMENT NO. 92

FACILITY OPERATING LICENSE NO. NPF-47

DOCKET NO. 50-458

Replace the following page of the Technical Requirements Manual with the attached page. The revised page is identified by Revision number and contain marginal lines indicating the areas of change.

REMOVE

TR 3.4-10

INSERT

TR 3.4-10

TR 3.4.11 RCS Pressure and Temperature (P/T) Limits

TABLE 3.4.11-1
REACTOR VESSEL MATERIAL SURVEILLANCE PROGRAM-
WITHDRAWAL SCHEDULE

<u>CAPSULE NUMBER</u>	<u>VESSEL LOCATION</u>	<u>LEAD FACTOR AT L.D./WT</u>	<u>WITHDRAWAL TIME (EFPY)</u>
1	3'	0.67/0.89	10.4
2	177'	0.67/0.89	15
3	183'	0.67/0.89	Standby

ATTACHMENT TO LICENSE AMENDMENT NO. 92

FACILITY OPERATING LICENSE NO. NPF-47

DOCKET NO. 50-458

Replace the following page of the Technical Requirements Manual with the attached page. The revised page is identified by Revision number and contain marginal lines indicating the areas of change.

REMOVE

TR 3.4-10

INSERT

TR 3.4-10