



March 19, 1997

Docket No. 50-245

B16282

Re: 10CFR50.73(a)(2)(i)

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

This letter forwards Licensee Event Report (LER) 97-014-00, documenting an event that occurred at Millstone Nuclear Power Station, Unit No. 1 on February 17, 1997. This LER is submitted pursuant to 10CFR50.73(a)(2)(i).

The following are Northeast Nuclear Energy Company's (NNECO's) commitments made within this letter. All other statements made within this letter are for information only.

- B16282-1 NNECO commits that the Inservice Testing (IST) Program manual will be revised to indicate that, for the core spray keep-fill line check valves (1-CS-19A/B & 1-CS-20A/B), the category is 'A/C,' and a surveillance developed to test the valves prior to startup for operating Cycle 16.
- B16282-2 NNECO commits to provide sufficient trained staffing to implement and manage the IST Program prior to startup for operating Cycle 16. This staffing requirement will be endorsed by the program management as well as the unit management.
- B16282-3 NNECO commits to revise the IST Program Administrative Control Procedure based on the 10CFR50.54(f) findings prior to startup for operating Cycle 16. This program control requirement will be endorsed by the program management as well as the unit management.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

P. D. Hinnenkamp  
Director, Unit Operations

*JE 22*  
*||*

9703250110 970319  
PDR ADOCK 05000245  
S PDR

Attachment: LER 97-014-00

- cc: Dr. W. D. Travers, Director, Special Projects
- H. J. Miller, Region I Administrator
- S. Dembek, NRC Project Manager, Millstone Unit No. 1
- T. A. Easlick, Senior Resident Inspector, Millstone Unit No. 1

