

General Offices . Selden Street, Berlin, Connecticut

P.O. BOX 270 HARTFORD, CONNECTICUT 06141-0270 (203) 665-5000

February 29, 1988

Docket No. 50-336 B12832 Re: 10CFR50.90

U.S. Nuclear Regulatory Commission Attn: Document Control Desk Washington, D.C. 20555

Gentlemen:

Millstone Nuclear Power Station, Unit No. 2 New Personnel Door in Auxiliary Building

On December 23, 1987⁽¹⁾ Northeast Nuclear Energy Company (NNECO) submitted to the Staff a proposed revision to the Technical Specifications of Millstone Nuclear Power Station, Unit No. 2. The proposed change was the addition of a personnel door at the 38'-6" elevation of the Millstone Unit No. 2 Auxiliary Building. Subsequent discussions with the Staff have resulted in a request for additional information on the proposed door. The purpose of this letter is to provide the requested information.

The personnel door proposed to be added to the east end of the spent fuel pool area is to be added to Table 3.9-1 "Access Doors to Spent Fuel Pool Area," and conforms to the requirements for other doors in this table. The proposed door is designated as a three-hour fire barrier. The addition of the door will not adversely affect the capability of the wall to transmit all design loads.

We trust this information satisfies your concerns regarding the proposed door. Please call my staff with any further questions.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

Mroczka

Senior Vice President

- cc: W. T. Russell, Region I Administrator
 - D. H. Jaffe, NRC Project Manager, Millstone Unit No. 2
 - W. J. Raymond, Senior Resident Inspector, Millstone Unit Nos. 1, 2, and 3

 E. J. Mroczka letter to U.S. Nuclear Regulatory Commission "Proposed Revision to Technical Specifications-New Personnel Door in Auxiliary Building," dated December 23, 1987.



8803080136 880229 FDR ADOCK 05000336 P DCD