

TERA

SAND77-0274

Unlimited Release

## WIPP Conceptual Design Report

Addendum A: Design Calculations for Waste Isolation  
Pilot Plant (WIPP) Conceptual Design Report,  
Edited By Nuclear Waste Engineering Division 1142

90029040

POOR ORIGINAL

Prepared by Sandia Laboratories, Albuquerque, New Mexico 87115  
and Livermore, California 94550 for the United States Energy Research  
and Development Administration under Contract AT(29-1)-789

Printed April 1977



Sandia Laboratories

SF 2900 Q(7-73)

628  
8001220

## CONTENTS

<u>Section</u>	<u>Topic</u>
1	General/Nuclear Calculations
2	Radwaste Calculations
3	Structural Calculations
4	Mechanical Calculations
5	Civil Calculations
6	Electrical Calculations
7	TRU Waste Surface Facility Time and Motion Analysis
8	Shaft Sinking Procedures
9	Hoist Time and Motion Studies
10	Mining System Analysis
11	Mine Ventilation Calculations
12	Mine Structural Analysis
13	Miscellaneous Underground Calculations

90029041

General/Nuclear Calculations

*POOR ORIGINAL*

90029042

## WIPP SITE POPULATION

## BUILDING OR AREA

	Shift 1	Shift 2	Shift 3
Administration	80	2	2
Control/Computer	10	3	3
Security - Gate House (Site Entrance)	2	1	1
- Security Office & Gate House (into B area)	6	2	2
- Fire Protection	1	1	1
- Security Control Center	2	2	2
- First Aid	1		
Warehouse	4	-	-
Sewage Treatment	2	-	-
Water Treatment	1	-	-
Truck Drivers	4	-	-
Railroad Personnel	3	-	-
Motor Pool	3	-	-
Waste Treatment Area (Site Generated)			
- Liquid }	2	-	-
- Solid }			
- Laundry	3	-	-
TRU Waste Building			
- Administrative/Supervision	6	-	-
- Inventory/Inspection	3/6		
- Waste Handling Personnel			
- Health Physics	2	-	-
- Forklift/Equip. Operators	14	-	-
- Waste Handlers/Repair	4	-	-
TOTAL	159	11	11

90029043

## WIPP SITE POPULATION

## BUILDING OR AREA (Contd)

	Shift 1	Shift 2	Shift 3
-Container/Vehicle Preparation	4	-	-
- Floaters	3	-	-
- Hoist Operator(s)	2	-	-
- Health Physics Lab	3	-	-
RH Waste Building			
- Administrative	6	-	-
- Inventory	2	-	-
- Waste Handling Personnel			
- Health Physics	3	-	-
- Cask Handlers	6	-	-
- Cask Preparation & Decon	4	-	-
- Waste Handlers-Remote	4	-	-
- Hoist Operator(s)/Crane Op	1/1	-	-
Cafeteria (Mgr. - cashier - food prep. - dishwash)	8	-	-
Grounds - Landscape	2	-	-
Area clean. (roads - tracks - tailing area)	4	-	-
Janitorial (Office - labs - shops)	2	5	-
Power Plant (not coal)	6	2	2
General Maint. (total 8)			
Plumber	2	-	-
Carpenter-painter	2	-	-
Electrician	2	1	1
Air-Cond. & refriger.	2	1	1
Lube & P.M.	2	2	-
Helpers	<u>2</u>	<u>2</u>	<u>-</u>
TOTAL	73	13	4

90029044

## WIPP SITE POPULATION

## BUILDING OR AREA (Contd)

	<u>Shift 1</u>	<u>Shift 2</u>	<u>Shift 3</u>
Vehicle Maint. - (Motor pool - forklifts) (Mechanics, lube, hydraulics)	3	1	-
Machinery Maint. (above ground machinists and millwrights)	3	1	-
Mine Mach. Maint. (below ground)	6		-
Man/Materials Building			
- Administrative	2	-	-
- Health Physics	1	-	-
- Salt Disposal	4	-	-
- Hoist Operator(s)	2	-	-
Mine Personnel			
TRU Level			
- Supervision	5	-	-
- Miners	25	-	-
- Waste Handlers	10	-	-
- Maintenance	5	-	-
- Health Physics	3	-	-
RH Level			
- Supervision	5	-	-
- Miners	25	-	-
- Waste Handlers	10	-	-
- Maintenance	5	-	-
- Health Physics	3	-	-
TOTAL THIS SHEET	117	2	0
"    SHEET 1	159	11	11
"    "    2	<u>73</u>	<u>13</u>	<u>4</u>
TOTAL SITE POPULATION	349	26	15
GRAND TOTAL		<u>390</u>	

90029045

## INTERIM REPORT

### Remote Handling Facility Shielding Calculations - WIPP Conceptual Design

PURPOSE: The layout of the remote handling facility is in progress. Preliminary shielding calculations were performed in order to assess the adequacy of hot cell shielding in the current design.

SIGNIFICANT RESULTS, CONCLUSIONS AND RECOMMENDATIONS:  
Current plant capacity requirements will probably require the transportation of three high level waste canister at a time to the mine. It is, therefore, conceivable that three canisters could be in the hot cell at one time placed next to the control room or catwalk shield wall. For calculational purposes it was also assumed that a canister was located at the viewing window being inspected. An open, loaded shipping cask was assumed to be open to the hot cell.

The dose rates received from these three sources are tabulated below:

	<u>CONDITION</u>	<u>DOSE RATE (mR/hr)</u>		
		<u>4 ft - ordinary concrete</u>	<u>5/6 ft - ordinary concrete</u>	<u>4 ft - Barytes concrete</u>
(1)	Three canisters stored along shield wall awaiting transport			
	Primary gamma	750.0	21.0/0.09	0.0705
	Secondary gamma	6.5	-	-
	Neutrons	0.645	-	-
(2)	Single canister being handled in front of viewing window			
	Primary gamma	162.0	-	0.02
	Secondary gamma	1.43	-	-
	Neutrons	0.143	-	-

90029046

## INTERIM REPORT

October 15, 1976

Page Two

<u>CONDITION</u>	<u>DOSE RATE (mR/hr)</u>		
	<u>4 ft - ordinary concrete</u>	<u>5/6 ft - ordinary concrete</u>	<u>4 ft - Barytes concrete</u>
(3) Dose from open loaded shipping cask			
Primary gamma	0.21	-	-
Secondary gamma	-	-	-
Neutrons	-	-	-
Approximate Totals	1000 mR/hr		0.1 mR/hr

These calculations show that four feet of ordinary concrete is not sufficient to reduce dose rates below the design level of 0.5 mr/hr. Increasing the shield thickness to between 5 and 6 feet of ordinary concrete would reduce radiation levels to within allowable limits but would tend to increase the cost of the viewing windows. Four feet seems to be a practical shield thickness.

For planning purposes it is recommended that four feet of Barytes (or equivalent heavy) concrete be used for the shield walls of the hot cell.

As expected, designing the shield for attenuation of primary gamma radiation was the most important aspect of the problem. Contributions due to neutrons and secondary gamma radiation was negligible.

Again as expected, dose rate from fuel stored in the hot cell storage ports calculated at the side of the storage monolith was negligible. A shield thickness of eight feet was assumed for these calculations.

ADDITIONAL WORK: Additional shielding calculations will be performed at a later date to determine the dose rates in the cask preparation and decontamination areas due to streaming through the shield plug when the plug design is completed. These calculations will determine the design of the isolation doors on the transfer passage. If the floor of the hot cell over the transfer facility is constructed of ordinary concrete, there will be an additional contribution to dose rate which will be included in the calculation.

90029047

INTERIM REPORT

October 15, 1976

Page Three

Streaming up the mine shaft as well as calculation of dose rate in the hoist control room will also have to be considered in the near future when this location of the control area is fixed.

DISCUSSION:

- (1) BUILDDUP FACTORS: Dose buildup factors were calculated using two formulas; one from Glasstone and Sesonske (paragraph 10.70 and also in the Handbook, Vol. III-B, page 115) and the second taken from Reference (b).

Although 0.8 MEV monoenergetic gamma radiation was assumed since no gamma energy spectrum was specified for the high level waste, for 0.5 MEV gamma was assumed to add a degree of conservatism.

Dose buildup factors for a four foot thick ordinary concrete shield were calculated as follows:

G&S	43
H&N 8200.1	89.5

Although the G&S formula supposedly calculated dose buildup factors to within 5% accuracy, the H&N 8200.1 formula was used in all dose calculations in order to be conservative.

- (2) VERIFICATION OF SANDIA SUPPLIED DATA: Sandia supplied data is shown on Attachment 1. The accuracy of this data was checked in the following manner:

- (a) Line source geometry was assumed.
- (b) Average gamma energy of 0.8 MEV was assumed.
- (c) An energy flux ( $\text{MEV}/\text{cm}^2/\text{sec}$ ) was calculated from the dose rate data given and Table 9.2, Glasstone & Sesonske.
- (d) An equivalent line source flux ( $\text{MEV}/\text{cm/sec}$ ) was calculated, using the geometry of a cylindrical 16 in. diameter X 10 foot long H. L. waste cask. The area of the cylinder ends was included to produce as high a line source flux as possible.

90029048

## INTERIM REPORT

October 15, 1976

Page Four

- (e) The equivalent dose rate was at a distance of 10 feet in air.

The results are listed as follows:

<u>Source</u>	<u>Base Rate (mR/hr) @ 10 ft</u>
Sandia Data	$6.5 \times 10^3$
Line Source Calculations	$3.72 \times 10^3$

These results showed good correlation with Sandia data and verified the use of simple line geometry source terms. Most of the calculations used a line source. Calculated results were multiplied by two to initialize them to Sandia data.

- (3) ASSUMPTIONS: The assumptions made in the calculations had some conservatism included in their selection. These factors are summarized as follows:

- (a) Monoenergetic 0.8 MEV gamma. According to H&N 8200.1, most of the gamma energy in one year old HTGR spent fuel is 0.8 MEV gamma.
- (b) Buildup factors were conservatively calculated. See previous discussion.
- (c) Attenuation coefficients for both neutron and gamma radiation were conservatively selected. Values for ordinary concrete which were used:

$$\begin{array}{ll} \text{Neutrons} & = .083 \text{ cm}^{-1} \\ \text{Gamma} & = .126 \text{ cm}^{-1} \end{array}$$

- (d) Line source geometry calculations were modified by:
  - (1) Multiplying calculated result by 2.
  - (2) For three canister calculations, line sources were superimposed to maximize dose rate.
  - (3) For calculational purposes, line sources were assumed to be on the "edge" of the cylinder rather than on the center line in order to maximize dose rate.

90029049

INTERIM REPORT

October 15, 1976

Page Five

(4) COMPARISON WITH PREVIOUS HOLMES & NARVER WORK: The methods and level of detail used in these calculations is similar to that used in previous company work (Reference b). In that study, a gamma energy spectrum and multi-material shield was used. Self-absorption in HTGR fuel assemblies was also used in 8200.1 but was not needed in this study.

(5) PRINCIPAL REFERENCES:

- (a) Nuclear Reactor Engineering, S. Glasstone, A. Sesonske.
- (b) HTGR Reactor Service Building Alternate Fuel Handling and Storage Study 3000 MW(t) Reference Plant NSS - 8200.1- August 1974, Holmes & Narver, Inc.
- (c) Procedures for Shielding Calculations - Technical Report No. 1 AECU - 3510, January 1957, R. Dennis, S. N. Purohit, L. E. Brownell.

90029050

## HIGH LEVEL/INT. LEVEL SOURCES

CASK	WT (lbs)	WATT	DIMENS.	$\times$ SURF R/hr	$\times 10^4$ R/hr	$n$ SURFACE R/hr	$n 10^4$ R/hr.	NO PER CASK
ERDA HI (TRUCK)	7000	230	2' X 10'	5000	400	1.5	0.1	
ERDA HI (RAIL)	7000	230	2' X 10'	5000	400	1.5	0.1	
NFS (INTER) (TRUCK)	7500	110	4' X 4'	700	30	-	-	
AGNS INTER (TRUCK)	15000	220	4' X 8'	700	60	-	-	
AGNS IL (RAIL)	15000	220	4' X 8'	700	60	-	-	
HL (TRUCK)	3000	3500	16" X 10'	$1.3 \times 10^5$	$6.5 \times 10^3$	33		1.6
HL (RAIL)	3000	3500	16" X 10'	$1.3 \times 10^5$	$6.5 \times 10^3$	33		1.6
								8

90029051

Radwaste Calculations

POOR ORIGINAL

90029052

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_

**HOLMES & NARVER, INC.**  
 ENGINEERS—CONSTRUCTORS  
 400 E. ORANGETHORPE AVE.  
 ANAHEIM, CALIF. 92801

APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

JOB NO. 8251.00

SHEET 1 OF 13  
 BY RMB DATE 2/4/77

TITLE LIQUID WASTE VOLUME - DAILY

Generation of waste volumes can be divided into three major areas:

- Daily
- Intermittent / Infrequent
- Accident or abnormal conditions

DAILY

Sources that input daily to the liquid waste system are tabulated as follows:

R.H. Bldg.

- (1) Cask decontamination
- (2) Lid decontamination
- (3) Laboratory samples
- (4) Cask cooling and draining
- (5) Canister cleaning
- (6) Contaminated showers

TRU Bldg.

- (1) Lab samples
- (2) Contaminated showers

Radwaste / Laundry Bldg.

- (1) Laundry
- (2) Contaminated showers

Miscellaneous

- (1) Routine washdown

DAILY - RH BLDG

90029053

(1) Cask Decontamination

A total of 50 canisters per week, on the average, will be handled in the RH bldg. It is assumed that these canisters come in single canister casks.

San Onofre N.G.S. ships single element spent fuel casks. They decontaminate these casks prior to shipping and use about 40 gallons per cask for decontam. for unshielded casks.

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_

APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

TITLE Liquid Waste Volume - Daily

**HOLMES & NARVER, INC.**  
 ENGINEERS-CONTRACTORS  
 400 E. ORANGETHORPE AVE.  
 ANAHEIM, CALIF. 92801

JOB NO. \$151.00SHEET 2 OF 13  
 BY RMB DATE 2/4/77

Finned casks require much more water for decontamination.<sup>1</sup>

Spent Fuel <sup>casks</sup> shipped from nuclear power plants <sup>are</sup> generally "hotter" than the canisters expected at WIPP. The casks that we receive will have been cleaned at the sending location and should be fairly clean.

For design purposes, we will assume 40 gal/cask, 10 casks/day, or 400 gallons substrate per day. Since the casks will be clean, detergent will probably not be needed.

#### (2) Lid Decontamination

Lids will be inner wrapped in plastic and placed in the hot cell when putting the casks. After unpacking, lids will be cleaned and the lids washed for shipment.

Volume of water required for the lid is arbitrarily set at 1/2 that required for casks, i.e. 20 gal.

$$\text{Daily} = \frac{20 \text{ gal}}{\text{cask}} \times \frac{10 \text{ lid}}{\text{day}} = \boxed{200 \text{ gal/day}}$$

#### (3) Lab Drains

In accordance with Ref 2, RH lab drains are established at 90 gal/day

#### (4) Cask Cooling and Draining

In establishing the cask cool / drain input, data for the GE-1F-300 spent fuel shipping cask was used. This cask can handle 7 PWR assemblies.<sup>2,3</sup>

CHECKED _____	DATE _____	HOLMES & NARVER, INC.	JOB NO. <u>8251.00</u>
APPROVED _____	DATE _____	ENGINEERS-CONSTRUCTORS 400 E. ORANGETHORPE AVE ANAHEIM, CALIF. 92801	SHEET <u>3</u> OF <u>13</u> BY <u>RMB</u> DATE <u>3/4/77</u>
TITLE <u>LIQUID WASTE VOLUME - DAILY</u>			

If all our shipments come in 7 canister casks, then we would receive 1.43 ( $\frac{10}{7}$ ) casks per day.

$$\text{Net load} - 7 \text{ PWR assays} = 77 \text{ kw} \\ 7 \text{ ref canisters} = 25 \text{ kw}$$

Cooling water inventory = 4800 lbs for 7 PWR assays.

$$\frac{4800 \text{ lb}}{8.38 \text{ lbs}} \times \frac{\text{gal}}{1000} = 575 \text{ gal/cask}$$

Although the net load is less, it will be assumed for design purposes that 575 gal of water will be drained for each 7 canisters (1 large cask).

$$\text{Total gal/day} = 1.43 (575) \hat{=} \boxed{820 \text{ gal./day}}$$

#### (5) Canister Cleaning.

10 canisters per day will be decommissioned. Marc Reib, Aerojet, says shower system input will be 50 gal/day. Assume filter backflush included. Aerojet would not hangard a guess on contamination levels.

#### (6) Contaminated Showers

In accordance with Ref 2, 1 shower per day @ 50 gal is the total input.

90029055

CHECKED _____	DATE _____	HOLMES & NARVER, INC.	JOB NO. <u>8251.00</u>
APPROVED _____	DATE _____	ENGINEERS-CONSTRUCTORS 400 E. ORANGETHORPE AVE. ANAHEIM, CALIF. 92801	SHEET <u>4</u> OF <u>13</u>
TITLE <u>Liquid Waste Volume - Daily</u>		BY <u>RMB</u> DATE <u>3/4/77</u>	

TRU BLDG

(7) Lab Samples In accordance with Ref (2), 180 gal/day  
is estimated for lab samples.

(8) Contaminated Shower - 50 gal/day - see Ref 2.

Radwaste / Laundry(9) Laundry

Review of the final site population estimate<sup>(5)</sup> shows that about 187 sets of contaminated clothing per day will be generated. This compares favorably with previous laundry evaluations.<sup>(6)</sup> Information developed in Ref 6 will be used.

665 gal/day

(10) Contaminated Shower - Assume laundry 1 @ 50 gal per day

MISCELLANEOUS

(11) Reactor Truck washdown - 1000 gal/day.

Note that, per Sandia, there will be no contaminated shower from the Main/Materials Bldg. Decontamination that is necessary will be done below ground.

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_

**HOLMES & NARVER, INC.**  
 ENGINEERS-CONSTRUCTORS  
 400 E. ORANGETHORPE AVE.  
 ANAHEIM, CALIF. 92801

JOB NO. 8251.00

APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

SHEET 5 OF 13  
DATE 2/4/77

TITLE INTERMITTENT INFREQUENT LIQUID WASTE VOL BY RMB

General note - In order to simplify decontamination cycles, water used for decon was all treated on a  $\text{ft}^2$  basis. Based on building leak tests, Jim Robbins felt that a sufficient volume for cleaning was 35 gal /  $100 \text{ ft}^2$ .

A reasonable amount of water seems to be  $1/2"$  (RMB).  $100 \text{ ft}^2$  @  $1/2"$  =  $100 \text{ ft}^2 \times \frac{0.5 \text{ ft}}{12} \times \frac{7.48 \text{ gal}}{\text{ft}^3} = 32 \text{ gal} / 100 \text{ ft}^2$

For purposes of this analysis [35 gal /  $100 \text{ ft}^2$ ] will be assumed for decon.

→ Washdown Frequency = 4 week intervals

### DECONTAMINATION VOLUMES

<u>AREA</u>	<u>APPROX DIMENSION</u>	<u><math>\text{ft}^2</math> (35 gal / <math>100 \text{ ft}^2</math>) =</u>	<u>GALLONS</u>
TRU Receiving	.	12000	= 4200
TRU I&P	.	27000	9450
TRU O&R	65x65	4225	1479
RH RECEPTION		6720	2352
RH Cask Service		4800	1680
RH Hot Cell (28x60)		1680	588

In all probability, the I&P will not be decontaminated at once!  $\frac{9450}{2} = 4725$  = design basis decon

### Red note / New dry

Building has not yet been designed - assume  $2500 \text{ ft}^2$ .

$$2500 \text{ ft}^2 \times \frac{35 \text{ gal}}{100 \text{ ft}^2} = 875 \text{ gal / decon}$$

90029057

CHECKED _____	DATE _____	HOLMES & NARVER, INC.	JOB NO. <u>8251.00</u>
APPROVED _____	DATE _____	ENGINEERS-CONSTRUCTORS 400 E. ORANGETHORPE AVE. ANAHEIM, CALIF. 92801	SHEET <u>5</u> OF <u>13</u>
TITLE <u>LIQUID WASTE VOLUME - INTERMITTENT INFRA. RMB</u>		DATE <u>2/4/77</u>	

### FILTER WASHING EQUIPMENT DECON

Prefilter washing will be infrequent, we think, possibly every six months. Equipment decon requirements are not known. Four buildings are affected - TCR, LN, storage vent and hardware. For purposes of this study, 20 gal/mo. probably will be assumed.

3/8/77  
 Note that no quantity has been generated for cleanup of the duct after filter replacement. This will require cleanup also.

26

90029058

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_

**HOLMES & NARVER, INC.**  
 ENGINEERS-CONTRACTORS  
 400 E. ORANGETHORPE AVE.  
 ANAHEIM, CALIF. 92801

APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

 JOB NO. 8251.00  
 SHEET 7 OF 13  
 DATE 2/7/75
TITLE ACCIDENT CONDITIONS - LIQUID RADWASTE VOLUME RMB

Above ground accident conditions will be considered. For the RH facility, a fire in the hot cell will be assumed. For the TRU facility a fire in the RF box storage area will be assumed.

Fires will generate three sources of liquid radwaste -

- (1) Fire spray water
- (2) Cleaning, following the fire.
- (3) HEPA filter sprays.

→ Fire spray water amounts should be determined based on NFPA Hazardous material categories.

TRU FRC 111

Assumptions: (1) Duration of fire = 1/2 hour

(2) Location - RF box storage

(3) Spray volume =  $0.3 \text{ gpm}^2/\text{ft}^2$   $\ominus$

$$\text{Area} : (4 \times 7) \frac{\text{ft}^2}{\text{box}} \times 24 \text{ box} = 672 \text{ ft}^2$$

$$\text{Fire spray volume} = 0.3 \frac{\text{gall}}{\text{ft}^2} \times 672 \text{ ft}^2 \times 30 \text{ min} = \boxed{6048 \text{ gall.}}$$

$$\text{Cleanup} \quad \frac{35 \text{ gal}}{100 \text{ ft}^2} \times 27,000 \text{ ft}^2 = 9450 \text{ gal}$$

Proportionate spray volume =  $0.1 \text{ gpm} / 1000 \text{ cfm}$  For TRU - flow rate =  $17 \text{ gpm}$

$$\frac{17 \text{ gal}}{\text{min}} \times 30 \text{ min} = 510 \text{ gal}$$

$$\boxed{\text{Grand total for TRU} = 16,000 \text{ gal}}$$

90029059

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_

APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

**HOLMES & NARVER, INC.**ENGINEERS-CONTRACTORS  
400 E ORANGETHORPE AVE.  
ANAHEIM, CALIF. 92801

JOB NO. 8251.00

SHEET 8

OF 13

TITLE ACCIDENT CONDITIONS - LIQUID RADWASTE

BY RMB

DATE 2/14/77

**RH FACILITY**

A fire in the RH Facility is not too likely, however, for beam purposes of generating radwaste volumes, a fire in the prep and v area will be assumed.

$$(1) \text{ Light hazard} = 0.08 \text{ gpm/ft}^2 @$$

$$(2) \text{ Prefilter sprays} = 1/2 TDU$$

(3) Cleanup required after the fire

$$4830 \text{ ft}^2 \times \frac{.08 \text{ gal}}{\text{min-ft}^2} \times 30 \text{ min} = 11520 \text{ gal}$$

$$\text{Cleanup} = 6720 \times \frac{.35}{150} = 2352$$

$$\text{Prefilter sprays} = \underline{255}$$

$$\text{Total} = 14127$$

**STORAGE UNIT BLDG**

A fire in this bldg is also unlikely. For purposes of the analysis a fire in the filter storage area will be postulated and the quantity generated by a spray system calculated.

$$\text{Area} = (28 \times 5) - 120 - (8 \times 26) = 1476 \text{ ft}^2$$

$$t = 30 \text{ min}$$

$$\text{Group I hazard} = 0.05 \text{ gpm/ft}^2 @$$

$$1476 \text{ ft}^2 \times \frac{.05 \text{ gal}}{\text{min-ft}^2} \times 30 \text{ min} = 2214$$

$$\text{Cleanup} = 1476 \times .35 = 517$$

$$\text{Prefilter spray} = \underline{510}$$

$$3241 \rightarrow 3500 \text{ gal}$$

20

90029060.

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_  
 APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

**HOLMES & NARVER, INC.**  
 ENGINEERS-CONSTRUCTORS  
 400 E. ORANGETHORPE AVE  
 ANAHEIM, CALIF. 92801

JOB NO. 8251.00  
 SHEET 9 OF 13  
 BY RMB DATE 2/14/77

TITLE ACCIDENT CONDITIONS - LIQUID RADWASTE

RADWASTE BLDG - For our purposes, the tanking will be  
 the only fire hazard area assumed.

$$\text{Light hazard} = .08 \text{ gal/mm } / \text{ft}^2$$

$$\text{Area} \approx 25 \times 40 = 1000 \text{ ft}^2$$

$$1000 \times .08 \times 30 = 2400 \text{ gal.}$$

$$\text{Overflow} = 1000 \times .35 = 350$$

$$\text{Pump } 1 \text{ spray} = \frac{255}{3005} \text{ gal.}$$

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_

APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

**HOLMES & NARVER, INC.**  
 ENGINEERS-CONTRACTORS  
 400 E. ORANGETHORPE AVE.  
 ANAHEIM, CALIF. 92801

TITLE SOLID WASTE VOLUMES - "PROCESS"

JOB NO. 8251.00  
 SHEET 10 OF 13  
 BY RMB DATE 2/9/77

Solid wastes from "process" operations will come from the following sources:

- Spent ion exchange resins
- Cartridge filters
- Backflushable filter sludges

### BACKFLUSHABLE FILTER SLUDGE

A total of 2600 canisters will be handled per year

$$\text{Assumed surface area (at } 2' \times 15') = 2\pi + \pi dh = 32\pi = 100.5 \text{ ft}^2$$

From Fig 6<sup>9</sup> assume a corrosion rate of 60 g/ft<sup>2</sup>/yr or

$$60(100.5) = 6030 \text{ g/yr/canister}$$

Assume canisters are 1 month old.

$$\frac{6030 \text{ g}}{\text{yr/canister}} \times \frac{2600 \text{ canister}}{\text{yr}} \times \frac{1 \text{ yr}}{12} \times \frac{2.2(10^{-3}) \text{ ft}}{8} \times \frac{\text{in}^3}{0.3 \text{ ft}} \times \frac{\text{ft}^3}{1728 \text{ in}^3} =$$

$$\frac{6030(2600)(1)(2.2)(10^{-3})}{0.3(1728)(12)} = 5.54 \text{ ft}^3/\text{yr}$$

→  $\boxed{10 \text{ ft}^3}$  if we assume same water present

### CARTRIDGE FILTERS

From Ref 10, 3 µm data:

$$3.2 \text{ ft}^2 = 5 \text{ gpm slightly turbid}$$

$$3.2 \text{ ft}^2 = 1 \text{ gpm turbid with algae}$$

$$\text{diameter} = 3'$$

$$\text{length} = 10"$$

$$\text{compressed volume} = 3.2 \text{ ft}^2 \times 0.5 \text{ ft} \times \frac{\text{ft}}{12 \text{ in}} = .13 \text{ ft}^3$$

CHECKED _____	DATE _____	HOLMES & NARVER, INC.		JOB NO. <u>8251.00</u>
APPROVED _____	DATE _____	ENGINEERS-CONSTRUCTORS 400 E. ORANGETHORPE AVE. ANAHEIM, CALIF. 92801		SHEET <u>11</u> OF <u>13</u> BY <u>RMB</u> DATE <u>2/9/77</u>
TITLE <u>SOLID WASTE VOLUMES - "PROCESS"</u>				

Laundry filter - assume that it is sized on the basis of .13 ft<sup>3</sup> effective volume for 3 gpm

Flow is 10 gpm; Effective volume = .13 ( $\frac{10}{3}$ ) = .43 ft<sup>3</sup>/week

It is assumed that this filter will be changed out once per week based on San Jose's experience with the wastewater plant filter<sup>(11)</sup>.

Hourly volume =  $.43 \frac{\text{ft}^3}{\text{week}} \times \frac{52 \text{ weeks}}{\text{yr}} = 22.5 \text{ ft}^3/\text{yr.}$

### Miscellaneous Waste Filters

Assume that these will be changed out monthly.  
Size for 40 gpm flow.

$$22.5 \frac{\text{ft}^3}{\text{yr}} \times \frac{40}{10} \times \frac{12}{52} = 20.8 \text{ ft}^3/\text{yr}$$

$$\text{Total Filter volumes} = 20.8 + 22.5 = 43.3 \rightarrow \boxed{50 \text{ ft}^3/\text{yr.}}$$

### SPENT ION EXCHANGE RESINS

San Jose's Unit 1 mixed bed is non-regenerable and ~ 25 ft<sup>3</sup>. It is changed out once per year.<sup>(11)</sup>

Flow through the demineralizer will be based on an assumed normal process time of six hours.

Misc waste tank capacity = 8000 gal.

$$\text{Time} = 6 \times 60 = 360 \text{ min.}$$

$$\text{Flow} = \frac{8000}{360} = 22.2 \text{ gpm}$$

90029063

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_

APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

TITLE SOLID WASTE VOLUMES - "PROCESS"

## HOLMES &amp; NARVER, INC.

ENGINEERS-CONSTRUCTORS  
400 E ORANGETHORPE AVE.  
ANAHEIM, CALIF. 92801JOB NO. 8251.00  
SHEET 12 OF 13  
BY RMB DATE 2/1/77

Assume that 1 ft<sup>3</sup> is needed for each 2 gpm flow.<sup>12,13</sup>

Bed is assumed to be  $\frac{22.2}{2} = 11.1 \rightarrow 12 \text{ ft}^3$

Even though conditions should be far less severe than San Joaquin Unit 1, assume 12 ft<sup>3</sup>/year spent resin volume

26

90029064

CHECKED	DATE	HOLMES & NARVER, INC.		JOB NO. 8251.00
APPROVED	DATE	ENGINEERS-CONSTRUCTORS 400 E. ORANGETHORPE AVE. ANAHEIM, CALIF. 92801		SHEET 13 OF 13
TITLE REFERENCES				BY RMB DATE 2/9/77

- (1) Phone Conversation, R.M. Banister, H&N, to P.H. Pensayres, Southern California Edison of 1/28/77.
- (2) Radwaste Calculations, K.R. Brown, H&N, dated 10/26/76
- (3) General Electric IF-300 Shipping Cask Analysis, NEDC 10084-1
- (4) Phone Conversation, R.M. Banister, H&N, to Marv Reib, AMCC, of 1/28/77
- (5) Letter H&N 069, K.R. Brown to J.L. Ash, of January 21, 1977.
- (6) Memo 8251-M-35, R.M. Banister to K.R. Brown of October 21, 1976
- (7) Fire Protection Handbook (Fig 5-1B) 14<sup>th</sup> Edition, 1976
- (8) Fire Protection Handbook, Table 14-4B, 14<sup>th</sup> Edition, 1976
- (9) Metals Handbook Vol 1, Fig 6, pg 27
- (10) Pull Western Corporation Bulletin E256
- (11) Phone Conversation, R.M. Banister, H&N, to A.W. Beetz, SCE, of 2/9/77
- (12) SCE Coolwater Station Water Treatment Calculation Sheets
- (13) "Selecting Basic Ion Exchange Resins", C.H. Dallman, A.A. Aslakw, Paper Engineering, October, 1971

2778

90029065

Structural Calculations

*POOR ORIGINAL*

90029066

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_

**HOLMES & NARVER, INC.**

CONTRACTORS

400 EL ORANGE THORPE AVE

ANNE ARUNDEL COUNTY, MARYLAND

APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

JOB NO. \_\_\_\_\_

SUBSET \_\_\_\_\_ OF \_\_\_\_\_

TITLE WIPP FACILITY - SANDBIA

BY \_\_\_\_\_ DATE \_\_\_\_\_

**INDEX****PRELIMINARY STRUCTURAL CALCULATIONS**ITEMSHBET NO's

- Tornado Wind Loading Assumptions - General  
 Design Basis Tornado Missile Characteristics  
 Tornado Missile Impact Design Approach  
 Typical Wall Sections for Missile Impact  
 Typical Roof Sections for Missile Impact

- TL-1  
 TL-2  
 TL-3  
 TL-4 to TL-6  
 TL-7 to TL-9

Tru-Waste Building

- Preliminary Design Assumptions  
 Tornado Wind Loading Assumptions  
 Design Loading Combinations  
 High Bay Wall Sections  
 Tornado Wind Loads on Surfaces  
 Tornado Wind Shears on Walls  
 Tornado Wind Loads on Building Walls

- TRWB-1  
 TRWB-2  
 TRWB-3  
 TRWB-4 to TRWB-5  
 TRWB-6  
 TRWB-7  
 TRWB-8 to TRWB-9

29-30

90029067


CHECKED \_\_\_\_\_ DATE \_\_\_\_\_

**HOLMES & NARVER, INC.**  
 ENGINEERS-CONTRACTORS  
 400 E. ORANGETHORPE AVE.  
 ANAHEIM, CALIF. 92801

APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

JOB NO. F20-00TITLE WIPP FACILITY - SANDIASHEET TL-1 OF 1BY WPS DATE 4/4/77TORNADO LOADING ASSUMPTIONSTornado characteristics

Rotational Speed (mph)	Translational Speeds (mph)		Radius of Maximum Rotational Speed (feet)	Pressure Drop (psf)	Pressure Drop Rate (psf/sec)
	Maximum	Minimum			
240	60	5	160	2.25	12

Assumed Profile of Tornado Translational Wind Speeds

Note: Different scales are used

31

90029068

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_

APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

**HOLMES & MARVER, INC.**ENGINEERS-CONTRACTORS  
400 E. ORANGETHORPE AVE.  
ANAHEIM, CALIF. 92801TITLE WIPP FACILITY - SANDIA

FILE NO. \_\_\_\_\_

SHEET TL-2 OF \_\_\_\_\_OF WIP DATE 4/14/77DESIGN BASIS TORNADO MISSILE CHARACTERISTICS

The following missiles are summarized in Reference 0), and represent those which are currently accepted by the USNRC for the design of Nuclear Power Plants. This summary is included for information only.

<u>Missile</u>	<u>Size</u>	<u>Length</u> (feet)	<u>Weight</u> (pounds)	<u>Horizontal Velocity (ft./sec.)</u>		
				<u>I</u>	<u>II</u>	<u>III</u>
A. Wood plank	4 x 12	12.0	115	272	230	190
B. 6" $\phi$ Sch. 40 pipe	6.625" O.D.	15.0	287	171	138	33
C. 1" $\phi$ Steel Rod	1.0" O.D.	9.0	9	167	131	26
D. Wood Utility Pole	13.5" O.D.	35.0	1125	180	157	85
E. 12" $\phi$ Sch. 40 Pipe	12.75" O.D.	15.0	750	154	92	23
F. Automobile	6.56 x 4.27	16.4	4000	194	171	134

Recommended Design Basis Missiles for WIPP Facilities (See Reference 2)

<u>Missile</u>	<u>Size</u>	<u>Length</u> (feet)	<u>Weight</u> (pounds)	<u>Horizontal Velocity</u> (ft./sec.)
Structural Shape	W 14 x 34	30.0	1020	120
6" $\phi$ Sch. 40 Pipe	6.625" O.D.	21.0	400	138
Wood Utility Pole	14" O.D.	35.0	1500	157
Automobile	(20 ft <sup>2</sup> frontal area)		4000	171

Note: Vertical velocity assumed as 0.80 + horizontal velocity.

References

1. Preliminary Draft of USNRC Publication NUREG-0121, "An Assessment of the Bases for Selecting Criteria for Protection Against Tornado-Entrained Debris", by J.B.J. Read and L.W. Bell, dated November 1976.
2. H.S.N. Letter to Fenix and Sesson, Inc. dated January 21, 1977 and transmitting "Recommendations for the Tornado Generated Design Basis Missile for WIPP".

32

90029069

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_

APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

TITLE WIPP FACILITY - SANDIA

**HOLMES & NARVER, INC.**ENGINEERS-CONSTRUCTORS  
400 E. ORANGETHORPE AVE.  
ANAHEIM, CALIF. 92801

JOB NO. \_\_\_\_\_

SHEET TL-3 OF \_\_\_\_\_

BY HPS DATE 4/11/77

TYPICAL WALL-ROOF THICKNESSES - CATEGORY I STRUCTURES - EXPOSED TO MISSILE IMPACT.General Design Approach

1. Establish concrete thickness required to prevent interior face scabbing.
2. Review capacity of member to absorb total energy due to missile impact.
3. Assess shear capacity of member.

TYPICAL WALLGeneral penetration and perforation equations (Reference) $d = \text{projectile diameter (in)}$  $D = \text{caliber density} = W/d^3 (\text{lbs/in}^3)$  $e = \text{perforation thickness (in)}$  $f'c = \text{concrete ultimate compressive strength (lbs/in}^2) = 4000 \text{ psi}$  $K = \text{penetrability factor} = \frac{180}{\sqrt{f'c}} = \frac{180}{\sqrt{4000}} = 2.85$  $N = \text{projectile shape factor.}$  $s = \text{scabbing thickness (in.)}$  $t = \text{target thickness (in.)}$  $v = \text{striking velocity. (ft/sec)}$  $v_i = \text{instantaneous velocity @ time } t_i$  $w = \text{projectile weight (lbs)}$  $x = \text{total penetration depth}$  $x_i = \text{penetration depth at } t_i.$ 

$$G\left(\frac{x}{d}\right) = KNd^{0.20} D \left(\frac{v}{1000}\right)^{1.80} \quad \text{where } G\left(\frac{x}{d}\right) = \begin{cases} \left(\frac{x}{2d}\right)^2 & \text{for } \frac{x}{d} \leq 2.0 \\ \frac{x}{d} - 1 & \text{for } \frac{x}{d} > 2.0 \end{cases}$$

$$\frac{e}{d} = 1.32 + 1.24 \frac{x}{d} \quad \text{where } (3 \leq \frac{e}{d} \leq 18)$$

$$\frac{s}{d} = 2.12 + 1.36 \frac{x}{d} \quad \text{where } (3 \leq \frac{s}{d} \leq 18)$$

Reference Document

Modified NDRC Formula from "A Review of Procedures for Analysis and Design of Concrete Structures to Resist Missile Effects".  
by R.P. Kennedy, Holmes & Narver, Inc., September 1975.

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_

**HOLMES & NARVER, INC.**ENGINEERS-CONTRACTORS  
480 E. ORANGEHORSE AVE.  
ANAHEIM, CALIF. 92801

APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

JOB NO. \_\_\_\_\_

TITLE WIPP FACILITY - SANDIASHEET TL 4 OF \_\_\_\_\_

BY \_\_\_\_\_ DATE \_\_\_\_\_

TYPICAL WALL SECTIONCritical Missile for Wall penetration -  $W = 1020^{\text{lb}}$ ,  $V = 120 \text{ ft/sec.}$ a) Penetration thickness,  $x$ Assume  $t = 18''$ 

$$N = 0.72; A_s = 10.0 \text{ in}^2 = \pi d^2/4, d = 3.57; D = \frac{W}{d^2} = \frac{1020}{(3.57)^2} = 22.45$$

$$t/d = \frac{18}{3.57} = 5.04 > 3.0$$

$$G\left(\frac{x}{d}\right) = (2.85)(0.72)(3.57)^{0.20} \left(22.45\right) \left(\frac{120}{1000}\right)^{1.8} = 1.308$$

$$\left(\frac{x}{2d}\right)^2 = 1.308 \rightarrow \frac{x}{2d} = 1.144 \rightarrow \frac{x}{d} = 2.29 > 2.0$$

$$\therefore G\left(\frac{x}{d}\right) = \frac{x}{d} - 1 = 1.308; \frac{x}{d} = 2.308, x = (2.308)(3.57) = 8.24 \text{ in}$$

b) Perforation thickness,  $e$ 

$$\frac{e}{d} = 1.32 + 1.24(2.308) = 4.18 \quad e/d > 3$$

$$e = (4.18)(3.57) = 14.92 \text{ in}$$

c) Scabbing thickness,  $s$ 

$$\frac{s}{d} = 2.12 + 1.36(2.308) = 5.26 \quad s/d > 3$$

$$s = (5.26)(3.57) = 18.78 \text{ in}$$

Use 18"	Typical Exposed Wall Thickness
---------	-----------------------------------

TYPICAL ROOF SECTION

Missile design parameters assumed same as for wall section, except for V

$$G\left(\frac{x}{d}\right) = (2.85)(0.72)(3.57)^{0.20} (22.45) \left(\frac{0.104120}{1000}\right)^{1.8} = 0.875$$

$$\frac{x}{d} - 1 = 0.875, x = (0.875)(3.57) = 3.09 \quad \frac{x}{d} = \frac{3.09}{3.57} = 1.87 < 2.0$$

$$\left(\frac{x}{2d}\right)^2 = 0.875; \frac{x}{2d} = 0.935; \frac{x}{d} = 1.870 \quad x = (1.870)(3.57) = 6.68$$

$$\frac{e}{d} = 1.32 + 1.24(1.87) = 3.64, e = (3.64)(3.57) = 12.99 "$$

$$\frac{s}{d} = 2.12 + 1.36(1.87) = 4.66 \quad e = (4.66)(3.57) = 16.64 "$$

Use 17"	Typical Exposed Roof Slab Thickness
---------	--

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_

APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

TITLE WIPP FACILITY - SANDIA

**HOLMES & NARVER, INC.**ENGINEERS-CONTRACTORS  
400 E. ORANGETHORPE AVE.  
ANAHEIM, CALIF. 92801

JOB NO. \_\_\_\_\_

SHEET IL-4 OF \_\_\_\_\_BY W.H.B. DATE 4/11/77TYPICAL WALL SECTIONWall Response for Impact from Missile with greatest energy input4000# Automobile @ V = 171 ft/sec.

$$\text{Total KE} = \frac{WV^2}{2g} = \frac{4000 \times 171^2}{2 \times 32.2} = 1,816,200 \text{ ft-lbs} = 1816 \text{ ft-kips}$$

$$\frac{\pi d^2}{4} = 20.0 \text{ ft}^2, \quad d = 5.05 \text{ ft} \quad (\text{dia. of equivalent circular contact area})$$

$$\text{Assume } E \text{ (effective wall width)} = 0.45 + 3.75 = 15.75 \text{ ft} \quad (\text{Use } 15')$$

$$W = 0.150 \times 1.5 \times 30 + 15 = 101 \text{ k}$$

$$W_e = 0.32 + 101 = 133 \text{ k} \quad (\text{Effective Mass})$$

Period of Vibration T

$$T \approx \left(\frac{L}{d}\right) \frac{L}{3600\sqrt{\phi}} = \frac{30+12}{16} \times \frac{30}{3600} = 0.188 \text{ sec} \quad \phi = 1.0$$

Equivalent Static Load

$$\textcircled{1} \quad q_g = \frac{2\pi mV}{T} \sqrt{\frac{1}{2\mu-1}} = \frac{2\pi \times 4 \times 171}{32.2 \times 0.188} \sqrt{\frac{1}{(2+10)-1}} = 163 \text{ k}$$

Wall Response

$$W_H = \frac{163}{15} = 11 \text{ k}$$

$$1.1 q = 1.1 \times 0.00256 \times 300^2 = 253 \text{ psf}$$

$$W_w = 253 + 30 = 7.6 \text{ k}$$


Factored Loads per ft. of Wall Width

$$\text{Assume } 1.2 W_w + 1.2 W_H$$

$$P = 1.2 + 11 = 13.2 \text{ k} \quad W = 1.2 + 7.6 = 9.1 \text{ k}$$

$$M_{max} = 13.2 \times \frac{30}{4} + 9.1 \times \frac{30}{8} = 123 \text{ kft} \quad \text{Des. M} = \frac{133}{0.9} = 148 \text{ kft}$$

$$\text{For } p = 0.01, \quad a_u = 4.10 \quad A_s = \frac{123}{4.1 \times 16} = \frac{1.23}{0.2} \text{ in}^2 / \text{ft} \quad \begin{cases} \text{Reinf. is} \\ \text{a reasonable} \\ \text{quantity} \end{cases}$$

Maximum Wall Disp. (Missile only)

$$\textcircled{1} \quad x_m = \frac{mv^2}{q_g(2\mu-1) - 2mg} \left( \frac{1}{1 + \frac{m}{M}} \right) = \frac{\frac{4 \times (171 \times 12)^2}{384}}{163 \left( \frac{2+10}{10} \right) - \left( \frac{2 \times 4 \times 384}{384} \right)} \left( \frac{1}{1 + \frac{12}{4}} \right) = \frac{15.7}{163}$$

Reference Document ①

"Impact Effect of Fragments Striking Structural Elements"

By R.A. Williamson and R.R. Alvay, Holmes & Narver, Inc., Revised Nov. 1973

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_  
 APPROVED \_\_\_\_\_ DATE \_\_\_\_\_  
 TITLE WIPP FACILITY - SANDIA

**HOLMES & NARVER, INC.**  
 ENGINEERS-CONSTRUCTORS  
 400 E. ORANGEHORSE AVE.  
 ANAHEIM, CALIF. 92803

JOB NO. \_\_\_\_\_  
 SHEET YL-6 OF \_\_\_\_\_  
 BY MPS DATE 4/11/77

### TYPICAL WALL SECTION

18" Wall. Punching Shear

$$d = 16"$$

W 16 x 324 H-plate

$$x = 8.24" \quad V = 120 \text{ ft/sec}$$

$$T_s = \frac{2x}{\sqrt{V}} = \frac{2 \times 8.24}{\sqrt{120 \times 12}} = 0.0116 \text{ sec}$$

$$F_a = \frac{WV}{gT_s} = \frac{1020 \times 120}{32.2 \times 0.0116} = 332,000^* = \underline{332 \text{ kN}} \quad T_a = \frac{332}{10.0} = 33.2 \text{ sec} < 60.0$$

$$\text{Shear Perimeter } e = 2[14" + 6.75"] = 41.5"$$

N-plate crushing likely

$$\text{Avg } J = \frac{332}{41.5 \times 16} = 0.50 \text{ kip/in} < 0.2 \text{ kip/in} = 0.80 \text{ kip}$$

∴ Punching shear < Allowable punching shear

### Other Materials

4000# Automobile - Energy absorption due to crushable elements make punching shear failure unlikely.

1500# Wood Utility Pole - Wood crushing will occur and a punching shear failure is not possible.

CHECKED _____	DATE _____	HOLMES & NARVER, INC.	JOB NO. _____
APPROVED _____	DATE _____	ENGINEERS-CONSTRUCTORS 400 E. ORANGETHORPE AVE. ANAHEIM, CALIF. 92801	HEET <u>JT2B-1</u> OF _____
TITLE <u>WIPP FACILITY - SANDIA</u>		BY <u>MFB</u> DATE <u>4/11/77</u>	

TRU-WASTE BUILDINGPreliminary Design Assumptions

Roof - Reinforced concrete poured in place solid slab, flat plate or flat slab construction with beam and girder construction in areas requiring special framing.  
Minimum slab thickness = 17" governed by tornado missile.

Floors - Upper levels - Same construction as roof except for minimum slab thickness.

Ground level - Concrete slab on compacted fill.

Walls - Reinforced concrete poured in place -  
Minimum wall thickness = 18" governed by tornado missile.

Foundations - Spread footings. Continuous wall type or individual type under columns.

Assumed allowable bearing values

Load combinations not including wind, tornado or seismic loads \_\_\_\_\_ 6.0 ksf

Load combinations including wind, tornado or seismic loads \_\_\_\_\_ 8.0 ksf

Bottoms of footings at least 4.0 feet below existing ground level.

Materials : Concrete  $f'_{c} = 4000$   
 Reinf. Steel ASTM A615, Gr 60  
 Struct. Steel ASTM A36


CHECKED \_\_\_\_\_ DATE \_\_\_\_\_  
 APPROVED \_\_\_\_\_ DATE \_\_\_\_\_  
 TITLE WIPP FACILITY - SANDIA

**HOLMES & NARVER, INC.**  
 ENGINEERS-CONTRACTORS  
 400 E. ORANGEHORSE AVE.  
 ANAHEIM, CALIF. 92801

JOB NO. \$251-00  
 SHEET TOP-2 OF 1  
 BY HPS DATE 6/11/77

### TORNADO LOADING ASSUMPTIONS

#### TRU WASTE BUILDING



#### ASSUMED BUILDING LOADING

Note ① : Entry tunnels are assumed to act independently and are not considered to participate in transmitting loads to the building. Entry tunnels are to be capable of resisting the maximum tornado wind forces.

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_

**HOLMES & NARVER, INC.**ENGINEERS-CONTRACTORS  
400 E. ORANGETHORPE AVE.  
ANAHEIM, CALIF. 92801APPROVED \_\_\_\_\_ DATE \_\_\_\_\_  
TITLE WIPP FACILITY - SANDIA

JOB NO. \_\_\_\_\_

SHEET T2B-3 OF \_\_\_\_\_BY MAB DATE 4/11/70TRU-WASTE BUILDINGWIND LOADING SUMMARYDesign Loading Combinations $W_t = \text{Total Tornado load}$  $W_w = \text{Tornado wind load}$  $W_p = \text{Tornado differential pressure load}$  $W_m = \text{Tornado missile load}$ 

$$W_t = W_w$$

$$= W_p$$

$$= W_m$$

$$= W_w + 0.5 W_p$$

$$W_p = 2.25 \text{ psf} = 324 \text{ psf}$$

$$= W_w + W_m$$

$$= W_w + 0.5 W_p + W_m$$

Critical Tornado Wind Loadings - Not including Missile Loads

<u>Local Wall Loading (psf)</u>			<u>Building Translation Loading (psf)</u>	
<u><math>W_w</math></u>	<u><math>W_p</math></u>	<u><math>W_t</math></u>	<u>Longit Direction</u>	<u>Transverse Direction</u>
- 120	- 162	- 292	140	127
+ 153	-	+ 253		

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_

APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

TITLE WIPP FACILITY - SANDIA

## HOLMES &amp; MARVEL, INC.

ENGINEERS-CONSTRUCTORS  
400 E. ORANGEHORSE AVE.  
ANAHUAC, CALIF. 90201

JOB NO. \_\_\_\_\_

SHEET 7 of 8 OF 8BY WMB DATE 4/11/77TRU-WASTE BUILDINGHIGH BAY WALL W/ 25' T. CRANE SUPPORTCrane Wheel Load = 20<sup>k</sup> @ 25" from WallWind Loads

$$W_t = W_N + 0.5 W_p$$

$$= (0.00236 \times 300^2) + (0.5 \times \frac{2.25}{2} \times 164)$$


$$= 230 + 162 = 392 \text{ psf}$$

$$\text{McCrane Ld} = 20 \times \frac{25}{12} = 42 \text{ kF}$$

$$R_{top} = 42 / 52 = 0.79 \text{ k}$$

$$M_{above} = 0.79 \times 11 = 8.7 \text{ kF}, M_{below} = 33.3 \text{ kF}$$

$$M_d = 21 \text{ kF} \rightarrow \text{Assume 3.0' Strip, } M/ft = 7 \text{ kF}$$



$$W = 1.2 \times 0.392 + 53 = 24.93 \text{ k}$$

$$M_w = 24.93 + 53 / 12 = 165 \text{ kF}$$

$$\text{McCrane} = 1.4 \times (\text{Load Factor}) \times 7 = 10 \text{ kF}$$

$$EM = 175 \text{ kF}$$

$$t = \frac{h}{25} = \frac{25}{25} = 2.12'$$

$$\text{Use } t = 24" \quad d = 22"$$

# ACI 318-71, Sec 14.2(d)

$$M_g = 175 + 10 / 12 = 186 \text{ kF} \quad (\text{For 10" Wide Section, ACI SP 17(73) Vol 1, p 130})$$

$$A_s = 1.55 \text{ in}^2 = 0.25 \text{ pb} \quad (10" \text{ Width})$$

$$A_s = 1.55 + 12 / 10 = 1.86 \text{ in}^2 / \text{ft} \quad \cdot \underline{\text{Say } 24" \text{ to } 10"} \quad p = \frac{100 + 1.86}{12 + 22} = 0.70$$

∴ Say 24" Wall o.k.

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_  
APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

**HOLMES & NARVER, INC.**  
 ENGINEERS-CONSTRUCTORS  
 400 E. ORANGETHORPE AVE.  
 ANAHEIM, CALIF. 92801

TITLE WIPP FACILITY - SANDIA

JOB NO. \_\_\_\_\_  
SHEET T2B - 1 OF \_\_\_\_\_  
BY HPS DATE 4/11/77TRU-WASTE BUILDINGHIGH-BAY WALL W/ 25T. CRANE SUPPORT

Wall Response - 4000# Automobile Missile

$$KE = \frac{WV^2}{2g} = \frac{4000 + 17^2}{2 \times 32.2} = 181.6 \text{ ft-kips}$$

$$\pi d^2/4 = 20 \text{ ft}^2, d = 5.066 \text{ ft} = 60.56''$$

$$\text{Effective Width } E = 0.45 + 3.75 = (0.4 + 5.3) + 3.75 = 25 \text{ ft}$$

Assume  $E = 20 \text{ ft}$ 

$$W = 0.150 \times 53 + 20 \times 2.0 = 31.8 \text{ k}$$

$$We = 0.33 \times 31.8 = 10.6 \text{ k}$$

Period of Vibration


$$\omega = 22'' \quad \phi = 1.0\%$$

$$T = \left( \frac{L}{d} \right) \left( \frac{L}{3600 \text{ sec}} \right) = \frac{53 + 17}{22} \sqrt{\frac{53}{3600 + 1.0}} = 0.425 \text{ sec}$$

EQUIV. STATIC LOAD $\mu = 10$  (assumed)

$$q_{eq} = \frac{2\pi m \nu}{T} \sqrt{\frac{1}{2\mu + 1}} = \frac{2\pi \times 4 + 17}{32.2 \times 0.425} \sqrt{\frac{1}{(2 + 10) - 1}} = 72.0 \text{ k}$$

$$W_m = \frac{72}{30} = 3.6 \text{ k} \quad \text{for 1' strip}$$



$$1.1 q = 1.1 \times 0.00256(200)^2 = 25.3 \text{ psf}$$

$$W_w = 0.253 \times 53 = 13.4 \text{ k}$$

Use  $1.2 W_w + 1.2 W_m$ 

$$P = 1.2 \times 3.6 = 4.3 \quad W = 1.2 \times 13.4 = 16.1$$

$$M = 4.3 \times 53 \frac{1}{4} + 16.1 \times 53 \frac{1}{8} = 57 + 107 = 153 \text{ kft}$$

$$A_s = 1.4 + 12 \frac{1}{10} \times \frac{1.68 \text{ in}}{1.0} \text{ in} \quad (\text{ACI SP-17(73) - Vol 1, P-30})$$

$$* 11 @ 11 \quad p = \frac{100 + 1.68}{12 + 22} = 0.64\%$$

24" Wall o.k.

90029078

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_


APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

TITLE WIPP FACILITY - SANDIA

## HOLMES &amp; NARVER, INC.


ENGINEERS-CONSTRUCTORS  
400 E. ORANGETHORPE AVE.  
ANAHEIM, CALIF. 92801

JOB NO. \_\_\_\_\_

SHEET T2A-6 OF \_\_\_\_\_BY H.P. DATE 4/11/73TRU-WASTE BUILDINGSURFACE WIND PRESSURES

WIND DIRECTION

$$CP_L = \pm 0.3$$



$$CP_L = \pm 0.3$$

PRESSURE COEFFICIENTS CP & CP<sub>L</sub>

$$P = q_f C_p - q_m C_{pL}$$

$$\text{Velocity Pressures } q_f = 0.00256 V^2; V_{max} = 300 \text{ mph}; q = .00256 \times \frac{300^2}{3600} = 230 \text{ psf}$$

WIND PRESSURES ON BUILDING SURFACES

Surface No.	CP	$q_f C_p$	$C_{pL}$	$q_m C_{pL}$	P	CP	$q_f C_p$	$C_{pL}$	$q_m C_{pL}$	P
1	-0.7	-161	+0.3	+69	-92	+0.8	+184	+0.3	+69	+253
			-0.3	-69	-230			-0.3	-69	+115
2	-0.7	-161	+0.3	+69	-92	-0.5	-115	+0.3	+69	-46
			-0.3	-69	-230			-0.3	-69	-184
3	+0.8	+184	+0.3	+69	+153	-0.7	-161	+0.3	+69	-92
			-0.3	-69	+115			-0.3	-69	-230
4	-0.5	-115	+0.3	+69	-46	-0.7	-161	+0.3	+69	-92
			-0.3	-69	-184			-0.3	-69	-230
5	-0.7	-161	+0.3	+69	-92	-0.7	-161	+0.3	+69	-92
			-0.3	-69	-230			-0.3	-69	-230

$q_f = q_m = 230 \text{ psf}$  in above table

42

90029079

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_

APPROVED \_\_\_\_\_ DATE \_\_\_\_\_


TITLE WIPP FACILITY - SALINA

**HOLMES & NARVER, INC.**ENGINEERS-CONTRACTORS  
400 E. ORANGETHORPE AVE.  
ANAHEIM, CALIF. 92801

JOB NO. \_\_\_\_\_

SHEET TRB-7 OF \_\_\_\_\_

BY HHS DATE 4/11/77

TRU-WASTE BUILDINGWIND SHEARS ON WALLS

$$151 \times 54 = 8154 \text{ ft}^2 \times 146 = 1190 \text{ k} \quad (792 \text{ F}, 458 \text{ R})$$

$$63 \times 35 = 2205 \times 146 = 392 \text{ k} \quad (241 \text{ F}, 151 \text{ R})$$

$$151 \times 297 = 44,847 \text{ ft}^2 \times 161 = 7220 \text{ k}$$

$$63 \times 297 = 18,711 + 161 = 3012 \text{ k}$$


$$298 \times 63 = 18,774$$

$$196 \times \frac{63}{2} = 6,174$$


$$24,948 / 297 = 84 \text{ k}$$

ROOF DIAPHRAGM LOADSBUILDING WALL LOADS

WALL R



WALL RF



WALL F

HORIZ WIND SHEARS (kips)  
ACTING ON SIDE WALLS

$$494 / 297 = 1.66 \text{ k/ft}$$

$$V_{wind} = 1660 / 12 + 18 = 8 \text{ psi}$$

(Very low)


CHECKED \_\_\_\_\_ DATE \_\_\_\_\_

APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

TITLE WIPP FACILITY - SANDIA

**HOLMES & NARVER, INC.**ENGINEERS-CONTRACTORS  
400 E. ORANGEHORSE AVE.  
ANAHUAC, CALIF. 90801

JOB NO. \_\_\_\_\_

SHEET 102-1 OF \_\_\_\_\_BY MPS DATE 4/11/77TINU. WASTE BUILDINGEnd Wall Loads

$$H = \frac{54}{2} \times \frac{297}{2} + 0.8 \times 127 = 407^k$$

$$\frac{M}{2} = \frac{297}{2} \times 0.5 \times 127 = 90^k$$


$$\frac{M}{2} = \frac{297}{2} \times 0.8 \times 127 = 165^k$$

$$M = (497 \times 58) + (255 \times 59) = 38,771$$

$$A = 3 \times (151 + 63) = 642 \text{ ft}^2$$

$$S_a = 3 \times 154 \times 63 = 22,898$$

$$f_{ps} = 1.69$$



$$16 \times 12 = 192 \text{ ft}$$

$$P = 5.4 \times 151 = 513^k$$


$$5.4 \times 63 = 316^k$$

$$x = \frac{M}{P} = \frac{513 \times 151}{46.6} = 10.4$$

$$M = 10.4 \times 9807 = 99,726$$

$$f_m = 38726 / 22,898 = 1.73$$

$$f_a = 9807 / 642 = 15.93$$



$$16 \times 161 = 389^k$$

$$K_a = 161 \times 63 = 162^k$$

$$x = \frac{M}{P} = \frac{(389 + 151) + (162 + 182)}{455} = 551^k$$

$$x = 10.6 \text{ ft} \quad e = 0.2$$

$$M = 0$$

$$f_a = \frac{551}{642} = 0.86 \text{ ft}^2 / \text{ft}^2$$

Wall Footing Soil PressuresDL + Tornado Horiz + Tornado Vertical

$$\begin{aligned}
 f_p(\text{ksf}) &= 5.93 - 1.73 + 1.69 & - 0.86 &= 5.0 \\
 &= 5.93 + 1.73 - 1.69 & - 0.86 &= 5.1
 \end{aligned}
 \quad \left. \begin{array}{l} \\ \end{array} \right\} < 6.0 \text{ ksf}$$


CHECKED \_\_\_\_\_ DATE \_\_\_\_\_

APPROVED \_\_\_\_\_ DATE \_\_\_\_\_


TITLE WIPP FACILITY - SANDIA

**HOLMES & NARVER, INC.**ENGINEERS-CONTRACTORS  
400 E. ORANGETHORPE AVE.  
ANAHEIM, CALIF. 92801

JOB NO. \_\_\_\_\_

SHEET T2B-9 OF \_\_\_\_\_BY HPS DATE 4/11/77**TRU-WASTE BUILDING**Side Wall Loads


$$\begin{aligned} M &= 494 \times 39 = 19,266 \text{ kip} \\ A &= 3.0 \times 297 = 897 \text{ ft}^2 \\ S &= 3 \times \frac{299^2}{6} = 44,701 \\ f_{max} &\pm \frac{19,266}{44,701} = 0.43 \text{ ksf} \end{aligned}$$



$$\begin{aligned} \text{Roof} & 16' \times .72 = 3.4 \text{ ksf} \\ \text{Mem} & 10' \times .70 = 2.0 \text{ ksf} \\ \text{Wall} & 39' \times .225 = 8.78 \text{ ksf} \end{aligned}$$

$$P = 1010 + 594 + 2608 = 4212 \text{ ksf}$$

$$f_p = 4212 / 897 = 4.70 \text{ ksf}$$



$$\begin{aligned} 16' \times .161 &= 2.58 \text{ ksf} \\ 2.58 \times 297 &= 766 \text{ ksf} \\ f_p = 766 / 897 &= -0.85 \text{ ksf} \end{aligned}$$

Wall Footing Soil Pressures

DL + Tornado Horiz + Tornado Uplift

$f_p (\text{ksf})$	4.70	+	0.43	= 0.85	*	4.28	{}
	4.70	-	0.43	= 0.85	:	3.42	

< 6.0 ksf

Typical Foundation Loads - D.L + LLRoof Loads

LL =	20	LL =	150
Flg + Ins =	10	Flr	100
17" Slab =	213		250

263 psf

Column Footings - Typ

$$\begin{aligned} \text{Trib Area} &= 30 \times 30 = 900 \text{ sq ft} \\ \text{Trib Load} &= 1056 (\text{.243} + \text{.300}) = 57.5 \text{ ksf} \\ \text{Col Wt} & (30 \times 30 \times .94 \text{ ksf} \times 3) = 29 \text{ ksf} \end{aligned}$$

Wall Footings - Typical

Wall Ht	57'	38'
Wall Wt/ft	13.9	9.2
Roof Ld	16 + 243 = 3.9	3.9
Flr Ld	16 + 25 = 4.0	4.0
	21.8	17.1
Width w @ 6.0 ksf	= 4.0	3.0'

57' + (React Load)	57' + 1056 = 161.1'
Roof Ld = 27' x .300 =	8.1'
	29.2'
	5.0'

45-46

90029082

Mechanical Calculations

POOR ORIGINAL

90029083

COST OF ELECTRICAL POWER  
USED IN LIFCY1 RUNS  
FOR HVAC ENERGY STUDY

47-48

90029084

TRU

## Cost of Electricity

Assume .016 /kwh + 4.50 demand

Actual demand = 410 KW

Total usage = 1,970,442 KWH

---

$$\text{Demand charge} = \frac{410 \times 4.5 \times 12}{1,970,442} = .01124$$
$$\text{total cost /kwh} \quad \quad \quad + \frac{.016}{.02724}$$

$$\text{Cost /MBTU} = \frac{1000,000}{3413} \times .02724 = \$7.98$$

## Cost of Electricity (RH Bldg.)

Assume: .016/kwh + 4.50 demand charge

Actual demand rate =  $187 \times 1.1 = 205.7$

Total usage =  $895,656 \times 1.1 = 985,221$

---

$$\text{Demand charge} = \frac{205.7 \times 4.5 \times 12}{985,221} = .01127$$
$$\text{total cost/kwh}$$
$$+ .016$$

---

$$.0273$$

$$\text{Cost / MBTU} = \frac{1,000,000}{3413} \times .0273 = ^*\$7.999$$

900029086

## Cost of Electricity (Admin. Bldg. only)

Assume: .016/kwh + 4.50 demand charge.

Actual demand rate = 176

Total usage Alt. 3 = 727,797 kwh

Alt. 4 = 557,047 kwh

average = 642,422

$$\text{Demand charge} = \frac{176 \times 4.50 \times 12}{642,422} = .0148$$

$$\text{total cost / kwh} = \frac{.0148 + .016}{.0308}$$

$$\text{Cost / MBTU} = \frac{1,000,000}{3413} \times .0308 = 9.0243$$

Solar Assist.—

200 panels @ 306 x 2 = \$122,400

(to supply  $1.36 \times 10^9$  BTU/yr.)

## Laundry

Laundry - H.W. Energy use

$$30 \text{ KW} \times 5 \text{ hr.} = 150 \text{ KWH/day}$$

@ 30 KW demand

---

Cost of electricity - .016 kwh + 4.50 demand

$$\text{demand} = 30 \text{ KW} \quad \text{total usage} = 37,500$$

---

$$\begin{array}{rcl} \text{Demand charge} & \frac{30 \times 4.5 \times 12}{37,500} & = .0432 \\ & + .016 & \\ & \hline & 0.0592 \\ \text{total cost/kwh} & & \end{array}$$

$$\text{cost/MBTU} = \frac{1,000,000}{3413} \times .0592 = 17.345$$

---

$$\text{solar panels} - 30 @ 306 \times 2 = 18,360 + \$500/\text{yr. maint.}$$

---

KRB  
3/21/77  
1

FUEL CONSUMPTION  
DIESEL GENERATORS

2600 KW RATED MACHINE IS RATED AT  
3600 BHP. FROM PROPOSAL DATA SUPPLIED  
BY STEWART & STEVENSON THE FUEL  
CONSUMPTION WILL BE 0.404 LB/BHP-HR

$$\therefore \text{CONSUMPTION/HR} = 3600 \text{ BHP} (.404 \text{ LB/BHP-HR}) \\ = 1454.4 \text{ LB/HR}$$

$$\text{CONSUMPTION/DAY} = 24 \frac{\text{HR}}{\text{DAY}} (1454.4 \frac{\text{LB}}{\text{HR}}) \\ = 34,905.6 \frac{\text{LB}}{\text{DAY}}$$

$$2 \text{ GENERATORS} = 69,811.2 \frac{\text{LB}}{\text{DAY}}$$

CAPACITY IN GALLONS ASSUMING NO. 2 FUEL OIL  
API = 26              7.5 LB/GALLON

$$\text{GALLONS/DAY} = \frac{69,811.2}{7.5} \\ = \underline{\underline{9308 \text{ GALLONS/DAY}}}$$

KRB  
3/22/77

2

$$\begin{aligned}7 \text{ DAY FUEL SUPPLY} &= 7(9308 \text{ GPD}) \\&= \underline{\underline{65,156 \text{ GALLONS}}}\end{aligned}$$

RegGuide 1.108

Houston, Texas (713) 923-2161

3/23/77

Based on conversation with Robert Evans -  
National Contract Manager of Stewart & Stevenson  
and review of Reg. Guides the following  
is used to size the fuel system:

NRC requires 7 days - 168 hours. This  
is the capacity which should always be  
present in the system. Standard system  
tests shall never take system below  
168 hour capacity.

∴ to allow for condensation space  
and tests the system should be sized  
for 100,000 gallons. This will be in  
addition to the 500 gallon daytank  
provided for each generator.

3/23/77

3

## Mechanical Systems

### STANDBY GENERATOR RADIATOR AIR FLOW

FROM STEWART & STEVENS CATALOG, HEAT  
GENERATION RATE IS 50 BTU/MIN/KW

MACHINE RATING = 2600 KW

$$\begin{aligned}\therefore Q &= (50 \text{ BTU/MIN/KW}) 2600 \text{ KW} \\ &= 130,000 \text{ BTU/MIN} \\ &= 7,800,000 \text{ BTU/HR / MACHINE}\end{aligned}$$

AIR FLOW BASED ON  $30^{\circ}\text{F}$   $\Delta T$   
WILL BE 24000 CFM

BUILDING OPENING SIZE BASED ON 2000 FPM  
VELOCITY WILL BE  $120 \text{ FT}^2/\text{GENERATOR}$

55-56

90029091

ADDENDA

WIPP CONCEPTUAL DESIGN

HIGH LEVEL WASTE SHIPPING CASK  
COOLING SYSTEM

DESIGN CALCULATIONS

HOLMES & NARVER, INC.

57-58

90029092

Pages 1-3 dated 1/28/77 are concerned with the calculation of heat loads from high level waste shipping casks which will be cooled by this system.

KRB  
128/767

ERDA HIGH LEVEL WASTE - MULTIPLE CANISTER CASK

INPUT (SLA 1140/30; 11-30-76)

CASK SIZE 10' DIA X 18' LONG

GW = 100 TONS

CANISTERS - 7 @ 10,000 LBS

THERMAL POWER/CANISTER = 300 W

TOTAL THERMAL POWER = 2100 W = 2.1 KW

\* CASK SURFACE TEMPERATURE (AT RECEIPT) = 225°F

\* " " " (DESIRED) = 150°F

50 CANISTERS/WK = 7/7 SAY 8 CASKS/WK ~ 5 HRS/CASK

ASSUMPTIONS

CASK COMPOSITION      75% LEAD  
                          25% STEEL

		STEEL	LEAD
$C_p$	BTU/LB°F	.11	.034
$K$	BTU/FT-HR-°F	20	20
$\rho$	LB/FT <sup>3</sup>	488	708

WASTE COMPOSITION IS ASSUMED TO  
BE THE SAME AS LEAD FOR THIS CALC.

\* 10-14-76 - W.WOWAK

b1

90029094

KRB Z  
1/28/76

DESIRED MINIMUM COOLDOWN TIME IS 4 HRS/CASK

### CALCULATIONS

PER W.WOWAK

$$Q_{4\text{ HRS}} = \overset{\textcircled{A}}{\Delta Q_{75^\circ\text{F}}} + \overset{\textcircled{B}}{\Delta Q_{\text{CANISTER GENERATION (IN 4 HRS)}}}$$

$$\begin{aligned}\textcircled{A} \quad \Delta Q_{75^\circ\text{F}} &= \rho V c_p \Delta T \quad \left( \frac{\text{LB}}{\text{FT}^3} \right) \left( \frac{\text{BTU}}{\text{LB}^\circ\text{F}} \right) \circ\text{F} \\ &= \left[ 75 \text{TONS} \left( 2000 \frac{\text{LB}}{\text{TON}} \right) (.034) + 25(2000)(.11) \right] 75 \\ \Delta Q_{75} &= (5.1^{+3}_{-3} + 5.5^{+3}_{-3}) 75 \text{BTU} = 7.95^{+5}_{-5} = 795,000\end{aligned}$$

$$\Delta Q_{\frac{75}{\text{HR}}} = 795,000 / 4 \text{ HRS}$$

$$\Delta Q_{\frac{75}{\text{HR}}} \left\{ \begin{array}{l} \cong 200,000 \text{ BTU/HR} \\ \cong 58.5 \text{ KW} \end{array} \right.$$

KRB

1/28/76

$$\textcircled{B} \quad \Delta Q_{\text{CAN GEN}} = 7 \text{ CANS} (300 \frac{\text{W}}{\text{CAN}}) \\ = 2.1 \text{ KW}$$

$$Q = \textcircled{A} + \textcircled{B}$$

$$= 58.5 \text{ KW} + 2.1 \text{ KW}$$

$$\underline{Q = 60.6 \text{ KW}} \quad \underline{\text{FOR ERDA HIGH WASTE}}$$

### COMMERCIAL HIGH WASTE

$Q \approx 100 \text{ KW}$  FROM CALCS BY W.WOWAK  
ON 10-14-76

KRB

1/31/77

ASSUMPTIONS

1. DURING INITIAL COOLDOWN, FLOW FROM THE HOT WATER TANK TO THE CASKS WILL BE BY GRAVITY ONLY.
- 2.

64

90029097

CALCULATIONS

DETERMINE WATER FLOW REQ'D TO INITIALLY  
COOL THE CASK VIA ~~\_\_\_\_\_~~ VAPORIZATION  
OF THE HOT WATER FEED TO STEAM

WATER IN THE TANK IS HEATED TO 400°F  
BY AN ELECTRIC HEATER

$$T = 400^\circ\text{F}$$

$$P = 247.31 \text{ PSIA}$$

$$h_f = 374.97 \text{ BTU/LB}$$

$$h_{fg} = 826.0 \text{ "}$$

$$h_g = 1201.0 \text{ "}$$

SYSTEM SIZING WILL BE BASED ON COOL DOWN  
OF COMMERCIAL HIGH LEVEL WASTE. IT IS  
ASSUMED THAT COOLING TIME IS LIMITED TO  
4 HOURS. THE COOLDOWN RATE IS 100 KW  
PER CASK, WHICH IS 341,000 BTU/HR  
FOR PURPOSES OF THE CALCULATION IT IS  
ASSUMED THAT THE COOLING IS LINEAR - i.e. - THE  
HEAT REMOVAL RATE IS A CONSTANT 341,000 BTU/HR  
OVER THE 4 HOUR PERIOD IN QUESTION

3  
KRB  
1/31/77

SINCE THE FIRST PHASE COOLING IS BASED  
ON VAPORIZATION THE FLOW REQUIRED  
IS:

$$F = \frac{341,000 \frac{\text{BTU}}{\text{HR}}}{826 \frac{\text{BTU}}{\text{LB}}}$$

$$\underline{F = 413 \frac{\text{LB}}{\text{HR}}} \\ = 49.5 \text{ GPH} \\ \underline{\sim .83 \text{ GPM / CASK}}$$

ASSUMING THE COOLING TO BE 3 X AVERAGE  
DURING VAPORIZATION STILL REQUIRES ONLY  
2.5 GPM FLOW PER CASK

PHASE TWO (BOILING UNDER REDUCED PRESSURE)  
WILL REQUIRE APPROXIMATELY THE SAME FLOW  
AS DOES THE FIRST PHASE COOLING.

PHASE THREE (FORCED CONVECTION COOLING)  
WILL REQUIRE A FLOW BASED ON THE FOLLOWING  
WATER INLET TEMP. =  $100^{\circ}\text{F}$   $h_f = 67.97 \frac{\text{BTU}}{\text{LB}}$   
WATER OUTLET TEMP. =  $210^{\circ}\text{F}$   $h_f = 178.05 \frac{\text{BTU}}{\text{LB}}$   
 $Q = 341,000 \frac{\text{BTU}}{\text{HR}}$        $\Delta h = 110 \frac{\text{BTU}}{\text{LB}}$

66

90029099

KRB

1/31/77

$$F = \frac{341,000 \text{ BTU/HR}}{110 \text{ BTU/LB}}$$

$$= 3,100 \text{ LB/HR}$$

$$= 370 \text{ GPH}$$

$$= \underline{6.2 \text{ GPM}}$$

COMMENT

CASK COOLING IN REPROCESSING FACILITIES IS BASED ON REDUCING CASK TEMPERATURES TO THE LEVEL THAT WILL NOT RESULT IN BOILING WHEN THE CASK IS INSERTED IN THE FUEL STORAGE POOL. WIPP IS REQUIRED TO COOL THE CASKS FOR THE FOLLOWING REASONS

- TO REDUCE CASK SKIN TEMPERATURES TO THE POINT WHERE HANDLING IS SIMPLIFIED AND SAFER ( $\sim 150^{\circ}\text{F}$ ).
- TO REDUCE THE HEAT LOAD AND RESULTANT TEMPERATURES TO WHICH THE HOT CELL AND EQUIPMENT WILL BE EXPOSED.

FOR PURPOSES OF FURTHER ANALYSIS IT IS ASSUMED THAT <sup>CASK</sup> SKIN TEMPERATURE IS THE LIMITING

5  
KRB  
1/31/77

FACTOR - THEREFORE THE ANALYSIS - AS IT IS BASED ON SKIN TEMPERATURE REDUCTION FROM 225 TO 150°F IS ACCEPTABLE. THE FLOWS ARE ALSO ACCEPTABLE - ASSUME A MAXIMUM OF 5 COOLING STATIONS FOR HIGH LEVEL WASTE CASKS.

∴ THE MAXIMUM FLOWS FOR THE VARIOUS COOLING PHASES WILL BE

PHASE	FLOW(GPM)
I	12.5
II	12.5
III	31

ASSUMING DIVERSITY WILL ALLOW REDUCTION OF THE PHASE III FLOW - THIS FLOW WILL BE SET AT 25 GPM BASED ON THE THOUGHT THAT OVER WEEKENDS, HOLIDAYS, ETC. WHEN CASKS MAY BE COOLED FOR LONG PERIODS OF TIME THE ONLY HEAT TO BE REMOVED WILL BE THAT GENERATED BY THE WASTE, THE CASK HAVING BEEN PREVIOUSLY COOLED TO ITS DESIRED 150°F SKIN TEMPERATURE.

THE FLOW UNDER THIS CONDITION WILL THEN BE BASED ON A Q OF 28KW

KRB  
1/31/77

$$\begin{aligned} \text{Flow} &= \frac{28 \text{ KW} \left( 3415 \frac{\text{BTU/HR}}{\text{KW}} \right)}{100 \text{ BTU/LB}} \\ &= 955 \frac{\text{LB}}{\text{HR}} \\ &= 114 \text{ GPH} \\ &= \underline{1.9 \text{ GPM}} \end{aligned}$$

$$5 \text{ CASKS} = 9.5 \text{ GPM}$$


$\therefore$  SYSTEM COULD HANDLE 3 CASKS AT  
 MAX FLOW = 18.6 GPM, TWO AT  
 MAINTENANCE FLOW = 3.8 GPM WITH A 2.6 GPM  
 MARGIN —

$$\begin{array}{ll} 18.6 & \text{MAX.} \\ 3.8 & \text{MAINT.} \\ \hline 2.6 & \text{MARGIN} \\ \hline \underline{25.0 \text{ GPM}} & \end{array}$$

$\therefore$  25 GPM WILL BE UTILIZED

7  
KRB  
1/31/77

## SYSTEM DESIGN



FLOW FROM THE HOT WATER TANK TO THE CASKS WILL BE BY GRAVITY ONLY - THE TANK IS ASSUMED TO BE LOCATED IN THE HVAC AREA - AVAILABLE PRESSURE HEAD = 32'  
THIS IS APPROXIMATELY 14 PSI - THE  $\Delta P$  WILL BE SPLIT  $\frac{1}{2}$  FOR LINE LOSSES  $\frac{1}{2}$  FOR CONTROL -  $\therefore \Delta P_{LINE} = 7 \text{ PSI}$   
FOR 2" PIPE  $V = 1.3 \text{ FEET/SECOND}$   
 $\Delta P_{FRICTION} \sim 0.2 \text{ PSI}/100'$

FOR THE PURPOSES OF CONCEPTUAL  
DESIGN 2" PIPE WILL BE USED FOR MAJOR  
SYSTEM ~~BRANCHES~~ <sup>SECTIONS</sup> WITH 1" PIPE USED  
FOR BRANCHES.

PUMP SIZE = 25 GPM

OUTLET PRESSURE = 300 PSIA

INLET PRESSURE = 14.7 PSIA

---

---

### HOT WATER TANK (Now a pressure tank)

ASSUMING 5 CASKS BEING COOLED IN  
PARALLEL WITH A MAX FLOW TO EACH OF  
2.5 GPM TOTAL FLOW = 12.5 GPM.

ASSUME ALSO THAT THE MAXIMUM ~~LEVEL~~  
VARIATION IN A 1 HR PERIOD SHOULD NOT  
BE MORE THAN 20% OF THE VOLUME

$$\therefore \text{TANK SIZE} = \frac{(12.5 \frac{\text{GAL}}{\text{MIN}})(60 \frac{\text{MIN}}{\text{HR}})}{20\%/\text{HR}}$$
$$= \underline{3750 \text{ GAL}}$$

THIS IS A LARGE VOLUME OF WATER TO  
MAINTAIN AT A HIGH TEMPERATURE  $\therefore 40\%/\text{HR}$

9  
KRB  
4/31/77

WILL BE ASSUMED GIVING A VOLUME OF 1775 GAL.  
THE TANK WILL BE SIZED AT 2000 GAL

CATCH TANK

LOW TEMP RECEIVER

THE RECEIVER WILL BE SIZED AT  
500 GALLONS CAPACITY

~~- TO BE CALCULATED  
SYSTEM CONDENSER AFTER SYSTEM BALANCE  
COMPLETED -  
SIZED ON THE BASIS OF 5 CASKS IN  
PHASE I COOLING -~~

$$Q = 5(341,000 \frac{\text{BTU}}{\text{HR}})$$

$$= 1,705,000 \frac{\text{BTU}}{\text{HR}}$$


SAY 2,000,000 BTU/HR FOR DESIGN  
PURPOSES

CATCH TANK

THE TANK HAS A 3000 GAL CAPACITY

7.2  
90029105

10  
KRB  
2/3/77



F=FLOW

### COMPONENT DESIGN BASIS

$$T_2 = 380^\circ\text{F} \quad T_6 = 300^\circ\text{F}$$

$$P_2 = P_1 \quad F_8 = F_1 = F_2 = F_3 = F_4 = F_5 \neq F_6$$

$$\therefore Q_{12} = 413 \frac{\text{LB}}{\text{HR}} (h_{380} - h_{150})$$

$$= 413 (353.45 - 117.89)$$

$$= 413 (235.56)$$

$$Q_{12} = 97,000 \text{ BTU/HR} \quad \text{RECOVERY}$$

$$Q_{23} = 413 \frac{\text{LB/HR}}{} (h_{400} - h_{380})$$

$$= 413 (374.97 - 353.45)$$

$$= 413 (21.52)$$

$$Q_{23} = 9,100 \text{ BTU/HR}$$

} ELECTRIC  
HEAT  
ADDITION

11  
KRB  
2/5/77

$$F_5 = F_6 = Q_{12} / [h_{fg}(400) + \Delta h_f_{400-500}]$$
$$= \frac{97,000 \frac{\text{BTU}}{\text{HR}}}{\frac{1201.0 \frac{\text{BTU}}{\text{LB}} + (374.97 - 269.59)}{826 \frac{\text{LB}}{\text{HR}}}} \frac{\text{BTU}}{\text{LB}}$$
$$= \frac{97000}{931.4} \text{ LB/HR}$$

$$F_5 = F_6 = 104 \text{ LB/HR}$$

$$F_7 = 413 - 104 \text{ LB/HR}$$

$$\underline{F_7 = 309 \text{ LB/HR}}$$

$$\underline{\underline{F_8 = 413 \text{ LB/HR}}}$$

$$\Delta Q \text{ FOR SYSTEM} = 341,000 - 97,000 + 9,100$$
$$= 244,000 \text{ BTU/HR REJECTED}$$

IN PHASE I TO AN EXTERNAL


$$\therefore Q_{\text{CONDENSER}} = \frac{\text{SYSTEM}}{\frac{253,000}{244,000 \frac{\text{BTU/HR}}{\text{CASK}} (5 \text{ CASKS})}} \frac{253,000}{\text{CASK}}$$
$$= \underline{\underline{1,265,000 \text{ BTU/HR}}}$$
$$\sim \underline{\underline{1,300,000 \text{ BTU/HR MAXIMUM}}}$$

THIS IS THE PEAK SYSTEM HEAT LOAD TO BE  
CONSIDERED FOR REJECTION TO ATMOSPHERE  
AND TO BE CONSIDERED FOR CONSERVATION.

711

90029107

## SYSTEM CONFIGURATION



## RH BUILDING

### COMPONENT DATA

#### HEAD TANK

CAPACITY = 2000 GAL

DESIGN PRESSURE = 500 PSIA

" TEMPERATURE = 180°F

#### SYSTEM PUMP - 2 INSTALLED - 1 AS SPARE

FLOW = 25 GPM

INLET TEMPERATURE = 150°F

" PRESSURE = ATMOSPHERIC

DISCHARGE PRESSURE = 300 PSIA (MAX RUMOUT)

" 250 PSIA NORMAL

13  
KRB  
2/5/77

### HOT WATER HEATER (STEAM)

MAXIMUM FLOW = 6.2 GPM

" "  $\Delta P = 5 \text{ PSI}$

NORMAL FLOW = 0.83 GPM

INLET PRESSURE  $\geq 260 \text{ PSIA}$

INLET TEMPERATURE =  $150^\circ\text{F}$

OUTLET TEMPERATURE =  $380^\circ\text{F}$

$$Q = 97,000 \text{ BTU/HR}$$

### ELECTRIC HEATER (SUPPLEMENTAL)

MAXIMUM FLOW = 6.2 GPM

" "  $\Delta P = 5 \text{ PSI}$

NORMAL FLOW = 0.83 GPM

INLET PRESSURE  $\approx 255 \text{ PSIA}$

INLET TEMPERATURE =  $380^\circ\text{F}$

OUTLET TEMPERATURE =  $400^\circ\text{F}$

$$Q = 9,100 \text{ BTU/HR}$$

**SHELL & TUBE**  
**STEAM IN SHELL**

**SHORT TERM DUTY**  
 $Q = 107,000 \text{ BTU/HR}$   
 $T_{IN} = 150^\circ\text{F}$   
 $T_{OUT} = 400^\circ\text{F}$   
FLOW = 0.83 GPM  
-THIS IS THE  
STARTUP MODE

### KNOCK-OUT POT

CAPACITY = 150 GALLONS

DESIGN PRESSURE = 300 PSIA

" TEMPERATURE =  $\frac{450}{400}^\circ\text{F}$

### LIQUID RECEIVER

CAPACITY = 500 GAL. PER PAGE 9

DESIGN PRESSURE = 300 PSIA

" TEMPERATURE =  $400^\circ\text{F}$

KRB  
2/3/77

### VENT CONDENSER

CAPACITY = 24,000 BTU/HR (10% OF MAIN UNIT)

KNOCKOUT DRUM = 10 GALLON CAPACITY

### OPERATING NOTES

1. RELIEF VALUES DISCHARGE TO THE BUILDING SUMP
2. SYSTEM MAKE-UP WATER COMES FROM THE RADWASTE RECYCLE TANK. IF WATER IN THIS SYSTEM BECOMES EXCESSIVELY CONTAMINATED IT IS ROUTED TO THE RAD WASTE SYSTEM FOR PROCESSING - NO PROCESSING WILL BE PERFORMED IN THIS SYSTEM. THE SYSTEM WILL RELY UPON THE CAPACITY OF THE RAD WASTE SYSTEM. EXCESS LIQUIDS WILL ALSO BE DRAINED TO THE LIQUID WASTE SYSTEM.

15  
KRB  
2-3-77

### ENERGY CONSERVATION

HEAT FROM THE SYSTEM WILL BE DUMPED VIA AIR-WATER HEAT EXCHANGERS - TO BE LOCATED IN EITHER THE INLET OR DISCHARGE AIR STREAMS - ELIMINATING THE NEED FOR ADDITIONAL FANS - ONLY PENALTY ASSOCIATED WITH SYSTEM IS NEED TO INSTALL TWO H<sub>x</sub>'S AND ASSOCIATED PIPING - TWO REQ'D BECAUSE BLDG WON'T ALWAYS BE ABLE TO USE, OR NEED INLET AIR PREHEATING - IN ADDITION INLET FANS AREN'T ON VITAL BUS AND A MEANS OF ASSURED HEAT REJECTION VIA THE EXHAUST SYSTEM (UTILIZES VITAL POWER) IS REQUIRED -

MAXIMUM ENERGY AVAILABLE/YEAR -  
ENERGY/CASK =  $\frac{253,000}{1,012,000}$  BTU/HR (4 HRS)  
 $= \frac{253,000}{1,012,000} \times 4 \times 60 \times 60$  BTU  
 $= 1,364,000$  BTU

$$\frac{\text{CASKS/YR}}{50 \frac{\text{CANS}}{\text{WK}}} = \frac{7 \text{ CASKS/WK}}{7 \frac{\text{CANS/CASK}}{}} = \frac{364 \frac{\text{CASKS}}{\text{YR}}}{}$$

$$\begin{aligned} \text{MAX ENERGY/YR} &= 364(1,012,000) \\ &= 3.79 \times 10^8 \text{ BTU/YR} \end{aligned}$$

ASSUME SYSTEM RECOVERS 80%  $\therefore Q_R = 3.01 \times 10^8 \text{ BTU/YR}$   
APPROXIMATE COST OF SYSTEM = \$  
(4-2 CONTROL)  
COST COVERS ONE H<sub>x</sub>, VALVES AND 200' OF 1" PIPE.

16  
KRB  
2-8-77

ENERGY CONSERVATION PAYOFF WILL HAVE TO  
OFFSET THE OPERATING AND SAFETY AND MAINTENANCE  
PROBLEMS ASSOCIATED WITH A DUAL HEAT REJECTION  
SYSTEM.

90029112

PP-80

2-7-77

KRB

1

## CASK COOLING SYSTEM

### HEAT RECOVERY MODE

#### Systems

1. Baseline - heat recovery is utilized for the RT building to preheat inlet air with via a water loop from the building discharge.
2. Heat Recovery - the cask cooling system would supplement the above recovery system by providing heat to the water system.

#### Assumptions

1. The cooling system is a highly variable source of heat with complete dependence upon the rate of waste receipt.
2. Building heating (RH bldg) is expected to occur over only a 4 month period per year, further the occurrence of waste heat need and availability is assumed to be only 50% of the time. Therefore the

2-7-77

KRB  
2

waste heat recovery will represent only  $\frac{1}{6}$ th of the annual energy available from the system.

### Calculations

From 2-3-77 Calculations, page 15,

$$\text{Max Energy /year} = 3.79 \times 10^8 \text{ BTU}$$

$$\text{Recoverable} = \frac{1}{6} (\text{Max})$$

$$= \underline{3.79 \times 10^8}$$

6

$$= .63 \times 10^8$$

$$= \underline{\underline{6.3 \times 10^7 \text{ BTU/YR}}}$$

For analysis the baseline system is assumed to be in at \$0 capital cost but it uses energy in the above amount.


The alternative system has a capital cost but utilizes only minimal energy.

82  
90029114

2-7-77  
KRB  
3

The data sheet is attached.

System would look like



SYSTEM WOULD REQUIRE 200' OF 2" PIPE AND  
TWO VALVES, HEAT EXCHANGER AND INSTRUMENTS

AND SPACE - PIPE 4,000

H<sub>x</sub> 3,000

VALVES 500

BLDG SPACES 5,000

SAY \$15,000 TOTAL COST

See Page 10.

2-7-77

KRB  
4

ELECTRICAL ENERGY USED = 1 HP FOR  
 2 MONTHS = 8 WKS ( $\frac{168 \text{ HRS}}{\text{WK}}$ ) 1 HP ( $\frac{.7457 \text{ KW}}{\text{HP}}$ )

$$= 1008 \text{ KWHR /YEAR}$$

$$\text{CONSUMPTION} = (1008 \frac{\text{KWHR}}{\text{YEAR}}) \frac{3415 \frac{\text{BTU}}{\text{KWHR}}}{\text{KWHR}} \\ = 3.69 \times 10^6 \text{ BTU/YR}$$

### COST OF ENERGY

FUEL OIL FOR STEAM = \$.35/GALLON

ELECTRICITY = \$0.016/kW + 4.25 DEMAND

### STEAM COST

STEAM 1390 BTU/LB

$$\text{LBS STEAM} = \frac{6.3 \times 10^7 \frac{\text{BTU}}{\text{YR}}}{1.39 \times 10^3 \frac{\text{BTU}}{\text{LB}}} \\ = 4.5 \times 10^4 \text{ LB/YR}$$

FUEL OIL BURNED TO CREATE STEAM

$$\text{GALLONS OIL} = \frac{6.3 \times 10^7 \text{ BTU/YR}}{1.39 \times 10^6 \frac{\text{BTU}}{\text{GAL}}} \\ = 4.5 \times 10^2 \\ = 450 \text{ GAL/YR} \\ = \$157/\text{YR}$$

84

CH10000

90029116

2-7-77  
KRB  
5

### COST OF STEAM / $10^6$ BTU

OIL = \$0.35/GALLON

1 GALLON = 138,700 BTU

$$10^6 \text{ BTU} = \frac{10^6}{1.39 + 5} \quad (.35)$$

$$= 2.52$$

ASSUME COST = \$5.00 TO TAKE INTO  
ACCOUNT C&M, ETC ON STEAM PLANT

## COST OF ELECTRICITY / $10^6$ BTU

COST OF ELECTRICITY IS BASED ON HEAT  
AVAILABLE FROM 1 KW HR |  $1 \text{ KWHR} = 3415 \text{ BTU}$   
COST OF 1 KWHR = \$0.016

$$10^6 \text{ BTU} = \frac{10^6}{3.415^{+3}} (.016) = \underline{\underline{293 \text{ KWTS}}}$$

$$= .293^{+3} (.016)$$

$$= \$4.68 \text{ PER } 10^6$$

TOTAL = 4.68 + 4.25 = \$ 8.93

2-7-77

KPB

6

COSTS

HEAT EXCHANGER \$ 25 /FT<sup>2</sup>  
PIPE \$ 5.00 / FT  
VALVES \$ 55.00 EACH

H <sub>x</sub> = 100FT <sup>2</sup> (\$25)	2500
PIPE = 200' (\$5)	1000
VALVES = \$ 55 (6)	<u>330</u>
	3830
CENTINGENCY	<u>1200</u>
TOTAL	= 5030

DEMAID \$1,200.00/MONTH  
PAID ON 10/10/1977

511400

90029118

86

Life cycle cost calculations run on LIFCY1 for various assumptions on every saved and cost of energy are attached. In all cases the payoff period is  $> 25$  years. Therefore the heat recovery systems considered for this system over and above those utilized in the basic design are uneconomic and will not be utilized in the WIPP design

77/02/08, 10.11.32.  
PROGRAM LIFCY1

-----  
\$\$\$\$ LIFE-CYCLE COST COMPARISONS \$\$\$

\*\*INPUT DATA\*\*

BLDG: RH  
PROJ. DIR. NO.: WIPP CONCEPTUAL DESIGN  
LOCATION: CASK COOLING  
DESIGNER: K. BROWN #4

COST OF ELECTRICAL ENERGY USED, PER MILLION BTU = \$8.9300  
COST OF STEAM, GAS OR OTHER ENERGY USED, PER MBTU = \$7.2000  
YEARLY ESCALATION RATE FOR ELECTRICITY IS 5.7 %  
YEARLY ESCALATION RATE FOR STEAM, GAS OR OIL IS 8.0 %  
YEARLY DISCOUNT RATE IS 8.0 %  
NUMBER OF ALTERNATIVES BEING CONSIDERED ARE 2 ALTERNATES

\*\*\*RESULTS OF ECONOMIC STUDY\*\*\*

ALTERNATE NO. 1 DATA (BASELINE)

INSTALLATION FIRST COST.....	\$0.00
ANNUAL O & M COST (LESS ENERGY)....	\$0.00
ELECTRICAL ENERGY USED.....	0 MILLION BTU
STEAM, GAS AND/OR OIL USED.....	63 MILLION BTU
ECONOMIC LIFE.....	25 YEARS

RESULTS

TOTAL FIRST YEAR ENERGY COST IS	\$453.60
TOTAL ANNUALIZED COST IS	\$1,062.32
TOTAL PRESENT WORTH IS	\$11,340.00

ALTERNATE NO. 2 DATA (HEAT RECOVERY)

INSTALLATION FIRST COST.....	\$10,000.00
ANNUAL O & M COST (LESS ENERGY)....	\$200.00
ELECTRICAL ENERGY USED.....	3.7 MILLION BTU
STEAM, GAS AND/OR OIL USED.....	0 MILLION BTU
ECONOMIC LIFE.....	25 YEARS

RESULTS

TOTAL FIRST YEAR ENERGY COST IS	\$38.04
TOTAL ANNUALIZED COST IS	\$1,195.99
TOTAL PRESENT WORTH IS	\$12,766.90

\*\*\*DISCOUNTED PAYBACK PERIODS\*\*\*

TO GO FROM ALT 1\* TO ALT 2 PAYOFF PERIOD IS GREATER THAN 25 YEARS!!!!  
SAVINGS/INVESTMENT RATIO IS .857  
ENERGY SAVINGS IS 148,249 BTU PER ANNUAL DISCOUNTED INVESTMENT DOLLAR.

\* - LOWEST INCREMENTAL INSTALLATION FIRST COST ALTERNATE

-----  
SRU 1,230 UNITS.

RUN COMPLETE.

77/02/08, 10.15.09.  
PROGRAM : LIFCY1

-----  
\$\$\$\$ LIFE-CYCLE COST COMPARISONS \$\$\$\$\br/>-----

\*\*INPUT DATA\*\*

BLDG: RH  
PROJ. DIR. NO.: WIPP CONCEPTUAL DESIGN  
LOCATION: CASK COOLING  
DESIGNER: K. BROWN #3

COST OF ELECTRICAL ENERGY USED, PER MILLION BTU = \$4.6800  
COST OF STEAM, GAS OR OTHER ENERGY USED, PER MBTU = \$7.2000  
YEARLY ESCALATION RATE FOR ELECTRICITY IS 5.7 %  
YEARLY ESCALATION RATE FOR STEAM, GAS OR OIL IS 8.0 %  
YEARLY DISCOUNT RATE IS 8.0 %  
NUMBER OF ALTERNATIVES BEING CONSIDERED ARE 2 ALTERNATES

\*\*\*RESULTS OF ECONOMIC STUDY\*\*\*

ALTERNATE NO. 1 DATA (BASELINE)

INSTALLATION FIRST COST.....	\$0.00
ANNUAL D & M COST (LESS ENERGY)....	\$0.00
ELECTRICAL ENERGY USED.....	0 MILLION BTU
STEAM, GAS AND/OR OIL USED.....	63 MILLION BTU
ECONOMIC LIFE.....	25 YEARS

RESULTS

TOTAL FIRST YEAR ENERGY COST IS	\$453.60
TOTAL ANNUALIZED COST IS	\$1,062.32
TOTAL PRESENT WORTH IS	\$11,340.00

ALTERNATE NO. 2 DATA (HEAT RECOVERY)

INSTALLATION FIRST COST.....	\$10,000.00
ANNUAL D & M COST (LESS ENERGY)....	\$200.00
ELECTRICAL ENERGY USED.....	3.7 MILLION BTU
STEAM, GAS AND/OR OIL USED.....	0 MILLION BTU
ECONOMIC LIFE.....	25 YEARS

RESULTS

TOTAL FIRST YEAR ENERGY COST IS	\$17.32
TOTAL ANNUALIZED COST IS	\$1,167.81
TOTAL PRESENT WORTH IS	\$12,466.14

\*\*\*DISCOUNTED PAYBACK PERIODS\*\*\*

TO GO FROM ALT 1\* TO ALT 2 PAYOFF PERIOD IS GREATER THAN 25 YEARS!!!!  
SAVINGS/INVESTMENT RATIO IS .887  
ENERGY SAVINGS IS 148,249 BTU PER ANNUAL DISCOUNTED INVESTMENT DOLLAR.

\* - LOWEST INCREMENTAL INSTALLATION FIRST COST ALTERNATE

-----  
SRU 1.228 UNTS.

RUN COMPLETE.

90029121

90

PROGRAM LIFCY1

\$\$\$\$ LIFE-CYCLE COST COMPARISONS \$\$\$

\*\*INPUT DATA\*\*

BLDG: RH  
PROJ. DIR. NO.: WIPP CONCEPTUAL DESIGN

LOCATION: CASK COOLING  
DESIGNER: K. BROWN #2

COST OF ELECTRICAL ENERGY USED, PER MILLION BTU = \$4.6800  
COST OF STEAM, GAS OR OTHER ENERGY USED, PER MBTU = \$5.0000  
YEARLY ESCALATION RATE FOR ELECTRICITY IS 5.7 %  
YEARLY ESCALATION RATE FOR STEAM, GAS OR OIL IS 8.0 %  
YEARLY DISCOUNT RATE IS 8.0 %  
NUMBER OF ALTERNATIVES BEING CONSIDERED ARE 2 ALTERNATES

\*\*\*RESULTS OF ECONOMIC STUDY\*\*\*

ALTERNATE NO. 1 DATA (BASELINE)

INSTALLATION FIRST COST.....	\$,00
ANNUAL D & M COST (LESS ENERGY)....	\$,00
ELECTRICAL ENERGY USED.....	0 MILLION BTU
STEAM, GAS AND/OR OIL USED.....	63 MILLION BTU
ECONOMIC LIFE.....	25 YEARS

RESULTS

TOTAL FIRST YEAR ENERGY COST IS	\$315.00
TOTAL ANNUALIZED COST IS	\$737.72
TOTAL PRESENT WORTH IS	\$7,875.00

ALTERNATE NO. 2 DATA (HEAT RECOVERY)

INSTALLATION FIRST COST.....	\$10,000.00
ANNUAL D & M COST (LESS ENERGY)....	\$200.00
ELECTRICAL ENERGY USED.....	3.7 MILLION BTU
STEAM, GAS AND/OR OIL USED.....	0 MILLION BTU
ECONOMIC LIFE.....	25 YEARS

RESULTS

TOTAL FIRST YEAR ENERGY COST IS	\$17,32
TOTAL ANNUALIZED COST IS	\$1,167.81
TOTAL PRESENT WORTH IS	\$12,466.14

\*\*\*DISCOUNTED PAYBACK PERIODS\*\*\*

TO GO FROM ALT 1\* TO ALT 2 PAYOFF PERIOD IS GREATER THAN 25 YEARS!!!!  
SAVINGS/INVESTMENT RATIO IS .541  
ENERGY SAVINGS IS 148,249 BTU PER ANNUAL DISCOUNTED INVESTMENT DOLLAR.

\* - LOWEST INCREMENTAL INSTALLATION FIRST COST ALTERNATE

SRU 1,206 UNTS.

RUN COMPLETE.

RUN

77/02/08, 10.08.07.  
PROGRAM LIFCY1

-----  
\$\$\$\$ LIFE-CYCLE COST COMPARISONS \$\$\$\$\br/>-----

♦♦INPUT DATA♦♦

BLDG: RH  
PROJ. DIR. NO.: WIPP CONCEPTUAL DESIGN  
LOCATION: CASK COOLING  
DESIGNER: K. BROWN #1

COST OF ELECTRICAL ENERGY USED, PER MILLION BTU = \$8.9300  
COST OF STEAM, GAS OR OTHER ENERGY USED, PER MBTU = \$5.0000  
YEARLY ESCALATION RATE FOR ELECTRICITY IS 5.7 %  
YEARLY ESCALATION RATE FOR STEAM, GAS OR OIL IS 8.0 %  
YEARLY DISCOUNT RATE IS 8.0 %  
NUMBER OF ALTERNATIVES BEING CONSIDERED ARE 2 ALTERNATES

\*\*\*RESULTS OF ECONOMIC STUDY\*\*\*

ALTERNATE NO. 1 DATA (BASELINE)

INSTALLATION FIRST COST.....	\$0.00
ANNUAL D & M COST (LESS ENERGY)....	\$0.00
ELECTRICAL ENERGY USED.....	0 MILLION BTU
STEAM, GAS AND/OR OIL USED.....	63 MILLION BTU
ECONOMIC LIFE.....	25 YEARS

RESULTS

TOTAL FIRST YEAR ENERGY COST IS	\$315.00
TOTAL ANNUALIZED COST IS	\$737.72
TOTAL PRESENT WORTH IS	\$7,875.00

ALTERNATE NO. 2 DATA (HEAT RECOVERY)

INSTALLATION FIRST COST.....	\$10,000.00
ANNUAL D & M COST (LESS ENERGY)....	\$200.00
ELECTRICAL ENERGY USED.....	3.7 MILLION BTU
STEAM, GAS AND/OR OIL USED.....	0 MILLION BTU
ECONOMIC LIFE.....	25 YEARS

RESULTS

TOTAL FIRST YEAR ENERGY COST IS	\$33.04
TOTAL ANNUALIZED COST IS	\$1,195.99
TOTAL PRESENT WORTH IS	\$12,766.90

\*\*\*DISCOUNTED PAYBACK PERIODS\*\*\*

TO GO FROM ALT 1\* TO ALT 2 PAYOFF PERIOD IS GREATER THAN 25 YEARS!!!!  
SAVINGS/INVESTMENT RATIO IS .511  
ENERGY SAVINGS IS 148,249 BTU PER ANNUAL DISCOUNTED INVESTMENT DOLLAR.

\* - LOWEST INCREMENTAL INSTALLATION FIRST COST ALTERNATE

-----  
SRU 1,200 UNTS.

RUN COMPLETE.

22

90029123

HOLMES & HARVER, INC.  
ENGINEERS - CONSTRUCTORS

## PHONE-TALK

TO: K. R. Brown

Date: September 3, 1976

FROM: B. Steinbaugh, Sandia Labs. *VKB*Page 1 of 1

SUBJECT: WIPP - ENERGY COSTS AND WATER SUPPLY

Bob called with the following energy costs:

Natural Gas  
Fuel Oil  
Electricity

Cost/1,000,000 BTU *use*  
 Pres. 85 - 1.50/10<sup>6</sup> BTU  
 \$ 0.40 - .33. - .35 gal  
 2.14 - .0134 .016/<sub>kw</sub> (4.25 demand  
 Electricity 6.74 - (3.90) charge)  
 (3.90)

Sandia currently favors the Double Eagle water system but would like to carry both Double Eagle and Carlsbad through the cost estimate phase of the project.

I requested that Bob investigate for any available rainfall data in the vicinity of the site for use in hydrology studies.

Drawings of the Super Tiger and 600 series ATMX cars are being sent in the mail to F&S and H&N.

KRB/bl

cc: L. Scully, Sandia Labs.  
 B. Steinbaugh, Sandia Labs.  
 J. Ash, Fenix & Scisson  
 M. Klatskin  
 A. Dunham

*Co<sub>2</sub>/  
 19.00/ton at mine*

9344

90029124

ERDA STANDA 3TU CONVERSION FACTOR  
FOR ENERGY CONSERVATION REPORTING (1)

<u>Form of Energy</u>	<u>Btu Content</u>	<u>Btu x 10<sup>9</sup> per Reporting Unit</u>
Electricity (2)	11,600 Btu/KWH	0.0116 per MWH (Megawatt hour)
Fuel Oil	138,700 Btu/Gal.	0.1387 per 1000 Gal.
Natural Gas	1,031 Btu/C.F.	0.001031 per 1000 C.F.
LPG (3)	95,500 Btu/Gal.	0.0955 per 1000 Gal.
Coal	24,580,000 Btu/Short ton	0.2458 per short ton
Other (Examples) - Steam (4)	1,390 Btu/Lb.	0.00139 per 1000 Lbs.
- Chilled Water (5)	24,000 Btu/Ton-hour	0.024 per 1000 ton-hours
- Methanol	63,500 Btu/Gal.	0.0635 per 1000 Gal.
Automotive Gasoline	125,000 Btu/Gal.	0.125 per 1000 Gal.
Diesel	138,700 Btu/Gal.	0.1387 per 1000 Gal.
Aviation Gasoline	125,000 Btu/Gal.	0.125 per 1000 Gal.
Jet Fuel	130,000 Btu/Gal.	0.130 per 1000 Gal.

- (1) The use of different conversion factors is permitted only where such factors are identified and justified, and is subject to FCM approval.
- (2) Electricity - Assumes 10,536 Btu per KWH generated at station and 9% line loss.
- (3) Includes Propane and Butane.
- (4) Assumes 1000 Btu per pound of steam generated at boiler plant, 80% boiler efficiency at 11% line loss.
- (5) Assumes 12,000 Btu per ton-hour, and overall efficiency and 11% line loss.

90029125

95-96

## HVAC CALCULATIONS

These calculations are supplemented  
by the HVAC Energy Study

2-7-77

\*\*\*LIFCY1\*\*\*

INPUT DATA

4030 DATA "	TRU Waste Facility	"	Bldg. Name - K\$
4040 DATA "	Carlsbad	"	Location - JS
4050 DATA "	Brown	"	Proj. Dir. No. - PS
4060 DATA "	Katskita Brown	"	Designer - DS
4070 DATA	\$ 8.93 4.6B	Cost of Electricity, Per MBTU - C2	<del>2040</del>
4080 DATA	\$ 5.00 (7.20)	Cost of Steam, gas and/or oil, per MBTU-C3	
4090 DATA	5.7%	Annual Electricity Escalation Rate, % - R1	
4100 DATA	<del>6.5 10%</del> Oil - 8%	Annual Steam, Gas or Oil Escalation Rate, % - R2	
4110 DATA	8%	Annual Cost of Money (discount rate), % - I	
4120 DATA	2	Number of Alternates being considered - H	

ALTERNATE NO. 1

4130 DATA "	Baseline	"	Alternate Name - AS
4140 DATA	0		Installation First Cost - C
4150 DATA	0		Annual O&M Cost (less energy) - M
4160 DATA	—		Electrical Energy Used, MBTU - E
4170 DATA	63		Steam, Gas and/or Oil used, MBTU - S $63^{+6}$
4180 DATA	25		Economic Life, Years - N

ALTERNATE NO. 2

4190 DATA "	Heat Recovery	"	Alternate Name - AS
4200 DATA	<del>15,000</del> 10,000		Installation First Cost - C
4210 DATA	<del>100</del> 200		Annual O&M Cost (less energy) - M
4220 DATA	3.69 <sup>+6</sup>		Electrical Energy Used, MBTU - E
4230 DATA	0		Steam, Gas and/or Oil used, MBTU - S
4240 DATA	25		Economic Life, Years - N

99-100

90029127

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_  
 APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

## HOLMES &amp; NARVER, INC.

ENGINEERS-CONSTRUCTORS  
 400 E ORANGETHORPE AVE.  
 ANAHEIM, CALIF. 92801

JOB NO. 8251.00  
 SHEET 1 OF 3  
 BY MK DATE 1-20-77

TITLE WIPP-HVAC (High & Low Level Facilities)

## Design Criteria (Work Areas)

Summer	Outside	99°F	
	Inside	82°F	ΔT = 17°F
Winter	Outside	21°F	
	Inside	65°F	ΔT = 44°F
	(Offices)		
Winter	Inside	72°	ΔT = 51°F

## "U" Factors

Walls	0.097
Roof	0.08
Slab	0.16

## Total Equiv. Temp Dif. Correction

$$\text{Inside } 75 - 82 = -7^\circ \quad \text{outside } 99 - 85 = 14^\circ$$

$$\text{total correction} = 14 - 7 = 7^\circ F$$

## High Level Fac. (High Bay only)

$$\text{summer Inside} = \frac{T_o + T_i}{2} = \frac{99 + 82}{2} = 90.5 \quad \Delta T = 8.5^\circ F$$

$$\text{winter Inside} = \frac{T_o + T_i}{2} = \frac{21 + 65}{2} = 43 \quad \Delta T = 22.0^\circ F$$

## "U" Factor

$$\text{Wall} \quad 0.5025$$

## TETD Correction

$$\text{Inside } 75 - 90.5 = -15.5 \quad \text{outside } 99 - 85 = 14$$

$$\text{total correction} = 14 - 15.5 = -1.5^\circ F$$

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_

APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

**HOLMES & NARVER, INC.**ENGINEERS-CONSTRUCTORS  
400 E. ORANGETHORPE AVE.  
ANAHEIM, CALIF. 92801JOB NO. 8251-00SHEET 2 OF 3BY MRDATE 1-20-77TITLE WIPP - HVAC

## Construction Data - "U" Factors

## Exterior Wall

	$f_o$	0.17
Concrete (24")		2.28
	$f_i$ (2)	1.36
Block (12" L.W. w/filled voids)		5.82
	$f_i$	0.68
		<u>10.31</u>

$$U = \frac{1}{10.31} = 0.09699$$

## Roof

	$f_o$	0.25
Roofing		0.33
Insulation (Rigid-3 1/2")		9.68
Slab (Concrete-12")		1.32
	$f_i$	0.92
		<u>12.50</u>

$$U = \frac{1}{12.50} = 0.08$$

## Exterior Wall (High Level-High Bay)

	$f_o$	0.17
Concrete (12")		1.14
	$f_i$	0.68
		<u>1.99</u>

$$U = \frac{1}{1.99} = 0.5025$$

90029129

102

BY R. SAWYER

CHECKED _____	DATE _____	HOLMES & NARVER, INC.		JOB NO. <u>8251.00</u>
APPROVED _____	DATE _____	ENGINEERS-CONSTRUCTORS 400 E. ORANGETHORPE AVE. ANAHEIM, CALIF. 92801		SHEET <u>3</u> OF <u>3</u>
TITLE <u>WIPP - HVAV</u>				BY <u>MK</u> DATE <u>1-20-77</u>

Multiplying Factors @ 4:00 P.M. Sun Time

NE Wall	0.09699 (14+7)	2.037
NW Wall	0.09699 (13+7)	1.94
SE Wall	0.09699 (15+7)	2.134
SW Wall	0.09699 (15+7)	2.134
SW Door	0.65 (27+7)	22.1
Roof	0.08 (23+7)	2.4

Winter

Wall	0.09699 (44)	4.267
Roof	0.08 (44)	3.52

High Level (High Bay) @ 4:00 P.M. Sun Time

NE Wall	0.5025 (14-1.5)	6.27
NW Wall	0.5025 (13-1.5)	5.779
NW Door	1.0 (21-1.5)	19.5
SE Wall	0.5025 (15-1.5)	6.784
SE Door	1.0 (21-1.5)	19.5
SW Wall	0.5025 (15-1.5)	6.784
Roof	0.08 (23-1.5)	1.72

Winter

Wall	0.5025 (22)	11.055
Roof	0.08 (22)	1.76

103-104

90029130

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_  
 APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

**HOLMES & NARVER, INC.**  
 ENGINEERS-CONSTRUCTORS  
 400 E. ORANGETHORPE AVE  
 ANAHEIM, CALIF. 92801

JOB NO. 8251.00  
 SHEET 1 OF 6  
 BY MK DATE 1-20-77

TITLE TRU Waste Facility

### Internal Heat Gain Assumptions

#### Unloading/Loading Area

Lighting	4 watts/sq.ft.	= 13.65 BTU / #
Drums	320 @ 10W	= 10,052
Hoists (50% use.)	2@40 HP = $\frac{40 \times 750 \times 3.413}{2}$	= 102,390
People	10 @ 300 BTU (sens)	= 3,000

#### Inventory/Prep Area

Lighting	4 watts/sq.ft.	= 13.65 BTU / #
Drums	1300 + 320 = 1620 @ 10 W	= 50,890
Forklifts (75% use.)	2@20 ton = $\frac{40 \times 3 \times 750 \times 3.413}{1.234}$	= 230,262
People	25 @ 300 BTU (sens.)	= 7,500

#### Overpack/Repair/Lab

Lighting	4 watts/sq.ft.	= 13.65 BTU / #
Drums	60 @ 10W	= 1885
Hoist (50% use.)	40 HP = $\frac{40 \times 750 \times 3.413}{2}$	= 51,195
People	5 @ 300 BTU (sens.)	= 1,500

#### Office Area

Lighting	3 watts/sq.ft.	= 10.24
People	10 @ 250 BTU (sens.)	= 2,500

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_  
 APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

**HOLMES & NARVER, INC.**  
 ENGINEERS-CONSTRUCTORS  
 400 E. ORANGETHORPE AVE.  
 ANAHEIM, CALIF. 92801

JOB NO. 8251.00  
 SHEET 2 OF 6  
 BY MK DATE 1-20-77

TITLE TRU Waste Facility

Unloading / Loading Area

	Area	Factor	Cooling Factor	Heating
NE Wall	$297 \times 40 = 11,880$	2.037	24,200	4.267 50,692
NW Wall	$(54 \times 40) - 324 = 1836$	1.94	3,562	4.267 7,834
NW Door	$18 \times 18 = 324$	$\frac{17}{2} = 8.5$	2,754	$4\frac{1}{2} - 22$ 7,128
SE Wall	$(54 \times 40) - 972 = 1188$	2.134	2,535	4.267 5,069
SE Door	$3 @ 18 \times 18 = 972$	8.5	7,880	22 20,394
Roof	$297 \times 54 = 16,038$	2.4	38,491	3.52 56,454
Lights	② 4W/b	13.65	218,919	
Motors	2 @ 40HP		102,390	
Drums	320 @ 10W		10,052	
People	10 @ 300 BTU (Sens)		3,000	
OSA (w/recov.)	21,353 \$	6x1.08	138,237	$15.4 \times 1.08$ 354,810
			<b>552,020</b>	<b>502,351</b>

106

90029132

CHECKED _____	DATE _____	<b>HOLMES &amp; NARVER, INC.</b>		JOB NO. <u>8251.00</u>
APPROVED _____	DATE _____	ENGINEERS-CONSTRUCTORS 400 E. ORANGETHORPE AVE. ANAHEIM, CALIF. 92801		SHEET <u>3</u> OF <u>6</u>
TITLE <u>TRV Waste Facility</u>				BY <u>MK</u> DATE <u>1-20-77</u>

Inventory & Preparation

	Area	Factor	Cooling	Factor	Heating
NW Wall	64 x 24	1536	1.94	2980	4.267 6554
SW Wall	100 x 24	2400	2.134	5122	4.267 10241
SE Wall	160 x 24	3840	2.134	8195	4.267 16385
Roof	37,000 ft <sup>2</sup>	37,000	2.4	88800	3.52 130,240
Lights	24 w/ft <sup>2</sup>	37,000	13.65	505050	
Motors	(2-20 ton diesel)	@ 75% usage		230262	
Drums	1300 + 320 @ 10 w			50890	
People	25 @ 300 BTU (seats)			7500	
OSA (w/recov.)	120,000 ft <sup>2</sup>		6 x 1.08	777,600	15.4 x 108 1,995,840
				<b>1,676,400</b>	<b>2,159,240</b>

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_  
 APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

**HOLMES & NARVER, INC.**  
 ENGINEERS-CONSTRUCTORS  
 400 E. ORANGETHORPE AVE.  
 ANAHEIM, CALIF. 92801

JOB NO. 8251.00  
 SHEET 4 OF 6  
 BY MK DATE 1-20-77

TITLE TRU Waste Facility

Overpack & Repair & Lab

	Area	Factor	Cooling Factor	Heating
NW Wall	96x40	3840	1.94	7,450
SW Wall	33x40	1320	2.134	2,817
SW Wall	33x25	825	2.134	1,760
SE Wall	64x15	960	2.134	2,049
Roof		5230	2.4	12,552
Lights	② 4w / <del>10w</del>	5230	13.65	71,390
Motors	40 HP (50% USE)			51,195
Drums	60 @ 10w			2,048
People	5 @ 300 BTU(Sens.)			1,500
OSA (w/recov)	10,460	6x1.08	67,780	15.4x1.08 173,970
			<b>202,541</b>	<b>221,966</b>

90029134

108

CHECKED _____	DATE _____	<b>HOLMES &amp; NARVER, INC.</b>		JOB NO. <u>8251-00</u>
APPROVED _____	DATE _____	ENGINEERS-CONSTRUCTORS 400 E. ORANGETHORPE AVE. ANAHEIM, CALIF. 92801		SHEET <u>5</u> OF <u>6</u>
TITLE <u>TRU Waste Facility</u>				BY <u>MK</u> DATE <u>1-20-77</u>

Office Area

	Area	Factor	Cooling Factor	Heating
SW Wall	130x24	3120	2.134	6,658 4.267 13,313
SW Doors	10x7=	70	17	1190 44 3,080
Lights	5290 <sup>#</sup> @ 3w			54,164
People	10 @ 250 BTU (sens)			2,500
OSA - 10% of total air = 700\$		17x1.08	12,852 44x1.08	32,264
			<u>72,364</u>	<u>48,657</u>

90029135

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_  
 APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

**HOLMES & NARVER, INC.**

ENGINEERS-CONSTRUCTORS  
 400 E ORANGETHORPE AVE  
 ANAHEIM, CALIF. 92801

TITLE TRU Waste Facility JOB NO. 8251.00  
 SHEET 6 OF 6 BY MK DATE 1-20-77

Summary of Heat/Kool Loads (w/ records)

	Cooling	Heat(day)	Heat(night)
Loading Area	552,020	505,351	43,576
Inv./Prep. Area	1,676,400	2,159,240	665,698
Overpack/Lab	202,541	221,966	34,833
Office Area	77,364		8,007
	<u>2,430,961</u>	<u>2,886,557</u>	<u>736,100</u>

21183000

110

90029136

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_  
 APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

**HOLMES & NARVER, INC.**  
 ENGINEERS-CONSTRUCTORS  
 400 E ORANGETHORPE AVE.  
 ANAHEIM, CALIF. 92801

JOB NO. 8251.00  
 SHEET 1 OF 6  
 BY MK DATE 2-14-72

TITLE WIPP - HVAC - RH Facility

### Internal heat gain assumptions

#### Preparation & Decon

Lighting	- 4 watts/sq. ft.	- $3888^{\Phi} \times 13.652 =$	53 079
Casks	- 48 cans @ 3.5 KW	- $48 \times 11945.5 =$	573 384
Hoists	- 160 HP @ 10% usage	- $160 \times 3072 \times .1 =$	49 152
Carts	- 2 @ 10 HP @ 100% usage	- $20 \times 3072 \times 1.0 =$	61 440
Turntable	- 5 HP @ 10% usage	- $5 \times 3072 \times .1 =$	1 536
Water Wash	- 20 HP @ 50% usage	- $20 \times 3072 \times .5 =$	30 720
People	- 4 working @ 300 BTU sensible	=	1 200
	2 mod. act. @ 250 BTU sensible	=	500
			<u>771 011</u>

#### Hot Cell

Lighting	- 4 watts/sq. ft.	- $1680^{\Phi} \times 13.652 =$	22 935
Casks	- 8 cans @ 100% + 10 @ 50%	- $13 \times 3.5 \text{ KW} =$	155 291
Hoist	- 40 HP @ 100% usage	- $40 \times 3072 \times 1.0 =$	122 880
Elevator	- 25 HP @ 10% usage	- $25 \times 3072 \times .1 =$	7 680
Misc. Motors	- 10 HP @ 50% usage	- $10 \times 3072 \times .5 =$	15 360
			<u>324 146</u>

#### Decon

Lighting	- 4 watts/sq. ft.	- $352^{\Phi} \times 13.652 =$	4 805
Casks	- 2 cans @ 3.5 KW	- $2 \times 11945.5 =$	23 891
Pumps	- 2 @ 60 HP @ 100% usage	- $120 \times 3072 \times 1.0 =$	368 640
Brushes	- 2 @ 25 HP @ 100% usage	- $50 \times 3072 \times 1.0 =$	153 600
			<u>550 936</u>

total 1,646,093 BTU

90029137

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_  
APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

**HOLMES & NARVER, INC.**  
ENGINEERS-CONSTRUCTORS  
400 E. ORANGETHORPE AVE.  
ANAHEIM, CALIF. 92801

JOB NO. 8251-00  
SHEET 2 OF 6  
BY MK DATE 2-14-77

TITLE WIPP - HVAC - RH Facility

## Preparation & Decon

	Area ft <sup>2</sup>	Factor	Cooling Factor BTU	Heating BTU
SE Wall	54 x 50 = 2700	2.134	5761	4.267
Roof	54 x 72 = 3888	2.4	9331	3.52
Lights	3888	13.652	53079	
Casks	48 x 11945.5		573384	
Hoists	160 x 3072 x .1		49152	
Carts	20 x 3072 x 1.0		61440	
Turntable	5 x 3072 x .1		1536	
Water Wash	20 x 3072 x .5		30720	
People	1200 + 500		1700	
OSA (w/recovery)	19,440 \$	6 x 1.08	<u>125971</u>	<u>15.4 x 1.08</u>
			912074	323326
				348532

117

90029138

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_  
 APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

**HOLMES & NARVER, INC.**  
 ENGINEERS-CONSTRUCTORS  
 400 E. ORANGETHORPE AVE.  
 ANAHEIM, CALIF. 92801

JOB NO. 8251.00  
 SHEET 3 OF 6  
 BY MK DATE 2-14-77

TITLE WIPP - HVAC - RH Facility

Hot Cell

	Area in	Factor	Cooling BTU	Factor	Heating BTU
SE Wall	28x48 = 1344	2.134	2868	4.267	5735
Roof	28x60 = 1680	2.4	4032	3.52	5914
Lights	1680	13.652	22935		
Casks	13 x 11945.5		155291		
Hoist	40 x 3072 x 1.0		122880		
Elevator	25 x 3072 x .1		7680		
Misc. Motors	10 x 3072 x .5		15360		
OSA	8,064 5	6 x 1.08	52254	15.4 x 1.08	134120
			383300		145769

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_  
 APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

**HOLMES & NARVER, INC.**  
 ENGINEERS-CONSTRUCTORS  
 400 E. ORANGETHORPE AVE.  
 ANAHEIM, CALIF. 92801

JOB NO. 8251.00  
 SHEET 4 OF 6  
 BY MK DATE 2-14-77

TITLE WIPP - HVAC - RH Facility

Decon

		Area ft <sup>2</sup>	Factor	Cooling BTU	Factor	Heating BTU
Lights	$22 \times 16$	= 352	13.652	4805		
Casks	$2 \times 11$	945.5		23891		
Pumps	$120 \times 30$	72		368640		
Brushes	$50 \times 30$	72		153600		
OSA (w/recovery)	9,000	\$	$6 \times 1.08$	<u>58,320</u>	$15.4 \times 1.08$	<u>149,688</u>
				<u>609,256</u>		<u>149,688</u>

114

90029140

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_  
 APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

**HOLMES & NARVER, INC.**  
 ENGINEERS-CONSTRUCTORS  
 400 E. ORANGETHORPE AVE.  
 ANAHEIM, CALIF. 92801

TITLE WIPP - HVAC - RH Facility

JOB NO. 82.51.00  
 SHEET 5 OF 6  
 BY MK DATE 2-14-77

## Shipping & Receiving

Area	Factor	Cooling	Factor	Heating
------	--------	---------	--------	---------

NW Wall

SW Wall

SW Door

NE Wall

NE Door

Roof

Lights

Hoist

People

OSA (w/recovery) 23,466 \$

(No Refrig.)

90029141

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_

APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

TITLE WIPD-HVAC-RH Facility

## HOLMES &amp; NARVER, INC.

ENGINEERS-CONSTRUCTORS  
400 E. ORANGETHORPE AVE.  
ANAHEIM, CALIF. 92801

JOB NO. 8251.00

SHEET 6 OF 6

BY MR DATE 2-14-77

## Offices &amp; Control Room

	Area	Factor	Cooling	Factor	Heating
	#		BTU		BTU
NW Wall	16' x 15'	2505	1.94	4860	4.267
SW Wall	82' x 15'	1230	2.134	2625	4.267
SE Wall	39' x 15'	585	2.134	1248	4.267
Roof	82' x 39'	3198	2.4	7675	3.52
Lights	3198 @ 3 watts/#		10.239	32744	
Equipment	3198 @ 2 watts/#		6.826	21830	
People	10 @ 250 BTU sensible			2500	
OSA	7300\$ @ 10% = 730\$		17 x 1.08	13403	44 x 1.08
				86885	34690
					64380

FAR 800

116

90029142

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_  
 APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

**HOLMES & NARVER, INC.**  
 ENGINEERS-CONSTRUCTORS  
 400 E. ORANGETHORPE AVE.  
 ANAHEIM, CALIF. 92801

JOB NO. 8251.10  
 SHEET 1 OF 1  
 BY MK DATE 11-12-76

TITLE Use of Mine Exh. Air as Heat Sink

Assume maximum mine exh. air = 500,000  $\frac{\text{ft}^3}{\text{min}}$

Assume exhaust air at  $85^\circ\text{F}$  - 50% R.H.  
 (with sprayed coil) =  $73^\circ\text{F}$  - 90% R.H.)

Assume condenser water  $75^\circ\text{F}$  in -  $95^\circ\text{F}$  out =  $20^\circ\text{at}$

Total sink available =  $500,000 \times 20 \times 1.08 = 10,800,000 \text{ BTU}$

Sink required per ton of absorption refrigeration  
 $= 12,000 + 18,000 = 30,000 \text{ BTU}$

$\therefore$  Total sink available =  $\frac{10,800,000}{30,000} = 360 \text{ tons}$

Note: Total facility load approx. 800-900 tons

90029143

## Alternate I

### Central Plant (Chillers - Boilers - Cooling Towers)

1.	3-300 ton chillers @ 37,000 (incl. starters & freight)	111,000
2.	3-300 ton cooling towers @ 5,800 (incl. freight & erection)	17,400
3.	6- 40 HP circulating pumps @ 1450 (freight)	8,700
4.	2- 5,000 * boilers @ 18,000 + controls, cond. ret., blowoff, feedwater 8,250	44,250
5.	3 - converters @ 1500	4,500

#### Buried pipe (3'-6' depth)

6. 3,375' of 8" steel chilled water (insulated) @ 45°-55°F
7. 1,688' of 6" steam (insulated) @ 100 psi
8. 1,688' of 4" condensate return (insulated)

## Alternate II

(Separate cooling &amp; heating each building)

TRU Bldg.

1. 2- 225 ton cent. heat pumps	@ 43,500	87,000
2. 2- 225 ton cooling towers	@ 4,300	8,600
3. 4- 25 HP pumps	@ 1,151	4,604
4. 1 heat exchanger	@ 1,000	1,000
		<u>101,204</u>

RH Bldg.

1. 2- 150 ton cent. heat pumps	@ 38,400	76,800
2. 2- 150 ton cooling towers	@ 3,300	6,600
3. 4- 15 HP pumps	@ 955	3,820
4. 1 heat exchanger	@ 850	850
		<u>88,070</u>

## Administration Bldg.

1. 2- 75 ton recip. heat pumps	@ 20,000	40,000
2. 2- 75 ton cooling towers	@ 2,300	4,600
3. 4- 10 HP pumps	@ 755	3,020
4. 1 heat exchanger	@ 750	750
		<u>48,370</u>

total 237,644

90029145 <sup>120</sup>

## Alternate III

(Central cooling tower + separate cool.& heat. each bldg.)

- |  |        |
|--|--------|
| 1. 3- 300 ton cooling towers @ 5,800   | 17,400 |
| 2. 3 - 50 HP circ. pumps @ 1533  | 4,599  |
| 3. 3,375' of 10" steel buried pipe 80-90°F<br>(wrapped w/minimun insulation) |        |

Plus

### TRU Bldg.

- |  |        |
|--|--------|
| 1. 2-225 ton cent. heat pumps @ 43,500 | 87,000 |
| 2. 2- 25 HP pumps @ 1151               | 2,302  |
| 3. 1-heat x-changer @ 1,000            | 1,000  |

### RH Bldg.

- |   |        |
|---|--------|
| 1. 2- 150 ton cent. heat pumps @ 38,400 | 76,800 |
| 2. 2- 15 HP pumps @ 955                 | 1,910  |
| 3. 1- heat x-changer @ 750              | 850    |

### Admin. Bldg.

- |   |        |
|---|--------|
| 1. 2- 75 ton recip. heat pumps @ 20,000 | 40,000 |
| 2. 2- 10 HP pumps @ 755                 | 1,510  |
| 3. 1- heat x-changer @ 750              | 750    |

卷之三

HORNIG & HORNIG, INC.

CONTINUOUS

KUNLUN JOURNAL

GÖTTSCHE

二

MINTLE 3

*NETS: BLOWET HILL DIRECT COSTS  
NO ACCORDING TO*

WISCONSIN STATE PLATE

ESTATE PLANNING

卷之三

90029147

ITEM	DESCRIPTION	QUANTITY	UNIT PRICE	AMOUNT	ITEM	DESCRIPTION	QUANTITY	UNIT PRICE	AMOUNT	ITEM	DESCRIPTION	QUANTITY	UNIT PRICE	AMOUNT	
1	ESTIMATE SHEET				2	WATER METER (P)				3	PIPE - COATING				
	FOR 100' X 100' TOWER					4	WATER METER (P)				5	COATING TOWER			
	500' TOWER HILL					6	WATER METER (P)				7	COATING TOWER			
	300' COATING TOWER					8	WATER METER (P)				9	COATING TOWER			
	100' PIPE COATING					10	WATER METER (P)				11	COATING TOWER			
	5000# / 4" BOLTS					12	WATER METER (P)				13	COATING TOWER			
	CONNECTIONS					14	WATER METER (P)				15	COATING TOWER			
						16	WATER METER (P)				17	COATING TOWER			
						18	WATER METER (P)				19	COATING TOWER			
						20	WATER METER (P)				21	COATING TOWER			
						22	WATER METER (P)				23	COATING TOWER			
						24	WATER METER (P)				25	COATING TOWER			
						26	WATER METER (P)				27	COATING TOWER			
						28	WATER METER (P)				29	COATING TOWER			
						30	WATER METER (P)				31	COATING TOWER			
						32	WATER METER (P)				33	COATING TOWER			
						34	WATER METER (P)				35	COATING TOWER			
						36	WATER METER (P)				37	COATING TOWER			
						38	WATER METER (P)				39	COATING TOWER			
						39	WATER METER (P)				40	COATING TOWER			
						41	WATER METER (P)				42	COATING TOWER			
						43	WATER METER (P)				44	COATING TOWER			
						45	WATER METER (P)				46	COATING TOWER			
						47	WATER METER (P)				48	COATING TOWER			
						49	WATER METER (P)				50	COATING TOWER			
						51	WATER METER (P)				52	COATING TOWER			
						53	WATER METER (P)				54	COATING TOWER			
						55	WATER METER (P)				56	COATING TOWER			
						57	WATER METER (P)				58	COATING TOWER			
						59	WATER METER (P)				60	COATING TOWER			
						61	WATER METER (P)				62	COATING TOWER			
						63	WATER METER (P)				64	COATING TOWER			
						65	WATER METER (P)				66	COATING TOWER			
						67	WATER METER (P)				68	COATING TOWER			
						69	WATER METER (P)				70	COATING TOWER			
						71	WATER METER (P)				72	COATING TOWER			
						73	WATER METER (P)				74	COATING TOWER			
						75	WATER METER (P)				76	COATING TOWER			
						77	WATER METER (P)				78	COATING TOWER			
						79	WATER METER (P)				80	COATING TOWER			
						81	WATER METER (P)				82	COATING TOWER			
						83	WATER METER (P)				84	COATING TOWER			
						85	WATER METER (P)				86	COATING TOWER			
						87	WATER METER (P)				88	COATING TOWER			
						89	WATER METER (P)				90	COATING TOWER			
						91	WATER METER (P)				92	COATING TOWER			
						93	WATER METER (P)				94	COATING TOWER			
						95	WATER METER (P)				96	COATING TOWER			
						97	WATER METER (P)				98	COATING TOWER			
						99	WATER METER (P)				100	COATING TOWER			
						101	WATER METER (P)				102	COATING TOWER			
						103	WATER METER (P)				104	COATING TOWER			
						105	WATER METER (P)				106	COATING TOWER			
						107	WATER METER (P)				108	COATING TOWER			
						109	WATER METER (P)				110	COATING TOWER			
						111	WATER METER (P)				112	COATING TOWER			
						113	WATER METER (P)				114	COATING TOWER			
						115	WATER METER (P)				116	COATING TOWER			
						117	WATER METER (P)				118	COATING TOWER			
						119	WATER METER (P)				120	COATING TOWER			
						121	WATER METER (P)				122	COATING TOWER			
						123	WATER METER (P)				124	COATING TOWER			
						125	WATER METER (P)				126	COATING TOWER			
						127	WATER METER (P)				128	COATING TOWER			
						129	WATER METER (P)				130	COATING TOWER			
						131	WATER METER (P)				132	COATING TOWER			
						133	WATER METER (P)				134	COATING TOWER			
						135	WATER METER (P)				136	COATING TOWER			
						137	WATER METER (P)				138	COATING TOWER			
						139	WATER METER (P)				140	COATING TOWER			
						141	WATER METER (P)				142	COATING TOWER			
						143	WATER METER (P)				144	COATING TOWER			
						145	WATER METER (P)				146	COATING TOWER			
						147	WATER METER (P)				148	COATING TOWER			
						149	WATER METER (P)				150	COATING TOWER			
						151	WATER METER (P)				152	COATING TOWER			
						153	WATER METER (P)				154	COATING TOWER			
						155	WATER METER (P)				156	COATING TOWER			
						157	WATER METER (P)				158	COATING TOWER			
						159	WATER METER (P)				160	COATING TOWER			
						161	WATER METER (P)				162	COATING TOWER			
						163	WATER METER (P)				164	COATING TOWER			
						165	WATER METER (P)				166	COATING TOWER			
						167	WATER METER (P)				168	COATING TOWER			
						169	WATER METER (P)				170	COATING TOWER			
						171	WATER METER (P)				172	COATING TOWER			
						173	WATER METER (P)				174	COATING TOWER			
						175	WATER METER (P)				176	COATING TOWER			
						177	WATER METER (P)				178	COATING TOWER			
						179	WATER METER (P)				180	COATING TOWER			
						181	WATER METER (P)				182	COATING TOWER			
						183	WATER METER (P)				184	COATING TOWER			
						185	WATER METER (P)				186	COATING TOWER			
						187	WATER METER (P)				188	COATING TOWER			
						189	WATER METER (P)				190	COATING TOWER			
						191	WATER METER (P)				192	COATING TOWER			
						193	WATER METER (P)				194	COATING TOWER			
						195	WATER METER (P)				196	COATING TOWER			
						197	WATER METER (P)				198	COATING TOWER			
						199	WATER METER (P)				200	COATING TOWER			
						201	WATER METER (P)				202	COATING TOWER			
						203	WATER METER (P)				204	COATING TOWER			
						205	WATER METER (P)				206	COATING TOWER			
						207	WATER METER (P)				208	COATING TOWER			
						209	WATER METER (P)				210	COATING TOWER			
						211	WATER METER (P)				212	COATING TOWER			
						213	WATER METER (P)				214	COATING TOWER			
						215	WATER METER (P)				216	COATING TOWER			
						217	WATER METER (P)				218	COATING TOWER			
						219	WATER METER (P)				220	COATING TOWER			
						221	WATER METER (P)				222	COATING TOWER			
						223	WATER METER (P)				224	COATING TOWER			
						225	WATER METER (P)				226	COATING TOWER			
						227	WATER METER (P)				228	COATING TOWER			
						229	WATER METER (P)				230	COATING TOWER			
						231	WATER METER (P)				232	COATING TOWER			
						233	WATER METER (P)				234	COATING TOWER			
						235	WATER METER (P)				236	COATING TOWER			
						237	WATER METER (P)				238	COATING TOWER			
						239	WATER METER (P)				240	COATING TOWER			
						241	WATER METER (P)				242	COATING TOWER			
						243	WATER METER (P)				244	COATING TOWER			
						245	WATER METER (P)				246	COATING TOWER			
						247	WATER METER (P)				248	COATING TOWER			
						249	WATER METER (P)				250	COATING TOWER			
						251	WATER METER (P)				252	COATING TOWER			
						253	WATER METER (P)				254	COATING TOWER			
						255	WATER METER (P)				256	COATING TOWER			
						257	WATER METER (P)				258	COATING TOWER			
						259	WATER METER (P)				260	COATING TOWER			
						261	WATER METER (P)				262	COATING TOWER			
						263	WATER METER (P)				264	COATING TOWER			
						265	WATER METER (P)				266	COATING TOWER			
						267	WATER METER (P)				268	COATING TOWER			
						269	WATER METER (P)				270	COATING TOWER			
						271	WATER METER (P)				272	COATING TOWER			
					</td										

WASTEFLOSS AND PESTICIDE

cost \$7108 inv no. 9251.10

ACT II

-124

90029148

PRINCIPAL USES OF THE INTEGRAL

卷之三

卷之三

Visit SSTE/SDB Library 8/207

卷六

90029149

.125

ITEM	DESCRIPTION	QUANTITY	UNIT PRICE	EXT PRICE	DISCOUNT	NET PRICE	DATE
10' X 10' X 10' SHEET	STEEL	1	100	100	0	100	3-5-72
ALUMINUM SHEET	STEEL	1	17400	17400	0	17400	
300 TON COOLING TOWER	STEEL	3	552	1656	0	1656	
50 HP PUMP SET	STEEL	3	72	216	0	216	
10' X 10' PIPE INSULATED	STEEL	3	220	660	0	660	
TECHNIC JACK HILL	STEEL	1800	24	43200	0	43200	
TECH BLOC	STEEL	160	0	0	0	0	
225 TON HEAT PUMPS	STEEL	3	552	1656	0	1656	
25 H2O PUMPS	STEEL	2	16	32	0	32	
HEAT EXCHANGER	STEEL	1	16	16	0	16	
RH BLDG	STEEL	120	0	0	0	0	
150 TON HEAT PUMP	STEEL	2	57	114	0	114	
15 HP PUMP	STEEL	2	16	32	0	32	
HEAT EXCHANGER	STEEL	1	16	16	0	16	
RH BLDG	STEEL	100	0	0	0	0	
25 TON HEAT PUMP	STEEL	2	57	114	0	114	
10 HP PUMP	STEEL	2	16	32	0	32	
HEAT EXCHANGER	STEEL	1	16	16	0	16	
CONCRETE	STEEL	11	0	0	0	0	
TEST SUPP	STEEL	45	0	0	0	0	
		3324	35	116540	320060	36520	472860

CISST SYSTEMS JOB NO. B25110

PRINCIPAL SUBJECTS.

26

90029150

RH Bldg.

L. UN 1

Alt. 1 - Base System (no recovery - no evap. cool.)

energy use cool. = 914,499 KW = 3121 therms  
(therms) heat. =

$$\frac{1336}{4457} @ 1.1 = 4903$$

Install cost =

---

Alt. 2 - Base System (w/recovery)

energy use cool = 895,656 KW = 3057

heat =

$$\frac{363}{3420} = 3762$$

Install cost =

RUN 2

---

Alt. 1 - Base System (w/recovery)

---

Alt. 2 - Base System (w/recov. + evap. cool.)

energy use cool = 808,165 KW = 2758

heat - = 41  
= 3199 : 3519

Install cost =

These charts represent the average BTU's per day per month that can be collected on a Raypak solar panel. For locations shown, merely pick the amount of heat you need and the chart can tell you how many panels are needed.

Example - average home - family of four - 140° hot water usage - 15 gal. per person

Amount of water needed - 60 gal./140°

Incoming water temperature - 60°F

60 gal. X 8.33 wt. per gal. water = 499.80 lbs.


1 BTU will heat one lb. of water 1° per hr. Thus 1 gal. of water can be heated 1° by 8.5 BTU's  
 $1 \times 499.80 \text{ lbs.} = 499.8 \text{ BTU's for 60 gal. at } 1^\circ$

Thus,  $499.8 \times 80 = 39,984 \text{ BTU's needed to heat 60 gal. of water to } 140^\circ\text{F.}$

EXAMPLE MAY NOT BE APPLICABLE IN ALL LOCATIONS

### APPROXIMATE BTU PER DAY FOR ONE MODEL SG-I8P SINGLE GLAZED COLLECTOR

MBTU  
PER DAY  
AVERAGE



APPROX. LATITUDE  
32° N  
32°  
60°F  
CITY SUPPLY  
140°F  
SOUTH  
LIGHT  
AMOUNT OF SUN  
PER DAY  
WEATHER  
BUREAU

PHOENIX  
LOS ANGELES  
SAN DIEGO  
ALBUQUERQUE  
CARLSBAD

$$= 223.75 \text{ MBTU}/12 =$$

$$18.646 \text{ MBTU/day}$$

$$= 18,646 \text{ BTU/day}$$

$$= .000253/5^{\circ} (7.95/\text{kWh}) = 6,805,790 \text{ BTU/yr}, 1/28$$

1814300R

90029152

Civil Calculations

POOR ORIGINAL

90029153

2-22-77

WIPP - WATER SUPPLY AND SEWAGE  
TREATMENT

DESIGN BASIS

The WIPP facility includes a water supply and distribution system and a sewage treatment plant. The site population is approximately 400 on a 24 hour basis, and the systems are designed on the following basis:

	<u>Gallons/Day/Person</u>
Water Supply	50
Sewage Treatment	100

The capacity of the sewage treatment plant exceeds the water supply system capacity in order to account for system surges. If the two systems were designed for the same capacity the sewage treatment process would be unable to accept surges in flow. The effluent control would suffer as a result. Using a design philosophy which allows for surges results in a higher quantity sewage treatment plant.

The WIPP facility peak water demand will be based on a combination of fire control flows, personnel demand flows and process requirements. The peak 8 hour demand flows and process requirements. The peak 8 hour demand will therefore be:

	<u>Capacity Gallons</u>
Fire System Make-Up	135,000
Domestic Demand - 400 x 50	20,000
Process Demand	<u>5,000</u>
Total Peak Demand	160,000

Peak System flow in the eight hour period will therefore be:

$$\text{Peak Flow} = 160,000 \text{ gallons}/480 \text{ minutes}$$

$$\text{Peak Flow} = 332 \text{ gpm} \text{ during fire water make-up}$$

From Sandia Design Criteria

90029154

Average daily demand will be based on total site population per 24 hours day plus process requirements.

$$\begin{aligned}\text{Average Demand} &= 400 \text{ people } (\frac{50 \text{ gpd}}{\text{person}}) + 5000 \text{ gpd (Process)} \\ &= 20,000 \text{ gpd} + 5000 \text{ gpd}\end{aligned}$$

$$\text{Average Demand} = 25,000 \text{ gpd}$$

$$\text{Average Peak flow during 8 hour period} = \frac{25,000}{480} = 52 \text{ gpm Average}$$

Due to the small site approximately 1000 feet by 2000 feet and containing 11 buildings having 164 plumbing fixtures and a kitchen with a total of 902 fixture units, the 902 fixture units require a peak flow of 200 gpm.

A duplex constant pressure water system with 2 - 100 gpm pumps at 60 psig will distribute the domestic water to the buildings.

900029155

120

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_

**HOLMES & NARVER, INC.**  
**TECHNOLOGY - CONSTRUCTION**  
 400 E. ORANGETHORPE AVE.  
 ANAHEIM, CALIF. 92801

APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

JOB NO. 8251.00TITLE WIPP - WATER DEMANDSSHEET 1 OF \_\_\_\_\_BY ERG DATE 2-22-77

NO	BUILDING	PLUMBING			FIXTURES		
		W.C	U.	LAV	SH.	D.F	J.S
5	MAN / MATERIALS	10	6	10	23	2	2
2	ADMINISTRATION	15	6	15			3
10	TRU WASTE	5	3	5	8		1
3	WAREHOUSE / SHOPS	6	3	6	2		1
11	HOIST HOUSE	2		2			
4	VEHICLE MAINTENANCE	1	1	1			
1	GATE HOUSE	1		1			
21	MINE FILTER	1		1	1	1	
16	EMERGENCY POWER	1		1			
6	RAD. WASTE LAUNDRY	1		1	1	1	
12	R.H. WASTE	7	5	7	5	2	1
TOTAL		40	24	40	40	10	8
							2

PEAK WATER DEMAND BY FIXTURE UNITS  
 TOTAL SITE

WATER CLOSET	$40 \times 10$	= 400
URINAL	$24 \times 5$	= 120
LAVATORY	$40 \times 2$	= 80
SHOWER	$40 \times 4$	= 160
DRINK FT.	$10 \times 1$	= 10
JAN. SINK	$8 \times 3$	= 24
FOOT WASH	$2 \times 4$	= 8
KITCHEN		= 100

TOTAL FIXTURE UNITS = 902

TOTAL DEMAND 902 FU = 200 GPM.

USE DUPLEX CONSTANT PRESSURE SYSTEM  
 200 GPM AT 60 PSI FOR DISTRIBUTION.

90029156

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_

HOLMES & NARVER, INC.  
TECHNOLOGY - CONSTRUCTION

APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

400 E. ORANGETHORPE AVE.  
ANAHEIM, CALIF. 92801

JOB NO. 8251.00

TITLE WIPP - WATER DEMANDS

SHEET 2 OF \_\_\_\_\_

BY ERQ DATE 2-22-77

MAN-MATERIALS BUILDING  
FIXTURE UNITS

WC - 10 x 10	= 100
U - 6 x 5	= 30
LAV - 10 x 2	= 20
SHOW - 23 x 4	= 92
D.F. - 2 x 1	= 2
J.S - 2 x 3	= 6
FOOT WA - 2 x 4	= 8

TOTAL F.U. = 258 FIXTURE UNITS

TOTAL DEMAND = 258 FU = 100 GPM PEAK

ADMINISTRATION BLDG  
FIXTURE UNITS

WC - 15 x 10	= 150
U - 6 x 5	= 30
LAV - 15 x 2	= 30
J. S - 3 x 3	= 9
KITCHEN	= <u>100</u>

TOTAL = 319 FIX. UNITS

TOTAL DEMAND = 110 GPM PEAK

TRV WASTE  
FIXTURE UNITS

WC - 5 x 10	= 50
U - 3 x 5	= 15
LAV - 5 x 2	= 10
SHOWER - 8 x 4	= 32
J. SINK - 1 x 3	= <u>3</u>

TOTAL 110 FIXTURE UNITS

TOTAL DEMAND = 70 GPM PEAK

132

90029157

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_

**HOLMES & NARVER, INC.**  
**TECHNOLOGY - CONSTRUCTION**  
 400 E. ORANGETHORPE AVE  
 ANAHEIM, CALIF. 92801

APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

JOB NO. 8251.00

TITLE WIPP - WATER DEMANDSHEET 3 OF \_\_\_\_\_BY ERQ DATE 2-22-72

**WAREHOUSE & SHOPS**  
**FIXTURE UNITS**

WC -	6 x 10	=	60
U -	3 x 5	=	15
LAV -	6 x 2	=	12
SHOWER -	2 x 4	=	8
J. SINK	1 x 3	=	3

TOTAL = 98 FIXTURE UNITS

TOTAL DEMAND = 67 GPM PEAK

**HOIST HOUSE**

**FIXTURE UNITS**

WC -	2 x 10	=	20
LAV -	2 x 2	=	4

TOTAL = 24 FIXTURE UNITS

TOTAL DEMAND = 40 GPM PEAK.

**VEHICLE MAINTENANCE**

**FIXTURE UNITS**

WC -	1 x 10	=	10
U -	1 x 5	=	5
LAV -	1 x 2	=	2

TOTAL = 17 FIXTURE UNITS

TOTAL DEMAND = 33 GPM PEAK.

**GATE HOUSE**

**FIXTURE UNITS**

WC -	1 x 10	=	10
LAV -	1 x 2	=	2
TOTAL = 12			

TOTAL DEMAND 26 GPM PEAK

**MINE FILTER**

**FIXTURE UNITS**

WC -	1 x 10	=	10
LAV -	1 x 2	=	2
SHOWER	1 x 4	=	4
D.F	1 x 1	=	1

90029158

TOTAL = 17

TOTAL DEMAND = 35 GPM PEAK.

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_

HOLMES & NARVER, INC.  
TECHNOLOGY—CONSTRUCTION  
400 E. ORANGETHORPE AVE.  
ANAHEIM, CALIF. 92801

APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

JOB NO. 8251.00

TITLE WIPP - WATER DEMAND

SHEET 4 OF \_\_\_\_\_

BY ERQ DATE 2-22-77

## EMERGENCY POWER

## FIXTURE UNITS

WC - 1 x 10 = 10

LAV - 1 x 2 = 2

TOTAL = 12 F.U.

TOTAL DEMAND = 26 GPM PEAK

## RAD. WASTE LAUNDRY

## FIXTURE UNITS

WC - 1 x 10 = 10

LAV - 1 x 2 = 2

SHOWER - 1 x 4 = 4

D.F. - 1 x 1 = 1

TOTAL = 17 F.U.

TOTAL DEMAND = 33 GPM PEAK

## R. H. WASTE

## FIXTURE UNITS

WC - 7 x 10 = 70

U. - 5 x 5 = 25

LAV - 7 x 2 = 14

SHOWER - 5 x 4 = 20

D.F. - 2 x 1 = 2

J. SINK - 1 x 3 = 3

TOTAL = 134 F.U.

TOTAL DEMAND = 76 GPM PEAK,

821PSLDR

90029159<sup>34</sup>

SUSPECT WATER POND

200,000 GAL = 26,737 CF USE 30,000 CF

Ⓐ AVE. DEPTH USE 70' x 70'


$$70 \times 70 = 4900 \text{ SF}$$

$$\frac{30,000}{4900} = 6.12'$$


MAKE DEPTH 7'

SIDE SLOPES 2:1

BOTTOM DIM 58' x 58'



INTERCEPTER DITCH  
& BERM



$$C = 17 \times 7 = 119 \text{ SF}$$

$$F = 20 \times 5 = 100 \text{ SF}$$

$$= 100 \times 1.9\% = 119 \text{ SF}$$

00108008

136

90029161

## EFFLUENT POND

250,000 GAL STORAGE

3' LIQUID DEPTH


3' FREEBOARD

$$\frac{250,000}{7.48} = 33,422 \text{ CF}$$

$$\frac{33,422}{3} = 11,140 \text{ SF } @ \text{ AVE DEPTH}$$

$$\sqrt{11,140} = 105.5'$$

USE 110'



$$464 \times 14 = 6496$$

$$104 \times 104 = 10816$$

$$4 \times 128 \times 2 = \frac{1024}{18336}$$

$$\frac{1024}{18336} \text{ SF } 3110 \text{ LINER}$$

Electrical Calculations

6

*POOR ORIGINAL*

90029163

CHECKED \_\_\_\_\_ DATE \_\_\_\_\_

APPROVED \_\_\_\_\_ DATE \_\_\_\_\_

TITLE REFERENCE ELECTRICAL LOAD CALCSHOLMES & NARVER, INC.  
TECHNOLOGY - CONSTRUCTION  
400 E. ORANGETHORPE AVE  
ANAHEIM, CALIF. 92801

JOB NO. \_\_\_\_\_

SHEET \_\_\_\_\_ OF \_\_\_\_\_

BY KRB DATE 4/6/77

THE WIPP ELECTRICAL LOAD SUMMARY HAS BEEN COMPILED UTILIZING ESTIMATED MOTOR HORSEPOWER SIZES. THE CONNECTED, NORMAL AND VITAL LOADS, IN KVA, HAVE BEEN CALCULATED USING THE FOLLOWING FORMULA.

$$\text{LOAD(KVA)} = \left( \frac{\text{FULL LOAD}}{\text{CURRENT-AMPS}} \right) \sqrt[3]{\text{FOR ONE PHASE}} \quad (\text{POWER SUPPLY IN KV})$$

RH WASTE FACILITY

NOTE: These calculations were originally performed for the dual preparation/decontamination room concept. Room sizes have changed. Lighting loads are conservative.

90029165

APR 18 1988

146

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... H.L. BLDG.....

Area to be lighted..... LOCKER R M & SHOWERS.....


Design level of illumination..... 10 FC..... (flame) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 53..... Room Length  
 ..... 35..... Room Width  
 ..... 7.5..... Height of room between luminaire & work plane (hrc)  
 ..... 0.5..... Distance from luminaire plane to ceiling (hcc)  
 ..... 0..... Height of work plane above floor (hfc)



8

### Room Surface Reflectance in %

..... 70..... Ceiling  
 ..... { 20..... Walls above luminaire plane  
 ..... 20..... Walls between luminaire & work plane  
 ..... { 20..... Walls below work plane  
 ..... 20..... Floor

### Luminaire

Manufacturer .....  
 Catalog No. ..... 7100.....  
 No. & Type lamps ..... 2-F40 CW.....  
 Lumens/lamp ..... 6200.....  
 Light loss Factor ..... .70..... (LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = .8 ; Ceiling Cavity Ratio = .1 ; Floor Cavity Ratio = 0

- Obtain effective ceiling cavity reflectances ( $\mu_{rc}$ ) from Table B;  $\mu_{rc} = .67$

- Obtain effective floor cavity reflectance ( $\mu_{rf}$ ) from Table B;  $\mu_{rf} = .20$

- Find coefficient of utilization from published data (for  $\mu_{rc} = 20\%$ ) C.U. = .67

$$\begin{aligned} \text{No. of} &= \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}} \\ \text{FIXTURES} &= \frac{10 \times 1855}{6200 \times .67 \times .75} = \frac{18550}{3115.5} = 6 \end{aligned}$$

14418608

1.

90029166

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... H.L. BLDG.....

Area to be lighted..... Toilet.....


Design level of illumination..... 1 P.F.C. .... 4000 (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 10 ..... Room Length  
 ..... 10 ..... Room Width  
 ..... 13.5 ..... Height of room between luminaire & work plane (hrc)  
 ..... 10.5 ..... Distance from luminaire plane to ceiling (hcc)  
 ..... 0 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 70 ..... Ceiling  
 ..... { Walls above luminaire plane  
 ..... 50 ..... Walls between luminaire & work plane  
 ..... } Walls below work plane  
 ..... 20 ..... Floor

### Luminaire

Manufacturer .....  
 Catalog No. ..... 3100 .....  
 No. & Type lamps ..... 1 P.40.CW .....  
 Lumens/lamp ..... 3100 .....  
 Light loss Factor ..... .70 .....  
 (LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

### 1. Determine cavity ratios using Table A or by formula

Room Cavity Ratio = 13.5 ; Ceiling Cavity Ratio = .5 ; Floor Cavity Ratio = 0

2. Obtain effective ceiling cavity reflectances ( $\mu_{rc}$ ) from Table B;  $\mu_{rc} = 64$

3. Obtain effective floor cavity reflectance ( $\mu_{rf}$ ) from Table B;  $\mu_{rf} = 20$

4. Find coefficient of utilization from published data (for  $\mu_r = 20\%$ ) C.U. = .26

$$\text{No. of fixtures} = \frac{\text{Foot Candles} \times \text{Area}}{\text{Lamps/Fixture} \times \text{Lumens/Lamp} \times \text{C.U.} \times \text{LLF}}$$

$$= \frac{10 \times 100}{3100 \times .26 \times .75} = \frac{1000}{604.5} = 1.65 - 2 ea$$

142

90029167

6618600P

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... H. L. BLDG.....

Area to be lighted..... Toilet #2.....

Design level of illumination..... 10 F.C. (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions


..... 16 ..... Room Length

..... 10 ..... Room Width

..... 13.5 ..... Height of room between luminaire & work plane (hrc)

..... 0.5 ..... Distance from luminaire plane to ceiling (hcc)

..... 9 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 70 ..... Ceiling

..... { 50 ..... Walls above luminaire plane

..... 50 ..... Walls between luminaire & work plane

..... { 50 ..... Walls below work plane

..... 20 ..... Floor

### Luminaire

Manufacturer .....

Catalog No. .... 4100 .....

No. & Type lamps ... 1 - F40 CW .....

Lumens/Lamp .... 3100 .....

Light loss Factor .... ?0 .....

(LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = .11 ; Ceiling Cavity Ratio = .4 ; Floor Cavity Ratio = 0

- Obtain effective ceiling cavity reflectances ( $\mu_{rc}$ ) from Table B;  $\mu_{rc} = .65$

- Obtain effective floor cavity reflectance ( $\mu_{rf}$ ) from Table B;  $\mu_{rf} = .20$

- Find coefficient of utilization from published data (for  $\mu_{rc} = 20\%$ ) C.U. = .26

$$\frac{\text{No. of fixtures}}{\text{Foot Candles} \times \text{Area}} = \frac{\text{Foot Candles} \times \text{Area}}{\text{Lamps/Fixture} \times \text{Lumens/Lamp} \times \text{C.U.} \times \text{LLF}}$$

$$= \frac{10 \times 160}{3100 \times .26 \times .75} = \frac{1600}{604.5} = 2.6 - 3.00$$

143  
10193004

90029168

3

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... H.L. BLDG.....

Area to be lighted..... OFFICE..... 1,243.....


Design level of illumination..... 70 FC..... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 12 ..... Room Length  
 ..... 11 ..... Room Width  
 ..... 11 ..... Height of room between luminaire & work plane (hrc)  
 ..... 0.5 ..... Distance from luminaire plane to ceiling (hcc)  
 ..... 2.5 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 70 ..... Ceiling  
 ..... { ..... Walls above luminaire plane  
 ... 50 ..... Walls between luminaire & work plane  
 ..... } ..... Walls below work plane  
 ..... 20 ..... Floor

### Luminaire

Manufacturer .....  
 Catalog No. ..... 7100 .....  
 No. & Type lamps .. 2 - F40 CYN .....  
 Lumens/lamp ..... 6200 .....  
 Light loss Factor ..... : 75 .....  
 (LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

### 1. Determine cavity ratios using Table A or by formula

$$\text{Room Cavity Ratio} = 10.3 \quad ; \quad \text{Ceiling Cavity Ratio} = .5 \quad ; \quad \text{Floor Cavity Ratio} = 2.3$$

### 2. Obtain effective ceiling cavity reflectances ( $\mu_{rc}$ ) from Table B; $\mu_{rc} = .64$

### 3. Obtain effective floor cavity reflectance ( $\mu_{rf}$ ) from Table B; $\mu_{rf} = .18$

### 4. Find coefficient of utilization from published data (for $\mu_{rl} = 20\%$ ) C.U. = .26

$$\frac{\text{No. of fixtures}}{\text{Fixtures}} = \frac{\text{Foot Candles} \times \text{Area}}{\text{Lamps/Fixture} \times \text{Lumens/Lamp} \times \text{CU} \times \text{LLF}}$$

$$= \frac{70 \times 132}{6200 \times .75 \times .26} = \frac{9240}{1209} = 7.6 - 8$$

144

90029169

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... H.L. BLDG.....

Area to be lighted..... OFFICE..... 4.F.S.....


Design level of illumination..... 70 F.C. .... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 14 ..... Room Length  
 ..... 9 ..... Room Width  
 ..... 11 ..... Height of room between luminaire & work plane (hrc)  
 ..... 0.5 ..... Distance from luminaire plane to ceiling (hcc)  
 ..... 2.5 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 70 .....	Ceiling
..... { .....	Walls above luminaire plane
..... 2P. .....	Walls between luminaire & work plane
..... { .....	Walls below work plane
..... 20 .....	Floor

### Luminaire

Manufacturer .....	
Catalog No. .....	7100
No. & Type lamps .....	2 - F40C W
Lumens/lamp .....	6200
Light loss Factor .....	.75 (LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = .12 ; Ceiling Cavity Ratio = .45 ; Floor Cavity Ratio = 2.3

- Obtain effective ceiling cavity reflectances ( $\mu_{rc}$ ) from Table B;  $\mu_{rc} = .64$

- Obtain effective floor cavity reflectance ( $\mu_{rf}$ ) from Table B;  $\mu_{rf} = .18$

- Find coefficient of utilization from published data (for  $\mu_r = 20\%$ ) C.U. = .26

$$\frac{\text{No. of FIXTURES}}{\text{=}} \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$= \frac{70 \times 120}{6200 \times .26 \times .75} = \frac{8820}{1209} = 7$$

145

5  
90029170

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... H. L. BLDG .....

Area to be lighted..... OFFICE... ACC. FLOOR... CEILING.....


Design level of illumination..... 10 FC..... (Initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 18 ..... Room Length  
 ..... 12 ..... Room Width  
 ..... 11 ..... Height of room between luminaire & work plane (hrc)  
 ..... 0.5 ..... Distance from luminaire plane to ceiling (hcc)  
 ..... 2.5 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 70 ..... Ceiling  
 ..... { Walls above luminaire plane  
 ..... 50 ..... } Walls between luminaire & work plane  
 ..... { Walls below work plane  
 ..... 20 ..... Floor

### Luminaire

Manufacturer .....  
 Catalog No. .... 7200 .....  
 No. & Type lamps ... 2 - E40 G.W .....  
 Lumens/lamp ..... 6200 .....  
 Light loss Factor ..... .75 .....  
 (LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = .55 ; Ceiling Cavity Ratio = .25 ; Floor Cavity Ratio = .125

- Obtain effective ceiling cavity reflectances ( $\mu_{rc}$ ) from Table B;  $\mu_{rc} = .67$

- Obtain effective floor cavity reflectance ( $\mu_{rf}$ ) from Table B;  $\mu_{rf} = .20$

- Find coefficient of utilization from published data (for  $\mu_r = 20\%$ ) C.U. = .38

$$\frac{\text{No. of FIXTURES}}{\text{Foot Candles} \times \text{Area}} = \frac{\text{Lamps/Fixture} \times \text{Lumens/Lamp} \times \text{CU} \times \text{LLF}}$$

$$= \frac{10 \times 696}{6200 \times .75 \times .38} = \frac{6960}{1767} = 4$$

DRIVERS

146

90029171

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... H.L. BLDG.....

Area to be lighted..... CONTROL ROOM.....


Design level of illumination..... 70 FC..... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 54 ..... Room Length  
 ..... 10 ..... Room Width  
 ..... 10 ..... Height of room between luminaire & work plane (hrc)  
 ..... 5 ..... Distance from luminaire plane to ceiling (hcc)  
 ..... 2.5 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 70 ..... Ceiling  
 ..... { ..... Walls above luminaire plane  
 ..... 50 ..... Walls between luminaire & work plane  
 ..... } ..... Walls below work plane  
 ..... 20 ..... Floor

### Luminaire

Manufacturer .....  
 Catalog No. .... 7100 .....  
 No. & Type lamps ... 2 .. F40. CW .....  
 Lumens/lamp ..... 3100 .....  
 Light loss Factor ..... .75 .....  
 (LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

$$\text{Room Cavity Ratio} = 5.9 \quad ; \quad \text{Ceiling Cavity Ratio} = 0.3 \quad ; \quad \text{Floor Cavity Ratio} = 1.5$$

- Obtain effective ceiling cavity reflectances ( $\mu_{rc}$ ) from Table B;  $\mu_{rc} = .64$

- Obtain effective floor cavity reflectance ( $\mu_{rf}$ ) from Table B;  $\mu_{rf} = .18$

- Find coefficient of utilization from published data (for  $\mu_{rc} = 20\%$ ) C.U. = .39

$$\frac{\text{No. of fixtures}}{\text{Foot Candles} \times \text{Area}} = \frac{\text{Foot Candles} \times \text{Area}}{\text{Lamps/Fixture} \times \text{Lumens/Lamp} \times \text{C.U.} \times \text{LLF}}$$

$$= \frac{70 \times 540}{6200 \times .75 \times .39} = \frac{37800}{1813.5} = 20$$

147

147

90029172

7

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... H. L. BLDG.....

Area to be lighted..... SHIPPING & RECEIVING (DOCK).....

Design level of illumination..... 20 FC.....(initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions


..... 216 ..... Room Length

..... 36 ..... Room Width

..... 54.5 ..... Height of room between luminaire & work plane (hrc)

..... 2.5 ..... Distance from luminaire plane to ceiling (hcc)

..... 6 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... Ceiling

..... Walls above luminaire plane

..... W.P. .... Walls between luminaire & work plane

..... Walls below work plane

..... Floor

### Luminaire

Manufacturer ..... HOLOPHANE.....

Catalog No. ..... #1047 EG-P1-277

No. & Type lamps ..... P.N.E.....

Lumens/Lamp ..... 50000

Light loss Factor ..... .9 X .9 = .81  
(LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = .90 ; Ceiling Cavity Ratio = .4 ; Floor Cavity Ratio = .9

- Obtain effective ceiling cavity reflectances ( $\mu_{rc}$ ) from Table B;  $\mu_{rc} = .46$

- Obtain effective floor cavity reflectance ( $\mu_{rf}$ ) from Table B;  $\mu_{rf} = .19$

- Find coefficient of utilization from published data (for  $\mu_r = 20\%$ ) C.U. = .0.36

$$\text{No. of FIXTURES} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$= \frac{20 \times 7776}{50000 \times .36 \times .81} = \frac{155520}{14580} = 10.6 \rightarrow 12$$

18' apart

2 rows of 6 ea 36' apart

148

SURVEY

90029173

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... H. L. BLDG.....

Area to be lighted..... MECH./ELEC. ROOM..... (-16 LEVEL).....


Design level of illumination..... 20 F.C. .... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 53 ..... Room Length  
 ..... 35 ..... Room Width  
 ..... 9.5 ..... Height of room between luminaire & work plane (hrc)  
 ..... 2.5 ..... Distance from luminaire plane to ceiling (hcc)  
 ..... 4 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... Ceiling  
 ..... Walls above luminaire plane  
 ..... 50 ..... Walls between luminaire & work plane  
 ..... Walls below work plane  
 ..... 20 ..... Floor

### Luminaire

Manufacturer .....  
 Catalog No. ..... 1930  
 No. & Type lamps ..... 100 W  
 Lumens/Lamp ..... 9500  
 Light loss Factor ..... .81  
 (LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

### 1. Determine cavity ratios using Table A or by formula

Room Cavity Ratio = 2.25 ; Ceiling Cavity Ratio = .5 ; Floor Cavity Ratio = .8

2. Obtain effective ceiling cavity reflectances ( $\mu_{rc}$ ) from Table B;  $\mu_{rc} = .46$

3. Obtain effective floor cavity reflectance ( $\mu_{rf}$ ) from Table B;  $\mu_{rf} = .19$

4. Find coefficient of utilization from published data (for  $\mu_{rl} = 20\%$ ) C.U. = .66

$$\frac{\text{No. of FIXTURES}}{\text{Foot Candles} \times \text{Area}} = \frac{\text{Lamps/Fixture} \times \text{Lumens/Lamp} \times \text{C.U.} \times \text{LLF}}{}$$

$$= \frac{20 \times 1855}{9500 \times .66 \times .81} = \frac{37100}{5079} = 7.3$$

149

90029174

9

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... H. L. BLDG.....

Area to be lighted..... CASK FLOOR: (-16 LEVEL)


Design level of illumination..... 10 FC..... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 56 ..... Room Length  
 ..... 17 ..... Room Width  
 ..... 20.5 ..... Height of room between luminaire & work plane (hrc)  
 ..... 2.5 ..... Distance from luminaire plane to ceiling (hcc)  
 ..... 4 ..... Height of work plane above floor (hfc)



27

### Room Surface Reflectance in %

..... 70 ..... Ceiling  
 ..... 50 ..... Walls above luminaire plane  
 ..... 50 ..... Walls between luminaire & work plane  
 ..... 50 ..... Walls below work plane  
 ..... 20 ..... Floor

### Luminaire

Manufacturer ..... HOLO .....  
 Catalog No. ..... \* 1730 .....  
 No. & Type lamps ..... 1-100W HPS .....  
 Lumens/Lamp ..... 9500 .....  
 Light loss Factor ..... .81 .....  
 (LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = 7.9 ; Ceiling Cavity Ratio = .95 ; Floor Cavity Ratio = 1.5

- Obtain effective ceiling cavity reflectances ( $\rho_{ce}$ ) from Table B;  $\rho_{ce} = .58$

- Obtain effective floor cavity reflectance ( $\rho_{fr}$ ) from Table B;  $\rho_{fr} = .18$

- Find coefficient of utilization from published data (for  $\rho_h = 20\%$ ) C.U. = .45

$$\text{NO. OF FIXTURES} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$= \frac{10 \times 952}{9500 \times .45 \times .81} = \frac{9520}{3463} = 3$$

150

INTRODUCY

90029175

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... H. L. BLDG.....

Area to be lighted..... CASK PREPARATION/DECON ROOM.....


Design level of illumination..... 50 FC..... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 70 ..... Room Length  
 ..... 62 ..... Room Width  
 ..... 3.95 ..... Height of room between luminaire & work plane (hrc)  
 ..... 2.5 ..... Distance from luminaire plane to ceiling (hcc)  
 ..... 4 ..... Height of work plane above floor (hfc)



Room Surface Reflectance 17 %

..... 70 ..... Ceiling  
 ..... 50 ..... Walls above luminaire plane  
 ..... 50 ..... Walls between luminaire & work plane  
 ..... 2.9 ..... Walls below work plane  
 ..... 2.9 ..... Floor

### Luminaire

Manufacturer .....  
 Catalog No. .... 1047 E.G.-P1-277 .....  
 No. & Type lamps ... DNE ... 400 W. HPS .....  
 Lumens/Lamp .... 50,000 .....  
 Light loss Factor ..... .81 .....  
 (LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = .43 ; Ceiling Cavity Ratio = .25 ; Floor Cavity Ratio = .4

- Obtain effective ceiling cavity reflectances ( $\mu_{rc}$ ) from Table B;  $\mu_{rc} = .66$

- Obtain effective floor cavity reflectance ( $\mu_{rf}$ ) from Table B;  $\mu_{rf} = .20$

- Find coefficient of utilization from published data (for  $\mu_{rc} = 20\%$ ) C.U. = .55

$$\text{No. of FIXTURES} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$= \frac{50 \times 5580}{50000 \times .81 \times .55} = 12.5$$

20 center

3 rows of 4 ea

22 center

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... H. L. BLDG.....

Area to be lighted..... UPPIER TRANSFER (HOT CELL).....

Design level of illumination..... 50 FC..... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions


..... 48 ..... Room Length

..... 44 ..... Room Width

..... 23.5 ..... Height of room between luminaire & work plane (hrc)

..... 2.5 ..... Distance from luminaire plane to ceiling (hcc)

..... 4 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 70 ..... Ceiling

..... 50 ..... Walls above luminaire plane

..... 50 ..... Walls between luminaire & work plane

..... 50 ..... Walls below work plane

..... 20 ..... Floor

### Luminaire

Manufacturer ..... HOLOPHANE.....

Catalog No. ..... 1047-EQ-P1-277.

No. & Type lamps ..... ONE - 400 WATT. HPS

Lumens/Lamp ..... 50000.....

Light loss Factor ..... .81  
(LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = .73 ; Ceiling Cavity Ratio = .5 ; Floor Cavity Ratio = .8

- Obtain effective ceiling cavity reflectances ( $\mu_{rc}$ ) from Table B;  $\mu_{rc} = .64$

- Obtain effective floor cavity reflectance ( $\mu_{rf}$ ) from Table B;  $\mu_{rf} = .19$

- Find coefficient of utilization from published data (for  $\mu_{rc} = 20\%$ ) C.U. = .46

$$\frac{\text{No. of FIXTURES}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{C.U.} \times \text{LLF}} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{C.U.} \times \text{LLF}}$$

$$= \frac{50 \times 2112}{50000 \times .46 \times .81} = \frac{105600}{18630} = 5.6 \rightarrow 6$$

2 rows of 3

152

90029177

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... H.L. BLDG.....

Area to be lighted..... STORAGE ROOM..... 25A.....

Design level of illumination..... 10 FC..... (Hatched) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions


..... 30..... Room Length

..... 16..... Room Width

..... 7.5..... Height of room between luminaire & work plane (hrc)

..... 2.5..... Distance from luminaire plane to ceiling (hcc)

..... 4..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... Ceiling

..... Walls above luminaire plane

..... 50..... Walls between luminaire & work plane

..... Walls below work plane

..... 20..... Floor

### Luminaire

Manufacturer .....

Catalog No. .... 1990.....

No. & Type lamps ..... 100W.....

Lumens/Lamp ..... 9500.....

Light loss Factor ..... .81.....  
(LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

$$\text{Room Cavity Ratio} = 4.5 ; \text{Ceiling Cavity Ratio} = 1.1 ; \text{Floor Cavity Ratio} = 1.8$$

- Obtain effective ceiling cavity reflectances ( $\rho_{rc}$ ) from Table B;  $\rho_{rc} = 41$

- Obtain effective floor cavity reflectance ( $\rho_{rf}$ ) from Table B;  $\rho_{rf} = 78$

- Find coefficient of utilization from published data (for  $\rho_{rf} = 20\%$ ) C.U. = 54

$$\frac{\text{No. of FIXTURES}}{\text{Foot Candles} \times \text{Area}} = \frac{\text{Lamps/Fixture} \times \text{Lumens/Lamp} \times \text{C.U.} \times \text{LLF}}{\text{Foot Candles} \times \text{Area}}$$

$$= \frac{10 \times 480}{9500 \times .54 \times .81} = \frac{4800}{4155} = 1.15 - 2$$

153

90029178

19

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... H. L. BLDG.....

Area to be lighted..... EQUIP... PASS... THRU..... (10' x 10')


Design level of illumination..... 10 FC..... (Initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 57 ..... Room Length  
 ..... 12 ..... Room Width  
 ..... 17.5 ..... Height of room between luminaire & work plane (hrc)  
 ..... 2.5 ..... Distance from luminaire plane to ceiling (hcc)  
 ..... 4 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 70 ..... Ceiling  
 ..... { Walls above luminaire plane  
 ..... 50 ..... Walls between luminaire & work plane  
 ..... } Walls below work plane  
 ..... 20 ..... Floor

### Luminaire

Manufacturer .....  
 Catalog No. ..... 1930  
 No. & Type lamps ..... 100 W  
 Lumens/Lamp ..... 9500  
 Light loss Factor ..... 81  
 (LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

$$\text{Room Cavity Ratio} = 8.8 \quad ; \quad \text{Ceiling Cavity Ratio} = 1.25 \quad ; \quad \text{Floor Cavity Ratio} = 2.0$$

- Obtain effective ceiling cavity reflectances ( $\rho_{rc}$ ) from Table B;  $\rho_{rc} = .56$

- Obtain effective floor cavity reflectance ( $\rho_{rf}$ ) from Table B;  $\rho_{rf} = .18$ .

- Find coefficient of utilization from published data (for  $\rho_{rc} = 20\%$ ) C.U. = .44

$$\frac{\text{No. of FIXTURES}}{\text{=}} = \frac{\text{FCFT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$= \frac{10 \times 684}{9500 \times .44 \times .81} = \frac{6840}{3386} = 2.02$$

8CIRUGOR

154

90029179

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... H. L. BLDG.....

Area to be lighted..... MECH./ELEC. T18' LEVEL.....


Design level of illumination..... 20 F.C. (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 7.3 ..... Room Length  
 ..... 6.4 ..... Room Width  
 ..... 14.5 ..... Height of room between luminaire & work plane (hrc)  
 ..... 2.5 ..... Distance from luminaire plane to ceiling (hcc)  
 ..... 4 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

.....	Ceiling
.....	Walls above luminaire plane
.50	Walls between luminaire & work plane
.....	Walls below work plane
.... 20	Floor

### Luminaire

Manufacturer .....	
Catalog No. ....	1930
No. & Type lamps .....	100W
Lumens/Lamp .....	9500
Light loss Factor .....	.81
(LLD x LDD)	

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = .45 ; Ceiling Cavity Ratio = .25 ; Floor Cavity Ratio = .4

- Obtain effective ceiling cavity reflectances ( $\mu_{rc}$ ) from Table B;  $\mu_{rc} = .48$

- Obtain effective floor cavity reflectance ( $\mu_{rf}$ ) from Table B;  $\mu_{rf} = .29$

- Find coefficient of utilization from published data (for  $\mu_{rc} = 20\%$ ) C.U. = .69

$$\text{No. of FIXTURES} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$= \frac{20 \times 4672}{9500 \times .69 \times .81} = \frac{93440}{5309.5} \approx 17.6 - 18$$

155

15

90029180

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... H.L. BLDG.....

Area to be lighted..... CORRIDOR .....


Design level of illumination..... 10. FC..... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 53 ..... Room Length  
 ..... 6 ..... Room Width  
 ..... 9.5 ..... Height of room between luminaire & work plane (hrc)  
 ..... 0.5 ..... Distance from luminaire plane to ceiling (hcc)  
 ..... 0 ..... Height of work plane above floor (hfc)



Room Surface Reflectance 10 %

..... 70 ..... Ceiling  
 ..... 50 ..... Walls above luminaire plane  
 ..... 50 ..... Walls between luminaire & work plane  
 ..... 20 ..... Walls below work plane  
 ..... 20 ..... Floor

### Luminaire

Manufacturer .....  
 Catalog No. ..... 6100 .....  
 No. & Type lamps ... 1 - F40 GWW .....  
 Lumens/Lamp ..... 3100 .....  
 Light loss Factor ..... .75 .....  
 (LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

### 1. Determine cavity ratios using Table A or by formula

Room Cavity Ratio = 8.8 ; Ceiling Cavity Ratio = .46 ; Floor Cavity Ratio = 0

2. Obtain effective ceiling cavity reflectances ( $\mu_{rc}$ ) from Table B;  $\mu_{rc} = 64$

3. Obtain effective floor cavity reflectance ( $\mu_{rf}$ ) from Table B;  $\mu_{rf} = 20$

4. Find coefficient of utilization from published data (for  $\mu_{rc} = 20\%$ ) C.U. = .32

$$\frac{\text{No. of FIXTURES}}{\text{=}} \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$= \frac{10 \times 318}{3100 \times .32 \times .75} = \frac{3180}{744} = 4.3$$

156

OUTSIDE

90029181

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... H.L. BLDG.....

Area to be lighted..... LAB. #4.....


Design level of illumination..... 70 FC..... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 17 ..... Room Length  
 ..... 11 ..... Room Width  
 ..... 7 ..... Height of room between luminaire & work plane (hrc)  
 ..... 0.5 ..... Distance from luminaire plane to ceiling (hcc)  
 ..... 2.5 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 70 ..... Ceiling  
 ..... { ..... Walls above luminaire plane  
 .... 50 ..... Walls between luminaire & work plane  
 ..... { ..... Walls below work plane  
 ..... 20 ..... Floor

### Luminaire

Manufacturer .....  
 Catalog No. ..... 7100 .....  
 No. & Type lamps ..... 2 F40 CW .....  
 Lumens/lamp ..... 6200 .....  
 Light loss Factor ..... .75 ..... (LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

$$\text{Room Cavity Ratio} = 5.24 ; \text{Ceiling Cavity Ratio} = 0.4 ; \text{Floor Cavity Ratio} = 1.9$$

- Obtain effective ceiling cavity reflectances ( $\mu_{rc}$ ) from Table B;  $\mu_{rc} = .65$

- Obtain effective floor cavity reflectance ( $\mu_{rf}$ ) from Table B;  $\mu_{rf} = .18$

- Find coefficient of utilization from published data (for  $\mu_{rl} = 20\%$ ) C.U. = .43

$$\frac{\text{No. of FIXTURES}}{\text{FOOT CANDLES} \times \text{AREA}} = \frac{1}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$= \frac{70 \times 187}{6200 \times .43 \times .75} = \frac{13090}{1999.5} = 6.5 - 7$$

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... H.L. AHRE .....

Area to be lighted..... LAB... N.O. 1, 2, 3 .....


Design level of illumination..... 70. FC..... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 18 ..... Room Length  
 ..... 15 ..... Room Width  
 ..... 7 ..... Height of room between luminaire & work plane (hrc)  
 ..... 0.5 ..... Distance from luminaire plane to ceiling (hcc)  
 ..... 2.5 ..... Height of work plane above floor (hfc)



Room Surface Reflectance in %

..... 70 ..... Ceiling  
 ..... 50 ..... Walls above luminaire plane  
 ... 50 { ..... Walls between luminaire &  
 ..... work plane  
 ..... 20 ..... Walls below work plane  
 ..... 20 ..... Floor

### Luminaire

Manufacturer .....  
 Catalog No. ..... 7120 .....  
 No. & Type lamps ..... 2 F. 40 CW .....  
 Lumens/Lamp ..... 6200 .....  
 Light loss Factor ..... .75 .....  
 (LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

1. Determine cavity ratios using Table A or by formula

Room Cavity Ratio = 4.3 ; Ceiling Cavity Ratio = .3 ; Floor Cavity Ratio = 1.5

2. Obtain effective ceiling cavity reflectances ( $\mu_{rc}$ ) from Table B;  $\mu_{rc} = .66$

3. Obtain effective floor cavity reflectance ( $\mu_{rf}$ ) from Table B;  $\mu_{rf} = .18$

4. Find coefficient of utilization from published data (for  $\mu_{rc} = 20\%$ ) C.U. = .48

$$\frac{\text{No. of FIXTURES}}{\text{=}} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$= \frac{70 \times 270}{6200 \times .48 \times .75} = \frac{18900}{2232} = 8.46 - 9$$

S81PS008

158

90029183

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... H. L. BLDG .....

Area to be lighted..... OBSERVATION ROOM .....

Design level of illumination..... 70 FC ..... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions


..... 20 ..... Room Length

..... 10 ..... Room Width

..... 7 ..... Height of room between luminaire & work plane (hrc)

..... 0.5 ..... Distance from luminaire plane to ceiling (hcc)

..... 2.5 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 70 ..... Ceiling

..... { 50 ..... Walls above luminaire plane

..... } 50 ..... Walls between luminaire & work plane

..... { 50 ..... Walls below work plane

..... 20 ..... Floor

### Luminaire

Manufacturer .....

Catalog No. .... 7100 .....

No. & Type lamps ... 2 - F40 CW .....

Lumens/lamp .... 6200 .....

Light loss Factor .... .75 .....

(LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

### 1. Determine cavity ratios using Table A or by formula

$$\text{Room Cavity Ratio} = 5.25 ; \text{Ceiling Cavity Ratio} = 0.4 ; \text{Floor Cavity Ratio} = 1.9$$

### 2. Obtain effective ceiling cavity reflectances ( $\rho_{rc}$ ) from Table B; $\rho_{rc} = .65$

### 3. Obtain effective floor cavity reflectance ( $\rho_{rf}$ ) from Table B; $\rho_{rf} = .18$

### 4. Find coefficient of utilization from published data (for $\rho_{rf} = 20\%$ ) C.U. = .43

$$\text{No. of FIXTURES} = \frac{\text{FCOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$= \frac{70 \times 200}{6200 \times .43 \times .75} = \frac{14000}{1999.5} = 7$$

90029184

19

59

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... H. L. BLDG.....

Area to be lighted..... CORRIDOR.....


Design level of illumination..... 10 F.C. .... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 19 ..... Room Length  
 ..... 5 ..... Room Width  
 ..... 13.5 ..... Height of room between luminaire & work plane (hrc)  
 ..... 9.5 ..... Distance from luminaire plane to ceiling (hcc)  
 ..... 0 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 20 ..... Ceiling  
 ..... { ..... Walls above luminaire plane  
 ..... 50 ..... Walls between luminaire & work plane  
 ..... } ..... Walls below work plane  
 ..... 20 ..... Floor

### Luminaire

Manufacturer .....  
 Catalog No. ..... 6100 .....  
 No. & Type lamps ..... 1-P40 SW .....  
 Lumens/Lamp ..... 3100 .....  
 Light loss Factor ..... .75 .....  
 (LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = 17.0 ; Ceiling Cavity Ratio = .6 ; Floor Cavity Ratio = 0

- Obtain effective ceiling cavity reflectances ( $\mu_{rc}$ ) from Table B;  $\mu_{rc} = 63$

- Obtain effective floor cavity reflectance ( $\mu_{rf}$ ) from Table B;  $\mu_{rf} = 20$

- Find coefficient of utilization from published data (for  $\mu_{rc} = 20\%$ ) C.U. = .25

$$\text{No. of FIXTURES} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$= \frac{10 \times 95}{3100 \times .75 \times .25} = \frac{950}{581} \quad 1.6 - 2$$

4018500P

160

90029185

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... H.L. BLDG.....

Area to be lighted..... CORRIDOR #3.....

Design level of illumination..... 10 F.C. .... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions


..... 15..... Room Length

..... 6..... Room Width

..... 12.5..... Height of room between luminaire & work plane (hrc)

..... 0.5..... Distance from luminaire plane to ceiling (hcc)

..... 2.5..... Height of work plane above floor (hfc)



Room Surface Reflectance in %

..... 20..... Ceiling

..... { 50..... Walls above luminaire plane

..... 50..... Walls between luminaire & work plane

..... { 50..... Walls below work plane

..... 20..... Floor

### Luminaire

Manufacturer .....

Catalog No. ..... 6100 .....

No. & Type lamps ..... 1-F12 C.W. ....

Lumens/Lamp ..... 315 .....

Light loss Factor ..... .75  
(LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

$$\text{Room Cavity Ratio} = 15.7 \quad ; \quad \text{Ceiling Cavity Ratio} = .6 \quad ; \quad \text{Floor Cavity Ratio} = 0$$

- Obtain effective ceiling cavity reflectances ( $\rho_{rc}$ ) from Table B;  $\rho_{rc} = .63$

- Obtain effective floor cavity reflectance ( $\rho_{rf}$ ) from Table B;  $\rho_{rf} = .20$

- Find coefficient of utilization from published data (for  $\rho_{rf} = 20\%$ ) C.U. = .25

$$\frac{\text{No. of FIXTURES}}{\text{Foot Candles} \times \text{Area}} = \frac{\text{Lamps/Fixture} \times \text{Lumens/Lamp} \times \text{C.U.} \times \text{LLF}}{3100 \times .25 \times .75}$$

$$= \frac{10 \times 90}{3100 \times .25 \times .75} = \frac{900}{581} \quad 1.5 - 2$$

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... H.L. BLDG.....

Area to be lighted..... CORRIDOR 14.....


Design level of illumination..... 10. PC..... (written) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 10.3 ..... Room Length  
 ..... 5 ..... Room Width  
 ..... 12.5 ..... Height of room between luminaire & work plane (hrc)  
 ..... 0.5 ..... Distance from luminaire plane to ceiling (hcc)  
 ..... 0 ..... Height of work plane above floor (hfc)



Room Surface Reflectance 17 %

..... 70 ..... Ceiling  
 ..... { Walls above luminaire plane  
 ..... 50 ..... Walls between luminaire & work plane  
 ..... } Walls below work plane  
 ..... 20 ..... Floor

### Luminaire

Manufacturer .....  
 Catalog No. ..... 6100 .....  
 No. & Type lamps ..... 1-P.40. SW .....  
 Lumens/Lamp ..... 3100 .....  
 Light loss Factor ..... .75 ..... (LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

1. Determine cavity ratios using Table A or by formula

Room Cavity Ratio = 14 ; Ceiling Cavity Ratio = .5 ; Floor Cavity Ratio = 0

2. Obtain effective ceiling cavity reflectances ( $\mu_{rc}$ ) from Table B;  $\mu_{rc} = 64$

3. Obtain effective floor cavity reflectance ( $\mu_{rf}$ ) from Table B;  $\mu_{rf} = 20$

4. Find coefficient of utilization from published data (for  $\mu_r = 20\%$ ) C.U. = .26

$$\frac{\text{No. of FIXTURES}}{\text{FOOT CANDLES X AREA}} = \frac{\text{LAMPS/FIXTURE X LUMENS/LAMP X CU X LLF}}$$

$$= \frac{10 \times 103 \times 5}{3100 \times .26 \times .75} = \frac{5150}{604.5} = 8.5 - 9 \text{ ea}$$

90029187

381RS004

1A

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... H. L. BLDG.....

Area to be lighted..... EQUIP. REPAIR ROOM (HOIST MAINT).....

Design level of illumination..... 20 FC..... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions


..... 44 ..... Room Length

..... 12 ..... Room Width

..... 16.5 ..... Height of room between luminaire & work plane (hrc)

..... 2.5 ..... Distance from luminaire plane to ceiling (hcc)

..... 3 ..... Height of work plane above floor (hfc)



22

Room Surface Reflectance 10 %

..... 70 ..... Ceiling

..... ..... Walls above luminaire plane

..... 40.3 ..... Walls between luminaire & work plane

..... ..... Walls below work plane

..... 20 ..... Floor

### Luminaire

Manufacturer .....

Catalog No. .... 1930 .....

No. & Type lamps ... 1 - 100 W. HPS .....

Lumens/Lamp .... 9500 .....

Light loss Factor ..... 81  
(LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = 2.7 ; Ceiling Cavity Ratio = 1.3 ; Floor Cavity Ratio = 1.6

- Obtain effective ceiling cavity reflectances ( $\mu_{rc}$ ) from Table B;  $\mu_{rc} = .56$

- Obtain effective floor cavity reflectance ( $\mu_{rf}$ ) from Table B;  $\mu_{rf} = .18$

- Find coefficient of utilization from published data (for  $\mu_{rl} = 20\%$ ) C.U. = .43

$$\text{No. of FIXTURES} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$= \frac{20 \times 528}{9500 \times .43 \times .81} = \frac{11560}{3308.8} = 3$$

.90029188

163

23

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... H.L. BLDG.....

Area to be lighted..... CASK DECONTAMINATION .....


Design level of illumination..... 50 FC..... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 90 ..... Room Length  
 ..... 62 ..... Room Width  
 ..... 7.5 ..... Height of room between luminaire & work plane (hrc)  
 ..... 2.5 ..... Distance from luminaire plane to ceiling (hcc)  
 ..... 4 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 70 ..... Ceiling  
 ..... Walls above luminaire plane  
 ... 50 ..... Walls between luminaire & work plane  
 ..... Walls below work plane  
 ..... 22 ..... Floor

### Luminaire

Manufacturer .... HQDOPHANE.....  
 Catalog No. .... 1047 EG-P1-277.....  
 No. & Type lamps .... ONE 400W HPS.....  
 Lumens/Lamp .... 50,000.....  
 Light loss Factor .... .81.....  
 (LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = .43 ; Ceiling Cavity Ratio = .25 ; Floor Cavity Ratio = .4

- Obtain effective ceiling cavity reflectances ( $\rho_{ce}$ ) from Table B;  $\rho_{ce} = .64$

- Obtain effective floor cavity reflectance ( $\rho_{fe}$ ) from Table B;  $\rho_{fe} = .20$

- Find coefficient of utilization from published data (for  $\rho_{fl} = 20\%$ ) C.U. = .55

$$\text{No. of FIXTURES} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$= \frac{50 \times 5580}{50000 \times .81 \times .55} = \frac{279,000}{22275} = 12.5$$

3 rows of 4  
 081R5000  
 20 1/2 center  
 22 1/2 center

124

90029189

TRU WASTE FACILITY

90029190

165-166

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... L L BLDG.....

Area to be lighted..... A.O.B.G.Y.....

Design level of illumination..... 10 F.C. .... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions


..... 44 ..... Room Length

..... 15 ..... Room Width

..... 7 ..... Height of room between luminaire & work plane (hrc)

..... 0.5 ..... Distance from luminaire plane to ceiling (hcc)

..... 2.5 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 70 ..... Ceiling

..... 70 ..... Walls above luminaire plane

..... 70 ..... Walls between luminaire & work plane

..... 70 ..... Walls below work plane

..... 42 ..... Floor

### Luminaire

Manufacturer .....

Catalog No. .... 7100 .....

No. & Type lamps .... 2 - F40CV .....

Lumens/Lamp ..... 3100 .....

Light loss Factor ..... .75 .....

(LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = .22 ; Ceiling Cavity Ratio = .15 ; Floor Cavity Ratio = .15

- Obtain effective ceiling cavity reflectances ( $\rho_{rc}$ ) from Table B;  $\rho_{rc} = .68$

- Obtain effective floor cavity reflectance ( $\rho_{rf}$ ) from Table B;  $\rho_{rf} = .19$

- Find coefficient of utilization from published data (for  $\rho_{rf} = 20\%$ ) C.U. = .61

$$\text{No. of FIXTURES} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$\frac{10 \times 44 \times 2.5}{1.200 \times .61 \times .75} = \frac{1100}{2837} = 3.8$$

90029191

167

SEARCHED

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... L.L. BLDG.....

Area to be lighted..... CONFERENCE.....

Design level of illumination..... 50. FG..... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions


..... 35 ..... Room Length

..... 16 ..... Room Width

..... Height of room between luminaire & work plane (hrc)

..... 9.5 ..... Distance from luminaire plane to ceiling (hcc)

..... 2.5 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 70 ..... Ceiling

..... Walls above luminaire plane

..... 22 ..... Walls between luminaire & work plane

..... Walls below work plane

..... 12 ..... Floor

### Luminaire

Manufacturer .....

Catalog No. .... 123

No. & Type lamps ... 2 - F40CW

Lumens/Lamp ..... 3100

Light loss Factor ..... .75  
(LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = .32 ; Ceiling Cavity Ratio = .27 ; Floor Cavity Ratio = .125

2. Obtain effective ceiling cavity reflectances ( $\rho_{rec}$ ) from Table B;  $\rho_{rec} = .66$

3. Obtain effective floor cavity reflectance ( $\rho_{rfc}$ ) from Table B;  $\rho_{rfc} = .20$

4. Find coefficient of utilization from published data (for  $\rho_{rc} = 20\%$ ) C.U. = .45

$$\frac{\text{No. of FIXTURES}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$\frac{20 \times 2.5 \times 16}{6200 \times .45 \times .75} = \frac{20000}{2093} = 7.5$$

18195068

168

90029192

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... L.L. BLDG.....

Area to be lighted..... P.V. - LOCKER - R.R. AREA.....

Design level of illumination..... 10. F.C. .... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions


..... 22..... Room Length

..... 15..... Room Width

..... 7.2..... Height of room between luminaire & work plane (hrc)

..... 2.8..... Distance from luminaire plane to ceiling (hcc)

..... 0..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 70..... Ceiling

..... 50..... Walls above luminaire plane

..... 50..... Walls between luminaire & work plane

..... 50..... Walls below work plane

..... 20..... Floor

### Luminaire

Manufacturer .....

Catalog No. ..... 7100.....

No. & Type lamps ..... 2 - F40CW.....

Lumens/Lamp ..... 3100.....

Light loss Factor ..... 75.....  
(LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = .22 ; Ceiling Cavity Ratio = .38 ; Floor Cavity Ratio = .6

2. Obtain effective ceiling cavity reflectances ( $\rho_{ce}$ ) from Table B;  $\rho_{ce} = .65$

3. Obtain effective floor cavity reflectance ( $\rho_{fr}$ ) from Table B;  $\rho_{fr} = .19$

4. Find coefficient of utilization from published data (for  $\rho_{fr} = 20\%$ ) C.U. = .60

$$\frac{\text{No. of FIXTURES}}{\text{LAMPS/FIXTURE}} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$= \frac{10 \times 90 \times 45}{6200 \times .75 \times .60} = \frac{40500}{2790} = 14.5$$

169

3

90029193

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... L.L.BLDG.....

Area to be lighted..... LABORATORY.....


Design level of illumination..... 70. FC..... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 10 ..... Room Length  
 ..... 8.2 ..... Room Width  
 ..... 7 ..... Height of room between luminaire & work plane (hrc)  
 ..... 0.5 ..... Distance from luminaire plane to ceiling (hcc)  
 ..... 2.5 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 70 ..... Ceiling  
 ..... 50 ..... Walls above luminaire plane  
 ..... 50 ..... Walls between luminaire & work plane  
 ..... 20 ..... Walls below work plane  
 ..... 20 ..... Floor

### Luminaire

Manufacturer .....  
 Catalog No. ..... 7100  
 No. & Type lamps ..... 2 - F40CLV  
 Lumens/Lamp ..... 3100  
 Light loss Factor ..... .75  
 (LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = .2 ; Ceiling Cavity Ratio = .15 ; Floor Cavity Ratio = .75

- Obtain effective ceiling cavity reflectances ( $\rho_{rc}$ ) from Table B;  $\rho_{rc} = .68$

- Obtain effective floor cavity reflectance ( $\rho_{rf}$ ) from Table B;  $\rho_{rf} = .19$

- Find coefficient of utilization from published data (for  $\rho_{rl} = 20\%$ ) C.U. = .60

$$\frac{\text{No. of Fixtures}}{\text{Foot Candles} \times \text{Area}} = \frac{\text{Foot Candles} \times \text{Area}}{\text{Lamps/Fixture} \times \text{Lumens/Lamp} \times \text{C.U.} \times \text{LLF}}$$

$$\frac{70 \times 60 \times 22}{100 \times 2 \times .60 \times .75} = \frac{92400}{2700} = 33$$

178

90029194

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... L.L. BLDG.....

Area to be lighted..... I.B.P. AREA.....

Design level of illumination..... 30 F.C. .... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions


..... 200 ..... Room Length

..... 150 ..... Room Width

..... 11.5 ..... Height of room between luminaire & work plane (hrc)

..... 2.5 ..... Distance from luminaire plane to ceiling (hcc)

..... 6 ..... Height of work plane above floor (hfc)



Room Surface Reflectance 10 %

..... 70 ..... Ceiling

..... 40 ..... Walls above luminaire plane

..... 40 ..... Walls between luminaire & work plane

..... 40 ..... Walls below work plane

..... 10 ..... Floor

### Luminaire

Manufacturer ..... HOLLOW PHANE .....

Catalog No. ..... 1930 .....

No. & Type lamps ..... 1-100 W. HPS .....

Lumens/Lamp ..... 9500 .....

Light loss Factor ..... .81 .....

(LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = .9 ; Ceiling Cavity Ratio = .2 ; Floor Cavity Ratio = .48

- Obtain effective ceiling cavity reflectances ( $\rho_{rc}$ ) from Table B;  $\rho_{rc} = .67$

- Obtain effective floor cavity reflectance ( $\rho_{rf}$ ) from Table B;  $\rho_{rf} = .19$

- Find coefficient of utilization from published data (for  $\rho_{rf} = 20\%$ ) C.U. = .74

$$\frac{\text{No. of FIXTURES}}{\text{=}} \frac{\text{FEET CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{C.U.} \times \text{LLF}}$$

$$\frac{30 \times 200 \times .74}{9500 \times .81 \times .74} = \frac{504000}{5694} = 88$$

90029195

11

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... H.L. BLDG.....

Area to be lighted..... AIR LOCK #1 & 2.....

Design level of illumination..... 10 FC..... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions


..... 12.0 ..... Room Length

..... 2.0 ..... Room Width

..... 11.5 ..... Height of room between luminaire & work plane (hrc)

..... 2.5 ..... Distance from luminaire plane to ceiling (hcc)

..... 6 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... Ceiling

..... Walls above luminaire plane

..... 5.0 ..... Walls between luminaire & work plane

..... Walls below work plane

..... 2.0 ..... Floor

### Luminaire

Manufacturer .....

Catalog No. .... 1930 .....

No. & Type lamps .... 100W .....

Lumens/Lamp .... 9500 .....

Light loss Factor ..... (LLD x LDD) .....

..... .81 .....

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

$$\text{Room Cavity Ratio} = 5.5 \quad ; \quad \text{Ceiling Cavity Ratio} = .75 \quad ; \quad \text{Floor Cavity Ratio} = .8$$

- Obtain effective ceiling cavity reflectances ( $\rho_{ce}$ ) from Table B;  $\rho_{ce} = .44$

- Obtain effective floor cavity reflectance ( $\rho_{fr}$ ) from Table B;  $\rho_{fr} = .18$

- Find coefficient of utilization from published data (for  $\rho_{fr} = 20\%$ ) C.U. = .53

$$\frac{\text{NO. OF FIXTURES}}{\text{FEAT CANDLES X AREA}} = \frac{\text{LAMPS/FIXTURE X LUMENS/LAMP X CU X LLF}}{}$$

$$\frac{10 \times 2.0 \times 12.0}{7500 \times .53 \times .81} = \frac{24000}{4078} = 5.8 \rightarrow 6 \times 2 \text{ ft}^2 \\ \text{AL 182} \\ = 12 \text{ fix} \\ 20' centers$$

90029196

6172

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... L.L. BLDG.....

Area to be lighted..... AIR LOCK \* S.F. 4.....

Design level of illumination..... 10. FC..... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions


..... 60 ..... Room Length

..... 20 ..... Room Width

..... 11.5 ..... Height of room between luminaire & work plane (hrc)

..... 2.5 ..... Distance from luminaire plane to ceiling (hcc)

..... 6 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... Ceiling

..... Walls above luminaire plane

..... 50 ..... Walls between luminaire & work plane

..... Walls below work plane

..... 20 ..... Floor

### Luminaire

Manufacturer .....

Catalog No. .... 1930 .....

No. & Type lamps .... 100W .....

Lumens/Lamp .... 9500 .....

Light loss Factor .... .81 .....

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

$$\text{Room Cavity Ratio} = 3.8 ; \text{Ceiling Cavity Ratio} = .8 ; \text{Floor Cavity Ratio} = 1.72$$

- Obtain effective ceiling cavity reflectances ( $\rho_{ce}$ ) from Table B;  $\rho_{ce} = .43$

- Obtain effective floor cavity reflectance ( $\rho_{fe}$ ) from Table B;  $\rho_{fe} = .18$

- Find coefficient of utilization from published data (for  $\rho_{fe} = 20\%$ ) C.U. = .57

$$\frac{\text{No. of FIXTURES}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$= \frac{10 \times 60 \times 20}{9500 \times .57 \times .81} = \frac{12000}{4386} = 2.7 \rightarrow 3 - 6 \text{ for } 24/\text{LS}$$

3 on 20' centers

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... L.L. BLDG

Area to be lighted..... AIR LOCK #5

Design level of illumination..... 10. F.S. .... (initial) (mainained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions


.... 36 ..... Room Length

.... 22 ..... Room Width

.... 11.5 ..... Height of room between luminaire & work plane (hrc)

.... 2.5 ..... Distance from luminaire plane to ceiling (hcc)

.... 6 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

.... Ceiling

.... Walls above luminaire plane

.... 50 ..... Walls between luminaire & work plane

.... Walls below work plane

.... 20 ..... Floor

### Luminaire

Manufacturer .....

Catalog No. .... 1930 .....

No. & Type lamps ... 100 W .....

Lumens/Lamp ..... 9500 .....

Light loss Factor ..... .81 .....

(LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

$$\text{Room Cavity Ratio} = 4.2 ; \text{Ceiling Cavity Ratio} = .9 ; \text{Floor Cavity Ratio} = 2.1$$

- Obtain effective ceiling cavity reflectances ( $\rho_{ce}$ ) from Table B;  $\rho_{ce} = .43$

- Obtain effective floor cavity reflectance ( $\rho_{fe}$ ) from Table B;  $\rho_{fe} = .18$

- Find coefficient of utilization from published data (for  $\rho_f = 20\%$ ) C.U. = .54

$$\frac{\text{No. of FIXTURES}}{\text{Foot Candles} \times \text{Area}} = \frac{\text{Foot Candles} \times \text{Area}}{\text{Lamps/Fixture} \times \text{Lumens/Lamp} \times \text{C.U.} \times \text{LLF}}$$

$$\frac{10 \times 36 \times 22}{9500 \times 156 \times .81} = \frac{7920}{4309} = 1.8 - 2 \text{ fix}$$

8 174

90029198

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... L.L. BLDG.....

Area to be lighted..... AIR LOCK #6.....

Design level of illumination..... 10..... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions


..... 20..... Room Length

..... 12..... Room Width

..... 11.8..... Height of room between luminaire & work plane (hrc)

..... 1.5..... Distance from luminaire plane to ceiling (hcc)

..... 6..... Height of work plane above floor (hfc)



Room Surface Reflectance 10 %

### Luminaire

..... Ceiling

Manufacturer .....

..... Walls above luminaire plane

Catalog No. .... 1930 .....

..... Walls between luminaire & work plane

No. & Type lamps ..... 100 W .....

..... Walls below work plane

Lumens/Lamp ..... 9500 .....

..... Floor

Light loss Factor ..... 81 .....

(LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = 7.6 ; Ceiling Cavity Ratio = 1.6 ; Floor Cavity Ratio = 3.9

- Obtain effective ceiling cavity reflectances ( $\rho_{rc}$ ) from Table B;  $\rho_{rc} = .39$

- Obtain effective floor cavity reflectance ( $\rho_{rf}$ ) from Table B;  $\rho_{rf} = .17$

- Find coefficient of utilization from published data (for  $\rho_r = 20\%$ ) C.U. = .44

$$\text{No. of FIXTURES} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$\frac{10 \times 20 \times 12}{9500 \times .81 \times .44} = \frac{2400}{3387} = 1$$

90029199

9

175

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... L.L. BLDG

Area to be lighted..... SHAFT ROOM


Design level of illumination..... 50 ..... (5000) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 6.0 ..... Room Length  
 ..... 3.2 ..... Room Width  
 ..... 13.5 ..... Height of room between luminaire & work plane (hrc)  
 ..... 7.5 ..... Distance from luminaire plane to ceiling (hcc)  
 ..... 6 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 72 ..... Ceiling  
 ..... 50 ..... Walls above luminaire plane  
 ..... 50 ..... Walls between luminaire & work plane  
 ..... 50 ..... Walls below work plane  
 ..... 20 ..... Floor

### Luminaire

Manufacturer .....  
 Catalog No. ..... 1932  
 No. & Type lamps ..... 100W  
 Lumens/Lamp ..... 9500  
 Light loss Factor ..... .81  
 (LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

$$\text{Room Cavity Ratio} = 1.7 ; \text{Ceiling Cavity Ratio} = .6 ; \text{Floor Cavity Ratio} = 1.4$$

- Obtain effective ceiling cavity reflectances ( $\rho_{ce}$ ) from Table B;  $\rho_{ce} = .62$

- Obtain effective floor cavity reflectance ( $\rho_{fe}$ ) from Table B;  $\rho_{fe} = .18$

- Find coefficient of utilization from published data (for  $\rho_{fl} = 20\%$ ) C.U. = .64

$$\frac{\text{No. of FIXTURES}}{\text{FCBT CANDLES X AREA}} = \frac{\text{LAMPS/FIXTURE X LUMENS/LAMP X CU X LLF}}$$

$$\frac{50 \times 60 \times 32}{9500 \times .64 \times .81} = \frac{76800}{4924.8} = 15.5$$

RETR0008

90029Z096

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... L. L. BLDG.....

Area to be lighted..... OVER PACK AREA.....

Design level of illumination..... 50. FC..... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions


..... 70 ..... Room Length

..... 40 ..... Room Width

..... 12.5 ..... Height of room between luminaire & work plane (hrc)

..... 1.7 ..... Distance from luminaire plane to ceiling (hcc)

..... 4 ..... Height of work plane above floor (hfc)



Room Surface Reflectance in %

..... 70 ..... Ceiling

..... ..... Walls above luminaire plane

..... 5.2 ..... Walls between luminaire & work plane

..... 4 ..... Walls below work plane

..... 20 ..... Floor

### Luminaire

Manufacturer .....

Catalog No. .... 1930 .....

No. & Type lamps ..... 100 W .....

Lumens/Lamp ..... 9500 .....

Light loss Factor ..... (.81) .....

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

$$\text{Room Cavity Ratio} = .245 ; \text{Ceiling Cavity Ratio} = .49 ; \text{Floor Cavity Ratio} = .8$$

- Obtain effective ceiling cavity reflectances ( $\rho_{rc}$ ) from Table B;  $\rho_{rc} = .64$

- Obtain effective floor cavity reflectance ( $\rho_{rf}$ ) from Table B;  $\rho_{rf} = .19$

- Find coefficient of utilization from published data (for  $\rho_{rf} = 20\%$ ) C.U. = .64

$$\frac{\text{No. of FIXTURES}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$\frac{50 \times 70 \times 40}{9500 \times .64 \times .81} = \frac{140000}{4925} = 28$$

90029201

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... L.L. BLDG.....

Area to be lighted..... DESK AREA.....

Design level of illumination..... 20 F.C. (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions


.... 300' Room Length

.... 60' Room Width

.... 31.5' Height of room between luminaire & work plane (hrc)

.... 2.5' Distance from luminaire plane to ceiling (hcc)

.... 6' Height of work plane above floor (hfc)



### Room Surface Reflectance in %

.... 50% Ceiling

.... Walls above luminaire plane

.... 50% { Walls between luminaire & work plane

.... Walls below work plane

.... 12% Floor

### Luminaire

Manufacturer ..... 1908

Catalog No. ....

No. & Type lamps .... 150 W. HPS

Lumens/Lamp ..... 16000

Light loss Factor ..... .81  
(LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

### 1. Determine cavity ratios using Table A or by formula

Room Cavity Ratio = .3 ; Ceiling Cavity Ratio = .25 ; Floor Cavity Ratio = .6

2. Obtain effective ceiling cavity reflectances ( $\rho_{rc}$ ) from Table B;  $\rho_{rc} = .48$

3. Obtain effective floor cavity reflectance ( $\rho_{rf}$ ) from Table B;  $\rho_{rf} = .19$

4. Find coefficient of utilization from published data (for  $\rho_{rc} = 20\%$ ) C.U. = .7

$$\text{No. of FIXTURES} = \frac{\text{FOOT CAVITIES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{C.U.} \times \text{LLF}}$$

$$= \frac{20 \times 300 \times 60}{16000 \times .7 \times .81} = \frac{360,000}{1056} = 340$$

1000000

12 178

90029202

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... L.L.C. BLDG.....

Area to be lighted..... MECH. EQUIP. ROOM.....


Design level of illumination..... 20. FC..... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 60 ..... Room Length  
 ..... 45 ..... Room Width  
 ..... 13.5 ..... Height of room between luminaire & work plane (hrc)  
 ..... 2.5 ..... Distance from luminaire plane to ceiling (hcc)  
 ..... 4 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

Ceiling ..... 50  
 Walls above luminaire plane ..... 50  
 Walls between luminaire & work plane ..... 50  
 Walls below work plane ..... 20  
 Floor ..... 20

### Luminaire

Manufacturer .....  
 Catalog No. ..... 1930 .....  
 No. & Type lamps ..... 100 W .....  
 Lumens/Lamp ..... 9500 .....  
 Light loss Factor ..... .81 .....  
 (LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

$$\text{Room Cavity Ratio} = .26 \quad ; \quad \text{Ceiling Cavity Ratio} = .49 \quad ; \quad \text{Floor Cavity Ratio} = .72$$

- Obtain effective ceiling cavity reflectances ( $\rho_{ce}$ ) from Table B;  $\rho_{ce} = .46$

- Obtain effective floor cavity reflectance ( $\rho_{fe}$ ) from Table B;  $\rho_{fe} = .19$

- Find coefficient of utilization from published data (for  $\rho_{fe} = 20\%$ ) C.U. = .62

$$\frac{\text{NO. OF FIXTURES}}{\text{NO. OF FIXTURES}} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$\frac{20 \times 60 \times 45}{9500 \times .62 \times .62} = \frac{54000}{4771} = 11.3$$

90029203

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... L.L. BLDG.....

Area to be lighted..... M.I.S.C. STORAGE..... #1.....


Design level of illumination..... 10. FC..... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 90 ..... Room Length  
 ..... 18 ..... Room Width  
 ..... 11.5 ..... Height of room between luminaire & work plane (hrc)  
 ..... 2.5 ..... Distance from luminaire plane to ceiling (hcc)  
 ..... 6 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... Ceiling  
 ..... Walls above luminaire plane  
 ..... 52 ..... Walls between luminaire & work plane  
 ..... Walls below work plane  
 ..... 22 ..... Floor

### Luminaire

Manufacturer .....  
 Catalog No. ..... 1930 .....  
 No. & Type lamps ... 120W .....  
 Lumens/Lamp ..... 7500 .....  
 Light loss Factor ..... .70 ..... (LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

### 1. Determine cavity ratios using Table A or by formula

Room Cavity Ratio = .8 ; Ceiling Cavity Ratio = .37 ; Floor Cavity Ratio = .9

2. Obtain effective ceiling cavity reflectances ( $\mu_{rc}$ ) from Table B;  $\mu_{rc} = .46$

3. Obtain effective floor cavity reflectance ( $\mu_{rf}$ ) from Table B;  $\mu_{rf} = .19$

4. Find coefficient of utilization from published data (for  $\mu_{rc} = 20\%$ ) C.U. = .66

$$\text{No. of FIXTURES} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$\frac{10 \times 90 \times 48}{9500 \times .66 \times .81} = \frac{432.00}{5078} = 8.5 -$$

EDSR500P

14  
180

90029204

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address.....

Area to be lighted..... MISC. STORAGE #2

Design level of illumination..... 10 FC (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions


..... 56 ..... Room Length

..... 56 ..... Room Width

..... 11.5 ..... Height of room between luminaire & work plane (hrc)

..... 6.5 ..... Distance from luminaire plane to ceiling (hcc)

..... 6 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... Ceiling

### Luminaire

..... Walls above luminaire plane

Manufacturer .....

..... 52.5 ..... Walls between luminaire & work plane

Catalog No. .... 1932 .....

..... Walls below work plane

No. & Type lamps .... 100 W .....

..... Floor

Lumens/Lamp .... 9500 .....

Light loss Factor (LLD x LDD) .... .81 .....

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = 2 ; Ceiling Cavity Ratio = , 4 ; Floor Cavity Ratio = /

2. Obtain effective ceiling cavity reflectances ( $\rho_{rc}$ ) from Table B;  $\rho_{rc} = .46$

3. Obtain effective floor cavity reflectance ( $\rho_{rf}$ ) from Table B;  $\rho_{rf} = .19$

4. Find coefficient of utilization from published data (for  $\rho_{rf} = 20\%$ ) C.U. = .66

$$\text{No. of FIXTURES} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$\frac{10 \times 56 \times 56}{9500 \times .66 \times .81} = \frac{31360}{5078.7} = .6$$

181-182

90029205

5

ADMINISTRATION FACILITY

183-184

90029206

**For Use with IES Zonal-Cavity Method**

(See individual data sheets on luminaires for coefficients of utilization)

### GENERAL INFORMATION

Company name and address..... AD. BLDG.....

Area to be lighted..... 6' x 12' x 8'.....


Design level of illumination..... 10. FC..... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

### DESCRIPTION OF AREA AND LUMINAIRE

#### Dimensions

..... 30 ..... Room Length  
 ..... 18 ..... Room Width  
 ..... 6 ..... Height of room between luminaire & work plane (hrc)  
 ..... 1.5 ..... Distance from luminaire plane to ceiling (hcc)  
 ..... 4.5 ..... Height of work plane above floor (hfc)



#### Room Surface Reflectance in %

..... 80 ..... Ceiling  
 ..... 50 ..... Walls above luminaire plane  
 ..... 50 ..... Walls between luminaire & work plane  
 ..... 20 ..... Walls below work plane  
 ..... 20 ..... Floor

#### Luminaire

Manufacturer .....  
 Catalog No. .....  
 No. & Type lamps ..... 2 - F40 .....  
 Lumens/Lamp ..... 3100 .....  
 Light loss Factor ..... .75 .....  
 (LLD x LDD)

### SELECTION OF COEFFICIENT OF UTILIZATION

#### 1. Determine cavity ratios using Table A or by formula

Room Cavity Ratio = .7 ; Ceiling Cavity Ratio = .7 ; Floor Cavity Ratio = .1

2. Obtain effective ceiling cavity reflectances ( $\rho_{rc}$ ) from Table B;  $\rho_{rc} = .70$

3. Obtain effective floor cavity reflectance ( $\rho_{rf}$ ) from Table B;  $\rho_{rf} = .20$

4. Find coefficient of utilization from published data (for  $\rho_{rf} = 20\%$ ) C.U. = .63

$$\text{No. of FIXTURES} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$\frac{10 \times 30 \times 18}{12 \times .63 \times .75} = \frac{5400}{2929} = 2$$

90029207

185

For Use with IES Zonal-Cavity Method  
(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... A.D. BLDG.....

Area to be lighted..... ERDA OFFICE.....

Design level of illumination..... 70 FC..... (initially maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions


.... 54 ..... Room Length

.... 12 ..... Room Width

.... 6 ..... Height of room between luminaire & work plane (hrc)

.... 1.5 ..... Distance from luminaire plane to ceiling (hcc)

.... 2.5 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

	Luminaire
.... 80 ..... Ceiling	Manufacturer .....
..... Walls above luminaire plane	Catalog No. .....
.... 50 ..... Walls between luminaire & work plane	No. & Type lamps ..... 2 F 40
..... Walls below work plane	Lumens/Lamp ..... 3100
.... 20 ..... Floor	Light loss Factor ..... .75 (LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = 3 ; Ceiling Cavity Ratio = .75 ; Floor Cavity Ratio = 1.25

- Obtain effective ceiling cavity reflectances ( $\rho_{rc}$ ) from Table B;  $\rho_{rc} = 70$

- Obtain effective floor cavity reflectance ( $\rho_{rf}$ ) from Table B;  $\rho_{rf} = 19$

- Find coefficient of utilization from published data (for  $\rho_{rf} = 20\%$ ) C.U. = 40

$$\begin{aligned} \text{No. of fixtures} &= \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{C.U.} \times \text{LLF}} \\ &= \frac{70 \times 648}{4200 \times .60 \times .75} = \frac{45360}{2790} = 16 \end{aligned}$$

1000000

90029208

186

For Use with IES Zonal-Cavity Method  
(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... A.D. BLDG.....

Area to be lighted..... W.I.P.P. OFFICE.....

Design level of illumination..... 70 F.C. (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions


..... 7.4 ..... Room Length

..... 12 ..... Room Width

..... 9 ..... Height of room between luminaire & work plane (hrc)

..... 1.5 ..... Distance from luminaire plane to ceiling (hcc)

..... 2.5 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 80 ..... Ceiling

..... Walls above luminaire plane

..... 50 ..... Walls between luminaire & work plane

..... Walls below work plane

..... 20 ..... Floor

### Luminaire

Manufacturer .....

Catalog No. .....

No. & Type lamps ..... 2 - F40 .....

Lumens/Lamp ..... 3100 .....

Light loss Factor ..... 1.75 .....  
(LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

### 1. Determine cavity ratios using Table A or by formula

Room Cavity Ratio = 3 ; Ceiling Cavity Ratio = .75 ; Floor Cavity Ratio = 1.25

2. Obtain effective ceiling cavity reflectances ( $\rho_{rc}$ ) from Table B;  $\rho_{rc} = 70$

3. Obtain effective floor cavity reflectance ( $\rho_{rf}$ ) from Table B;  $\rho_{rf} = 19$

4. Find coefficient of utilization from published data (for  $\rho_{rl} = 20\%$ ) C.U. = .60

$$\frac{\text{No. of FIXTURES}}{\text{FOOT CANDLES} \times \text{AREA}} = \frac{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}{}$$

$$\frac{70 \times 648}{6200 \times .60 \times .75} = \frac{45360}{2790} = 16$$

90029209

For Use with IES Zonal-Cavity Method  
(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... AD BLDG.....

Area to be lighted..... MANAGEMENT CONF.....


Design level of illumination..... 50 FC..... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 24..... Room Length  
..... 12..... Room Width  
..... 6..... Height of room between luminaire & work plane (hrc)  
..... 11.5..... Distance from luminaire plane to ceiling (hcc)  
..... 2.5..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 80..... Ceiling  
..... Walls above luminaire plane  
..... 80..... Walls between luminaire & work plane  
..... Walls below work plane  
..... 20..... Floor

### Luminaire

Manufacturer .....  
Catalog No. .....  
No. & Type lamps ..... 2 F40  
Lumens/Lamp ..... 3100  
Light loss Factor ..... .75  
(LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

$$\text{Room Cavity Ratio} = 3.7 \quad ; \quad \text{Ceiling Cavity Ratio} = .9 \quad ; \quad \text{Floor Cavity Ratio} = 1.6$$

- Obtain effective ceiling cavity reflectances ( $\rho_{ce}$ ) from Table B;  $\rho_{ce} = .68$

- Obtain effective floor cavity reflectance ( $\rho_{fr}$ ) from Table B;  $\rho_{fr} = .20$

- Find coefficient of utilization from published data (for  $\rho_{fr} = 20\%$ ) C.U. = .55

$$\begin{aligned} \text{NO. OF FIXTURES} &= \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}} \\ &\quad \left. \begin{array}{c} | \\ | \\ | \\ | \end{array} \right| \\ &\quad \left. \begin{array}{c} | \\ | \\ | \\ | \end{array} \right| \\ &\quad \left. \begin{array}{c} | \\ | \\ | \\ | \end{array} \right| \\ &\quad \left. \begin{array}{c} | \\ | \\ | \\ | \end{array} \right| \\ &\quad \left. \begin{array}{c} | \\ | \\ | \\ | \end{array} \right| \end{aligned}$$

$$\frac{50 \times 12 \times 24}{62.00 \times .55 \times .75} = \frac{14400}{2557} = 5.6$$

90029210

188

**For Use with IES Zonal-Cavity Method**

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... A.D. BLDG.....

Area to be lighted..... THEATER- CONFERENCE RM.....

Design level of illumination..... 50 FC..... (Initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions


..... 48 ..... Room Length

..... 24 ..... Room Width

..... 6 ..... Height of room between luminaire & work plane (hrc)

..... 1.5 ..... Distance from luminaire plane to ceiling (hcc)

..... 2.5 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 80 ..... Ceiling

..... 50 ..... Walls above luminaire plane

..... 50 ..... Walls between luminaire & work plane

..... 50 ..... Walls below work plane

..... 20 ..... Floor

### Luminaire

Manufacturer .....

Catalog No. .....

No. & Type lamps ..... 2 - F40 .....

Lumens/Lamp ..... 3100 .....

Light loss Factor ..... .75  
(LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

### 1. Determine cavity ratios using Table A or by formula

Room Cavity Ratio = 1.8 ; Ceiling Cavity Ratio = .45 ; Floor Cavity Ratio = .75

2. Obtain effective ceiling cavity reflectances ( $\rho_{rc}$ ) from Table B;  $\rho_{rc} = .73$

3. Obtain effective floor cavity reflectance ( $\rho_{rf}$ ) from Table B;  $\rho_{rf} = .19$

4. Find coefficient of utilization from published data (for  $\rho_{rf} = 20\%$ ) C.U. = .70

$$\text{No. of FIXTURES} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$\frac{50 \times 1152}{6200 \times .70 \times .75} = \frac{57600}{3255} = 17.6$$

90029211

189

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... AD GLDG .....

Area to be lighted..... V.I.P. SEATING .....

Design level of illumination..... 50 ..... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions


..... 12 ..... Room Length

..... 12 ..... Room Width

..... 6 ..... Height of room between luminaire & work plane (hrc)

..... 1.5 ..... Distance from luminaire plane to ceiling (hcc)

..... 2.5 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 80 ..... Ceiling

..... 80 ..... Walls above luminaire plane

..... 80 ..... Walls between luminaire & work plane

..... 80 ..... Walls below work plane

..... 20 ..... Floor

### Luminaire

Manufacturer .....

Catalog No. .....

No. & Type lamps 27. F. 4P .....

Lumens/Lamp ..... 3100 .....

Light loss Factor ..... .75 .....

(LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = 4/16 ; Ceiling Cavity Ratio = 1.0 ; Floor Cavity Ratio = 1.7

- Obtain effective ceiling cavity reflectances ( $\rho_{ce}$ ) from Table B;  $\rho_{ce} = .67$

- Obtain effective floor cavity reflectance ( $\rho_{fe}$ ) from Table B;  $\rho_{fe} = .18$

- Find coefficient of utilization from published data (for  $\rho_{fe} = 20\%$ ) C.U. = .54

$$\text{No. of FIXTURES} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$\frac{50 \times 12 \times 18}{6200 \times .54 \times .75} = \frac{10800}{2511} = 4.3$$

DISCOUR

90029212

190

# ILLUMINATION CALCULATION SHEET

*For Use with IES Zonal-Cavity Method*

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... A.D. BLDG.....

Area to be lighted..... FOOD PREP.....


Design level of illumination..... 70 FC..... (initial) (maintained) FROM IES

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 36 ..... Room Length  
 ..... 18' ..... Room Width  
 ..... 6 ..... Height of room between luminaire & work plane (hrc)  
 ..... 1.5 ..... Distance from luminaire plane to ceiling (hcc)  
 ..... 4 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 80 ..... Ceiling  
 ..... Walls above luminaire plane  
 ..... 50 ..... Walls between luminaire & work plane  
 ..... Walls below work plane  
 ..... 20 ..... Floor

### Luminaire

Manufacturer ..... S.H.....  
 Catalog No. ..... GP-24R-FA5.....  
 No. & Type lamps ... 2 - F40.....  
 Lumens/Lamp ..... 3100.....  
 Light loss Factor ..... .75.....  
 (LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = 2.5 ; Ceiling Cavity Ratio = .6 ; Floor Cavity Ratio = 1.6

- Obtain effective ceiling cavity reflectances ( $\rho_{rc}$ ) from Table B;  $\rho_{rc} = .71$

- Obtain effective floor cavity reflectance ( $\rho_{rf}$ ) from Table B;  $\rho_{rf} = .18$

- Find coefficient of utilization from published data (for  $\rho_{rc} = 20\%$ ) C.U. = .63

$$\frac{\text{NO. OF FIXTURES}}{\text{LAMPS/FIXTURE}} \times \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$\frac{70 \times 36 \times 18}{6200 \times .63 \times .75} = \frac{45360}{2929} = 15.5$$

90029213

191

AL-9300

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address ..... ADMIN., BLDG.

Area to be lighted ..... CAFETERIA

Design level of illumination ..... 50 FC. (initial) (maintained) 120M 15S

Calculated by ..... Date ..... Checked by ..... Date .....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions


..... 20' Room Length

..... 10' Room Width

..... 6' Height of room between luminaire & work plane (hrc)

..... 15' Distance from luminaire plane to ceiling (hcc)

..... 2.5' Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 50% Ceiling

..... 10% Walls above luminaire plane

..... 50% Walls between luminaire & work plane

..... 10% Walls below work plane

..... 40% Floor

### Luminaire

Manufacturer ..... SMOOTH HOLMAN

Catalog No. ..... G.P.-24R-FAS

No. & Type lamps ..... 2 F40

Lumens/Lamp ..... 3100

Light loss Factor ..... .75  
(LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

### 1. Determine cavity ratios using Table A or by formula

Room Cavity Ratio = 1.45 ; Ceiling Cavity Ratio = .4 ; Floor Cavity Ratio = .6

2. Obtain effective ceiling cavity reflectances ( $\rho_{rc}$ ) from Table B;  $\rho_{rc} = .74$

3. Obtain effective floor cavity reflectance ( $\rho_{rf}$ ) from Table B;  $\rho_{rf} = .19$

4. Find coefficient of utilization from published data (for  $\rho_{rc} = 20\%$ ) C.U. = .71

$$\text{No. of FIXTURES} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$= \frac{50 \times 100 \times .71}{2 \times 10 \times .71 \times .75} = \frac{84400}{301} = 26$$

LIBRARY

192

90029214

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... A.D. BLDG.....

Area to be lighted..... CORRIDOR.....


Design level of illumination..... 10 F.C. .... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 10' ..... Room Length  
 ..... 6' ..... Room Width  
 ..... 9.5' ..... Height of room between luminaire & work plane (hrc)  
 ..... 7' ..... Distance from luminaire plane to ceiling (hcc)  
 ..... 0' ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 72 ..... Ceiling  
 ..... 50 ..... Walls above luminaire plane  
 ..... 50 ..... Walls between luminaire & work plane  
 ..... 50 ..... Walls below work plane  
 ..... 22 ..... Floor

### Luminaire

Manufacturer ..... HOLOPHANE  
 Catalog No. ..... 6100  
 No. & Type lamps ..... 1 - F40  
 Lumens/Lamp ..... 3100  
 Light loss Factor ..... 75  
 (LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

$$\text{Room Cavity Ratio} = .8 \quad ; \quad \text{Ceiling Cavity Ratio} = .45 \quad ; \quad \text{Floor Cavity Ratio} = 0$$

- Obtain effective ceiling cavity reflectances ( $\rho_{rc}$ ) from Table B;  $\rho_{rc} = 72$

- Obtain effective floor cavity reflectance ( $\rho_{rf}$ ) from Table B;  $\rho_{rf} = 20$

- Find coefficient of utilization from published data (for  $\rho_{rf} = 20\%$ ) C.U. = 31

$$\text{No. of FIXTURES} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$\frac{10 \times 640}{3100 \times .34 \times 75} = \frac{6400}{721} = 8.9$$

90029215

For Use with IES Zonal-Cavity Method  
(See individual data sheets on luminaires for coefficients of utilization)

### GENERAL INFORMATION

Company name and address..... A.P. BLPG .....

Area to be lighted..... COBRI DOR 2 #3 .....


Design level of illumination..... 10. FC. (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

### DESCRIPTION OF AREA AND LUMINAIRE

#### Dimensions

..... 60 ..... Room Length  
..... 6 ..... Room Width  
..... 9.5 ..... Height of room between luminaire & work plane (hrc)  
..... 5 ..... Distance from luminaire plane to ceiling (hcc)  
..... 0 ..... Height of work plane above floor (hfc)



#### Room Surface Reflectance 10 %

..... 10 ..... Ceiling	Luminaire
..... Walls above luminaire plane	Manufacturer .....
..... 10 ..... Walls between luminaire & work plane	Catalog No. .... 6100 .....
..... Walls below work plane	No. & Type lamps .... 1-F4?
..... 10 ..... Floor	Lumens/Lamp .... 3120 .....

#### Luminaire

..... 10 ..... Ceiling	Manufacturer .....
..... Walls above luminaire plane	Catalog No. .... 6100 .....
..... 10 ..... Walls between luminaire & work plane	No. & Type lamps .... 1-F4?
..... Walls below work plane	Lumens/Lamp .... 3120 .....
..... 10 ..... Floor	Light loss Factor .... .75 (LLD x LDD)

### SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

$$\text{Room Cavity Ratio} = .7 ; \text{Ceiling Cavity Ratio} = .45 ; \text{Floor Cavity Ratio} = 0$$

- Obtain effective ceiling cavity reflectances ( $\mu_{rc}$ ) from Table B;  $\mu_{rc} = .73$

- Obtain effective floor cavity reflectance ( $\mu_{rf}$ ) from Table B;  $\mu_{rf} = .90$

- Find coefficient of utilization from published data (for  $\mu_{rl} = 20\%$ ) C.U. = .28

$$\frac{\text{No. of FIXTURES}}{\text{FOOT CANDLES X AREA}} = \frac{\text{LAMPS/FIXTURE X LUMENS/LAMP X CU X LLF}}{10 \times 360 = \frac{2600}{3100 \times .28 \times .75} = 5.5 \text{ ft}^2 \text{ per fixture}}$$

194

21545004

90029216

*For Use with IES Zonal-Cavity Method*  
 (See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... A.P. B.L.D.C.....

Area to be lighted..... CORRIDOR #4.....

Design level of illumination..... 10 FC..... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions


..... 19.2 ..... Room Length

..... 6 ..... Room Width

..... 2.2 ..... Height of room between luminaire & work plane (hrc)

..... 1.5 ..... Distance from luminaire plane to ceiling (hcc)

..... 9 ..... Height of work plane above floor (hfc)



Room Surface Reflectance 10 %

..... 90 ..... Ceiling

..... Walls above luminaire plane

..... 52 ..... Walls between luminaire & work plane

..... Walls below work plane

..... 29 ..... Floor

### Luminaire

Manufacturer .....

Catalog No. .....

No. & Type lamps ..... 1-F40 .....

Lumens/Lamp ..... 3100 .....

Light loss Factor ..... .75 .....

(LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = .8 ; Ceiling Cavity Ratio = .4 ; Floor Cavity Ratio = 0

2. Obtain effective ceiling cavity reflectances ( $\rho_{rc}$ ) from Table B;  $\rho_{rc} = .74$

3. Obtain effective floor cavity reflectance ( $\rho_{rf}$ ) from Table B;  $\rho_{rf} = .20$

4. Find coefficient of utilization from published data (for  $\rho_{rf} = 20\%$ ) C.U. = .31

$$\frac{\text{No. of FIXTURES}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$\frac{12 \times 19.2 \times 6}{3100 \times .31 \times .75} = \frac{11520}{721} = 16$$

195

90029217

For Use with IES Zonal-Cavity Method  
(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... A.D. BLDG.....

Area to be lighted..... GENERAL AREA.....

Design level of illumination..... 50 FC..... (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions


..... 12' ..... Room Length

..... 6.2 ..... Room Width

..... 6 ..... Height of room between luminaire & work plane (hrc)

..... 11.5 ..... Distance from luminaire plane to ceiling (hcc)

..... 2.5 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 80 ..... Ceiling

..... Walls above luminaire plane

..... 20 ..... Walls between luminaire & work plane

..... 10 ..... Walls below work plane

..... 80 ..... Floor

### Luminaire

Manufacturer .....

Catalog No. .....

No. & Type lamps ..... 2 - F40 .....

Lumens/Lamp ..... 3600 .....

Light loss Factor ..... .75 .....

(LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = .8 ; Ceiling Cavity Ratio = .18 : Floor Cavity Ratio = .3

2. Obtain effective ceiling cavity reflectances ( $\rho_{rc}$ ) from Table B;  $\rho_{rc} = .77$

3. Obtain effective floor cavity reflectance ( $\rho_{rf}$ ) from Table B;  $\rho_{rf} = .20$

4. Find coefficient of utilization from published data (for  $\rho_f = 20\%$ ) C.U. = .80

$$\frac{\text{No. of FIXTURES}}{\text{Foot Candles} \times \text{Area}} = \frac{\text{Lamps/Fixture} \times \text{Lumens/Lamp} \times \text{CU} \times \text{LLF}}{6200 \times .80 \times .75} = \frac{50 \times 108 \times 60}{6200 \times .80 \times .75} = \frac{324000}{3720} = .87$$

90029218

196

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... A.P. BLDG .....

Area to be lighted..... SECURITY / SAFETY .....


Design level of illumination..... 70 F.C. (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 48 ..... Room Length  
 ..... 24 ..... Room Width  
 ..... 6 ..... Height of room between luminaire & work plane (hrc)  
 ..... 11.5 ..... Distance from luminaire plane to ceiling (hcc)  
 ..... 6.5 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 80 ..... Ceiling  
 ..... 50 ..... Walls above luminaire plane  
 ..... 50 ..... Walls between luminaire & work plane  
 ..... 20 ..... Walls below work plane  
 ..... 20 ..... Floor

### Luminaire

Manufacturer .....  
 Catalog No. .....  
 No. & Type lamps ..... 2 : F.40 .....  
 Lumens/Lamp ..... 3100 .....  
 Light loss Factor ..... (.75 .....  
 (LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

$$\text{Room Cavity Ratio} = .8 \quad ; \quad \text{Ceiling Cavity Ratio} = .5 \quad ; \quad \text{Floor Cavity Ratio} = .8$$

- Obtain effective ceiling cavity reflectances ( $\rho_{rc}$ ) from Table B;  $\rho_{rc} = .72$

- Obtain effective floor cavity reflectance ( $\rho_{rf}$ ) from Table B;  $\rho_{rf} = .19$

- Find coefficient of utilization from published data (for  $\rho_{rc} = 20\%$ ) C.U. = .67

$$\frac{\text{No. of FIXTURES}}{\text{FOOT CANDLES} \times \text{AREA}} = \frac{1}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$\frac{70 \times 24 \times .8}{6200 \times 67 \times .75} = \frac{80640}{3116} = 26$$

90029219

197

DESIGNER

For Use with IES Zonal-Cavity Method  
(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... AD BLDG

Area to be lighted..... INVENTORY & CONTROL


Design level of illumination..... 70 F.C. (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 48 ..... Room Length  
..... 24 ..... Room Width  
..... 6 ..... Height of room between luminaire & work plane (hrc)  
..... 1.5 ..... Distance from luminaire plane to ceiling (hcc)  
..... 2.5 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 80 ..... Ceiling  
..... Walls above luminaire plane  
..... 22 ..... Walls between luminaire & work plane  
..... Walls below work plane  
..... 22 ..... Floor

### Luminaire

Manufacturer .....  
Catalog No. ....  
No. & Type lamps ..... 2 - F40  
Lumens/Lamp ..... 3100  
Light loss Factor ..... .75  
(LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

### 1. Determine cavity ratios using Table A or by formula

$$\text{Room Cavity Ratio} = .8 ; \text{Ceiling Cavity Ratio} = .5 ; \text{Floor Cavity Ratio} = .8$$

2. Obtain effective ceiling cavity reflectances ( $\rho_{rc}$ ) from Table B;  $\rho_{rc} = .72$

3. Obtain effective floor cavity reflectance ( $\rho_{rf}$ ) from Table B;  $\rho_{rf} = .19$

4. Find coefficient of utilization from published data (for  $\rho_{rl} = 20\%$ ) C.U. = .67

$$\text{No. of FIXTURES} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$\frac{70 \times 24 \times 48}{6200 \times .67 \times .75} = \frac{80640}{3116} = 26$$

198

REVERSE

90029220

For Use with IES Zonal-Cavity Method  
(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... AD BLDG.....

Area to be lighted..... FILES.....


Design level of illumination..... 50 FC (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 24 ..... Room Length  
..... 24 ..... Room Width  
..... 6 ..... Height of room between luminaire & work plane (hrc)  
..... 1.5 ..... Distance from luminaire plane to ceiling (hcc)  
..... 2.9 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 80 ..... Ceiling  
..... 70 ..... Walls above luminaire plane  
..... 50 ..... Walls between luminaire & work plane  
..... 70 ..... Walls below work plane  
..... 20 ..... Floor

### Luminaire

Manufacturer .....  
Catalog No. .....  
No. & Type lamps ..... 2 - F40 .....  
Lumens/Lamp ..... 7100 .....  
Light loss Factor ..... .75 .....  
(LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = 2.5 ; Ceiling Cavity Ratio = .6 ; Floor Cavity Ratio = 1.0

- Obtain effective ceiling cavity reflectances ( $\mu_{rc}$ ) from Table B;  $\mu_{rc} = .71$

- Obtain effective floor cavity reflectance ( $\mu_{rf}$ ) from Table B;  $\mu_{rf} = .79$

- Find coefficient of utilization from published data (for  $\mu_{rl} = 20\%$ ) C.U. = .63

$$\frac{\text{No. of FIXTURES}}{\text{Foot Candles} \times \text{Area}} = \frac{\text{Foot Candles} \times \text{Area}}{\text{Lamps/Fixture} \times \text{Lumens/Lamp} \times \text{C.U.} \times \text{LLF}}$$

$$\frac{50 \times 24 \times 24}{6200 \times .63 \times .75} = \frac{22800}{2929} = 10$$

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address ..... A.D. BLDG.

Area to be lighted ..... M/H/L R/M


Design level of illumination ..... 50 ..... (initial) (maintained)

Calculated by ..... Date ..... Checked by ..... Date .....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 24 ..... Room Length  
 ..... 24 ..... Room Width  
 ..... 6 ..... Height of room between luminaire & work plane (hrc)  
 ..... 1.5 ..... Distance from luminaire plane to ceiling (hcc)  
 ..... 2.5 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance

..... 80 ..... Ceiling  
 ..... 1 ..... Walls above luminaire plane  
 ..... 50 ..... Walls between luminaire & work plane  
 ..... 1 ..... Walls below work plane  
 ..... 20 ..... Floor

### Luminaire

Manufacturer .....  
 Catalog No. .....  
 No. & Type lamps 2. F.-40 .....  
 Lumens/Lamp ..... 3100 .....  
 Light loss Factor ..... .75 .....  
 (LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = 2.5 ; Ceiling Cavity Ratio = .6 ; Floor Cavity Ratio = .1

- Obtain effective ceiling cavity reflectances ( $\rho_{ec}$ ) from Table B;  $\rho_{ec} = .71$

- Obtain effective floor cavity reflectance ( $\rho_{ef}$ ) from Table B;  $\rho_{ef} = .19$

- Find coefficient of utilization from published data (for  $\rho_{ec} = 20\%$ ) C.U. = .63

$$\text{NO OF FIXTURES} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIX.} \times \text{LUMENS/LAMP} \times \text{C.U.XLLF}}$$

$$\frac{50 \times 24 \times 24}{6200 \times .63 \times .75} = \frac{249600}{2929} = 10$$

90029222

200

11SPR500

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... A.D. REPC.....

Area to be lighted..... REPRODUCTION.....

Design level of illumination..... 70. FC. (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions


4.8..... Room Length

2.4..... Room Width

6..... Height of room between luminaire & work plane (hrc)

1.5..... Distance from luminaire plane to ceiling (hcc)

1.5..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

80	Ceiling
.....	Walls above luminaire plane
50	Walls between luminaire & work plane
.....	Walls below work plane
20	Floor

### Luminaire

Manufacturer .....
Catalog No. .....
No. & Type lamps ..... 2 - F40 .....
Lumens/Lamp ..... 3100 .....
Light loss Factor ..... .75 .....
(LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = .8 ; Ceiling Cavity Ratio = .5 ; Floor Cavity Ratio = .8

2. Obtain effective ceiling cavity reflectances ( $\mu_{rc}$ ) from Table B;  $\mu_{rc} = .72$

3. Obtain effective floor cavity reflectance ( $\mu_{rf}$ ) from Table B;  $\mu_{rf} = .19$

4. Find coefficient of utilization from published data (for  $\mu_r = 20\%$ ) C.U. = .67

$$\text{No. of FIXTURES} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$\frac{70 \times 24 \times 48}{6202 \times .67 \times .75} = \frac{80640}{3116} = 26$$

201

90029223

For Use with IES Zonal-Cavity Method  
(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... AD. BLDG.....

Area to be lighted..... FIRST AID & TREATMENT.....


Design level of illumination..... 100..... (initial) (maintained) IES

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 22 ..... Room Length  
..... 12 ..... Room Width  
..... 5.5 ..... Height of room between luminaire & work plane (hrc)  
..... 1.5 ..... Distance from luminaire plane to ceiling (hcc)  
..... 3 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 80 ..... Ceiling  
..... Walls above luminaire plane  
..... 80 ..... Walls between luminaire & work plane  
..... Walls below work plane  
..... 20 ..... Floor

### Luminaire

Manufacturer .....  
Catalog No. .....  
No. & Type lamps ..... 2 - F40 .....  
Lumens/Lamp ..... 3100 .....  
Light loss Factor ..... 75 .....  
(LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = 3.5 ; Ceiling Cavity Ratio = .97 ; Floor Cavity Ratio = 1.95

- Obtain effective ceiling cavity reflectances ( $\mu_{rc}$ ) from Table B;  $\mu_{rc} = .74$

- Obtain effective floor cavity reflectance ( $\mu_{rf}$ ) from Table B;  $\mu_{rf} = .25$

- Find coefficient of utilization from published data (for  $\mu_r = 20\%$ ) C.U. = .55

$$\text{No. of FIXTURES} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$\frac{100 \times 12 \times 22}{6200 \times .55 \times .75} = \frac{26400}{2557} = 10$$

90029224

202

CS 38100 R

For Use with IES Zonal-Cavity Method  
(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... AD... BLDG.....

Area to be lighted..... MEC14 RM.....

Design level of illumination..... 20 FC (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions


..... 24 ..... Room Length

..... 19 ..... Room Width

..... 5.5 ..... Height of room between luminaire & work plane (hrc)

..... 1.5 ..... Distance from luminaire plane to ceiling (hcc)

..... 3 ..... Height of work plane above floor (hfc)



Room Surface Reflectance 17 %

	Luminaire
..... 80 .....	Manufacturer .....
Ceiling	Catalog No. .....
..... 50 .....	No. & Type lamps ..... 2 - F40 .....
Walls above luminaire plane	Lumens/Lamp ..... 3100 .....
..... 50 .....	Light loss Factor ..... 65 .....
Walls between luminaire & work plane	
..... 50 .....	
Walls below work plane	
..... 20 .....	
Floor	

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = 2.4 ; Ceiling Cavity Ratio = .7 ; Floor Cavity Ratio = 1.4

2. Obtain effective ceiling cavity reflectances ( $\mu_{rc}$ ) from Table B;  $\mu_{rc} = 70$

3. Obtain effective floor cavity reflectance ( $\mu_{rf}$ ) from Table B;  $\mu_{rf} = 18$

4. Find coefficient of utilization from published data (for  $\mu_{rl} = 20\%$ ) C.U. = 63

$$\frac{\text{No. of FIXTURES}}{\text{Foot Candles} \times \text{Area}} = \frac{\text{Lamps/Fixture} \times \text{Lumens/Lamp} \times \text{C.U.} \times \text{LLF}}{\text{Lamps/Fixture} \times \text{Lumens/Lamp} \times \text{C.U.} \times \text{LLF}}$$

$$\frac{2.0 \times 24 \times 19}{6200 \times 63 \times 65} = \frac{9120}{2539} = 3.6 - 4$$

203

90029225

**For Use with IES Zonal-Cavity Method**

(See individual data sheets on luminaires for coefficients of utilization)

### GENERAL INFORMATION

Company name and address..... AD 73 LDC .....

Area to be lighted..... MECH., ELEC., TEL. ROOM .....


Design level of illumination..... 20.05 (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

### DESCRIPTION OF AREA AND LUMINAIRE

#### Dimensions

..... 4.8 ..... Room Length  
 ..... 4.2 ..... Room Width  
 ..... 5.5 ..... Height of room between luminaire & work plane (hrc)  
 ..... 1.5 ..... Distance from luminaire plane to ceiling (hcc)  
 ..... 3 ..... Height of work plane above floor (hfc)



#### Room Surface Reflectance in %

	Luminaire
..... 80 ..... Ceiling	Manufacturer .....
..... { Walls above luminaire plane	Catalog No. .....
..... 50 { Walls between luminaire & work plane	No. & Type lamps ..... 2 P40
..... } Walls below work plane	Lumens/Lamp ..... 3100
..... 20 ..... Floor	Light loss Factor ..... .65 (LLD x LDD)

### SELECTION OF COEFFICIENT OF UTILIZATION

#### 1. Determine cavity ratios using Table A or by formula

Room Cavity Ratio = 1.1 ; Ceiling Cavity Ratio = 0.3 ; Floor Cavity Ratio = 0.4

2. Obtain effective ceiling cavity reflectances ( $\mu_{rc}$ ) from Table B;  $\mu_{rc} = 75$

3. Obtain effective floor cavity reflectance ( $\mu_{rf}$ ) from Table B;  $\mu_{rf} = 19$

4. Find coefficient of utilization from published data (for  $\mu_r = 20\%$ ) C.U. = 76

$$\text{No. of FIXTURES} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$\frac{20 \times 4.1 \times 4.8}{6200 \times .76 \times .65} = \frac{40320}{5063} = 13$$

90029226

204

For Use with IES Zonal-Cavity Method  
(See individual data sheets on luminaires for coefficients of utilization)


## GENERAL INFORMATION

Company name and address..... A.D. BLDG.....  
 Area to be lighted..... SECURITY CAR GARAGE.....  
 Design level of illumination..... 20 FC..... (initially maintained) IES  
 Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 3.6 ..... Room Length  
 ..... 2.6 ..... Room Width  
 ..... 6.5 ..... Height of room between luminaire & work plane (hrc)  
 ..... 5 ..... Distance from luminaire plane to ceiling (hcc)  
 ..... 3 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 72 ..... Ceiling  
 ..... Walls above luminaire plane  
 ..... 52 ..... Walls between luminaire & work plane  
 ..... Walls below work plane  
 ..... 20 ..... Floor

### Luminaire

Manufacturer .....  
 Catalog No. .....  
 No. & Type lamps ..... 2-F40 .....  
 Lumens/Lamp ..... 3100 .....  
 Light loss Factor ..... 75 .....  
 (LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

### 1. Determine cavity ratios using Table A or by formula

Room Cavity Ratio = 2 ; Ceiling Cavity Ratio = .15 ; Floor Cavity Ratio = .9

2. Obtain effective ceiling cavity reflectances ( $\rho_{rc}$ ) from Table B;  $\rho_{rc} = .67$

3. Obtain effective floor cavity reflectance ( $\rho_{rf}$ ) from Table B;  $\rho_{rf} = .19$

4. Find coefficient of utilization from published data (for  $\rho_{rf} = 20\%$ ) C.U. = .67

$$\frac{\text{No. of FIXTURES}}{\text{LAMPS/FIXTURE}} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$\frac{20 \times 936}{6200 \times .67 \times 75} = \frac{18720}{3115} = .6$$

90029227

For Use with IES Zonal-Cavity Method  
(See individual data sheets on luminaires for coefficients of utilization)


### GENERAL INFORMATION

Company name and address..... A.D. BLDG.....  
 Area to be lighted..... TRAILER INSPECTION.....  
 Design level of illumination..... 20 F.C. (initial) (maintained)  
 Calculated by..... Date..... Checked by..... Date.....

### DESCRIPTION OF AREA AND LUMINAIRE

#### Dimensions

..... 76 ..... Room Length  
 ..... 44 ..... Room Width  
 ..... 13.5 ..... Height of room between luminaire & work plane (hrc)  
 ..... 2.5 ..... Distance from luminaire plane to ceiling (hcc)  
 ..... 4 ..... Height of work plane above floor (hfc)



20'

#### Room Surface Reflectance in %

..... 52 ..... Ceiling  
 ..... 22 ..... Walls above luminaire plane  
 ..... 22 ..... Walls between luminaire & work plane  
 ..... 22 ..... Walls below work plane  
 ..... 22 ..... Floor

#### Luminaire

Manufacturer .....  
 Catalog No. ..... 1909  
 No. & Type lamps ..... 150 14... HPS  
 Lumens/Lamp ..... 16000  
 Light loss Factor ..... .81  
 (LLD x LDD)

### SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

$$\text{Room Cavity Ratio} = .45 ; \text{Ceiling Cavity Ratio} = .45 ; \text{Floor Cavity Ratio} = .72$$

- Obtain effective ceiling cavity reflectances ( $\rho_{ce}$ ) from Table B;  $\rho_{ce} = .43$

- Obtain effective floor cavity reflectance ( $\rho_{fe}$ ) from Table B;  $\rho_{fe} = .17$

- Find coefficient of utilization from published data (for  $\rho_{ce} = 20\%$ ) C.U. = .62

$$\frac{\text{No. of FIXTURES}}{\text{FOOT CANDLES X AREA}} = \frac{\text{LAMPS/FIXTURE X LUMENS/LAMP X CU X LLF}}{}$$

$$\frac{20 \times 44 \times 76}{16000 \times .81 \times .62} = \frac{66380}{8035} = .8$$

90029228

207

For Use with IES Zonal-Cavity Method  
(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address.....

Area to be lighted..... *Lab. (Security bldg.)*

Design level of illumination..... 70. FG. (initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions


..... 30 ..... Room Length

..... 15 ..... Room Width

..... 8 ..... Height of room between luminaire & work plane (hrc)

..... 1.5 ..... Distance from luminaire plane to ceiling (hcc)

..... 2.5 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 80 ..... Ceiling

..... 80 ..... Walls above luminaire plane

..... 82 ..... Walls between luminaire & work plane

..... 80 ..... Walls below work plane

..... 80 ..... Floor

### Luminaire

Manufacturer .....

Catalog No. .....

No. & Type lamps ... 2-F-40 .....

Lumens/Lamp ..... 2100 .....

Light loss Factor ..... .75 .....

(LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = .4 ; Ceiling Cavity Ratio = .7 ; Floor Cavity Ratio = .1

- Obtain effective ceiling cavity reflectances ( $\rho_{ce}$ ) from Table B;  $\rho_{ce} = .70$

- Obtain effective floor cavity reflectance ( $\rho_{fr}$ ) from Table B;  $\rho_{fr} = .18$

- Find coefficient of utilization from published data (for  $\rho_{fr} = 20\%$ ) C.U. = .64

$$\frac{\text{No. of fixtures}}{\text{Foot Candles} \times \text{Area}} = \frac{\text{Lamps/Fixture} \times \text{Lumens/Lamp} \times \text{C.U.} \times \text{LLF}}{6200 \times .64 \times .75}$$

$$\frac{70 \times 540}{6200 \times .64 \times .75} = \frac{39600}{2976} = 12.7$$

90029229

208

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... *Securady* 13 L.D.G.....

Area to be lighted..... COMPUTER ROOM.....


Design level of illumination..... 70 FC....(initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 59..... Room Length  
 ..... 31..... Room Width  
 ..... 6..... Height of room between luminaire & work plane (hrc)  
 ..... 4.5..... Distance from luminaire plane to ceiling (hcc)  
 ..... 2.5..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 70..... Ceiling  
 ..... Walls above luminaire plane  
 ..... 50..... Walls between luminaire & work plane  
 ..... Walls below work plane  
 ..... 20..... Floor

### Luminaire

Manufacturer..... SMOOTH HOLMAN.....  
 Catalog No. .... G.P.-24R-FAS.....  
 No. & Type lamps .. 2-F40.....  
 Lumens/Lamp .. 3100.....  
 Light loss Factor .. .75.....  
 (LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = .5 ; Ceiling Cavity Ratio = .4 ; Floor Cavity Ratio = .6

- Obtain effective ceiling cavity reflectances ( $\rho_{rc}$ ) from Table B;  $\rho_{rc} = .74$

- Obtain effective floor cavity reflectance ( $\rho_{rf}$ ) from Table B;  $\rho_{rf} = .19$

- Find coefficient of utilization from published data (for  $\rho_{rl} = 20\%$ ) C.U. = .71

$$\frac{\text{NO. OF FIXTURES}}{\text{FOOT CANDLES X AREA}} = \frac{1}{\text{LAMPS/FIXTURE X LUMENS/LAMP X CU X LLF}}$$

$$= \frac{70 \times 59 \times 31}{6200 \times .71 \times .75} = \frac{128030}{3301} = 38.7$$

209

90029230

# ILLUMINATION CALCULATION SHEET

For Use with IES Zonal-Cavity Method

(See individual data sheets on luminaires for coefficients of utilization)


## GENERAL INFORMATION

Company name and address..... Security BLDG.....  
 Area to be lighted..... Security & HVAC Monitor.....  
 Design level of illumination..... 70 ..... (initial) (maintained)  
 Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... 32 ..... Room Length  
 ..... 31 ..... Room Width  
 ..... 6 ..... Height of room between luminaire & work plane (hrc)  
 ..... 1.5 ..... Distance from luminaire plane to ceiling (hcc)  
 ..... 2.5 ..... Height of work plane above floor (hfc)



Room Surface Reflectance 17 %

..... 72 ..... Ceiling  
 ..... Walls above luminaire plane  
 ..... 50 ..... Walls between luminaire & work plane  
 ..... Walls below work plane  
 ..... 20 ..... Floor

### Luminaire

Manufacturer ..... S.H. ....  
 Catalog No. ..... GP-24.R-FAF....  
 No. & Type lamps ..... 2. P40....  
 Lumens/Lamp ..... 3100....  
 Light loss Factor ..... .75....  
 (LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = 2.0 ; Ceiling Cavity Ratio = .5 ; Floor Cavity Ratio = .8

- Obtain effective ceiling cavity reflectances ( $\rho_{rc}$ ) from Table B;  $\rho_{rc} = .72$

- Obtain effective floor cavity reflectance ( $\rho_{rf}$ ) from Table B;  $\rho_{rf} = .19$

- Find coefficient of utilization from published data (for  $\rho_{rc} = 20\%$ ) C.U. = .67

$$\frac{\text{No. of Fixtures}}{\text{Foot Candles} \times \text{Area}} = \frac{\text{Foot Candles} \times \text{Area}}{\text{Lamps/Fixture} \times \text{Lumens/Lamp} \times \text{CU} \times \text{LLF}}$$

$$= \frac{70 \times 32 \times 31}{6200 \times .75 \times .67} = \frac{69440}{3115} = 22$$

90029231

210

For Use with IES Zonal-Cavity Method  
(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address..... Security BLDG.....

Area to be lighted..... MAIN, SECURITY, OFFICE.....

Design level of illumination..... 70 FC.....(Initial) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions


..... 74 ..... Room Length

..... 26 ..... Room Width

..... 6 ..... Height of room between luminaire & work plane (hrc)

..... 1.5 ..... Distance from luminaire plane to ceiling (hcc)

..... 2.5 ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... 80 ..... Ceiling

..... 50 ..... Walls above luminaire plane

..... 50 ..... Walls between luminaire & work plane

..... 50 ..... Walls below work plane

..... 22 ..... Floor

### Luminaire

Manufacturer .....

Catalog No. .....

No. & Type lamps ..... 2-F40 .....

Lumens/Lamp ..... 3100 .....

Light loss Factor ..... .75 .....

(LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

### 1. Determine cavity ratios using Table A or by formula

Room Cavity Ratio = .3 ; Ceiling Cavity Ratio = .3 ; Floor Cavity Ratio = .5

2. Obtain effective ceiling cavity reflectances ( $\rho_{rc}$ ) from Table B;  $\rho_{rc} = .75$

3. Obtain effective floor cavity reflectance ( $\rho_{rf}$ ) from Table B;  $\rho_{rf} = .19$

4. Find coefficient of utilization from published data (for  $\rho_{rf} = 20\%$ ) C.U. = .73

$$\frac{\text{No. of FIXTURES}}{\text{FOOT CANDLES} \times \text{AREA}} = \frac{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}{1}$$

$$\frac{70 \times 74 \times 36}{6200 \times .73 \times .75} = \frac{186400}{3394} = 55$$

90029232

211-212

WAREHOUSE / SHOPS

213-214

90029233

# ILLUMINATION CALCULATION SHEET

*For Use with IES Zonal-Cavity Method*

(See individual data sheets on luminaires for coefficients of utilization)

## GENERAL INFORMATION

Company name and address.....

Area to be lighted..... **WAREHOUSE**


Design level of illumination..... **10** ..... (~~initial~~) (maintained)

Calculated by..... Date..... Checked by..... Date.....

## DESCRIPTION OF AREA AND LUMINAIRE

### Dimensions

..... **270** ..... Room Length  
 ..... **75** ..... Room Width  
 ..... **2.2** ..... Height of room between luminaire & work plane (hrc)  
 ..... **1** ..... Distance from luminaire plane to ceiling (hcc)  
 ..... **6'** ..... Height of work plane above floor (hfc)



### Room Surface Reflectance in %

..... **.15** ..... Ceiling  
 ..... Walls above luminaire plane  
 ..... **.50** ..... Walls between luminaire & work plane  
 ..... Walls below work plane  
 ..... **.12** ..... Floor

### Luminaire

Manufacturer .....  
 Catalog No. ..... **966** .....  
 No. & Type lamps ..... **150 W HPS** .....  
 Lumens/Lamp ..... **16000** .....  
 Light loss Factor ..... : **.81** .....  
 (LLD x LDD)

## SELECTION OF COEFFICIENT OF UTILIZATION

- Determine cavity ratios using Table A or by formula

Room Cavity Ratio = **.2** ; Ceiling Cavity Ratio = **.08** ; Floor Cavity Ratio = **.5**

- Obtain effective ceiling cavity reflectances ( $\rho_{ce}$ ) from Table B;  $\rho_{ce} = .49$

- Obtain effective floor cavity reflectance ( $\rho_{fe}$ ) from Table B;  $\rho_{fe} = .19$

- Find coefficient of utilization from published data (for  $\rho_{fe} = 20\%$ ) C.U. = **.55**

$$\frac{\text{No. of FIXTURES}}{\text{FLOOR AREA}} = \frac{\text{FOOT CANDLES} \times \text{AREA}}{\text{LAMPS/FIXTURE} \times \text{LUMENS/LAMP} \times \text{CU} \times \text{LLF}}$$

$$\frac{10 \times 270 \times 75}{16000 \times .55 \times .81} = \frac{502500}{7125} = .72$$

25-216

90029234

TRU Waste Surface Facility Time and Motion Analysis

7

POOR ORIGINAL

90029235

## WIPP - TRU WASTE SURFACE FACILITY TIME AND MOTION ANALYSIS

The analysis of material handling in the TRU Waste Facility was conducted and discussed over an extended period of time stretching from July to December of 1976. During that period of time, a number of TRU facility configurations were developed and considered. The final design concept resulted from this extended evolutionary process. As a record of the evolution, attached are several pertinent documents relating to the time and motion study for the facility.

Item I is letter H&N-023 discussing utilization factors for work areas within the building. The results of this portion of the work were the decisions that both truck and railcars should be handled simultaneously, that two overhead cranes should be used, and that separate truck and railcar airlocks should be provided.

Item II is a draft discussion, with comments on laydown space utilization within the facility. Item III is a partial revision to Item II.

27 218

90029236

ITEM 1



400 EAST ORANGEHORPE AVENUE

ANAHEIM, CALIFORNIA 92801

(714) 870-8700

August 20, 1976  
H&N-023

bcc: ✓ J. Duncan  
Distribution  
K. R. Brown  
File

Mr. James L. Ash  
Fenix & Scisson, Inc.  
P. O. Box 15609  
Tulsa, Oklahoma 74115

Dear Jim:

Attached for review and comment is a Material Handling Time and Sequencing Analysis for the TRU Waste Handling Facility. The analysis is based on the most current material flow requirements and presents a matrix of results based on the various combinations of waste shipments which may be received at the site. Section I is a summary of the various package configurations to be handled. Section II is the basis for the process flow and Section III presents the analysis and results.

Based on the analysis results, as shown in the attached, a number of recommendations regarding facility design may be made. These are:

1. A minimum of three single railcar movers will probably be required for the facility. One of the three, or a separate vehicle, will have to be sized to handle multiple cars from site entrance to storage yard and back. Two movers will support movement of TRU wastes, one will support RH waste operations.
2. A minimum of two railcar unloading stations are required. A third station may be required, depending upon decisions on such things as a separate car lid removal area.
3. Two overhead cranes should be used in the TRU Waste building for car unloading.

219

90029237

Mr. James L. Ash  
August 20, 1976  
H&N-023  
Page 2

4. Two truck stations are required. One may be a combination truck and railcar station. Further development of the site arrangement and building configuration will aid in the decision on final configuration.
5. Consideration should be given to a combination lid removal, container storage and sorting station in the facility yard area. Railcars and trucks which have been unloaded in the TRU building would be utilized to transport empty containers from the building rather than requiring their immediate removal (empty) and subsequent return to be loaded. Containers would be stockpiled in the storage area on pads until such time as a vehicle was available to transport them offsite to their point of origin.

*deco*  
Review of the analysis will show considerable reduction in station (and therefore equipment) utilization if containers could be returned to any sender. Based on current criteria requiring return of containers to point of origin these reductions will not be realized. Use of an outside station would minimize the utilization of building stations resulting in a more efficient facility. Use of such a station would also reduce the interior storage space required for empty containers which are waiting for a vehicle to transport them home.

Review of the attached will be appreciated and will aid in decisions regarding configuration of the site and TRU waste handling system. In order to be most effective the comments should be received by September 3. If questions arise, please let me know.

Very truly yours,

HOLMES & NARVER, INC.

*Kent*

Kent R. Brown

Attach.

cc: L. Scully, Sandia Labs. (w/2 attachs.)

90029238

220

WIPP PROJECT

TRU WASTE HANDLING FACILITY

MATERIAL HANDLING TIME

AND SEQUENCING ANALYSIS

AUGUST 20, 1976

HOLMES & NARVER, INC.

221-222

90029239  
90029230

WIPP PROJECT  
CONTACT HANDLING WASTE FACILITY  
I. PACKAGE SPECIFICATIONS

Item	Symbol	Dimensions, Ft.			Maximum Weight, Lbs.	
		Length	Width	Height	Gross	Tare
Supertiger Container	ST	20	8	8	UP* 44,300	17,000
					P 46,700	17,000
Cargo Container	CC	20	8	8	UP 44,000	5,000
					P 43,700	5,000
Rocky Flats Fiberglassed Box	RF	7	4	4	10,000	
Overpack Fiberglassed Box	OB	8	5	5	11,000	1,000
Mark 3 Container	M3	5	4	6	UP 6,000	750
					P 8,000	750
					C 10,000	750
55 Gallon Drum, DOT-17C	55D				UP 650	< 100
					P 900	< 100
83 Gallon Overpack Drum, DOT-17C	83D				UP 750	100
					P 1,000	100

\* UP = Unprocessed Waste

P = Processed Waste

C = Mark 3 Container Holding Undrummed Waste

90029240

## II. BASIS FOR PROCESS FLOW

1. All quantities are alternative average maxima per 8-hour shift unless otherwise noted. That is, the quantity flows between or through stations for the different packages are not additive; they are alternative possibilities. The quantities are daily averages based on a stated annual throughput and do not represent the maxima which could occur due to nonuniform frequency of shipments during a week or longer period of time. These surges could be leveled by holding the arriving vehicles for unloading at a later time.
2. Work will be performed during only one 8-hour shift per day, 5 days per week.
3. Four 55D or 83D drums per pallet.
4. Truck shipments are by flatbed truck only. A flatbed truck carries only one ST. No other type of package is shipped by truck.
5. A Supertiger can contain up to 33 drums of processed waste (29,700 lbs. maximum payload) or up to 42 drums of unprocessed waste (27,300 lbs. maximum payload).
6. A rail flatcar can carry up to three STs. No other type of package is shipped by rail flatcar. Each ST can contain the same payloads as in Item 5.
7. An ATMX railcar can contain three types of packages in combination or as single-package type shipments. The maximum number of packages for single-package type shipments are:

24 RF Boxes

2 Cargo Containers

20 Mark 3 Bins

8. RF boxes are never unpacked. However, they may be damaged. Minor damage requires repair and major damage or external contamination requires overpack.
9. Cargo containers hold up to 60 55D of unprocessed waste (39,000 lbs. maximum payload) or up to 43 55D of processed waste (38,700 lbs. maximum payload).

90029241

10. Mark 3 bins hold up to 8 55-gallon drums each. Maximum payloads are:
- Unprocessed waste 5,200 lbs.
- Processed waste 7,200 lbs.
11. Mark 3s containing undrummed waste or contaminated drums and soil are not unpacked. However, they may require minor repair or overpack.
12. On the average, 1,300 55D drums per week will be received. These could be received by any combination (or single type shipment) of the following possible shipment types:
- a. Flatbed truck [1-ST (33-55D-P, 42-55D-UP)]
  - b. Flatcar [3-ST (99-55D-P, 126-55D-UP)]
  - c. ATMX [2-CC (86-55D-P, 120-55D-UP)]
  - d. ATMX [20-M3 (160-55D-P or UP)]
13. Based on Item 12, the average number of drums per day is 260 (32.5 drums/hr.), and the average maximum number (assuming containers and vehicles are loaded to capacity) of containers and vehicles per day and per hour for each shipment type is as follows:

Container and Vehicle Flow Rates (Average)

Shipment Type			Vehicles Per		Containers Per	
Vehicle	Container	Waste	Day	Hour	Day	Hour
Flatbed	ST	UP	6.2	0.8	6.2	0.8
Flatbed	ST	P	7.9	1.0	7.9	1.0
Flatcar	ST	UP	2.1	0.3	6.3	0.8
Flatcar	ST	P	2.6	0.3	7.9	1.0
ATMX	CC	UP	2.2	0.3	4.4	0.6
ATMX	CC	P	3.0	0.4	6.0	0.7
ATMX	M3	P/UP	1.6	0.2	32	4

14. Since vehicles arrive as discrete units, the next higher whole number of vehicles is used as the flow basis. Thus, the daily and hourly flow rates for vehicles, containers, and drums is as follows:

**Basic Flow Rates**  
**(Maximum Average Alternatives)**

Shipment Type			Vehicles Per		Containers Per		Drums Per	
Vehicle	Container	Waste	Day	Hour	Day	Hour	Day	Hour
Flatbed	ST	UP	7	0.9	7	0.9	294	37
Flatbed	ST	P	8	1	8	1	264	33
Flatcar	ST	UP	3	0.4	9	1.1	378	47
Flatcar	ST	P	3	0.4	9	1.1	297	37
ATMX	CC	UP	3	0.4	6	0.8	360	45
ATMX	CC	P	3	0.4	6	0.8	258	32
ATMX	M3	P/UP	2	0.3	40	5	320	40

90029243

### III. TIME AND SEQUENCING ANALYSIS

#### 1. SPOT AND REMOVE VEHICLES

##### 1.1 Requirements

The maximum number of railcars appears to be 4 per day (3 for drums, 1 for RF boxes once per week; contaminated M3s are assumed to be included with drums or RFs). The railcar must be spotted, the containers removed from the car, and the car removed from its unloading station to wait for the containers to be unloaded. (Containers must be returned to the sender on the same car as received.)\* When the containers are available, the car is respotted, the containers loaded on the car, and the car moved to the yard to await pickup by a Santa Fe engine. Thus, there could be 7 spotting cycles per day. (Cars carrying RF boxes or contaminated M3s will not need to be respotted since RFs or these M3s are not returned to the sender.)

If all drums are received in STs on flatbed trucks, a maximum of 8 trucks could be received in a day. Arriving trucks would go to the truck parking area to wait for an available truck unloading station. When a station is available, the truck moves to the station, the ST is removed, and the truck returns to the parking area to wait for the ST to be unloaded. (The same truck/ST combination as received must be returned to the sender.)\* When the ST is available, the truck is respotted, the ST loaded on the flatbed, and the truck returns to the sender. (Truck/ST combinations should be given priority treatment since the truck and driver are unproductive during unloading of the ST and while waiting for a truck unloading station.) To handle the maximum daily truck arrivals will require 16 truck spotting cycles.

##### 1.2 Time Estimates

- a. Move car from holding yard to unloading station and spot. Minimum distance approximately 2,100', maximum distance approximately 5,500', average distance approximately 3,800'.

\* Requirement modified August 4, 1976 - Analysis retained for continuity and future reference. Assumption is now that all containers, etc., return to point of origin but may be shipped on a different vehicle.

Average travel time at 3 mph (260 ft/min)	14.5 min
Hookup and start moving	4 min
Slow, enter building, stop, unhook	<u>5.5</u> min
Time Required	24 min

(These times assume that rail switches and building doors are controlled such that the railcar never waits for these actions.)

b. Remove ATMX car lids (3 per car)

Sandia estimate	25 min
-----------------	--------

c. Unload cargo containers from ATMX

Sandia estimate, 25 min each (Includes removal of braces and shoring)	50 min
--	--------

d. Unload M3s from ATMX

(Assume M3s unloaded in groups of four). There will be 5 lifts made. Braces and shoring will need to be removed only once. Assume 20 minutes per lift cycle.

Time Required	100 min
---------------	---------

e. Replace ATMX lids

Lid restraints and braces are not replaced on empty cars waiting for reloading with CCs or M3s. Restraints are replaced on cars ready for return to sender (those that carried RFs or contaminated M3s). Assume replacement of lids and lid restraints requires same time as removal (i.e., 25 min.). Assume 10 min. required for lid restraints. Assume 15 min. for braces.

Time Required:

Empty cars to be returned	40 min
Reloaded cars to be returned	25 min
Empty cars to hold area	15 min

f.	Unload STs (3) from flatcar	
	Remove ST tiedowns (4 per ST)	10 min
	Engage crane sling (4 points)	5 min
	Lift and move to laydown area	
	(80 ft ave. at 40 fpm)	2 min
	disengage crane sling	5 min
	Return crane for next ST	2 min
	Repeat lift cycle for 2nd ST	14 min
	Engage crane to 3rd ST	5 min
	Lift 3rd ST free of flatcar	<u>1</u> min
	Time from spot car to car ready to move out	44 min
g.	Unload RF boxes from ATMX (24 boxes per ATMX, lifted 4 at a time. Includes removal of braces and shoring).	
	Remove shoring (first 4; others removed while preceding boxes removed.)	20 min
	Lift 4 boxes, move to laydown, and return to ATMX	16 min
	Repeat lift cycle 5 times	<u>80</u> min
		116 min
h.	Move car from unloading station to holding yard	24 min
i.	Remove ATMX lid from reload	15 min
j.	Reload cargo containers on ATMX and replace braces (same as unload)	50 min

k. Reload M3s on ATMX

Load in groups of 4. Assume 20 minutes per lift cycle                    100 min

l. Reload STs on flatcar

Engage crane to ST, move to flatcar, disengage crane, and move to next ST (perform twice)                    28 min

Engage 3rd ST, load and disengage                    12 min

Replace tie downs                    10 min

Time to reload                    40 min

m. Move truck from parking area to unloading station and spot.

Travel distance, approximately 400' including turnaround and back in to station.

Travel time at 1 mph average (87 ft/min)                    4.5 min

Turning and spotting                    1.5 min

6.0 min

n. Unload ST from flatbed

Remove ST tiedowns (4 per ST)                    10 min

Engage crane sling (4 points)                    5 min

Lift ST free of flatbed                    1 min

16 min

o. Move truck out of unloading station                    4 min

p. Respot truck for loading                    6 min

q. Load ST on flatbed

Engage crane sling (4 points)                    5 min

Move ST and place on flatbed	2	min
Disengage crane sling	5	min
Replace tie downs	<u>10</u>	min
	22	min

1.3 A summary for Vehicle Unloading/Reloading Cycle times is presented in Table 1.3.

1.4 Shipment Scenarios

The usage of the railcar unloading stations can be determined from Table 1.3 for various shipment scenarios. For example, (assuming use of only one railcar prime mover):

- a. If all drums are received in CCs in ATMX cars, 3 cars per day are required. In addition, the weekly ATMX containing RFs could arrive on the same day. The unloading station time required would be:

$$\begin{array}{lcl} 3 \text{ ATMX (CC)} = 276 \times 3 & = & 828 \\ 1 \text{ ATMX (RF)} = 229 \times 1 & = & \underline{229} \\ & & 1,057 \text{ min} \end{array}$$

Since, with two 10-minute rest periods, there are 460 minutes in an 8-hour day, this requires 2.3 station days. Thus, two stations would fall 2.4 hours short of handling this vehicle load. However, since the RF shipment arrives only once per week, the daily average station time required, if all drums received in cargo containers in ATMX cars is 874 minutes. This could be handled in 1.9 station days, or 2 stations each utilized 95 percent of the time.

- b. If all drums are received in returnable M3s, 2 ATMX cars per day are required. In addition the weekly RF shipment would arrive on one of the days. The unloading station time required would be:

$$\begin{array}{lcl} 2 \text{ ATMX (M3)} = 376 \times 2 & = & 752 \\ 1 \text{ ATMX (RF)} = 229 \times 1 & = & \underline{229} \\ & & 981 \end{array}$$

## TIME SUMMARY FOR VEHICLE UNLOADING/RELOADING

Vehicle/Container Combination Unload - Reload Cycle	ATMX With CC	ATMX With M3 (returnable)	ATMX With M3 (contaminated)	ATMX With RF	Flatcar With ST	Truck With ST
Unload Vehicle (min.)						
Spot vehicle (from hold yard)	24	24	24	24	24	6
Remove vehicle restraints and lids	25	25	25	25	--	--
Unload container(s)	50	100	100	116	44	16
Replace vehicle lids	15	15	40	40	--	--
Move vehicle to hold yard	<u>24</u>	<u>24</u>	<u>24</u>	<u>24</u>	<u>24</u>	<u>4</u>
Unload Cycle Time (min.)	138	188	213	229	92	26
Unload Cycle Time (hrs.)	2.3	3.2	3.6	3.8	1.5	0.5
Reload Vehicle (min.)						
Spot empty vehicle	24	24	(Not Reloaded)	(Not Reloaded)	24	6
Remove vehicle lid	15	15		Re-loaded)	--	--
Reload container(s)	50	100			40	22
Replace vehicle lid and restraints	25	25			--	--
Move vehicle to hold yard	<u>24</u>	<u>24</u>			<u>24</u>	<u>4</u>
Reload Cycle Time (min.)	138	188			88	32
Reload Cycle Time (hrs.)	2.3	3.1			1.5	0.5
Unload/Reload Cycle (min.)	276	376	213	229	180	58
Unload/Reload Cycle (hrs.)	4.6	6.3	3.6	3.8	3.0	1.0

90029249

23

Thus, the maximum day would require 2.1 station days, and two stations would fall 48 minutes short of handling the vehicle load. The daily average station time required would be 798 minutes or 1.75 station days.

Thus 2 stations, each utilized 88 percent of the time, could handle this situation on the weekly average.

- c. If all drums are received in STs on flatcars, 3 flatcars per day is the maximum required. The weekly shipment of RFs would also arrive. The unloading station time required would be:

2 hr 53 min

$$3 \text{ Flatcars (ST)} = 180 \times 3 = 540$$

$$1 \text{ ATMX (RF)} = 229 \times 1 = 229$$

6 hrs  
+ total  
360 min

Thus, the maximum day would require 1.7 station days, and the weekly average would require 586 minutes or 1.3 station days. Two stations each utilized 65 percent of the time could handle this average day.

- d. If all drums are received in STs on flatbed trucks, 8 trucks per day will be required for processed waste. The weekly shipment of RFs would also arrive but would be unloaded at a rail station rather than a truck station. The maximum truck unloading station time required would be:

$$8 \text{ Flatbed trucks (ST)} = 8 \times 58 = 464 \text{ min}$$

Thus, one truck station utilized 100 percent of the time would handle the maximum unloading requirement, if this very tight schedule could be maintained. However, materials and supplies must also be received at the truck station. Therefore, a single truck station is inadequate. Placing two truck stations side-by-side appears to provide adequate unloading capacity, since only 4 hours of actual use of the crane is required. (Only one crane can service these two truck stations.) However, greater flexibility could be obtained by using a railcar station and the second crane for the second truck unloading station. Thus, only one truck-only station would be required.

- e. If drums are received by any mix of ATMX (CC), ATMX (M3), Flatcar (ST) and Truck (ST), the railcar unloading station weekly time utilization (2 stations) will fall between the maximum of 95 percent for both stations if all ATMX (CC) and 50 percent for one station if all Truck (ST) (assuming one truck station is a railcar station). Shipments of contaminated M3s reduce the utilization of the railcar stations since the ATMX is not reloaded in this case.

## 1.5 Observations

1.5.1 The high utilization (95% and 88%) of the railcar stations seems too high for sustained operation. However, if shipments are equally distributed between ATMX (CC), ATMX (M3) and Flatcar (ST), the average utilization would be about 83%. If truck shipments also are considered, the utilization is reduced to 75%.

1.5.2 The utilization factor for the railcar stations could be reduced by providing rail access to the truck unloading station. This would provide the capability to handle the worst day case (ATMX (CC) + ATMX (RF)) with an average utilization of 75 percent for each of the three stations. The average utilization of each station during the worst week would be 63%.

With three unloading stations the utilization factor for worst day shipments of ATMX (M3) would be 71 percent, and the average for the worst week would be 57 percent.

1.5.3 Utilization of the bridge cranes in the unload/load area is as follows:

	<u>% of cycle</u>	<u>% of time</u>
ATMX (CC) shipment	58	
ATMX (RF) shipment	64	
ATMX (M3) shipment	70	
Truck (ST) shipment	66	
ATMX (CC) + ATMX (RF) worst day		68

	<u>% of cycle</u>	<u>% of time</u>
ATMX (CC) + ATMX (RF) average day	--	55
ATMX (M3) + ATMX (RF) worst day	--	73
ATMX (M3) + ATMX (RF) average day	--	60

By comparison of the utilization factors for the stations and the cranes, it is evident that for three stations and two cranes, the capacity of the cranes rather than the number of stations becomes the limiting constraint on the receiving capacity of the facility.

The above crane utilization factors assume that the cranes are not used for any other functions such as removal of container cover restraints or bracing, or removal and replacement of bin covers if the bin air-lock concept is used.

- 1.5.4 The cycle time for a station could be reduced by having two prime movers for railcars. This would permit an incoming car to standby just beyond the switch closest to the station. Thus, the tieup of the station for car movements would be reduced to about 22 minutes per unload/reload cycle rather than 96 minutes. Under these conditions, the worst day station time required would be 800 minutes. With two stations, each would be utilized 87 percent of the time. Comparing the use of two prime movers to use of three stations indicates that three stations gives better utilization factors than two prime movers. With two prime movers, the station utilization rather than crane utilization is the controlling factor.

- 1.5.5 The utilization time required for the prime movers would be as follows:

	<u>Min</u>
Hookup and start moving	4
Travel from hold yard to wait station	15
Wait at wait station	15

Enter building and unhook	6
Return to hold yard	<u>15</u>
	55

This sequence (or the equivalent) would occur four times for each unload/reload cycle. Thus the time utilized for the worst case day would be 770 minutes. This would utilize two prime movers, each 84 percent of the time. Three prime movers total probably would be needed to provide for high level waste and material and supply shipments.

If the wait time were eliminated, the prime mover time utilized would be 560 minutes, or 61 percent utilization of two prime movers.

- 1.5.6 Since a minimum of two prime movers is required to handle the worst day traffic, the utilization of two stations can be reduced to 87 percent by having a prime mover with incoming car wait near the unload/reload station. If three stations and the wait concept are used, the utilization of each station would be 58 percent, and the utilization of the cranes would become the controlling factor. This would provide flexibility and some relief in the event of malfunction of station doors.
- 1.5.7 The utilization of the stations could be reduced if any of the functions performed at the station could be removed to another station outside the building. The candidate functions and their time requirements are:

	<u>Remove</u>	<u>Replace</u>
Vehicle restraint	10	10
Vehicle lids	15	15
Vehicle bracing	15	15

Lid removal at a remote station would also reduce the crane utilization.

If it is assumed that:

- Vehicle restraints, lids and bracing are removed outside the building
- Cars wait close to the building for an available station

then the cycle times would be:

<u>Unload</u>	(Minutes) ATMX (CC)	(Minutes) ATMX (M3)	(Minutes) ATMX (RF)
Spot vehicle	6	6	6
Unload container	50	100	116
Move out vehicle	— 5	— 5	— 5
	61	111	127
Reload	— 61	— 111	— 0
Total cycle	122	222	127

Utilization factors would be:

	<u>Station % Each</u>		<u>Cranes</u>
	<u>2 Stations</u>	<u>3 Stations</u>	<u>% Each</u>
ATMX (CC) + ATMX (RF), worst day	54	36	45
ATMX (CC) + ATMX (RF), average day	42	28	35
ATMX (M3) + ATMX (RF), worst day	62	41	56
ATMX (M3) + ATMX (RF), average day	51	34	46

If the vehicle bracing remained in the car until it reached the unload station, approximately 30 minutes would be added to the cycle and the ATMX (CC) + ATMX (RF) worst day station utilization with 2 stations would be 76 percent, and 51 percent for 3 stations.

1.5.8 Another possibility for reduction of the station utilization factor could be achieved if different containers (of the same type) than those received could be returned to sender. The effect on station utilization would be significant if lid removal cannot be performed outside the building, but minor if lid removal is outside. The effect on crane utilization appears to be insignificant since the only crane time eliminated would be about 8 minutes of crane travel for unloading CCs per cycle. The major effect would be reduction of delay time for the railcar or truck. As noted under Item 1.1 a modification of criteria allows the return of containers by different vehicles but still requires that they be shipped to the point of origin.

1.5.9 On the worst railcar day there are 3.5 unload/reload cycles. For each cycle the prime mover enters and leaves the building four times as follows:

- Enter, spot loaded vehicle, leave
- Enter, attach empty, leave
- Enter, spot empty, leave
- Enter, attach vehicle, leave

Therefore, the door is opened 14 times during the day. If 15 minutes is assumed to open the door, 5 minutes to close the door, and 10 minutes for the prime mover to move in and out, 280 minutes per day will find the door unsealed. This represents 61 percent of the active work day. Entry of trucks delivering materials or supplies will increase the percentage of time that doors are unsealed.  
*(14 20  
---  
280)*

For the worst truck day there are 8 truck unloads, 8 truck reloads, and one ATMX (RF) unload/reload cycle. Therefore a door is opened 32 times for trucks and 2 times for the ATMX (RF). Thus, if a door open/close cycle requires 13 minutes for a truck and 20 minutes for the ATMX (RF), the total time a door is unsealed during the day is 456 minutes or essentially 100 percent of the work day.

90029255  
*238*

The large portion of the time that a door to the loading area must be unsealed appears to cast doubt on the acceptability of a facility concept without an air lock between the loading area and the container area.

It also is observed that with these large unit factors for the doors, the doors could become the limiting factor on the receiving capacity of the facility, if they are interlocked to allow only one unsealed door at any time.

Utilization of air locks for trucks and railcars therefore appears to be the most reasonable means of providing building access while assuring maintenance of control of facility environment.

- 1.5.10 A possible concept for an air lock between the loading area and the container unloading area is a bin, top opening into the vehicle unloading/loading area and end opening into the container unloading area. This would permit a container to be loaded into the bin through the open top by the vehicle unloading crane. After the bin lid is in place, the end of the bin is opened and the container unloaded through its end door.

The utilization of the cranes will be increased by the time required to remove and replace bin lids. Two bin lid lifts are required for each 8 M3s and each 10 1/2 RFs. If it is assumed that five minutes is required to move a bin lid from the top of a bin to a storage platform at the same elevation as the top of the bin, the crane time required for bin lid lifting associated with unloading each type of shipment is:

ATMX (CC)	10 minutes
ATMX (M3)	25 minutes
ATMX (RF)	24 minutes
Flatcar (ST)	10 minutes

Thus the added crane time and crane utilization for the maximum days would be as follows. (No station utilization time is added if it is assumed that lids are moved while the vehicles are being moved into or out of the station.)

	<u>Time (min)</u>	<u>Utilization %</u>
3 ATMX (CC) + ATMX (RF)	54	6
2 ATMX (M3) + ATMX (RF)	74	8

During the August 4 - 5, 1976 review meeting this concept was judged to be less desirable than the addition of truck/railcar air locks. This data is therefore presented for completeness but the represented design approach is not being pursued.

- 1.5.11 Discussions during the August 4 - 5, 1976 review meeting centered on the utilization of air locks for truck/railcar access to the building. Two air locks would be added to retain the ability to have access to any station without disrupting operations in other stations. Addition of air locks will impact station utilization because of the additional door travel required. The additional time for a railcar will be 5 minutes to open and 5 minutes to close the door and for trucks a total of 6 minutes additional time. Tables 1.6 and 1.7 show the impact of air locks and changes in shipping criteria on cycle times.
- Three or 4 reg'd?  
4 UTILIZED 4/14/77  
+ start/stop  
time for  
vehicle in  
lock  
etc*

The impact of this additional time on the various cycles analyzed to this point is summarized in Table 1.8, Sections 6 and 7, for the assumed operation without close wait and without a lid station.

Table 1.8, Section 8, shows the impact of the addition of air locks to operation with close wait and an external lid station for removal of lids and bracing.

## 1.6 Summary and Conclusions

- 1.6.1 Table 1.7 summarizes the utilization factors for railcar stations and cranes under various conditions. It also contains incremental utilization factors for cranes to be added to the crane factors if air lock bins are used and the bin lids are handled by the cranes.
- 1.6.2 Station and crane utilization factors should be kept low to provide for future increased rates of material inflow, to provide flexibility, and to partially accommodate malfunctions of equipment.

TIME SUMMARY FOR VEHICLE UNLOADING/RELOADING  
UTILIZING AIR LOCKS FOR BUILDING ACCESS

Vehicle/Container Combination Unload - Reload Cycle	ATMX With CC	ATMX With M3 (returnable)	ATMX With M3 (contaminated)	ATMX With RF	Flatcar With ST	Truck With ST
Unload Vehicle (min.)						
Spot vehicle (from hold yard)	24	24	24	24	24	6
Air lock operation	10	10	10	10	10	3
Remove vehicle restraints and lids	25	25	25	25	--	--
Unload container(s)	50	100	100	116	44	16
Replace vehicle lids	15	15	40	40	--	--
Air lock operation	10	10	10	10	10	(3)
Move vehicle to hold yard	<u>24</u>	<u>24</u>	<u>24</u>	<u>24</u>	<u>24</u>	<u>4</u>
Unload Cycle Time (min.)	158	208	233	249	112	32
Unload Cycle Time (hrs.)	2.6	3.5	3.9	4.2	1.8	0.5

00029258

TIME SUMMARY FOR VEHICLE UNLOADING/RELOADING  
UTILIZING AIR LOCKS FOR BUILDING ACCESS

Unload - Reload Cycle	Vehicle/Container Combination	ATMX With CC	ATMX With M3 (returnable)	ATMX With M3 (contaminated)	ATMX With RF	Flatcar With ST	Truck With ST
<b>Reload Vehicle (min.)</b>							
Spot empty vehicle		24	24	(Not Reloaded)	(Not Re- loaded)	24	6
Air lock operation		10	10			10	3
Remove vehicle lid		15	15			--	--
Reload container(s)		50	100			40	22
Replace vehicle lid and restraints		25	25			--	--
Air lock operation		10	10			10	3
Move vehicle to hold yard		<u>24</u>	<u>24</u>			<u>24</u>	<u>4</u>
Reload Cycle Time (min.)		158	208			108	38
Reload Cycle Time (hrs.)		2.6	3.5			1.8	0.6
Unload/Reload Cycle (min.)		316	416	233	249	220	70
Unload/Reload Cycle (hrs.)		5.2	7.0	3.9	4.2	3.6	1.1

9002959

TIME SUMMARY FOR VEHICLE UNLOADING/RELOADING  
UTILIZING AIR LOCKS FOR BUILDING ACCESS  
ASSUMING EMPTY CONTAINERS AVAILABLE FOR RETURN TO SENDER

Unload - Reload Cycle	Vehicle/Container Combination	ATMX With CC	ATMX With M3 (returnable)	ATMX With M3 (contaminated)	ATMX With RF	Flatcar With ST	Truck With ST
<i>Unload</i>							
Unload vehicle (min.)							
Spot vehicle (from hold yard)	24	24	24	24	24	24	6
Air lock operation	10	10	10	10	10	10	3
Remove vehicle restraints and lids	25	25	25	25	25	--	--
Unload container(s)	50	100	100	116	44	16	
Reload container(s)	50	100	--	--	40	22	
Replace vehicle lids	15	15	40	40	--	--	
Air lock operation	10	10	10	10	10	3	
Move vehicle to hold yard	<u>24</u>	<u>24</u>	<u>24</u>	<u>24</u>	<u>24</u>	<u>4</u>	
Cycle Time (min.)	208	308	233	249	152	54	
Cycle Time (hrs.)	3.5	5.1	3.9	4.2	2.5	0.9	

TABLE 1.8  
UTILIZATION FACTOR (% EACH UNIT)  
(Railcar Stations and Cranes)

Handling Conditions Shipment Scenario	Maximum Day			Average Day		
	2 Stations	3 Stations	2 Cranes	2 Stations	3 Stations	2 Cranes
<u>1. Without close wait, without lid station</u>						
3 ATMX (CC) + ATMX (RF)	115	75	68	95	63	55
2 ATMX (M3) + ATMX (RF)	105	71	73	88	57	60
3 Flatcar (ST) + ATMX (RF)	85			65		
1/3 each ATMX (CC), ATMX (M3), Flatcar (ST) + ATMX (RF)					83	
1/4 each ATMX (CC), ATMX (M3), Flatcar (ST), Truck (ST) + ATMX (RF)					75	
<u>2. Without close wait, without lid station</u>						
3 ATMX (CC) + ATMX (RF)	87	58	68			55
2 ATMX (M3) + ATMX (RF)			73			60
3 Flatcar (ST) + ATMX (RF)						
<u>3. With close wait, with lid station (lid only)</u>						
3 ATMX (CC) + ATMX (RF)	76	51	45			35
2 ATMX (M3) + ATMX (RF)			56			46
3 Flatcar (ST) + ATMX (RF)						

19262961

TABLE 1.8 - Cont.  
 UTILIZATION FACTOR (% EACH UNIT)  
 (Railcar Stations and Cranes)

Handling Conditions Shipment Scenario	Maximum Day			Average Day		
	2 Stations	3 Stations	2 Cranes	2 Stations	3 Stations	2 Cranes
<b>4. With close wait, with lid station (lid + bracing)</b>						
3 ATMX (CC) + ATMX (RF)	54	36	45	42	28	35
2 ATMX (M3) + ATMX (RF)	62	41	56	51	34	46
3 Flatcar (ST) + ATMX (RF)						
<b>5. Air lock lids (add for lids)</b>						
3 ATMX (CC) + ATMX (RF)			6			
2 ATMX (M3) + ATMX (RF)			8			
<b>6. Building air locks</b> (Without close wait, without lid station)						
3 ATMX (CC) + ATMX (RF)	130	87		105	70	
2 ATMX (M3) + ATMX (RF)	120	80		90	60	
3 Flatcar (ST) + ATMX (RF)	100	67		70	47	

90029262

TABLE 1.8 - Cont.  
 UTILIZATION FACTOR (% EACH UNIT)  
 (Railcar Stations and Cranes)

Handling Conditions Shipment Scenario	Maximum Day			Average Day		
	2 Stations	3 Stations	2 Cranes	2 Stations	3 Stations	2 Cranes
<u>7. Return of containers to sender on different vehicle plus addition for air locks</u> (Without close wait, without lid station)						
3 ATMX (CC) + ATMX (RF)	95	63		70	47	
2 ATMX (M3) + ATMX (RF)	95	63		65	43	
3 Flatcar (ST) + ATMX (RF)	75	50		50	33	
<u>8. Building air locks with close wait, with lid station (lid and bracing)</u>						
3 ATMX (CC) + ATMX (RF)	80	53		55	37	
2 ATMX (M3) + ATMX (RF)	80	53		55	37	
3 Flatcar (ST) + ATMX (RF)	125	83		100	67	

69229002

- 1.6.3 Maximum day shipments of CCs and M3s cannot be accommodated by two stations unless the "close wait" concept is used. That is, a car is standing by as close as possible to the station to move in as soon as the station is available.
- 1.6.4 Even with the close wait concept, the utilization of two stations is 87 percent which is higher than comfortable. This can be reduced by either of two approaches; installing a third station, or installing a vehicle lid removal/replacement station external to the building.
- 1.6.5 A third station could be installed by extending the building at the truck station and providing a dead end spur track to accommodate a railcar. The door would also probably need to be enlarged. If this were done, the station utilization would decrease to 58 percent but the crane utilization could be as high as 81 percent for an M3 day if the crane is also used to lift air lock lids. Thus, the cranes would be controlling and there would be little, if any, flexibility or unused capacity in the system. The crane utilization could be reduced to 73 percent maximum by installing a separate crane or other mechanical device for air lock lid lifting.
- 1.6.6 The crane utilization can be reduced to 56 percent (64 percent if bin lids lifted) by using a remote station to remove the ATMX lids. If the car bracing also is removed at this remote station, the car unloading station utilization is reduced to 62 percent for two stations. Thus a good balance is achieved between station utilization and crane utilization. There would be no gain in potential throughput increase by installing a third station since the crane utilization is controlling and for three stations and two cranes the crane utilization increases faster than station utilization when the throughput is increased.
- 1.6.7 The preferred approach appears to be to use the "close wait" concept and a remote ATMX lid station, without providing railcar access to the truck station. This would provide the ability to accommodate equipment malfunctions without rapid buildup of backlog and to achieve maximum growth in throughput. It also presents the alternative of providing for the remote station but postponing its installation until the throughput proves to exceed the capacity.

- 1.6.8 To achieve the utilization factors indicated will require very precise scheduling and traffic control both inside the building and on the site rail system. Automatic display, complete communication, and possibly central control of yard traffic will be required.
- 1.6.9 Although the truck station maximum utilization factor is only 50 percent for two stations, the crane utilization would be 66 percent (without bin lids which would be lifted by the other crane) since only one crane services both stations. Providing truck access to the railcar stations would be a minor expense and is recommended since it would provide access to the other crane.
- 1.6.10 If the "close wait" concept is used and there are only two prime movers, each would be utilized 84 percent of the working day. If there are two prime movers but the "close wait" concept is not used, each prime mover is utilized 61 percent of the time. Thus, 2 prime movers might suffice initially, but a third would need to be added as the number of movements increased or when a remote lid station was installed.

A&KRS:OUR

90029265

FD/af

## 2. LAYDOWN SPACE UTILIZATION

### 2.1 Basis and Requirements

Three types of containers (ST, CC, M3) holding 55 gallon drums (55D) are received at the unloading stations. In addition, RF boxes are received. All containers and boxes are unloaded from the vehicles and transported to a laydown area by bridge cranes. An alternative possibility would be to unload drums from an ST while the ST is on a flatbed truck. This method of unloading might also be applied to the last ST on a flatcar. The laydown area is an open floor space between the vehicle unloading area and the container unloading area. (The container air sampling location and procedure should be defined. If sampling can be performed before unloading the ST from the vehicle, this may not be a consideration in the time cycle since sampling could probably be performed while the tiedowns are being removed.)

The 55Ds are assumed to be unloaded three at a time from the containers (STs and CCs) through end-opening doors while the containers are in the laydown area. (A special design drum grabber will need to be developed to lift three drums from the side since there is inadequate headroom in an ST to lift from above.) The 55Ds are then moved to a 24-drum pallet. However, a small portion of the containers may be found to be contaminated on the inside. Internally contaminated containers are moved to the overpack area for unpacking. (If internal sampling is performed while containers are on the vehicle, contaminated containers would be moved directly from the vehicle to the overpack area.) This frees the space for other use. When containers are unloaded in the laydown space, the space is tied up until the proper type vehicle is available in a loading station to receive the container.

Twenty M3s are received in an ATMX car. They are lifted, four at a time, using a special spreader, and moved to a laydown space. Eight

Comments by R. Poli (markings on copy 7/18/77 by L. Evans on 12/1/77)

90029266

M3s can be placed in a 11' x 27' laydown space with space remaining for stacking of the M3 lids as they are removed. Since the M3s are top loading, empty laydown space must be left between groups of M3s to allow unloading. The air in each M3 is sampled for contamination prior to removing the lid from it. (The sampling method should be defined).

*2ST*  
55Ds are removed from the M3 using a ~~5~~T forklift equipped with a special design drum grabber based on the Lift-O-Matic concept. The drum lifting device will need to extend below the truck forks far enough to reach the bottom layer of drums in the M3. This can be done by a fixed extension of at least 3 feet or by a movable extension which can travel vertically to reach the drums. The fixed extension would be less costly but it would increase the lift height required for the forklift by about 3 feet to a clear lift height of at least 12 feet under the forks.

The present design of the M3 prevents unloading drums 4 at a time. However, the design may be modified to permit unloading 4 at a time. If this design modification is not made it will be necessary to unload drums one or possibly two at a time. This would require modification of the lifting device to permit rotation so that a drum in any quadrant could be gripped at the point on a radius of the four drum cluster.

After the M3s are emptied, and the lids replaced on them, they are lifted, four at a time, into an ATMX car for shipment back to the sender.

Twenty-four RFs are received in an ATMX. They are handled four at a time (stacked two high) using the slings which are left in place by the sender. A spreader will need to be designed to maintain a 6-inch spacing between the RF stacks to permit removal of the slings after the RFs are placed in the laydown area. It is visualized that slings would be removed by

90029267

unhooking the outboard side of the sling from the crane hook and then pulling the slings from around the RFs by raising the crane hook to pull the slings through the space between the RF stacks. The slings would be returned to the ATMX by the crane as it approached for the next load of RFs. About 38 ft. clear from floor to crane hook would be required for the slings to clear the top of the RF stack.

The air inside the RF is not sampled for contamination nor is any material removed from the RF. The RFs are removed from the laydown space, one at a time, using a 7.5 T forklift. They are transported to a 8.5' x 12.5' pallet which holds two RFs. Before being placed on the pallet they are inspected for damage and external contamination(?). If damaged or contaminated, they are moved to the minor repair or overpack areas as appropriate.

In summary, the quantity of items moving into and out of a laydown space for the various types of containers and waste received, are:

#### LAYDOWN SPACE MATERIAL FLOW

Item Received Container/Waste	Vertical		Horizontal Out
	In	Out	
Supertiger/Processed	1-ST	1-ST	33-55D
Supertiger/Unprocessed	1-ST	1-ST	42-55D
Cargo Container/Processed	1-CC	1-CC	43-55D
Cargo Container/Unprocessed	1-CC	1-CC	60-55D
Mark 3/Processed	8-M3	8-M3	64-55D
Mark 3/ <del>Unprocessed</del> Contaminated	8-M3	-	8-M3
Rocky Flats Box	12-RF	-	12-RF

The arrangement of items in the laydown space and in the containers is indicated in the following sketches. It can be observed that:

- If four M3s are carried in a single lift by the unloading crane, eight M3s (2 lifts) can be loaded into a laydown space with space inside the laydown to stack the M3 lids when they

90029268

are removed. 2.5 laydown spaces are required to hold the M3s from an ATMX car.

- Twelve RF's in a laydown space is one-half an ATMX carload.
- An ST with inside dimensions of 76" x 76" x 172" long will hold 42 55Ds in three columns of seven each. To unload two at a time by forklift would present difficulty. (When drums are three per row, it is difficult to pick up two per lift without having drums moved about between lifts. A man would have difficulty moving a 900 lb drum by hand.) Therefore, drums should be removed one at a time or three at a time.
- Above comments regarding unloading also apply to the CC. Inside dimensions of CCs are about 7' -9-3/4" (93-3/4") wide by 7'-4-1/8" (88-1/8") high.
- Portable ramps will need to be used with the ST and CC to allow the forklift to enter the container. These ramps will need to be stored when not in use. The ramp for the ST will be about 10" high; for the CC about 6-1/2" high.
- It appears that M3s (contaminated) can be removed one at a time from the end of the laydown area by means of a 7.5 T forklift. A boom attachment appears feasible for lifting the M3 with a 30" load center.
- It may not be possible to lift 55Ds from the M3 four at a time due to the lip on the M3 which reduces the minimum opening to 46-3/4". The Lift-O-Matic four drum device spaces the drums at 1" apart (i.e., 47" outside dimension). Redesign of the M3 will be required for four drum lifting.
- It should be possible to remove drums, two at a time, with two single drum grapples on a lifting beam. One at a time may be the most practical.
- With the arrangements shown, a single laydown space size (11' x 27') will accommodate all four containers.

90029269

60SRS008

- o One laydown space is equipped with a dolly (50,000 lbs. capacity) for transport of occasional STs or CCs (internally contaminated to the overpack area for unpacking).

## 2.2 Time Estimates

A container laydown station is "tied up" or utilized from the time it is designated to receive a container(s) until the container(s) is removed and the space is available to receive another shipment. Thus, the activities that determine the time cycle for laydown space utilization are:

- a) Move container(s) from vehicle to laydown
- b) Sample air inside container (ST or CC). (This should be done while container is on the vehicle, rather than in the laydown space.) *(if feasible)*
- c) Open container door (for ST and CC only)  
Remove Lids (for uncontaminated M3 only)
- d) Place ramp (ST and CC only)
- e) Empty container (if ST, CC or uncontaminated M3) or laydown space (if RF or contaminated M3)
- f) Close container door(s) (ST or CC)  
Replace lids (uncontaminated M3)
- g) Wait for proper type vehicle to be spotted (if ST, CC or uncontaminated M3) *(or for availability of crane, if necessary)*
- h) Move ST, CC or uncontaminated M3s from laydown space to vehicle.

Time cycle estimates for the four types of containers, two types of waste and three types of vehicles follow:

1. <u>Supertiger</u> , Processed Waste (ST-P), Flatcar or Truck,	<u>Min.</u>
Sample air at laydown, no wait for vehicle.	
1.1 Move ST-P from flatcar or truck to laydown and disengage sling	8
1.2 Sample air in ST	15

	<u>Min.</u>
1.3 Open ST door (unbolt and swing back two doors in sequence)	47
Based on estimate provided by Sandia:	
1. Remove 10 bolts from outer door	15
2. Open outer door and secure	7
3. Remove inner door bolts and open	25
	47
1.4 Place ramp on floor	10
1.5 Remove 33 55Ds from ST (3 per lift)	55
Assume forklift used to enter ST, engage three drums, backout and down ramp, turn, travel 20 ft. go up ramp onto pallet, release drums on pallet, back-off pallet and down ramp, turn, return 20 ft to ST (5 min/cycle)	
1.6 Remove ramp from floor and store	10
1.7 Close ST doors	47
1.8 Engage sling and move ST from laydown to flatcar or truck	8
	200
2. <u>Supertiger</u> , Unprocessed Waste (ST-U), Flatcar or Truck	
Sample air at laydown, no wait for vehicle.	
1.1 Time elements from moving the ST through placing ramp on floor (1.1 - 1.4) are the same as Case 1	80
1.5 Remove 42 55Ds from ST (3 per lift). Assume 5 min/lift cycle.	70
1.6 Time elements from removing ramp through returning ST to vehicle (1.6 - 1.8) are the same as Case 1.	65
	215
3. <u>Supertiger</u> , Processed Waste (ST-P), ST remains on Flatbed truck	
3.1 Sample air in ST.	15
3.2 Isolate tiedown from door only	10
3.3 Open ST door (unbolt and swing back two doors in sequence). <i>(ST must be shipped on shims to raise it off flatbed.)</i>	47
3.4 Place ramp on floor	10
3.5 Remove 33 55Ds from ST (3 per lift). Assume there are sufficient forklifts operating so that a forklift approaches the truck bed as soon as the approach is cleared by the	

90029271

	<u>Min.</u>
previous forklift (assume 4 min/cycle).	44
3.6 Remove ramp from floor and store	10
3.7 Close ST doors	47
3.8 Replace tiedown on door	<u>10</u>
	193

#### 4. Cargo Container

Cargo containers are shipped only in an ATMX. Therefore, they must be unloaded from the ATMX and moved to a laydown area for removal of the 55Ds. Internal air can be sampled only at laydown area.

	<u>Min.</u>
4.1 <u>CC, unprocessed waste (CC-U)</u> , sample air at laydown, no wait for vehicle.	
4.1.1 Move CC-U from ATMX to laydown area, disengage sling	8
4.1.2 Sample air in CC	15
4.1.3 Open CC doors (CCs are equipped with two doors and quick opening latch devices, 2 per door).	4
4.1.4 Place ramp on floor	10
4.1.5 Remove 60 55 Ds from CC (3 per lift, 5 min/cycle)	100
4.1.6 Remove ramp from floor and store	10
4.1.7 Close CC doors	4
4.1.8 Move CC from laydown to ATMX	<u>8</u>
	159
4.2 <u>CC, processed waste (CC-P)</u> sample air at laydown, no wait for vehicle	
4.2.1 Move CC-P from ATMX to laydown area	8
4.2.2 Sample air in CC	15
4.2.3 Open CC doors	4
4.2.4 Place ramp on floor	10
4.2.5 Remove 43 55Ds from CC (3 per lift, 5 min/cycle, 15 cycles)	75
4.2.6 Remove ramp from floor and store	10
4.2.7 Close CC doors	4
4.2.8 Move CC from laydown to ATMX	<u>8</u>
	134

90029272

5. Mark 3Min.

Eight M3s are moved from an ATMX (4 at a time) and placed in a laydown space. M3s with undrummed waste are removed from the laydown area, one at a time, and placed on pallets for transport down the mine shaft. Handling of processed and unprocessed waste (in drums) is identical through the laydown area. Drums are removed through the top of the M3, one at a time (or 4 at a time if the M3 is redesigned) and placed on a 24-drum pallet

5.1 M3, contaminated M3 or undrummed waste, no air sampling,  
no return of M3s

5.1.1 Move eight M3s from ATMX to laydown area (four at a time),

~~two~~ Lift cycles at 20 minutes (assumed) per cycle

40

5.1.2 Remove eight M3s from laydown space

40

( Attach forklift sling to M3, lift M3, back out, turn, move to pallet, move up ramp onto pallet, deposit M3, return to laydown area. Assume 8 min/cycle.)

80

As there are no barriers around the laydown space, the forklift can start moving M3s out of the space as soon as the crane deposits the first four. Thus, the cycle time added is only that required to remove the five M3s from the space after the last load is deposited.)

6. RF Box

Twenty-four (24) boxes are received in an AMTX car. The crane moves them four at a time, from the AMTX to the laydown space. Twelve boxes are placed in a laydown space, i.e., 3 lift cycles at 16 minutes per cycle. RF boxes contain undrummed waste and therefore are never returned to the sender and do not require sampling of air in the box. RF boxes are removed from the laydown space one at a time by forklift.

6.1 RF, undrummed waste, no air sampling, no wait for vehicle,  
assume only one forklift used.

STURDOOR

90029273

	<u>Min.</u>
6.1.1 Move 12 RFs from ATMX to laydown area (four at a time)	48
6.1.2 Remove 12 RFs one at a time, from laydown area to log-in area. (132 minutes elapsed time)	
a. Enter space, pick up RF, back out	1
b. Scan RF for contamination or minor repair	5
c. Move to log-in area or to minor repair area, laydown RF and return	5
(As there are no barriers on the laydown area, the forklift can remove the first RF as soon as the crane removes the sling from the RFs, i.e., about 12 minutes after starting to remove RFs from the ATMX. Thus RFs are being removed from the space during 36 minutes of the time the space is being loaded with RFs. Therefore, the added cycle time will be 96 minutes)	<u>96</u> 144

### 2.3 Shipment Scenarios

2.3.1 If all drums are shipped in STs on flatcars, nine (9) STs could arrive on the worst day and the ATMX with RFs could arrive the same day. Thus, on the worst day the following laydown space times would be required.

- a. The maximum time requirement occurs if the waste is unprocessed, and air sampling is done after unloading.

$$\begin{array}{rcl} 9 \text{ ST-UP} = 215 \times 9 & = & 2130 \\ 24 \text{ RF (2 spaces)} = 144 \times 2 & = & 288 \\ & & \hline & & 2418 \text{ min.} \end{array}$$

Thus for a 460 minute day, 5.2 laydown spaces would be required. Thus six spaces would need to be provided and would be 88% utilized. To provide turning space for the forklift unloading the STs, an empty space must be provided adjacent to each ST space, or a total of 12 spaces is required.

b. Since the RF's are received only once per week, the average day would require

$$9 \text{ ST-UP} = 215 \times 9 = 2130$$

$$24 \text{ RF} = 144 \times 2/5 = \frac{58}{2188}$$

Thus five spaces would be 95% utilized, but 378 drums would be processed rather than the 260 daily average.

---

2.3.2 If all drums are shipped in CCs, six (6) CCs could arrive on the worst day and the ATMX with RFs could arrive the same day. If the waste is unprocessed, air sampling is done in the laydown space and no wait period is required for a vehicle, the laydown space time required is:

$$6 \text{CC-U} = 159 \times 6 = 954$$

$$24 \text{ RF (2 binloads)} = \frac{288}{1242}$$

Thus 2.7 spaces would be adequate or 3 spaces would be 90% utilized.

2.3.3 If all drums (processed waste) are received in STs on flatbed trucks (8 per day) and the STs remain on the flatbed during unloading of ST, the tieup time for the truck station will be:

- a. Move flatbed from parking area, turn and spot inside building airlock 6
  - b. Close outer door, open inner door, move truck to unload station, decouple tractor. 6
  - c. Unload ST 193
  - d. Move truck out of unloading station through airlock 8
- $$\frac{8}{213}$$

$$8 \times 213 = 1704 \text{ min.}$$

Thus, 3.7 truck stations are required. Four (4) stations would need to be provided (93% utilized) for trucks and one (1) station to handle the RF boxes.

90029275

## 2.4 UNLOAD ATMX/M3

### Basis and Assumptions

- o Maximum of two ATMXs (20 M3s each) arrive per day.
- o Each M3 contains 8 55Ds.
- o On worst day an ATMX with 24 RFs will also arrive.
- o Flow through (in one airlock, out the other) used for vehicles.
- o When a railcar is pushed into station No. 1 it advances the incumbent car to station No. 2 and pushes the car from station No. 3 into airlock No. 2 where it is picked up by a donkey.
- o M3s are lifted 4 at a time from the ATMX and placed in position for unloading by a forklift.
- o M3 lids (12 gauge steel) are secured by 20, 5/16 x 1, 18 UNC screws (hex head). Assume 10 minutes to remove using power tool.
- o M3 lids weigh 100 lbs<sub>s</sub> and have no pickup points. They will need to be removed by using a sling. Assume sling attached to different forklift than will unload the M3s. Assume 5 minutes to lift, move and laydown lid.
- o Two 25 T cranes may work simultaneously on a single ATMX, but with the ATMX in Station 1 or 3 they must work in unison. Greater flexibility is obtained if each crane operates to the maximum extent in its own half of the building.
- o After the 25 T has moved an ATMX lid(s), the lid sling must be removed and a special sling or stiffback must be attached for lifting the 4 M3s. This time is included (on the average) in the M3 lifting cycle of 20 min per lift.
- o Air inside M3 must be sampled before lid is removed. Assume 10 minutes per M3. Assume sampling crew precedes lid removal crew in perfect sync. (Location of sampling port and method should be defined.)

DISRSGOP

90029276

	<u>Min.</u>
- Move to laydown area and lower	1
- Disengage 4 lifting bars (man must get to top of M3s)	10
- Move 25 T back to ATMX	<u>1</u> 20

### M3 UNLOAD, SPACE REQUIREMENTS

#### 1. Assumptions

- 1.1 ATMX lids are 17' x 10' x 6.3" thick
- 1.2 Space occupied by ST with door open is 25' x 11'.
- 1.3 Space occupied by CC with doors open is 24' x 8'.
- 1.4 Space occupied by 8 M3s with lids removed and stacked in two stacks at the end of the M3s is 25' x 8' min. or allowing 6" clearance between items, 27' x 8'6". If lids are rotated 90 degrees and stacked in a single stack the overall dimensions including clearance would be 26' x 8'6"
- 1.5 Space occupied by 12 RFs stacked 2 high is 24' x 7'. If 6" clearance is provided between RFs, the space becomes 26'6" x 7'.
- 1.6 Laydown space is needed for two spreaders for removal of CCs. Each spreader is 20' x 8'.
- 1.7 Unloading space module should be 27' x 11'.
- 1.8 When drums are unloaded from STs or CCs three at a time, the maximum payload is 2700 lbs. *When it is necessary to reach over one row of drums to reach second row on a sheet of plywood,* Assuming that pallets are loaded from both sides, the center of the load is 36" from the fork face, when the load is laid down in the inner rows on the pallet. The distance from axle centerline to fork face (4000 lb towmotor) is 12.5". Assuming the lifting device is equivalent to 800 lbs at 36", the total load is 3500 lbs. Thus the inch-pound rating is  $(36 + 12.5)(3500) = 170,000$ . A capacity of 5000 lbs at 24" is required to give this rating. The minimum aisle for 90 degree stacking is 94" + 48" load or 12'. Thus, a 2.5 T forklift has the ability to load pallets by either driving onto the pallet or reaching

DISP0004

90029277

- o Two 2.5 T forklifts work simultaneously to unload 55Ds one at a time from a group of M3s. Each forklift operates in a vacant laydown space; one on each side of the M3 group.
- o As soon as four M3s are emptied they can be reloaded on the ATMX (after lid replacement). Pickup and unhook time is included in the 20 minute M3 handling cycle.
- o As 55Ds are removed from the M3 they are carried by the forklift to a laydown area consisting of a pallet large enough to hold 24 55Ds in a 6 x 4 array. (6.67 pallets are needed to hold the 55Ds from an ATMX). 55Ds are placed on the pallet by driving the forklift up a ramp onto the pallet.
- o Assume the forklift is equipped with a single drum Lift-O-Matic mounted so it can be rotated 360 degrees and have two direction translation. It also has a vertical arm to provide lateral support at the lower portion of the drum.

	<u>Min.</u>
o 55D unload time estimate	
a. Obtain position at M3	.5
b. Lower, align gripper, engage and lift drum	2.0
c. Back, turn and start run	.5
d. Run to laydown and turn	.5
e. Inspect for repair and swipe representative sample	1.5
f. Laydown, back, turn and return to M3	1.0
g. Inventory taken on pallet, independent of handling process. (No cycle time involved.)	<u>0</u>
	<u>6</u>
o The lift cycle for removing M3s from an ATMX consists of:	
- Move 25 T crane with special sling into place	1
- Attach 4 lifting bars to 4 M3s (Crew on top of ATMX from lid removal)	6

and two pickup three drums from the  
outboard side of a 4' plywood sheet.

from either side to place drums in the center rows. It also provides some margin of safety if drums are handled four at a time. (The minimum aisle for a 2T forklift is about 11'-4". Thus no significant gain is made by using the smaller lift and some flexibility is sacrificed.)

869300

90029279

5.1 Calculation of Forklift size to handle loaded pallet.

12.5'		Load		
24 drums overpacked @ 1000 lbs ea.	8.5'	drums	24,000	
		pallet	5,000	
		forks	1,000	
			30,000 lbs	

Center of load is 51" from fork face. For trucks in 30K class, distance from fork face to centerline of drive axle is about 24". Thus, inch-pound rating required is  $(51 + 24) 30,000 = 2,250,000$  inch-pounds. The truck capacity at 30" (towmotor load center distance for trucks above 20,000 lb class) would be  $\frac{2,250,000}{(30 + 24)} = 42,000$  lbs

At 36" load center (Clark rating distance above 30,000 lbs), the truck capacity would be 38,000 lbs. For Clark trucks both the 35K and 40K trucks have 240" turning radius. Overall length to fork face is 242". Thus the machine with forks would be about 26 ft long by 11 ft wide. These trucks (Clark) have gas or diesel engines. The minimum aisle for 90 degree stacking is about 29 feet.

5.2 Calculation of forklift size to handle RF boxes.

This forklift should handle overpacked RFs as well as regular RFs. The overpacked RF is 5 x 5 x 8 and weighs up to 11,000 lbs with a 30" load center. In the 12,000 lb class, the drive axle to fork face distance is 16.13". Thus the inch-pound rating is  $(30 + 16.13)(11,000) = 510,000$ . The 12,000 lb capacity truck is rated at only 481,000 inch-pounds. Therefore, the next larger size, i.e., the 15,000 lb truck is required. This truck has about an 18" drive axle to fork face distance. Thus the inch-pound rating is  $(30 + 18)(11,000) = 528,000$ . This is well within the 628,125 inch-pound rating of the truck.

90029280

The minimum aisle for 90 degree stacking for the 15,000 lb truck is 128.25" plus load length (60"), or 188.25" (15.7'). An aisle width of 16' should be used.

#### 5.3 Fork lift dimensions (approximate)

<u>Capacity</u>	<u>Dimensions (unloaded)</u>		Min. aisle for 90° stacking
	<u>Length</u>	<u>Width</u>	
2000	8'	3'	10'
5000	10'	4'	12'
15,000	14'	5'	16'
40,000	26'	11'	<del>20'</del> 29'

#### 5.4 Hoist

25T with 5T aux (Shaw-Box) requires 3'3" from hook to rail centerline and 10-1/8" from rail to column or wall face. That is, the main hook will reach within 50" of the column face.

The auxiliary hook, following behind the main hook, has a separation distance of 4'10". Thus, it will reach within 9' of the column face.

With the aux hook leading, the main hook will reach within 100" (8'4") of the column face and the aux within 4".

The closest approach of the hooks to the stops in the direction of bridge travel is 8' in one direction and 12' in the other.

## 2. UNLOAD LAYDOWN SPACE

### 2.1 Basis and Requirements

Three types of containers (ST, CC, M3) holding 55 gallon drums (55D) are received at the unloading stations. In addition, RF boxes are received. All containers and boxes are unloaded from the vehicles and transported to a laydown area by bridge cranes. The laydown area is an open floor space if no airlock is used between the vehicle unloading area and the container unloading area. If an airlock is used, the laydown area could be end-opening bins with removable lids. If bins are used, about 25 percent more floor space will be required to provide for bin walls and for air sampling of STs if the sampling ports are not on the hinge side of the container. (The sampling location and procedure should be defined. If sampling can be performed before unloading the ST from the vehicle, this is not a consideration.)

The 55Ds are normally unloaded, two or three at a time, from the containers (STs and CCs) through end-opening doors while the containers are in the laydown area. The 55Ds are then moved to a receiving/inspection area. However, a small portion of the containers may be found to be contaminated on the inside. Internally contaminated containers are moved to the overpack area for unpacking. (If internal sampling is performed while containers are on the vehicle, contaminated containers would be moved directly from the vehicle to the overpack area.) This frees the space for other use. When containers are unloaded in the laydown space, the space is tied up until the proper type vehicle is available in a loading station to receive the container.

Since the M3 is top loading, it must be removed from the airlock bin (if the bin is used) before unloading and to free the bin for other use. (If the airlock is not used, the M3s would still be moved from the laydown area to an unloading/receiving/inspection area before unloading, since

CB3MSUDR

90029282

access is not available to all M3s while in the laydown area.) The M3s probably are removed one at a time from the bin or laydown area to an unloading/receiving/inspection area.

After the M3s are unloaded, they are moved back to a bin or laydown area to await loading onto an ATMX car.

RFs are removed from the bin (or laydown space), probably one at a time, to a receiving/inspection area. It may be desirable to equip the laydown area handling RFs with a movable dolly, so that the entire load (120,000 lbs) can be moved from the laydown area for forklife access to the long side of the RF.

In summary, the quantity of items moving into and out of the laydown space for the various types of containers and waste received, are:

Item (waste)	Bin Quantity - Item			
	In Top	Out Top	Out End	In End
Supertiger/Processed	1-ST	1-ST	33-55D	—
Supertiger/Unprocessed	1-ST	1-ST	42-55D	—
Cargo Container/Processed	1-CC	1-CC	43-55D	—
Cargo Container/ <sup>ed</sup> Unprocess <sub>s</sub> /	1-CC	1-CC	60-55D	—
Mark 3/Processed	10-M3	10-M3	10-M3	10-M3
Mark 3/Unprocessed	10-M3	10-M3	10-M3	10-M3
Mark 3/Undrummed	10-M3	—	10-M3	—
Rock Flats Box	12-RF	—	12-RF	—

Sus P. Sauer


90029283

The arrangement of items in the bin or laydown space and in the containers is indicated in the following sketch. It can be observed that:

- o If 4 M3s are carried in a single lift by the unloading crane, 10 M3s (2.5 lifts) can be loaded into an airlock bin by lowering to near the bin floor and moving two of the four M3s under the bin top deck. (The center of gravity remains about 2 feet clear of the deck.)
- o To load 10 M3s (4 per lift) into each bin, the loading sequence would be:
  1. Load 4 M3s into bin "a" near the door
  2. Lower 4 M3s at rear of bin "a", leaving two at wall
  3. Carry 2 M3s to bin "b" and deposit at rear wall
  4. Place 4 M3s at center of bin "a"
  5. Place 4 M3s in bin "b" near door
  6. Place 4 M3s in center of bin "b"
- o Ten M3s in a bin is one-half an ATMX carload (This is desirable).
- o Twelve RFs in a bin is also one-half an ATMX carload (This is also desirable).
- o With the arrangements shown, a single bin size and shape will accommodate all four containers.
- o The minimum dimensions for the bin appear to be:
  - Bin inside - 12' x 27'
  - Hatch opening - 9'6" x 22'
  - Door opening - 10' x 10'
- o An ST with inside dimensions of 76" x 76" x 172" long will hold 42 55Ds in 3 columns of 7 each. To unload 2 at a time by forklift would present difficulty. (When drums are 3 per row, it is difficult to

CB345004

90029284



AIR LOCK GINS  
PLAN VIEW

AIR LOCK BINS  
END ELEVATION  
(Hatchway, Door, Open)

sign it

**RIZI WIPP PROJECT  
ITFA ARRANGEMENT IN LIMS AND CONTAINERS**

55-2 Drum: 23" ad. x 35 1/4" hi.


2025 RELEASE UNDER E.O. 14176

90029285

2" square

55 D<sub>r</sub>  
in 13

56 3/4 inside clear opening  
61 0 outside



90029286

JP  
2/13/26

pick up two per lift without having drums moved about between lifts. A man would have difficulty moving a 900 lb drum by hand.) Therefore, drums should be removed one at a time or 3 at a time.

- o Above comments regarding unloading also apply to the CC.
- o If magnetic coupling to drums can be used (this is being investigated), and there is sufficient head room inside the ST and the CC, the drums might be picked out three at a time by forklift. (Other means of drum removal, such as "Lift-O-Matic", are also being investigated.)
- o Portable ramps will need to be used with the ST and CC to allow the forklift to enter the container. These ramps will need to be stored when not in use.
- o At least one laydown space will need to be equipped with a dolly (50,000 lbs capacity) for transport of occasional STs or CCs (internally contaminated) to the overpack area.
- o A practical means of removal of the M3s and RFs from the laydown area will need to be determined. (More detail on the configuration of the M3 and RF is needed as a basis for this determination.) One possibility is to install a roller floor in some of the laydown spaces. The rollers would extend about 8 feet beyond the roll up doors (if bins used) allowing M3s and RFs to be pushed or pulled into the working aisle for access by a forklift. Undesirable features of this approach are that it adds the cost of rollers, makes some laydown spaces different from others and adds an activity (lateral rolling movement) to the unloading sequence.
- o It appears that M3s can be removed one at a time from the laydown area by means of a forklift. There appears to be adequate head room, and a boom attachment appears feasible for lifting the M3.

DISCUSSION

90029287

- o Placing of RF boxes in the laydown space from above and removal from the end of the space can be visualized for two alternative configurations; one with the long dimension of the RF parallel to the long dimension of the bin; the other with the long RF dimension perpendicular to the long bin axis.
- o If the RF and bin major axes are parallel, the RFs can be loaded easily, four at a time, into the bin. However, unloading through the end of the bin may present a problem. The slings used to unload the RFs from the vehicle and transport to the bin will have been removed by the overhead crane for return to the sender in the ATMX. The only access under the RF is from the long dimension side. There are no other pickup points. Two approaches to removal from the bin are apparent: a special boom device with pendulous arms to grip an RF from above, or a means of sliding the RFs (on rollers or dollies) through the bin door to provide forklift access to the long dimension of the RFs. Both of these approaches would entail the cost of special equipment development for a low utilization activity. In addition, rollers would need to be covered or dollies removed for bin use with a CC or ST.
- o If the RF and bin major axes are perpendicular, the RFs cannot be loaded, four at a time, into the bin through the 22-foot long top opening indicated. This constraint could be removed by providing a removal section of top deck about 3 by 9 feet at the door end of the bin. (This constraint does not exist if the airlock concept is not used.) With the RF and bin major axes perpendicular, the RFs can be removed through the bin door, one at a time, by conventional forklift. This approach appears to be the simplest and least costly of the alternatives and is the preferred approach.

RBS/MSB

90029288

## 2.2 Time Estimates

A container laydown station or airlock bin is "tied up" or utilized from the time it is designated to receive a container(s) until the container(s) is removed and the space is available to receive another shipment. Thus, the activities that determine the time cycle for laydown space utilization are:

- a) move container(s) from vehicle to laydown
- b) close bin lid (if airlock used)
- c) open bin door (if air lock used)
- d) Sample air inside container (ST or CC). This should be done while container is on the vehicle, rather than in the laydown space.
- e) Open container door (for ST and CC only)
- f) Place ramp (ST and CC only)
- g) Empty container (if ST or CC) or laydown space (if RF or M3)
- h) Close container door(s) (ST or CC)
- i) Close bin door (if airlock used)
- j) Open bin lid (if airlock used)
- k) Wait for proper type vehicle to be spotted (if ST or CC).
- l) Move ST or CC from laydown space to vehicle.

Time cycle estimates for the four types of containers, two types of waste, and three types of vehicles, follow:

	<u>Min.</u>
1. Supertiger Processed Waste (ST-P), Flatcar or Truck, Bin Airlock, Sample air at laydown, wait for vehicle.	
1.1 Move ST-P from Flatcar to laydown, disengage sling and clear top of bin.	8
1.2 Close bin lid	5
1.3 Open bin door (door and lid are interlocked)	2
1.4 Sample air in ST	15
1.5 Open ST door (unbolt and swing back two doors in sequence)	15
1.6 Place ramp on floor	10
1.7 Remove 33 55Ds from ST (3 per lift)  (Is there dunnage to remove?)  Assume forklift used to enter ST, engage three drums, backout, turn, travel 20 ft., release drums on conveyor, turn, return 20 ft. to ST (4 min/cycle)	44
1.8 Remove ramp from floor and store	10
1.9 Close ST doors	15
1.10 Close bin door	2
1.11 Open bin lid	5
1.12 Wait for available of proper flatcar or truck	30
1.13 Move ST from laydown to flatcar or truck	<u>8</u>
	169

18583008

90029290

2. Supertiger, Unprocessed Waste (ST-U), Flatcar or Truck, Bin  
Airlock, Sample air at laydown, wait for vehicle. Min.

1. 1- Time elements from moving the ST through  
1. 6 placing ramp on floor are the same as Case 1. 55

1. 7 Remove 42 55Ds from ST (3 per lift). Assume  
4 min/lift cycle. 56

1. 8- Time elements from removing ramp through  
1. 13 returning ST to vehicle are the same as Case 1. 70

181

0000000000

90029291

3. Supertiger, Processed Waste (ST-P), ST remains on Flatbed  
Truck, No airlock.

	<u>Min.</u>
3.1 Sample air in ST.	15
3.2 Open ST door (unbolt and swing back two doors in sequence).	15
3.3 Place ramp on floor	10
3.4 Remove 33 55Ds from ST (3 per lift). Assume there are sufficient forklifts operating so that a forklift approaches the truck bed as soon as the approach is cleared by the previous forklift (assume 4 min/cycle).	44
3.5 Remove ramp from floor and store	10
3.6 Close ST doors	15
	109

90029292

Shaft Sinking Procedures

POOR ORIGINAL

90029293

WASTE ISOLATION PILOT PLANT

CONCEPTUAL DESIGN

SHAFT SINKING PROCEDURES

90029294

272.228

## TRU SHAFT SINKING PROCEDURE

No development on the TRU Level except for 30 feet of the station on both sides of the shaft will be done off the TRU shaft. Therefore, as storage operations are not to begin until May 1, 1983, the sinking of this shaft can be done relatively late during construction of the WIPP facility. However, its sinking will interfere with construction of the TRU Building on surface so the sinking operations will have to be scheduled to be compatible with the surface construction.

The sinking and grouting methods developed in the conceptual design for the TRU Shaft are shown on sheet A7 of Drawing No. 94569. ERDA No. 9 and the 21 potash evaluation holes provided the majority of the information used as a basis to formulate this shaft sinking plan. Thus, it is based upon extremely limited information.

The TRU Shaft sinking program developed for the conceptual design can be described in a stepwise manner as follows:

1. Contractor sets up his temporary electrical system, hoist and compressors.
2. Excavate the shaft collar area to at least a 14-foot depth with either a clamshell bucket or backhoe equipment.
3. Form and install the necessary rebar for the shaft collar.
4. Pour the shaft collar.
5. Commence actual shaft sinking for a 20 foot diameter excavation and establish the drilling and blasting pattern, depth of round, etc. while mucking with a clamshell shovel. Concurrent with the sinking operation, install an 15-inch thick shaft concrete lining at pour intervals suitable for the ground conditions. If problem areas are encountered, the shaft walls are shotcreted as necessary prior to concreting to insure a safe and efficient sinking and lining operation.

90029295

through the salt. However, as sinking progresses, sections may be encountered where siltstone and shales present loose ground conditions. In the event that condition develops, roof bolts and cyclone screen are used to secure the shaft walls. Spray-mortar, i.e., gunite or shotcrete, is then applied to prevent further air slackening of the shale members.

Sinking is continued to the shaft bottom located 13 feet below the anticipated floor elevation of the TRU Level to minimize floor damage on the TRU Level and also to allow examination of the bedding to determine the final mining horizon. Excavation of that portion of the station done off the shaft is started using the work deck as a drilling platform. The station excavation (30 feet on either side of the shaft) proceeds with both sides advanced concurrently with a cycle of drilling on one side while mucking on the other.

As this station has a large cross-sectional area, it is mined by benching to facilitate a cycle of drilling, blasting, mucking and roof bolting. Removal of the salt excavated in the station is done using compressed air operated tucker hoists to slush material to the shaft for loading into the sinking skip.

10. Upon completion of the TRU Level Station excavation for the concrete station sill is completed, then formed and the concrete poured.
11. Complete the shaft bottom.
12. Remove shaft sinking equipment, all temporary utilities and ventilation equipment from shaft.
13. Install the shaft conveyances.
14. Remove all of the shaft contractor's shaft equipment from the job site.

90029266

When the clamshell becomes inefficient for muck removal, a sinking headframe, hoist and sinking bucket are installed and used. (This will probably occur in the depth range of 50 to 60 feet.)

Initial ventilation for the sinking operation is established utilizing tubing with a positive blowing system. Later, when sinking at a greater depth, it will be more efficient if an exhaust ventilation system is used because the blasting fumes will be cleared faster from the shaft bottom.

6. Install a multideck sinking stage with hoist. These are then used to complete the shaft sinking.
7. Commence installation of shaft sets and guides.
8. Resume shaft sinking and installation of the concrete lining, shaft sets and guiles through the lined section of the shaft. The only potential fluid zones known at this time are the Magenta and Culebra Dolomites in the Rustler Formation and the contact between the Rustler and Solado Formations. If grouting of these zones becomes necessary, the suggested procedures are shown on sheet A4 of Drawing No. 94569.

The shaft lining is continued into the Salado Formation until a competent formation is reached that is suitable for effecting a water tight seal. There are several anhydrite beds near the top of the Solado Formation which, if present as expected, should be good candidates for this purpose. The bottom of the lining is then formed and keyed to provide a bearer set and water collecting ring.

9. Resume sinking, but at a 20.5-foot diameter. This will allow shaft closure, due to stress induced creep, to occur over the service life of the shaft without imposing the requirement for later enlargement. Severe ground problems are not expected while sinking

90029297

Supervisor

## RH SHAFT SINKING PROCEDURE

No development on the RH Level except for the underground transfer cell will be done from the RH Shaft. Therefore, as storage operations are not to begin until May 1, 1983, the sinking of this shaft can be done relatively late during construction of the WIPP facility. However, its sinking will interfere with construction of the RH Building on surface so the sinking operations will have to be scheduled for compatibility with the surface construction.

ERDA No. 9 and the 21 potash evaluation holes provided the majority of the information used as a basis to formulate the shaft sinking plan. Thus, the shaft sinking plan is based upon extremely limited information. Sheet A3 of Drawing No. 94567 shows the sinking and grouting methods developed during the conceptual design for the RH Shaft.

The RH Shaft sinking program developed for the conceptual design is described in a stepwise manner as follows:

1. Contractor sets up his temporary electrical system, hoist and compressors.
2. Excavate the shaft collar area to a minimum depth of 14 feet using either a clamshell bucket or backhoe equipment.
3. Install the concrete forms and rebar for the shaft collar.
4. Pour the shaft collar.
5. Commence actual shaft sinking at a 11-foot diameter and establish the drilling and blasting pattern, depth of round, etc. while mucking with a clamshell shovel. The 18-inch thick shaft concrete lining is poured concurrently at suitable pour intervals dependent upon ground conditions. The shaft walls through problem areas are shotcreted as necessary prior to concreting to insure a safe and efficient sinking and lining operation.

100029298

90029298

Efficient use of the clamshell for muck removal is anticipated to be in the range of 50 to 60 feet. When this operation becomes inefficient, a sinking headframe, hoist and sinking bucket are installed and used until later replaced with the permanent hoist system.

Ventilation for the sinking operation is established using tubing and a positive blowing system. Later on, at a deeper depth, it will be more efficient to use an exhaust ventilation system for clearing the blasting fumes from the shaft bottom.

6. Install a multideck sinking stage with its hoist. The multideck stage enables several work tasks to proceed concurrently for maximum efficiency by allowing drilling and mucking in the bottom to be done at the same time as the lining operation (forming, placing concrete or removing forms) or while sets and guides are being installed. This multideck stage is used until completion of the shaft sinking.
7. Commence installation of the shaft sets and guides.
8. Resume shaft sinking and installation of the concrete lining, shaft sets and guides through the upper lined section of the shaft.

Continue the shaft lining through all the potential water bearing zones and into the Salado Formation until a competent formation is reached that can be used to effect a water tight seal. Several anhydrite beds are expected to be present near the top of the Solado Formation and one of these should be a good candidate for this purpose. The bottom of the lining is then formed and keyed so as to provide a bearer set and water collecting ring.

90029299

At this time, the only known potential fluid zones are the Mugenta and Culebra Dolomites in the Rustler Formation and, possibly, a zone at or near the contact between the Rustler and Solado Formations. The suggested grouting procedures to be used, if required, are shown on sheet A3 of Drawing No. 94567.

9. Continue sinking of the shaft at a 9-foot diameter to an approximate depth of 2175 feet and then at a diameter of 10 feet to the shaft bottom. These increased shaft diameters provide an allowance for the closure resulting from stress induced creep.

Shaft sinking through the salt is not expected to present any ground problems. However, there may be sections where siltstone and shales present loose ground conditions as sinking progresses. Should this condition develop, roof bolts and cyclone screen are used for securing the shaft walls. If deemed advisable at the time, spray-mortar, i.e. gunite or shotcrete, is also applied to prevent further air slacking of the shale members.

10. At the depth of the RH Level, to improve ventilation, excavate a minimal sized temporary breakthrough to the shaft entry travelway mined previously by a continuous miner. The Underground Transfer Cell, because of its height, is best mined by benching to allow drilling and mucking simultaneously. Roof support is installed as dictated by the ground conditions. All excavation of the Underground Transfer Cell is completed via the RH Shaft. The shaft is completed when the sump below the floor of the Transfer Cell is completed.
11. Remove all shaft sinking equipment, temporary utilities and ventilation equipment from the shaft.
12. Install the shaft conveyances.
13. Remove all of the shaft contractor's shaft equipment from the job site.

90029300

## MAN AND MATERIALS SHAFT PROCEDURE

As with all of the shafts, the majority of the information used as a basic to formulate this shaft sinking plan was obtained from the 21 potash evaluation holes and ERDA No. 9. By necessity, therefore, it is based upon extremely limited information. The conceptual shaft sinking program developed for the Man and Material Shaft, along with the suggested grouting procedures, are shown on sheet A5 of Drawing No. 94571 and can be described in a stepwise manner as follows:

1. Contractor sets up his temporary electrical system, hoist and compressors.
2. Excavate the shaft collar area to a depth of 14 feet using either a clamshell bucket or backhoe equipment. Also excavate the permanent headframe foundation concurrently with the shaft collar.
3. Form and install the necessary rebar for both the shaft collar and headframe foundation.
4. Pour the shaft collar and the headframe foundation utilizing a monolithic concrete pour.
5. Commence actual sinking for a 26-foot diameter excavation and establish a drilling and blasting pattern, depth of round, etc.

while mucking with the clamshell shovel. In conjunction with the sinking operation, Pour an 18-inch thick concrete lining at pour intervals suitable for the ground conditions encountered. In any problem areas encountered, shotcrete as necessary prior to concreting for a safer and more efficient sinking and lining operation.

It is anticipated that use of the clamshell for muck removal will be efficient only down to a depth of 50 or 60 feet. When use of the clamshell becomes inefficient, then a sinking headframe, hoist and sinking bucket are installed and used until replaced at a later time by the permanent hoist system.

90029301

Ventilation for the sinking operation is initially established with tubing and a positive blowing system. Later, at a greater depth, it is replaced by an exhaust ventilation system for greater efficiency in clearing the blasting fumes from the shaft bottom.

6. Install a multideck sinking stage and hoist. These are then used to complete the shaft sinking.
7. Commence installation of the shaft sets and guides.
8. Resume shaft sinking and installation of the concrete lining, shaft sets and guides through the lined portion of the shaft.

The Magenta and Culebra Dolomites in the Rustler Formation and the contact between the Rustler and Solado Formations are the only potential fluid zones known at this time that will be encountered in this shaft. If grouting of these zones is required, the procedure recommended is shown on sheet A5 of Drawing No. 94571.

The shaft lining extends into the Salado Formation to the first competent formation reached that can be used to effect a water tight seal. The information available at this time indicates that there are several anhydrite beds near the top of the Solado Formation which will be good candidates for this purpose. The bottom of the shaft lining is formed and keyed in the anhydrite bed selected to provide a bearer set and water collecting ring.

9. After the concrete lining is completed, the last stage of forms are removed and, if deemed more efficient, the staging is modified to a double deck stage for installation of shaft sets only.
10. Recomence sinking, only at a 25.5-foot diameter. This is done to allow for that shaft closure which will occur as a result of the stress induced creep. A small pump station is excavated at a reasonable distance below the water ring. The water collected in

10CRS61

90029302

the water ring is piped to this pump station where it is then pumped to surface for disposal.

Install the permanent headframe, bin, hoist and a surface salt conveyor disposal system. This can be done at any time during the shaft sinking, but the earlier it is done, the more it benefits the shaft contractor with his muck removal. The production hoist is brought into service for muck handling with balanced self-dumping sinking buckets as soon as it is ready following erection of the headframe.

It is not expected that any severe ground problems will be encountered while sinking through the salt. However, there may be sections of the shaft in which siltstone and shales present loose ground conditions. To prevent undue delay if this occurs, roof bolts and cyclone screen are used to secure the shaft walls. Spray-mortar, i.e., gunite or shotcrete can be applied to prevent further air slacking of the shale members.

Sinking is continued to 15 or 20 feet below the anticipated floor elevation of the TRU Level. This additional distance will then minimize floor damage at the station and also allow examination of the bedding to determine the final mining horizon. Further, it also reduces the possibility of blasting damage when sinking is resumed.

11. Excavation of the station on the TRU Level is started using the work deck as a drilling platform and allowing the blasted salt to fall into the vacated shaft opening. Station excavation proceeds with both sides being advanced concurrently with a cycle of drilling on one side while mucking on the other. Mining of the station, as it has a large cross-section, is done by benching to facilitate a cycle of drilling, blasting, mucking and roof bolting.

90029303

Because this shaft is the main access for all personnel and materials handling, development advantages are gained for future concurrent work if some development is accomplished prior to completion of the shaft. Therefore, in addition to excavation of the station, an entry is mined from the shaft station to the Construction Ventilation Shaft. An early breakthrough into the Construction Ventilation Shaft allows improved ventilation flows with one shaft downcast and the other upcast. In addition, a minimal sized opening is mined to the top of the muck transfer raise with sufficient room made to allow installation of a raise drill at a later time. The major advantage gained from this procedure is the time that will be saved later by allowing equipment to be lowered and assembled while still sinking the shaft or during installation of the skip loading equipment.

Upon completion of the TRU Level Station, excavation for the station concrete sill is completed, formed, and then the concrete poured. The hardware shown in the station design is installed concurrently with the station construction in order to facilitate equipment handling. This hardware will include such items as the bridge crane and monorails in addition to that equipment useful to the shaft sinking and development done in this phase.

12. Resume shaft sinking operations to the RH Level at a shaft excavation diameter of 28 feet.
13. The RH Level Station is excavated following the same procedure as that described in Step 11 for the TRU Level Station. This includes installation of the monorail and crane to facilitate handling of equipment and supplies.

2020-01

90029304  
161

14. Upon completion of the station, an entry connecting the Man and Material Shaft to the Construction Ventilation Shaft is mined to improve ventilation. In addition, a minimal sized entry is also driven from the Construction Ventilation Shaft around to the top of the skip loading pocket. This will allow an early breakthrough to be made when later excavating for the skip loading facilities. Due to the relatively inefficient muck handling facilities available at this time (as compared to the skip loading equipment available later), all entry development should be kept to minimal sizes and then enlarged later when more efficient facilities are installed.
15. Excavate, form and pour the RH Station sill.
16. Resume shaft sinking at a 28-foot excavation diameter. As the shaft is deepened, excavate the opening required for installation of the skip loading pocket.
17. Continue with the skip pocket excavation and complete the shaft excavation to a depth that allows installation of the skip pocket equipment.
18. Form and pour the concrete floor of the skip loading pocket and install the loading pocket steel and skip loaders.
19. Complete excavation to the shaft bottom, including concreting the floor and sump. Also mine a 10-foot long entrance to the ramp off the shaft bottom to provide a safe breakthrough for the ramp when it is driven later.
20. Remove the shaft sinking equipment.
21. Install the shaft conveyances and remove all temporary utilities and ventilation equipment from the shaft.
22. Install the permanent power, connections, etc. in the shaft.  
The remainder of the shaft oriented work is done using the permanently installed shaft equipment (especially the skips) for improved efficiency.

90029305

23. Excavate the openings required for installation of the salt handling equipment below the RH Level. Until this facility is complete and operable, muck handling at the Man and Material Shaft is inefficient and no mine development can begin.

Start the excavation with a small sized (approximately 6 foot diameter) inclined raise to connect the skip loading pocket to the transfer gallery (about 35 feet in length). Then drive an opening (again of minimal dimensions for maximum advance rate) to the transfer storage location. This requires a sublevel 75 to 80 feet in length. At the end of this sublevel, drive a vertical breakthrough raise up to the RH Level. The purpose of this work is to provide ventilation with a minimal amount of muck handling. Upon making the connection, ventilation is established through the skip loading facility.

Starting at the top of the skip loading pocket and working upward, enlarge this breakthrough to its final dimensions by slashing. The excavated muck is fed through the skip loading pocket into the skips. All of the skip loading facility is mined from this shaft.

24. Install the equipment for the salt transfer facility, including the RH storage bin, the chute for the TRU salt transfer, the bin feeders and all conveyors. Concurrently, install the TRU transfer conveyor on the RH Level to the bottom of the proposed TRU-RH muck raise. At the same time this equipment is being installed, the TRU-RH muck raise pilot hole is drilled from the TRU Level.
25. The TRU-RH muck raise pilot hole is enlarged to its final 6-foot diameter by reaming upward. Since the cuttings fall by gravity to the RH Level, they are loaded onto the conveyor installed in

Step 24. As no facilities exist for handling muck from the TRU Level until this raise is completed, it is readily apparent that Steps 23, 24, and 25 must be carefully scheduled and until these facilities are complete and operable, full scale mining on both levels is delayed. Some equipment assembly and installation work can be performed, but the operation of the muck handling facility is the focal point for mining by continuous miners on the two underground levels and, therefore, the shaft salt handling capability must be operational before any significant development work can be started on either level.

26. Although it is not an integral part of the shaft, the incline from the RH Level to the shaft bottom is required for efficient full scale operation. Mining can commence prior to completion of this incline, however, it is required in order to provide an efficient method of cleaning the inevitable spill that will occur during skip loading.
27. Completion of Steps 25 and . i, and the removal from the site of the shaft sinking equipment constitutes completion of the shaft construction.

## VENTILATION SHAFTS SINKING PROCEDURE

Both ventilation shafts are the same size and, therefore, will be sunk in the same manner. As with all of the other shaft sinking plans formulated for the conceptual design, ERDA No. 9 and the 21 potash evaluation holes provided the majority of the information used as a basis to formulate this shaft sinking plan. Sheet A3 of Drawings No. 94573 and No. 94574 shows the sinking and grouting procedures developed during the conceptual design for the TRU-RH and Construction Ventilation Shafts respectively.

The shaft sinking program developed during the conceptual design for the two ventilation shafts is described in a stepwise manner as follows:

1. Contractor sets up his temporary electrical system, hoist and compressors.
2. Excavate the shaft collar area to a minimum depth of 14 feet using either a clamshell bucket or backhoe equipment.
3. Install the concrete forms and rebar for the shaft collar.
4. Pour the shaft collar.
5. Commence the actual shaft sinking at a 16.5-foot diameter excavation size and establish a drilling and blasting pattern, depth of round, etc. while mucking with a clamshell shovel. The 15-inch shaft concrete lining is poured concurrently with the sinking operations and at pour heights suitable for the ground conditions encountered. The shaft walls through any problem areas are shotcreted as necessary prior to concreting to insure a safe and efficient sinking and lining operation.

Efficient use of the clamshell for muck removal will probably be in the range of 50 or 60 feet. When this operation becomes

90029308

inefficient, then a sinking headframe, hoist and sinking bucket are installed and used.

Ventilation for the sinking operation is established with tubing and a positive blowing system. Later on, when at a deeper depth, it will be more efficient if an exhaust ventilation system is used for clearing the blasting fumes from the shaft bottom.

6. Install a multideck sinking stage with its hoist. These are then used to complete the shaft sinking. Use of the multideck stage allows concurrent performance of several tasks such as drilling and mucking on the bottom while forming, pouring or stripping forms for the shaft lining or while installing shaft sets and guides.
7. Commence installation of the shaft sets and guides.
8. Resume shaft sinking and installation of the concrete lining, shaft sets and guides through the upper lined section of the shaft.

Continue installation of the shaft lining through all the potential water bearing zones and into the Salado Formation until a competent formation is reached that can be used to effect a water tight seal. Based on presently available information there will be several anhydrite beds near the top of the Salado Formation which should be good candidates for this purpose. The bottom of the lining is formed and keyed at the selected bed so as to provide a bearer set for the shaft lining.

At this time, the only known potential fluid zones are the Magenta and Culebra Dolomites in the Rustler Formation and, possibly a zone at or near the contact between the Rustler and Solado Formations. The suggested grouting procedures to be used, if required,

80-100  
90029309

are shown on sheet A3 of Drawing No's. 94573 and 94574.

9. Continue sinking of the shaft at a 15.5-foot diameter to about 15 or 20 feet below the anticipated floor elevation of the TRU Level to minimize floor damage and also to allow examination of the bedding to determine the final mining horizon. Further, this also reduces the possibility of blasting damage when sinking is resumed.

Shaft sinking through the salt is not expected to present any ground problems. However, there may be sections where siltstone and shales present loose ground conditions as sinking progresses. Should this condition develop, roof bolts and cyclone screen are used for securing the shaft walls. If deemed advisable at the time, spray-mortar, i.e. gunite or shotcrete, is also applied to prevent further air slacking of the shale members.

Excavation of the station can be started by using the work deck as a drilling platform with the broken muck going into the vacated shaft opening. As this station is relatively small, both in cross-section and length, it can be mined rather easily off the shaft.

Connection between the station and the remainder of the TRU-  
Level is made from the level itself.

10. Upon completion of the TRU station, excavation of the concrete station sill is completed, then formed, and the concrete poured.
  11. Resume shaft sinking operations to the RH Level at an excavation diameter of 16.5 feet.
  12. The RH Level station is excavated following the same procedure as that in Step 9 for the TRU Level Station.
  13. Excavate, form and pour the RH station bearer.

90029310

14. Complete the shaft bottom.
15. Remove shaft sinking equipment, temporary utilities and ventilation equipment from the shaft.
16. Install the shaft conveyances.
17. Remove all of the shaft contractors shaft equipment from the job site.

0118300

90029311

Hoist Time and Motion Studies

*POOR ORIGINAL*

90029312

## TRU SHAFT HOISTING TIME MOTION STUDY

A TRU Shaft hoisting cycle was developed for the conceptual design. A brief description of this hoisting time-motion study follows.

A one-shift-per-day operation of 8 hours that includes a 30-minute lunch period and two breaks of 10 minutes each was used. It was assumed that preventive maintenance would be performed at the start of the shift and during the lunch and rest breaks, with major maintenance done on the weekends or back shifts. A hoisting speed of 500 fpm with an acceleration of 2 fps<sup>2</sup> and a retardation of 2.5 fps<sup>2</sup> was assumed. Allowance was also made for a 2-s creep time during acceleration and a 4-s creep time during retardation.

A test run by an empty cage will be made through the shaft from the collar to the underground station and back each day before loading. This will be required after an extended lapse in hoisting (overnight or weekends) and after any repairs to either the cage or the shaft. Safety regulations do not require it, but because of the type material handled, such a test run is advisable.

At the start of the shift the cage will be in a released position just below the collar to prevent access to the cage without first notifying the hoistman. The cage is set on the collar landing chairs and the hoistmen and cage tenders then routinely check the equipment before beginning operations. This, unlike the cage test run, is required at the start of each operating shift, regardless of whether the operation is on a continuous or intermittent basis. Typical landing chairs as conceptually designed for the TRU Shaft are shown on Sheet M3 of Drawing No. 945.

Moving the cage off the landing chairs initiates the test run cycle that ends when the cage is returned to the landing chairs on surface. During the check of the shaft equipment on surface and also during the test run cycle, the loading crew

90029313

performs routine equipment checks and then prepares the first load to have it ready for the first lowering cycle whenever the cage is ready. At the end of the shift, the cage is left in the released position. If the shaft operation is on a single-shift basis, the cage is then ready for an emergency situation. If the operation is on a continuous basis instead, no access to the cage is possible during the hoistmen's change of shift. Our analysis for the operation of the TRU shaft hoist over the period of one shift is summarized in Table II.2-2.

Morning and afternoon breaks, in addition to a lunch period, have been excluded from the time available to lower the TRU waste containers, as has the time needed for a shift wrap-up. These times, by proper planning and scheduling, can be used for minor equipment maintenance and repair with scheduled premaintenance and repairs on weekends. For maximum efficiency, the working hours for all personnel involved in the underground waste handling system must be carefully scheduled, both underground and on the surface. Scheduling the start of the underground work shift for later than those on the surface is recommended to allow an even flow of material into storage.

No additional time has been allowed for unforeseen delays in the cycle analysis. There is a small amount of conservatism in the estimated times allowed for the various tasks such as signaling and the opening and closing of doors, chairs, etc. Staggering breaks and rest periods for personnel can also provide additional time and an additional measurement of conservatism. For the purpose of the conceptual design, it is felt that this degree of conservatism is proper. Further definition of the tasks, especially the loading and unloading tasks, will allow further refinement of the time cycles.

90029314

29t

TABLE II.2-2

SUMMARY OF ONE SHIFT'S OPERATION  
FOR TRU SHAFT HOIST

<u>Function</u>	<u>Time Allotted (Minutes)</u>
Equipment Check.....	15
Shaft Test Run .....	12
Morning Break .....	15
Lunch Break .....	30
Afternoon Break .....	15
Shift Wrap-Up .....	15
Load Cycles (14 Trips @ 27 min. 00 sec. ea.).....	<u>378</u>
Total Time .....	480 min = 8 hrs

## CYCLE BREAKDOWNS

Shaft Test Run Action Item	Elapsed Time Min.      S	Load Cycles Action Item	Elapsed Time Min.      S
Signal, Hoist	0 - 05	Open Cage Doors	0 - 15
Hoist Cage off Chairs	0 - 03	Load Cage (incl. secur-	8 - 03
Signal, Stop	0 - 02	ing load)	0 - 15
Release Chairs	0 - 05	Close Cage Doors	0 - 05
Signal, Lower	0 - 05	Signal, Hoist	0 - 03
Lower Cage to Station	4 - 36	Hoist Cage off Chairs	0 - 02
Signal, Stop	0 - 02	Signal, Stop	0 - 05
Inspect Cage	2 - 04	Release Chairs	0 - 05
Signal, Hoist	0 - 05	Signal, Lower	0 - 36
Hoist Cage to Collar	4 - 36	Lower Cage to Station	0 - 15
Signal, Stop	0 - 02	Open Cage Doors	8 - 03
Set Chairs	0 - 05	Unload Cage, Load Empty	0 - 15
Signal, Lower	0 - 05	Close Cage Doors	0 - 05
Lower Cage onto Chairs	<u>0 - 05</u>	Signal, Hoist	4 - 36
Total Elapsed Time	12 min.	Hoist Cage to Collar	0 - 02
		Signal, Stop	0 - 05
		Set Chairs	0 - 05
		Signal, Lower	0 - 05
		Lower Cage onto Chairs	0 - 05
		Total Elapsed Time	27 min.

90029315

## RH SHAFT HOIST TIME-MOTION STUDY

An RH shaft hoisting cycle was developed for the conceptual design. A brief description of this time and motion-study follows.

A single 8-hr daily shift was assumed, with a 30-minute lunch and two breaks of 15 minutes each (one in the morning and one in the afternoon). It was assumed that preventive maintenance would be performed at the start of the shift and during the lunch and rest breaks, with major maintenance on either the weekends or the back shifts. A hoisting speed of 500 fpm with an acceleration of 2 fps<sup>2</sup> and a retardation of 2.5 fps<sup>2</sup> was used. In addition, an allowance was made for a 2-s creep time during acceleration and a 4-s creep time during retardation.

A test run by an empty cage will be made through the shaft from the clean cell on surface down to the underground transfer cell and back each day before loading. This procedure will be required after an extended lapse in hoisting (overnight or weekends) and after any repairs are made to either the shaft or its conveyance. Safety regulations do not require this, but considering the nature of the material being handled, such a test run would be very advisable.

At the start of a shift, the cage will be on the landing chairs at the clean cell. A brief equipment check is then made before commencing operations. This, unlike the cage test run, will be required at the start of each operating shift irrespective of whether the operation is on a continuous or intermittent basis. Moving the cage off the clean cell landing chairs initiates the test run cycle that ends when the cage is returned to the clean cell. During both the surface check of the shaft equipment and the test run through the shaft, the loading crew will perform routine equipment checks and then prepare the first load so that it is ready for the first cycle when the shaft conveyance is ready. Our analysis for operating the RH shaft hoist over one shift is summarized in Table II.2-1.

In our analysis the morning and afternoon breaks, the lunch period and the time estimated to be necessary for a shift wrap-up

90029316  
200

TABLE II.2-1

SUMMARY OF ONE SHIFT'S OPERATION  
FOR THE RH SHAFT HOIST

FUNCTION	TIME ALLOTTED (MINUTES)
Equipment Check.....	15
Shaft Test Run .....	14
Morning Break .....	15
Lunch Break .....	30
Afternoon Break.....	15
Shift Wrap-Up .....	30
*Load Cycles(25 trips @ 14 min. 00 sec. ea.)...	<u>350</u>
Total Time .....	469 = 7.8 hrs

\*25 trips of the cage per day is 15 more than required with the current surface hot cell design, but will allow for further expansion.

## CYCLE BREAKDOWNS

Shaft Test Run				Load Cycles	
Action Item	Elapsed Time			Action Item	Elapsed Time
	Min. Sec.				Min. Sec.
Signal Hoist	0 - 05			Load Cage (incl. securing load)	0 - 30
Hoist Cage off Chairs	0 - 03			Signal, Hoist	0 - 05
Signal, Stop	0 - 02			Hoist Cage off Chairs	0 - 03
Release Chairs	0 - 05			Signal, Stop	0 - 02
Signal, Lower	0 - 05			Release Chairs	0 - 05
Lower Cage to Station	5 - 00			Signal, Lower	0 - 05
Signal, Stop	0 - 02			Lower Cage to Station	5 - 00
Lower Cage into Transfer Cell	0 - 33			Signal, Stop	0 - 02
Check Cage	1 - 00			Signal, Lower	0 - 05
Check Turntable Operation	1 - 00			Lower Cage into Transfer Cell	0 - 30
Signal, Hoist	0 - 05			Unload Cage in Transfer Cell	0 - 26
Hoist Cage	5 - 00			Load Empty Cart onto Cage	0 - 30
Hoist Cage into Clean Cell	0 - 33			Signal, Hoist	0 - 05
Close Landing Chairs	0 - 15			Hoist Cage	5 - 00
Signal, Lower	0 - 05			Signal Stop	0 - 02
Lower Cage onto Chairs	0 - 07			Signal, Hoist	0 - 05
Total Elapsed Time 14 min.				Hoist Cage into Clean Cell	0 - 26
				Signal, Stop	0 - 02
				Close Chairs	0 - 15
				Signal, Lower	0 - 05
				Lower Cage onto Chairs	0 - 07
				Unload Empty Cart	0 - 30
				Total Elapsed Time	14 min.

90029317

at the end of the shift were excluded in determining the number of waste canisters requiring movement per conveyance trip. These times, through proper planning and scheduling, could be used for minor equipment maintenance and repair with scheduled premaintenance and repairs performed on the weekends. No additional time was allowed for unforeseen delays.

There is very little conservatism in estimated times allowed for tasks. Staggered breaks, lunch and rest periods for personnel could provide additional time and thus an additional measure of conservatism. For the purpose of the conceptual design, it is felt that the degree of conservatism utilized is proper and not overly estimated. Further definition of the tasks will allow further refinement of the hoisting cycles.

90029518

Mining System Analysis

POOR ORIGINAL

10

90029319

## MINING SYSTEM ANALYSIS AND EQUIPMENT DESCRIPTION

Within a hydrostatic stress field, mine openings having an aspect ratio other than one are more stable when they are of an ovaloidal shape. Underground openings mined by boring machines tend to be more stable than those mined by conventional drilling and blasting methods because the shock that results from blasting tends to fragment and fracture the ground surrounding the opening. For these reasons, boring machines were selected as the best method to mine the underground openings at the WIPP facility.

To have an opening with sufficient width but without excessive height, an elliptical, ovaloidal, or rectangularly shaped opening must be used. Of these three configurations, the ovaloidal shaped opening is the most practical selection because it allows a conventional roadway, which an elliptically shaped opening will not; and it will definitely be more stable than a rectangularly shaped opening.

A variable-height, three-bladed twin rotor, boring type of continuous miner was selected. For this analysis, 78 different room configurations and sizes were investigated. Taking into consideration the possible storage configurations that were practical for the TRU waste containers, these 78 opening configurations were reduced to 21 possibilities. Of these 21 possibilities, only 7 remained suitable after considering the requirements for closure resulting from stress-induced creep of the salt strata.

The final 7 candidate opening configurations were then compared on the basis of the areal extent required for the TRU-level mining horizon, mined tonnage required to obtain the volumes necessary to store the containers, storage room length, service life of the openings, number of cutting passes required to be made per opening, and the efficiencies of utilization for the spaced mined. From this comparison, a machine size was selected that

90029320

allowed cutting an opening 10 ft. high by 18 ft. wide with a 13.5-ft. roadway in a single pass. The actual opening sizes selected were a three-pass-wide, two-pass-high opening (16.5 ft. high by 45 ft. wide with a 40.5-ft. roadway) for the storage rooms on the TRU level. An average mining capacity of 450 tons per machine shift was used for the conceptual design.

All of the underground openings mined by the continuous miner are advanced in a stepwise procedure with the miner first advancing along the right-hand side of the opening, cutting as it moves forward. The miner advances for approximately its own length and then backs out, moves 13.5 ft. to the left, and advances the second pass of the opening to the same depth as the first. When necessary, such as for the storage rooms on the TRU level, the machine then backs out from the second pass and proceeds to cut a third pass. Upon advancing the final horizontal pass to the same depth as the first, the miner moves back to the right-hand side of the opening and repeats the advancing process.

In the TRU-level storage rooms, it is necessary also to cut a lower second vertical pass. This lower vertical pass is made in the floor of the first vertical pass and after the first vertical pass has been completed for the entire room length.

The continuous miner selected consists of two sections, the cutting and conveying mechanisms that are joined together and connected to the main frame, and the tractor frame tramping unit assembly. The main frame carries the rear thrust posts and serves as a mounting structure for both the rear trim cylinders and the conveyor lift cylinders. The front thrust posts are integral with the rotor-drive gearcase. The tractor frame supports the entire weight of the machine and transfers this weight to tractor treads through bogey wheels in the track assembly. The weight of the rotor drive gearcase, conveyor assembly and main frame is supported by the tractor frame through the front and rear trim cylinders

90029321

that provide for complete control of the cutting mechanism position regardless of the seam orientation. The thrust of the trammimg mechanism is transferred to the cutting elements through the thrust post on the rotor-drive gearcase. The miner uses three electric motors, one for each rotor, with the third driving the hydraulic system pump.

Each rotor contains three arms that are extended and retracted by a ball-screw mechanism. The two rotor assemblies, on which the tool holders and cutter bits are mounted, are driven through the rotor-drive gearcase. Trim-chains and cutter bars are used both on the top and bottom of the machine to trim the area between the rotor arm assemblies and also to extend the opening roadway width.

A conveyor passes through the machine and conveys the material excavated out to the back of the machine. This conveyor is loaded by gathering arms located on an apron at the front of the miner.

90029322

Mine Ventilation Calculations

POOR ORIGINAL

## VENTILATION

BASIC GENERAL EQUATIONS: The following equations have been used in designing the underground ventilation systems for the conceptual design of WIPR.


Pressure loss due to Friction

$$H_f = \frac{\rho g V^2}{2} \cdot 0.0754 = 0.3898854$$

Pressure loss due to Shock

$$H_s = X(Y_p) = \frac{\rho g V^2}{2} \cdot 32.174 \cdot 3600 \cdot 5.1918 = 1,002,695.00709 = 0.2166 \rho g V^2 \cdot 10^{-3}$$

Shock Factors for Bends (change in the airflow direction)




$\alpha$  = angle of air flow deflection  
 $r = r$  = radius ratio  
 $w = r =$  aspect ratio

For a Normal Bend,

$$X_N = \frac{0.25}{r^{0.5}} \left( \frac{\alpha}{w} \right)^2$$

$$X_S = \frac{0.60}{r^{0.5}} \left( \frac{\alpha}{w} \right)^2 = 2.40 X_N$$

Shock Factors for Area Changes (change in the airflow velocity)



$A_c = C =$  coefficient of contraction

$A_o = N_c =$  ratio of contraction (areas)

$A_e = N_e =$  ratio of expansion (areas)

$$C = \left( \frac{A_o}{A_e} - \frac{2N_c^2 + N_e^2}{N_c^2} \right)^{0.5} \text{ where } Z \text{ is the contraction factor}$$

$$X_o = \left( \frac{A_o}{A_e} \right)^{0.5} \quad X_e = \left( \frac{A_e}{A_o} \right)^{0.5} \quad X_c = \left( \frac{A_o}{A_e} \right)^{0.5}$$

Shock Factors for Splits and Junctions (air streams leaving or entering the main stream)

Splits are comparable to bend losses except the velocity pressure of the air stream in the split is used.

Junctions can be approximated by using a shock factor that is 1.5 times that for a bend using the velocity pressure at the junction.

2

stream.

SHOCK FACTORS FOR OBSTRUCTIONS IN THE AIR STREAM - can be approximated by using the equations for determining the shock factor at an area change with an appropriate substitution of the value used for  $\epsilon$ .

When the obstruction is sufficiently long, three pressure losses are involved: (1) an abrupt contraction, (2) an increase in friction loss over the constricted section of airway and (3) an abrupt expansion. The friction loss over the constricted section can be taken as equivalent to  $\frac{2-N}{N}$  times the normal loss for the same length of unobstructed airway, where  $N$  is the ratio of constricted area to normal area. An allowance must also be made to account for the velocity of the obstructions relative to that of the air stream for a moving obstruction.

#### SHOCK FACTORS FOR LOCAL ENLARGEMENTS OR AREAS AND DEAD ENDS

These shock losses are normally negligible because the expansion is very rapid if flow is small and over only a limited length. If the enlarged section is relatively long, the shock losses resulting from expansion and contraction are usually counteracted by the decreased friction loss occasioned by the lower flow velocity through the enlarged section of airway.

LENGTH OF AIRWAY REQUIRED TO GIVE A FRICTION LOSS EQUIVALENT TO A SHOCK LOSS

$$\text{From } H_p = H_0, \log = 2 \cdot 32.179 \cdot 3600 \cdot 5.1918 \cdot \epsilon P = 3,088,709 \epsilon P = \epsilon P \cdot 10^6$$

#### AIRFOIL LEAKAGE THROUGH STOPPINGS

$$Q = m(\Delta H)^n A \quad \text{where } m = 355.0 \text{ and } n = 0.7 \text{ for Juto @ 14.93 ft per sec}$$

0.05	1.0	w/1-inch $q^2$ foam
0.10	0.8	w/1/2-inch $q^2$ foam
0.05	1.0	Nylon, 30 mil thickness

0029325

308

use Q = 0.05AaH for both stoppings and ventilation compasses.

Based upon the temperature logs run at the ERDA "9" hole, the virgin rock temperature at the TBL and RH levels can be expected to be approximately 85.17° and 87.68° F. respectively. Use the values at 85.25° and 87.75° F. for the virgin rock temperature on the TBL and RH levels respectively.

From the available meteorological data, the mean temperatures on surface can be seen to vary from about 40° F. in the winter to about 80° F. in the summer with the normal extremes expected over the year being 2° to 110° F. In the mine, the surface air temperature can be expected to vary over the period of a day from a low of 67° F. to a high of 93° F. in the middle of summer and from a low of 28° F. to a high of 55° F. in the middle of winter. On a sunny day, the average low and high temperatures will be about 77° and 75° F. For the working and ventilation design, use surface air temperature extremes of 0° and 110° F. and an average daily temperature mean of 61° F. for sunny extremes of 76.5° and 75.5° F. in terms of surface air.

TEMPERATURE	DRY AIR DENSITY	DENSITY @ SATURATION	ABSOLUTE HUMIDITY @ SATURATION
0° F	396.52186	6 - 0.0923820589	0.0233679916
40.5° F	381.57356	6 - 0.1208692128	6 - 0.0376
61° F	392.50366	6 - 0.2093986939	0.1977307872
70.5° F	403.43376	6 - 0.3361530022	6 - 0.3180
110° F	429.93986	6 - 0.9783479039	0.3363013066

Note: 6" is the conversion factor in inches of mercury, density is in  $\frac{lb}{ft^3}$ , and absolute humidity is in lbs of water vapor per lb of dry air.

## SHAR AND MATERIAL SHARP

Using a diameter of 23 feet and  $\delta = 20 \times 10^{-10}$  to a 965-foot depth and  $= 60 \times 10^{-10}$  below the 965-foot depth with  $Z = 3.00$ ; the friction and shock factors and the equivalent lengths for the various shock factors are as follows:

SHAR BETWEEN THE COLLAR AND TELL LEVEL;  $\delta = 92.2120 \times 10^{-10}$  for  $L = 2170$  feet  
from  $\delta \times 10^{10} = \frac{60 \times 965}{2170} + \frac{60 \times 1005}{2170}$

SHAR BETWEEN THE TELL AND E.H. LEVELS;  $\delta = 60 \times 10^{-10}$  for  $L = 570$  feet

SHAR - COARSE;  $X = 0.39$  and  $l_{eq} = 199.95$  feet for  $Z = 3.50$

SHAR - DRAWDOWN;  $X = 0.3161$  per set and if assumed to be on 10-foot centers

then  $X = 216 \times 0.3161 = 68.2776$  and  $l_{eq} = 30,111.60$  feet for between the collar and TELL level and  $X = 57 \times 0.3161 = 18.0177$  and  $l_{eq} = 5590.36$  feet for between the TELL and E.H. levels at  $Z = 5.00$

FAREWELL SHAR;  $X = 0.01312 + 0.09315 + 0.00387 = 0.0601$  and  $l_{eq} = 26.52$  feet

CAGE MOVING UPWARD;  $X = 0.39.215 + 0.18837 + 0.30.21.7 = 0.73356$  and  $l_{eq} = 323.55$  feet

## TELL SHAR

Using a diameter of 17.5 feet and  $\delta = 20 \times 10^{-10}$  to a 965-foot depth and  $= 60 \times 10^{-10}$  below the 965-foot depth with  $Z = 3.00$ ; the friction and shock factors and the equivalent lengths for the various shock factors are as follows:

SHAR;  $\delta = 92.2120 \times 10^{-10}$  for  $L = 2170$  feet

SHAR - DRAWDOWN;  $X = 0.1117$  per set and if assumed to be on 10-foot centers

then  $X = 216 \times 0.1117 = 24.1272$  and  $l_{eq} = 8096.09$  feet at  $Z = 5.00$

CAGE MOVING DOWNWARD;  $X = 1.69036 + 0.69965 + 1.93629 = 3.7263$  and  $l_{eq} = 1250.38$  feet

08282018

90029327

310

## RH SHAFT

Using a diameter of 8 feet and  $t = 20 \times 10^{-10}$  to a 985-foot depth, =  $60 \times 10^{-10}$  between the 985-foot and 2720-foot depths and =  $20 \times 10^{-10}$  below the 2720-foot depth with  $Z = 3.00$ ; the friction and shock factors and the equivalent lengths for the various shock factors are as follows:

$$\text{SHAFT; } t = 45.1906 \times 10^{-10} \text{ for } l = 2755 \text{ feet from } t \times 10^{-10} = \frac{20 \times 985}{2755} + \frac{60 \times 1735}{2755} + \frac{20 \times 35}{2755}$$

$$\text{CASE MOVING DOWNWARD; } X = 7.61721 + 31.32378 + 8.27778 = 47.7686 \text{ and } \text{lg}^2 = 6899.67 \text{ feet}$$

## VERSES IN SHAFT

Using a diameter of 7.95 feet and  $t = 20 \times 10^{-10}$  to a 965-foot depth and =  $60 \times 10^{-10}$  between the 965-foot depth and  $Z = 3.00$ ; friction and shock factors and the equivalent lengths for the various shock factors are as follows:

$$\text{SHAFT BETWEEN THE COLLAR AND TELL LEVEL; } t = 42.2120 \times 10^{-10} \text{ for } l = 2170 \text{ feet}$$

$$\text{SHAFT BETWEEN THE TELL AND RH LEVELS; } t = 60 \times 10^{-10} \text{ for } l = 570 \text{ feet}$$

$$\text{SHAFT DIVIDERS; } X = 0.0329 \text{ per set and it assumed to be on 10-foot centers}$$

$$\text{then } X = 216 \times 0.0329 + 7.1069 \text{ and } \text{lg}^2 = 1907.68 \text{ feet for distance}$$

$$\text{for collar and Tell level and } l = 57 \times 0.0329 = 1.8753 \text{ and } \text{lg}^2 =$$

$$354.17 \text{ feet for distance the Tell and RH levels at } Z = 5.00$$

$$(0.21437) \quad (0.0975) \quad (46.85)$$

$$\text{EMERGENCY CASE; } X = 3.20939 + 0.21411 + 0.10374 = 0.5472 \text{ and } \text{lg}^2 = 196.95 \text{ feet}$$

$$\text{CONSTRAINED VENT COLLAR; } X = 0.35 + 0.0010 + (0.25 + 0.12375) \left( \frac{0.172}{7} \right)^2 = 0.3623$$

$$\text{and } \text{lg}^2 = 97.28 \text{ feet}$$

$$\text{TELL-RH VENT (COLLAR); } X = 0.60 + \frac{0.0767}{2} = 0.7692 \text{ and } \text{lg}^2 = 257.58 \text{ feet}$$

REV LEVEL

Use a minimum airflow velocity of 100 fpm in the development buildings, 75 fpm in the shops and fuel storage areas and 50 fpm in the warehouse and storage rooms.

In short-and-long-walls buildings, use a droptile curtains wall to divide the building into fresh and exhaust airways with the exhaust way cross-sectional area being approximately a quarter of that used for the fresh air.

Rate in the following for

of four persons, use 36,000 cfm of fresh air per room and assume two rooms at a time require ventilation.

For warehouse buildings, use 89,000 cfm of fresh air per room with 30 droptile curtains and located 9'-6" from the hot wall with cutting air at 100 fpm and use 89,000 cfm of fresh air per room with 30 droptile curtains and located 7'-6" from the hot wall.

Assume that there can be two rooms being cleaned simultaneously, for cleaning of quantities of article that are not circulated through the air or from supplies, use  $Q = 19,796.24 \text{ ft}^3/\text{hr}$  for those types of rooms,  $Q = 31,273.50 \text{ ft}^3/\text{hr}$  for three separate rooms and  $Q = 40,618.44 \text{ ft}^3/\text{hr}$  for recreation purposes.

Using an air temperature of 65.3°F at the TES level, the dew point being 61°F and the dew point at the surface being 59°F, the dew point will be 61.78331°F at the surface. The dew point will be 61.78331°F at the surface, having a relative humidity of 61.1223 60 water vapor/16 dry air. Therefore the barometric pressure at surface and the TES level to be 25.35 and 25.59 inches of mercury respectively and a temperature change of 11.75°F between surface and the TES level, then the surface ventilation pressure can be expected to vary from about 7.7237 inches of water in the winter months

ESCR500

312

90029329

7

downcast air stream remaining dry and the upcast air stream remaining saturated, to about -2.9565 inches of water, in the summer with the downcast air stream remaining saturated and the upcast air stream remaining dry.

Using  $t = 25.0^{\circ}$ ,  $\alpha = 1.50$  and Square Brads with  $r = 0.5$ ; the shock factors and equivalent lengths for the various shock losses are as follows:

Inlet Boxes and Courts;  $X = 0.13$  and  $Ly = 1066.00$  feet for  $\alpha = 90^{\circ}$

$X = 0.53$  and  $Ly = 266.72$  feet for  $\alpha = 75^{\circ}$

Entry Juncs.;  $X = 0.19$  and  $Ly = 1400.31$  feet for  $\alpha = 90^{\circ}$

$X = 0.90$  and  $Ly = 400.00$  feet for  $\alpha = 75^{\circ}$

Door Entrance;  $X = \{0.78(0.0037) + 0.5956 + 0.92(0.1625)\} \left( \frac{719.4933}{429.4701} \right)^2 = \frac{(2.7666)}{7.7698 \text{ and } Ly = 6129.59 \text{ ft}} \quad (1900.01)$

Front Fix & when open  $\alpha = 100.00^{\circ}$ ;  $X = \{0.0029 + 0.0080 + 0.5956 + 0.1875\} \left( \frac{719.4933}{429.4701} \right)^2 = \frac{(8.6282)}{7.7698 \text{ and } Ly = 7376.5 \text{ ft}} \quad (1407.80)$

and  $Ly = 5818.31$  feet

Door Fix & when jutting;  $X = \{0.0029 + 0.0080 + 1.5(0.5956) + 0.0302\} \left( \frac{719.4933}{429.4701} \right)^2 = \frac{(3.9010)}{10.9987}$

and  $Ly = 8635.93$  feet

Instrument Pass;  $X = \{0.0159 + 0.1107 + 0.1018\} \left( \frac{395.2440}{201.9998} \right)^2 = 0.9927$  and  $Ly = 296.81$  feet

Door & Sliding Glass Station;  $X = \{0.60 + 0.0088\} \left( \frac{895.9290}{207.7378} \right)^2 = 1.3977$  and  $Ly = 700.15$  feet

for  $r = 10$


Exit Box Station;  $X = 0.00$  and  $Ly = 339.95$  feet for  $r = 10$  and using the short A and P

Instrument Vent Smart and T24-R4 Vent Smart Stations;  $X = \{0.9318 + 0.90\} \times$

$\left( \frac{295.9140}{183.9280} \right)^2 = 8.9216$  and  $Ly = 2465.38$  feet for  $r = 10$  and a 14-foot shaft diameter.

The quantity of total air required on the T24 level will be what appears to be the worst condition will be 215,000 cfm plus the amount of air from the T24 shaft if 2500 cfm is taken as the airflow quantity if a 5% drop in T24 shaft then the total quantity of air required on the T24 level will be 229,500 cfm and the efficiency from the remaining  $\frac{72,000 + 86,000 + 9500}{229,500} = 0.7961 = 79.6\%$

## CONDENSATION ON A Panel During Storage Observations:



$$AB = BC = CD = DE = EF = FG = GH = IJ = JK = KL = LM = MN = NO = OP =$$

156.00 feet

$$GJ = HJ = 511.50 \text{ feet}$$

$$\text{Using } t = 25 \times 10^{-6} \text{ and } \rho = 0.0690 \frac{\text{lb}}{\text{ft}^3},$$

$$h_p = 0.727356 (L + log) V^2 \times 10^{-6} \text{ for GJ and HJ}$$

$$= 1.145291 (L + log) V^2 \times 10^{-6} \text{ for all the other airways}$$

$$L = 36,333 \text{ cu ft per room}, V = 0.250352 \times 10^{-3} \text{ ftm for GJ and HJ}$$

$$= 1.979992 \times 10^{-3} \text{ ftm for GH and IJ}$$

$$= 5.919767 \times 10^{-3} \text{ ftm for FG and JK}$$

$$h_{GJ} = 1.45291 (156.00 + 156.00) 1.979992 \times 10^{-6} + 0.727356 (618.5 + 511.50 + 581.8) 0.250352 \times 10^{-6}$$

$$= 0.000529 + 0.002260 = 0.002787 \text{ inches of water}$$

$$h_{GJ} = 0.727356 (618.5 + 511.50 + 863.6) 0.250352 \times 10^{-6} = 0.002781 \text{ inches of water}$$

This, a difference of  $0.002787 - 0.002781 = 0.000016$  inches of water must be added to the GJ circuit. This difference can be ignored for all practical purposes through most flows.

$$h_{GJ, \text{corr}} = \frac{0.002787 + 0.002781 + 1.145291 (156.00 + 156.00) 5.919767 \times 10^{-6}}{2}$$

$$= 0.002789 + 0.002115 = 0.004905 \text{ inches of water}$$

At  $t = 25 \times 10^{-6}$ , the pressure difference between A and P can be said to be  $0.004905 + 5 \times 1.145291 (156.00 + 156.00) 5.919767 \times 10^{-6} =$

$0.015982$  inches of water and if we assume a single stoppage between A and P, the pressure through that stoppage will only be 16.5 in.

If a just stoppage is assumed, the leakage will be 0.292 in.<sup>3</sup>/sec.

The total quantity of air flow leakage through such stoppages will naturally be somewhere between these two extremes so; as an approximation the quantity of air flow leakage is taken to be 0.292 in.<sup>3</sup>/sec. through a very stoppage, 1500 cu ft through a room stoppage

9

and 3500 cfm through a ventilation overpass.

Based on the above discussion,  $V^e = 0.250352 \times 10^6$  fpm for HI and GV  
 $1.979992 \times 10^6$  fpm for GH and JV  
 $5.919767 \times 10^6$  fpm for EG and HK  
 $6.168993 \times 10^6$  fpm for EF and LH  
 $6.423358 \times 10^6$  fpm for OE and LN  
 $6.682862 \times 10^6$  fpm for CD and JV  
 $6.997504 \times 10^6$  fpm for BC and VO  
 $7.217286 \times 10^6$  fpm for AG and JP  
 $7.992205 \times 10^6$  fpm for AH and P.

as air is taken during storage operations,

$$\begin{aligned}
 H = H_2 &= 1.145291(456.00 + 156.00)(1.979992 + 5.919767 + 6.168993 + 6.423358 + \\
 &\quad 6.682862 + 6.997504 + 7.217286) \times 10^{-6} + 1.145291(1067 + 156.00 + \\
 &\quad 156.00)7.992205 \cdot 10^{-6} + 0.707356(6125 + 511.50 + 581.0)0.250352 \times 10^{-6} \\
 &= 0.019593 + 0.011833 + 0.002268 = 0.028699 \text{ inches of water.}
 \end{aligned}$$

MATERIALS AT A PORT DURING CONSTRUCTION:

Under the same conditions as for a Panel during storage Eqn 10.10.3  
except for the average quantity that is required per room which is  
taken to be  $25,000 \text{ cu ft}$ ; then  $V = 1,002969 \times 10^6 \text{ fpm}$  for HI and GJ

$$2,111929 \times 10^6 \text{ fpm} \text{ for GH and JV}$$

$$8,495717 \times 10^6 \text{ fpm} \text{ for FG and JK}$$

$$8,742909 \times 10^6 \text{ fpm} \text{ for EF and LH}$$

$$9,045230 \times 10^6 \text{ fpm} \text{ for DE and LH}$$

$$9,303626 \times 10^6 \text{ fpm} \text{ for CD and NV}$$

$$9,665299 \times 10^6 \text{ fpm} \text{ for BC and NO}$$

$$9,983091 \times 10^6 \text{ fpm} \text{ for AB and SP}$$

$$10,305922 \times 10^6 \text{ fpm} \text{ for -A and P-}$$

$$\text{In addition; } q_1 = 1,071005 (k_1 + k_2) V \times 10^{-6} \text{ for JV and HI}$$

$$= 1,145229 (1,071005) V \times 10^{-6} \text{ for all the other rooms}$$

$$q_1 = 1,145229 (156.00 + 56.00) 2,111929 \times 10^6 + 1,071005 (1982 + 511.50 + 1908) 1,002969 \times 10^6$$

$$= 2,111929 + 0.032652 + 0.369806 \text{ inches of water}$$

$$q_1 = 2,111929 (156.00 + 56.00 + 52.90) 1,002969 \times 10^6 = 1,1149389 \text{ inches of water}$$

The equivalent of 1,1149389 inches of water can be passed for all proposed  
purposes and still be a Panel under construction;

$$q_2 H_2 = 1,145229 (156.00 + 56.00) (2,111929 + 8,495717 + 8,742909 + 9,045230 + 9,303626 + 9,665299 + 9,983091) \times 10^{-6} + 1,145229 (1067 + 156.00 + 156.00) 10,305922 \times 10^6 + 1,071005 (1982 + 511.50 + 1908) 1,002969 \times 10^6$$

$$= 0.020492 + 0.148077 + 0.333652 = 0.498421 \text{ inches of water}$$

PH Level

Use the same minimum airflow velocities and procedure for ventilating about and bridging as on the TBL level.

Based on the foregoing, for

garage operations, use 15,000 cfm of fresh air per room and assume two rooms at a time require ventilation.

Residential operations, use 25,000 cfm of fresh air per room and for rooms with the brother curtains wall installed 7'-0" from the left wall. Assume that there can be three bridging being driven simultaneously.

For computing the quantities of airflow that are short circuited between supply and ventilation bypasses, use  $Q = 21,473,505 \text{ cfm}$  for the supply and  $Q = 89,612,505 \text{ cfm}$  for ventilation bypasses.

Taking an air temperature of  $67.75^\circ\text{F}$  on the PH level; the dry air density will be  $6.06681 \frac{\text{lb}}{\text{ft}^3}$ ; the density @ saturation will be  $6.05000270508 \frac{\text{lb}}{\text{ft}^3}$  and the relative humidity @ saturation will be  $0.8299729992 \frac{\text{lb water vapor}}{\text{lb of dry air}}$ . Taking the barometric pressure at surface and the PH level to be 26.35 and 29.17 inches of mercury respectively and a temperature change of  $19.80^\circ\text{F}$  between surface and the PH level, then the natural ventilation pressure can be expected to vary from about 6.2056 inches of water, in the winter with the downcast air stream remaining dry and the upcast air stream remaining saturated, to about -3.8376 inches of water, in the summer with the downcast air stream remaining saturated and the upcast air stream remaining dry.

Using  $b = 25 \times 10^{-6}$ ,  $Z = 1.00$  and Square Bends with  $r = 0.5$ ; the static factors and resistance factors for various short losses are as follows:

Enter Bends and Spacing:  $\chi = 2.13$  and  $b_f = 106.88 \text{ feet for } \alpha = 90^\circ$

$\chi = 0.53$  and  $b_f = 266.72 \text{ feet for } \alpha = 95^\circ$

Entry JUNCTIONS;  $X = 3.18$  and  $Ly = 1500.31$  feet for  $\alpha = 80^\circ$

$X = 0.80$  and  $Ly = 800.00$  feet for  $\alpha = 95^\circ$

Door ENTRANCE;  $X = 3.13$  and  $Ly = 1066.00$  feet

Door EXIT when not jutting;  $X = 3.13$  and  $Ly = 1166.00$  feet

Door EXIT when jutting;  $X = 3.19$  and  $Ly = 1100.31$  feet

Passenger OVERPASS;  $X = \{0.0159 + 0.1107 + 0.1018\} \left( \frac{295.9240}{201.9998} \right)^2 = 0.3927$  and  $Ly = 896.81$  ft

Passenger OVERPASS;  $X = \{0.60 + 0.0888\} \left( \frac{295.9240}{207.2073} \right)^2 = 1.3977$  and  $Ly = 700.15$  feet

for  $r = 1.0$


24' short diameter;  $X = \{1.3997 + 0.60\} \left( \frac{295.9240}{20.26598} \right)^2 = 22.5182$  and  $Ly = 3226.56$  feet for  
 $r = 1.0$  and a diameter of 8-foot for the 24' shaft.

Passenger VENT SHAFT AND 24'x24' VENT SHAFT STAIRS;  $X = \{0.9318 + 0.1107 + 0.1018\} \left( \frac{295.9240}{153.9380} \right)^2 = 3.8130$  and  $Ly = 1910.09$  feet for  $r = 1.0$  and a 14-foot shaft diameter

The quantity of fresh air required at the 24' level, assuming an air flow volume of 15,000 cu ft per storage operations and an air of 35,000 cu ft per combustion process in the Government Area, will be 200,500 cu ft under normal operating conditions. This value of 200,500 cu ft above the air required for 30,000 cu ft per 24' shaft. The additional 30,000 cu ft per 24' shaft  $\frac{30,000 + 72,000 + 26,000}{200,500} = 0.6085 = 60.85\%$

90029555 348

IDENTIFICATION OF A PANEL DURING STORAGE OPERATIONS:



$$AE = EC = CO = DE = EF = FG = GH = IJ = JK = KL = LN = NH = NO = OP = 115 \text{ ft.}$$

$$HJ = 59.9 \text{ ft.}$$

$$\text{Using } k = 35 \times 10^{-6} \text{ and } p = 0.0701 \frac{\text{lb}}{\text{ft}^3}$$

$$A_p = 1.163550(L+kg) \sqrt{t} \times 10^{-6} \text{ for all the areas}$$

At 15000 rpm,  $\mu = 1000$ ,  $V^2 = 0.256939 \times 10^4$  fpm for HJ and taking the quantity of longitudinal tractive force through a stepping to be 1000 lb/in, then  $V^2 = 0.223818 \times 10^4$  fpm for GH

$$0.256939 \times 10^4 \text{ fpm for FG and HJ}$$

$$0.292339 \times 10^4 \text{ fpm for EF}$$

$$0.330018 \times 10^4 \text{ fpm for DE and LI}$$

$$0.369985 \times 10^4 \text{ fpm for CO and JK}$$

$$0.412237 \times 10^4 \text{ fpm for EC and KL}$$

$$0.456772 \times 10^4 \text{ fpm for AE and NH}$$

$$0.503591 \times 10^4 \text{ fpm for -A and LN}$$

$$0.552698 \times 10^4 \text{ fpm for -D}$$

$$0.609081 \times 10^4 \text{ fpm for OP}$$

$$0.657752 \times 10^4 \text{ fpm for F-}$$

$$= 1.163550(115)(0.223818 + 0.256939 + 0.292339 + 0.330018 + 0.369985 +$$

$$0.412237 + 0.456772) \times 10^{-6} + 1.163550(115)(0.330018 + 0.369985 +$$

$$0.412237 + 0.456772 + 0.503591 + 0.552698 +$$

$$1.163550(1067 + 59.9 + 10.0)0.256939 \times 10^{-6}$$

$$= 0.000414 + 0.000820 + 0.001693 + 0.000975 = 0.002502 \text{ inches of wear}$$

18

WATERLOSS AT A TOWER DURING CONSTRUCTION

1		P
2		O
3		N
4		H
5		J
6		K
7		L
8		M
9		N
10		O
11		P
12		Q
13		R
14		S
15		T

$$AB = BC = CD = DE = EF = FG = GH = IJ = JK = KL = LM = MN = NO = OP = 115 \text{ ft}$$

$$IJ = JK = 100 \text{ ft.}$$

$$\text{Using } t = 25 \times 10^{-6} \text{ sec. } \rho = 0.0701 \text{ lb/ft}^3$$

$$H_2 = 1163550 (t + \frac{L}{2}) \times 10^{-6} \text{ for all the airways}$$

$$= 29300 \text{ sec per room, } V^2 = 0.657752 \times 10^{-6} \text{ ftm for } GJ \text{ and } HJ$$

are using the quantity of air flow leakage through a  
perimeter of 100 ft, then

$$V^2 = 2.009181 \times 10^{-6} \text{ ftm for } IJ$$

$$2.27752 \times 10^{-6} \text{ ftm for } GJ \text{ and } HJ$$

$$2.718750 \times 10^{-6} \text{ ftm for } SH$$

$$2.009181 \times 10^{-6} \text{ ftm for } JK$$

$$2.631003 \times 10^{-6} \text{ ftm for } KL$$

$$2.781775 \times 10^{-6} \text{ ftm for } FJ \text{ and } LH$$

$$2.870287 \times 10^{-6} \text{ ftm for } EF \text{ and } MN$$

$$2.670161 \times 10^{-6} \text{ ftm for } DE \text{ and } NO$$

$$2.007782 \times 10^{-6} \text{ ftm for } OO \text{ and } DF$$

$$2.007182 \times 10^{-6} \text{ ftm for } SC \text{ and } P$$

$$2.320869 \times 10^{-6} \text{ ftm for } FG$$

$$2.454330 \times 10^{-6} \text{ ftm for } -$$

$$A_{\text{perimeter}} = (25 \times 10^{-6} \times 100) (2.009181 \times 10^{-6}) = 0.0024996 \text{ inches of water}$$

$$A_{\text{perimeter}} = (25 \times 10^{-6} \times 100) (2.009181 \times 10^{-6}) + (20000 \times 100) (0.657752 \times 10^{-6}) =$$

$$2.009181 (100 \times 10^{-6}) (2.009181 \times 10^{-6})$$

$$= 2.009181 \times 3.009181 \times 10^{-12} = 0.002108 \text{ inches of water}$$

This is about 0.002108 inches of water can be gained for each meter

of height of water in the tower.

$$A_{\text{perimeter}} = 20000 (25 \times 10^{-6}) (2.009181 \times 10^{-6}) + 0.002108 (100) (3.700000 \times 10^{-6})$$

320

90029337

$$\begin{aligned}
 & 2.631008 + 3.207682 + 3.329869) \times 10^{-6} + 1.163550(115) \times (3.741775 + \\
 & 2.859826 + 2.970161 + 3.087780) \times 10^{-6} + 1.163550(115 + 1600) \times \\
 & 3.207682 \times 10^{-6} + 1.163550(1067 + 115) 3.45933.9 \times 10^{-6} \\
 & = 0.002496 + 0.001568 + 0.003119 + 0.006901 + 0.004751 \\
 & = 0.018331 \text{ numbers of water}
 \end{aligned}$$

1

IRW/RH VENT SHAFT  
DECON. STA.

RADS/SAFE  
CHECK STA.

TRU SH/FT  
CONST. VENT SHAFT

SHOP AREA


MAN/MAT'L. SHAFT


S280.0' RADIUS  
(RADUS POINT 2 N - 180 F - 1980)

O FM SHAFT


2

90029339





90029341




90029342

-D

A


B



SACRIO

90029343


15



327

90029344

-E



EXPERIMENTAL AREA  
AND PILLAR SIZES UNDEFINED

ALL DRIFTS AND ROOMS  
X 31.5' WIDE AND ALL  
83.5' WIDE EXCEPT IN  
CIR-LEVEL PLATE-SWIFT

31.5' (TYP.)

228

800080

90029345

FENIX & SCISSION, INC.  
TULSA, OKLAHOMA 74112

COMPUTED BY: \_\_\_\_\_  
CHECKED BY: \_\_\_\_\_  
CALCULATIONS FOR: \_\_\_\_\_

DESIGN SHEET

SHEET 10 OF 10  
PROJECT NO. 280  
DATE: \_\_\_\_\_

NINE AIRWAY AEROFLOW PRESSURE LOSSES

AIRWAY	SIZE	CROSS-SECTION AREA sq ft	PIPE- MATERIAL IN FT	ACTUAL LENGTH IN FT	FRICITION FACTORS "A"	SHACK LENGTH IN FT	SHACK LENGTH IN FT	TOTAL LENGTH IN FT	AEROFLOW VOLUME CFM	PRESSURE LOSS IN INCHES OF WATER	REMARKS
0-1	23-4 1/2	415.98	70.26	2170	0.212	69.97	30.438	32,808	22,500	9.5370	Usd p = 0.0201 psf
1-2	10x31.5	295.92	76.50	250.75	0.0	3.83	176.7	304.8	82,950	0.0187	9.5559 Usd p = 0.0200 psf
1-34				106.5		1.90	300	307	191,050	0.0210	9.5580 ✓
2-58									1000	0.1595	
2-3				304.5		0.13	106.7	103	82,950	0.0187	9.5681
3-5				716.50		0.79	2900	317	26,900	0.0028	9.5709
3-9	10x31.5	295.92	76.50	106.5	250			106.5	56,050	0.0009	9.5685
4-0	17.5x14.9	298.53	59.98	2170	0.212	38.95	96.86	4,856	2500	0.0031	9.5716 Usd p = 0.0201 psf
4-5	10x31.5	295.92	76.50	493.96	25.0	0.00	300	497.5	96,550	0.0024	9.5709 Usd p = 0.0200 psf
5-6				199.15				193	72,980	0.0013	9.5722
54-37				597.81		1.86	98.3	198.1	68,850	0.0092	9.5672
38-38				58.39		0.63	26.7	320	72,200	0.0022	9.5612
35-59									1000	0.1597	
35-36				919.19		1.06	38.9	95.9	71,200	0.0063	9.5665 ✓
36-56									1000	0.1120	
36-37				106.5				106.5	70,200	0.0007	9.5672
37-38				702.59				302.5	10,100	0.0099	9.5771
37-55				106.5		0.13	106.7	117.2	38,050	0.0022	9.5684
55-59									3000	0.1050	
55-6				217.1		0.19	1600	181.3	39,550	0.0028	9.5722
6-32									1000	0.2276	
6-7				263.0				28	106,500	0.0032	9.5759
7-8									3800	0.1942	
7-9				590.59				590.5	103,000	0.0078	9.5828
9-31									1000	0.0892	
9-11									1000	0.1083	
9-10				54.5				54.5	101,120	0.0068	9.5896
10-11									3500	0.1375	
10-12				129.5				129.5	97,500	0.0015	9.5911
12-28									1000	0.0692	
12-49									1000	0.1239	
12-43				54.5				54.5	95,500	0.0061	9.5972
12-44									3500	0.1173	
12-45				129.5				129.5	92,000	0.0019	9.5986
12-25									1000	0.0597	

324

90029346

FENIX & SCISSON, INC.  
TULSA, OKLAHOMA 74112

DESIGN SHEET

COMPUTED BY: \_\_\_\_\_

CHECKED BY: \_\_\_\_\_

CALCULATIONS FOR: \_\_\_\_\_

MINE AIRWAY AEROFLOW PRESSURE LOSSES

SHEET 19 OF  
PROJECT NO. 208  
DATE: \_\_\_\_\_

AIRWAY	SIZE INCHES	CROSS- SECTION AREA sq. ft.	PIPE MATERIAL	ACTUAL LENGTH ft.	FRICTION FACTOR	SINGLE FACTOR LENGTH ft.	EQUIV. LENGTH ft.	TOTAL LENGTH ft.	AVERAGE PRESSURE LOSS		REMARKS
									LOCATE IN CHAMFER CROSS SECTION	AIRWAY INCHES IN WATER	
15-17									1000	0.1059	
15-16				54.5			54.5	90,100	0.1159	9.6090	
16-17									3000	0.1000	
16-18				109.5			109.5	86,500	0.0012	9.6052	
18-22				106.5	2.13	106.7	117.3	89,500	0.0110	9.6162	
18-19									1000	0.0903	
18-19									1000	0.0903	
19-20				46.5	3.19	1680	1707	2000	0.0800	9.6355	
38-53									1000	0.0899	
38-28				54.5			54.5	100,000	0.0067	9.5838	
39-52									1000	0.0778	
38-40				109.5			109.5	99,000	0.0016	9.5859	
40-51									1000	0.0749	
40-41				54.5			54.5	99,000	0.0069	9.5918	
51-50									1000	0.0629	
51-42				109.5			109.5	97,000	0.0015	9.5933	
42-49									1000	0.0600	
42-43									95,000	0.0808	9.6337
42-47				54.5			54.5		1000	0.0904	
43-48				106.5	2.13	106.7	117.3	95,000	0.0138	9.6375	
47-44									1000	0.0168	
47-48				106.5			106.5	81,000	0.0009	9.6505	
48-45									81,000	0.0287	9.6792
49-45									1000	0.0287	
45-46				106.5			106.5	82,000	0.0009	9.6801	
46-20				106.5	3.19	1680	1707	83,000	0.0159	9.6955	
47-46									1000	0.0630	
48-47									1000	0.0021	
82-47				106.5			106.5	81,000	0.0009	9.6171	400 0.0325 ANGLES ARE WATER RESISTANCE
40-21				54.5			54.5	81,000	0.0098	9.7003	
22-21									3000	0.0891	
21-28				109.5	0.99	297	371	88,500	0.0438	9.7091	
17-23				106.5	3.68	189.7	195.9	93,000	0.0001	9.7081	
90-89									1000	0.0866	
91-90				54.5			54.5	93,000	0.0058	9.6533	

FENIX & SCISSION, INC.  
TULSA, OKLAHOMA 74112

DESIGN SHEET

SHEET 20 OF \_\_\_\_\_  
PROJECT NO: 200  
DATE: \_\_\_\_\_

COMPUTED BY: \_\_\_\_\_

CHECKED BY: \_\_\_\_\_

CALCULATIONS FOR: \_\_\_\_\_

MINE AIRWAY AIRFLOW PRESSURE LOSSES

AIRWAY	CROSS-SECTIONAL AREA sq. ft.	PIPE LENGTH ft.	FRICITION FACTOR	SURFACE LENGTH ft.	TOTAL LENGTH ft.	AVERAGE VACUUM cm.	PRESSURE LOSS INCHES OF WATER	REMARKS
49-50		109.5			109.5	91,500	0.0018	9.6547
49-25		106.5			106.5	2500	0.0000	9.6533
23-29		511.5			511.5	99,000	0.0059	9.7100
25-29						3500	0.0567	
29-26		108.5	0.99	297	371	97,500	0.0046	9.7186
14-26		106.5	3.68	4897	1963	9500	1.1001	9.7186
30-26						1000	0.0599	
50-51		511.5			511.5	91,500	0.0056	9.6603
51-52		498.5			498.5	90,000	0.0013	9.6616
51-28		106.5			106.5	2500	0.0000	9.6603
26-27		511.5			511.5	103,000	0.0071	9.7217
28-27						3500	0.0619	
27-29		109.5	0.99	297	371	106,500	0.0055	9.7272
11-29		106.5	3.68	4897	1963	9800	0.0001	9.7272
52-29						1000	0.0656	
52-53		511.5			511.5	90,000	0.0059	9.6670
53-59		748.59			748.59	89,500	0.0076	9.6796
53-31		106.5			106.5	2500	0.0000	9.6670
29-30		511.5			511.5	112,000	0.0189	9.7356
31-30						3500	0.0686	
30-8		137.09	2.62	1319	1961	115,500	0.0390	9.7696
8-32		219.5	2.62	1319	4633	119,000	0.0302	9.7998
32-33		274.61	5.85	2732	3007	120,000	0.0566	9.8569
59-56		106.5	0.99	297	363	92,000	0.0039	9.6705
56-57		281.67	5.95	2732	3247	93,000	0.0869	9.7199
58-57 10-31.5	295.92	76.50	25.75	250	990	2465	2991	30000 0.0000 9.7149
1-59 23-11.0	915.98	72.06	57.0	60.1	18.02	5390	6160	300,500 0.2757 9.8157 1000 P = 0.0725 psf
59-60 10-31.5	295.92	76.50	67.0	250	1.90	700	767	89,500 0.0082 9.8239 1000 P = 0.0704 psf
59-11.5						598.5	111,000	0.0139 9.8296
60-61							3500	0.1208
68-62		116.0			116	86,000	0.0011	9.8250
62-63							3500	0.1820
62-69		116.0			116	82,500	0.0010	9.8260
69-72		1335.08	2.66	1334	2669	96,500	0.0077	9.8337 400 0.0825 INCHES OF WATER RESISTANCE
69-65		105.12	3.63	1067	4252	86,000	0.0022	9.8282

234

90029348

FENIX & SCISSION, INC.  
TULSA, OKLAHOMA 74112

DESIGN SHEET

SHEET 21 OF 288  
PROJECT NO: 288  
DATE: \_\_\_\_\_

COMPUTED BY: \_\_\_\_\_

CHECKED BY: \_\_\_\_\_

CALCULATIONS FOR: \_\_\_\_\_

MINE AIRWAY AEROFLOW PRESSURE LOSSES

AMWAY	SIZE	CROSS-SECTION AREA sq ft	AEROF. WATER ft	ACTUAL LENGTH ft	FRCTION FACTOR	SURFACE FACTOR	EQVNL. LENGTH ft	TOTAL LENGTH ft	AEROFLOW VOLUME cfm	PRESSURE LOSS AMWAY CUPID INCHES OF WATER	REMARKS
65-111									1000	0.1312	
65-67				3960		7.95	3729	4079	10,625	0.0009	9.8291
65-66	11+31.5	295.92	76.50	115.0	25.0	2.13	167	1297	22,375	0.0009	9.8291
66-0	8-44.0	50.27	25.13	2765	45.191	97.77	1895	9600	30,000	0.5971	5.9260 $U_3 = 0.0077 \text{ psf}^2$
66-67	10+31.5	295.92	76.50	115.0	25.0			115	2,375	0.0000	9.8291 $U_3 = 0.0071 \text{ psf}^2$
67-68				1429.79		0.63	267	1696.5	15,000	0.0005	9.8291
72-73									3500	0.0323	
72-78				3960					43,000	0.0008	9.9170
75-79									3500	0.0001	
79-76				526.0				525	96,500	0.0017	9.9187
76-107									1000	0.0091	
76-78									1000	0.0229	
76-77				115.0				115	99,500	0.0003	9.9190
77-78									3500	0.0226	
77-79				105.0				1035	41,000	0.0023	9.9213
79-78									1000	0.0203	
79-109									1000	0.0163	
79-80				115.0		2.13	1067	1162	39,000	0.0029	9.9237
80-81									3500	0.0182	
81-82				115.0				115	35,500	0.0005	9.9239
82-103									1000	0.0109	
82-83				115.0				115	35,500	0.0002	9.9241
83-102									1000	0.0109	
83-84				115.0				115	35,500	0.0002	9.9243
84-101									1000	0.0099	
84-85				3960				399	39,500	0.0009	9.9252
85-86									3500	0.0078	
85-87				115.0				115	31,000	0.0001	9.9253
87-89									1000	0.0075	
87-88				3960				399	30,000	0.0007	9.9260
88-89									3500	0.0058	
88-90				115.0				115	26,500	0.0001	9.9261
90-91									1000	0.0055	
91-91				3960				399	26,500	0.0006	9.9267
91-92									3500	0.0051	

332

90029349

FENIX & SCISSION, INC.  
TULSA, OKLAHOMA 74112

DESIGN SHEET

SHEET 22 OF 22  
PROJECT NO. 200  
DATE: \_\_\_\_\_

CO. UTED BY: \_\_\_\_\_

CHECKED BY: \_\_\_\_\_

CALCULATIONS FOR: \_\_\_\_\_

MINE AIRWAY AEROFLOW PRESSURE LOSSES

AIRWAY	SIZE	CROSS-SECTION AREA sq. ft.	PIPE LENGTH ft.	AIRFLOW FACTOR	SHOCK FACTOR	EMPIRICAL LENGTH ft.	TOTAL LENGTH ft.	AIRFLOW VOLUME cu. ft.	AIRWAY CHAM. INCHES OF WATER	PRESSURE LOSS	RAMKRS
91-97			115.0			115	23,000	0.0001	9.9268		
92-98							21,000	0.0025	9.9293		
93-99							1100	0.0025			
93-95							1100	0.0090			
94-96		70.80		2.13	1067	1776	25,000	0.0015	9.9308		
95-96		115.0				115	16,000	0.0011	9.9309		
97-96		115.0		3.68	1097	1962	35,000	0.0001	9.9309		
96-97		59.90				598	30,500	0.0007	9.9316		
97-98		115.0				115	31,500	0.0002	9.9318		
89-98		115.0		3.68	1097	1962	35000	0.0000	9.9318		
98-99		59.90				598	35,000	0.0010	9.9328		
99-100		115.0				115	36,000	0.0002	9.9330		
101-100		115.0		3.68	1097	1962	35000	0.0000	9.9330		
100-101		59.90				598	39,500	0.0012	9.9342		
101-102		115.0				115	40,500	0.0003	9.9345		
102-103		115.0				115	41,500	0.0003	9.9348		
103-104		115.0		2.13	1067	1182	42,500	0.0028	9.9376		
104-81		115.0				115	43,500	0.0003	9.9379		
81-105		113.50		0.89	297	1282	47,000	0.0032	9.9417		
78-105		115.0		3.68	1097	1962	55000	0.0001	9.9417		
113-105							1000	0.1268			
113-114		230.0		2.13	1067	1097	110,000	0.0009	9.8505		
119-116		621.37		1.59	900	1921.5	55,625	0.0059	9.8568		
119-115		259.10		1.86	533	287.5	54,375	0.0039	9.8599		
115-109							10000	0.0862			
115-116		118.63		0.80	700	380	53,375	0.0020	9.8669		
116-117		628.77				689	149,000	0.0099	9.8663		
117-118							3500	0.0688			
117-119		526.0				575	105,500	0.0085	9.8798		
119-120		115.0		2.13	1067	1182	39,500	0.0019	9.8767		
120-121							3500	0.0539			
120-109		115.0				115	31,000	0.0001	9.8768		
109-108							3500	0.0688			
109-75		115.0				115	27,500	0.0001	9.8769		
75-70		527.16				527	29,000	0.0009	9.8773		

## FENIX &amp; SCISSION, INC.

TULSA, OKLAHOMA 74112

## DESIGN SHEET

COMPUTED BY:

CHECKED BY:

CALCULATIONS FOR:

SHEET 23 OF 233  
PROJECT NO. 283  
DATE: \_\_\_\_\_

## MINE AIRWAY AEROFLOW PRESSURE LOSSSES

AIRWAY	SIZE	CROSS- SECTION AREA sq. ft.	PERI- METER ft.	ACTUAL LENGTH ft.	SECTION FACTOR	SURFACE FRICTION FACTORS CENTY FT.	EQUIV. CENTY FT.	TOTAL ft.	AVERAGE VOLUME CFM	PRESSURE LOSS INCHES OF WATER	RAMMERS
119-122				546.0				575	71,000	0.0839	9.8787
122-122									1000	0.0991	✓
122-120									1000	0.0925	✓
122-123				3.0	2.13	1067	1182	69,000	0.0875	9.8862	✓
123-129									1000	0.0899	✓
123-129				599.0				599	68,000	0.0836	9.8888
129-125									3600	0.0277	✓
129-126				115.0				115	69,500	0.0806	9.8908
126-127									1000	0.0266	✓
126-127				599.0				599	63,500	0.0832	9.8736
127-128									3600	0.0207	✓
127-129				115.0				115	60,000	0.0806	9.8792
129-135									1000	0.0196	✓
129-130				599.0				599	59,000	0.0827	9.8868
130-131				115.0	2.26	2139	2899	30,175	0.0827	9.8996	✓
130-132				115.0				115	28,825	0.0802	9.8971
132-132									1000	0.0382	✓
132-133				115.0	2.13	1067	1182	27,825	0.0812	9.8982	✓
133-134									3000	0.0310	✓
133-139				115.0	3.19	1600	1715	25,825	0.0815	9.8998	✓
134-134				115.0				115	30,175	0.0802	9.8998
134-92									1000	0.0310	✓
134-90									1000	0.0263	✓
134-135									53,000	0.0190	9.9438
134-135									1000	0.0190	✓
135-136				115.0				115	55,000	0.0805	9.9143
128-136				115.0	3.68	1597	1962	3600	0.0800	9.9143	✓
136-137				599.0				599	58,500	0.0827	9.9170
137-138				115.0				115	59,500	0.0805	9.9175
125-138				115.0	3.68	4497	1962	3500	0.1000	9.9175	✓
138-139				599.0				599	63,000	0.0831	9.9206
139-140				115.0				115	69,000	0.0806	9.9212
140-83									1000	0.0029	✓
140-141				115.0				115	69,000	0.0806	9.9218
141-82									1000	0.0021	✓

90029351

FENIX & SCISSION, INC.  
TULSA, OKLAHOMA 74112

DESIGN SHEET

COMPUTED BY: \_\_\_\_\_

CHECKED BY: \_\_\_\_\_

CALCULATIONS FOR: \_\_\_\_\_


MINE AIRWAY AIRFLOW PRESSURE LOSSSES

SHEET 29 OF 288  
PROJECT NO. 288  
DATE: \_\_\_\_\_

AIRWAY SIZE	CROSS- SECTION AREA sq ft	PERI- METER ft	ACTUAL LENGTH ft	FRICTION FACTORE	SHOCK FACTORE	EQUIV LENGTH ft	TOTAL LENGTH ft	AIRCRAFT EQUIP CRW	PRESSURE LOSS INCHES OF WATER	REMARKS
191-105								1000	0.0199	
191-102			46.0		2.13	1067	1182	67,000	0.0868	9.9278
192-107			46.0			115	200	0.0000	9.9278	
192-121			5760			575	60,500	0.0028	9.9306	
121-193			5760		0.99	227	822	69,000	0.0095	9.9251
105-116			1160			115	53,500	0.0009	9.9221	
107-106							3600	0.0193		
106-108			5760		0.99	297	822	57,000	0.0835	9.9456
108-110			3460		0.99	297	592	60,500	0.0829	9.9485
73-110			1160		0.87	187	382	1000	0.0000	9.9485
73-68			508.08		0.87	187	742	3500	0.0000	9.9485
110-63			1930.35		0.83	207	1697	61,500	0.0085	9.9570
63-111			108.12		0.99	297	982	65,000	0.0029	9.9599
111-112			230.0		3.19	1600	1630	66,000	0.0106	9.9700
71-112			2097.99		0.53	207	2365	71,500	0.0059	9.9700
112-33 10-31.5	295.92	76.50	932.0	250	3.81	1940	2892	107,500	0.0976	5.0136
19-40	153.98	50.98	370	60.0	1.08	354	924	47,500	0.1381	5.1517 4500 P=0.0696 psf
33-150 14-44	153.98	47.98	2165	42,263			2165	227,500	0.9839	6.1356 4500 P=0.0671 psf
110-193 14-31.5	295.92	76.50	480	250	3.68	1997	1962	3500	0.0000	9.9851 4500 P=0.0701 psf
122-198			675.32		0.83	267	502	67,500	0.0055	9.9406
109-61			668.29			660	68,500	0.0081	9.9437	
61-193			378.5		2.62	164	183	72,000	0.0117	9.9569
145-52 10-31.5	295.92	76.50	61.5	250	3.81	1940	1922	73,000	0.0136	9.9700
19-64	153.98	43.98	370	60.0	1.08	354	924	73,000	0.0637	5.0337 4500 P=0.0696 psf
57-0 14-44	153.98	43.98	2170	90,212	7.97	2005	4175	168,000	1.0335	6.0672 4500 P=0.0671 psf
150-0 11-18	153.98	50.0	230	30.0	0.77	389	619	227,500	0.1802	6.2858 4500 P=0.0672 psf
68-71								0.1350		
68-71								0.0461		
70-71								0.0873		



**JOY MANUFACTURING COMPANY**  
air moving products • NEW PHILADELPHIA, OHIO



**DIMENSIONS (Inches) JOY AXIVANE FANS**

A HUB DIA	B CAS- ING DIA	FAN UNIT PROPER						FAN UNIT WEIGHT— LESS MOTOR		FAN SUPPORTS						INLET BELL			RECOMMENDED OUTLET CONE (1.5/1.0 AREA RATIO)						
		C	D	E	F	G	H	I		L	M	N	P	Q	R	S	T	U	V	W	AA	BB	CC	DD	FF
14	18	14½	21½	28	10 GA	¾	7½	12	165	23%	1½	13	19½	8½			3½	4	23½	25½	26½	15	3½	14	
	21½	23½	24½	31	10 GA	¾	7½	12	195	28%	1½	15	22½	9½			3½	4½	27½	29½	30½	17	3½	16	
	23½	25½	26½	33	10 GA	¾	7½	14	215	30%	1½	16½	26½	11½			3½	5	29½	31½	32½	17	3½	16	
	25½	27½	24½	33	10 GA	¾	7½	14	230	30%	1½	17½	28½	12½			3½	6	33½	35½	35½	19½	3½	18	
	27½	29½	30½	33	10 GA	¾	7½	16	250	30%	1½	19	29	13			3½	6	34	35½	37½	19½	3½	18	
	29½	31½	32½	33	10 GA	¾	7½	16	260	30%	1½	20	31	14			3½	6	36	38	39½	19½	3½	20	
	32	31½	35½	33	10 CA	¾	7½	18	295	30%	1½	22	31½	14½			3½	4½	41½	42½	44½	45½	23½	3½	24
	34	35½	37½	36	10 CA	¾	7½	18	320	31½	1½	23½	33½	15½			3½	4½	44½	45½	47½	23½	3½	24	
	36	38	39½	36	10 CA	¾	7½	20	400	33½	1½	24½	38	17½			3½	4	47	49½	51½	23½	3½	24	
	21½	21½	31	10 GA	¾	7½	17	215	28%	1½	15	22½	9½			3½	4½	27½	29½	30½	17	3½	16		
17½	* 23½	25½	28½	33	10 GA	¾	7½	14	235	30½	1½	16½	26½	11½			3½	5	29½	31½	32½	17	3½	16	
	25½	27½	29½	33	10 GA	¾	7½	14	250	30½	1½	17½	28½	12½			3½	5½	32	33½	35½	19½	3½	18	
	27½	29½	30½	33	10 GA	¾	7½	16	270	30½	1½	19	29	13			3½	6	34	35½	37½	19½	3½	18	
	* 29½	31½	33	10 GA	¾	7½	16	285	30½	1½	20	31	14			3½	6½	36	38	39½	19½	3½	20		
	32	33½	35½	33	10 GA	¾	7½	18	315	30	1½	22	31½	14½			3½	6½	42½	44½	45½	29½	3½	24	
	34	35½	37½	36	10 GA	¾	7½	18	345	33½	1½	23½	33½	15½			3½	7½	42½	44½	45½	23½	3½	24	
	* 36	38	39½	36	10 GA	¾	7½	20	415	35	1½	24½	38	17½			3½	8	47	49½	51½	25½	3½	24	
	* 38	40	41½	40	10 GA	¾	7½	20	470	37½	1½	26	40	18½			3½	8½	48	50	51½	28½	3½	30	
	42½	44½	45½	42	10 GA	¾	7½	24	520	39½	1½	29½	40½	18½			3½	9	54	56½	58½	33½	3½	30	
	45	47	48½	44	10 GA	¾	7½	24	575	41½	1½	30½	42½	19			3½	9½	60	62½	64½	43	3½	30	
21	25½	27½	28½	33	10 GA	¾	7½	14	320	30½	1½	17½	26½	12½			3½	3	32	33½	35½	19½	3½	18	
	* 27½	29½	30½	33	10 CA	¾	7½	16	335	30½	1½	19	29	13			3½	6	34	35½	37½	19½	3½	18	
	* 29½	31½	32½	33	10 CA	¾	7½	16	355	30½	1½	20	31	14			3½	8	36	38	39½	19½	3½	20	
	* 32	33½	35½	33	10 GA	¾	7½	18	395	30	1½	22	31½	14½			3½	6½	42½	44½	45½	29½	3½	24	
	* 34	35½	37½	36	10 GA	¾	7½	18	425	32½	1½	23½	33½	15½			3½	7½	42½	44½	45½	23½	3½	24	
	* 36	38	39½	38	10 GA	¾	7½	20	505	33½	1½	24½	38	17½			3½	7½	45	47	48½	25½	3½	24	
	38	40	41½	40	10 GA	¾	7½	20	555	37½	1½	26	40	19½			3½	8	48	50	51½	28½	3½	30	
	42½	44½	45½	42	10 GA	¾	7½	24	620	39	1½	28	40½	18½			3½	9	54	56½	58½	33½	3½	30	
	45	47	48½	44	10 GA	¾	7½	24	670	41½	1½	30½	42½	19			3½	9½	60	62½	64½	43	3½	30	
	* 48	50	51½	44	10 GA	¾	7½	24	715	45	1½	32½	45½	21			3½	10	60	62½	64½	34	3½	30	
25½	34	35½	37½	36	10 GA	¾	7½	18	470	33	1½	23½	33½	15½			3½	7½	42	44½	45½	23½	3½	24	
	36	38	39½	39	10 GA	¾	7½	20	530	33	1½	24½	38	17½			3½	7½	45	47	48½	25½	3½	30	
	* 38	40	41½	40	10 GA	¾	7½	24	610	36	1½	26	40	18½			3½	8	43	50	51½	28½	3½	30	
	42½	43½	45½	42	10 GA	¾	7½	24	705	39	1½	28½	40½	18½			3½	9	54	56½	58½	33½	3½	30	
	45	47	48½	44	10 GA	¾	7½	24	760	41½	1½	30	42½	19½			3½	10	60	62½	64½	34	3½	30	
	* 48	50	51½	48	10 GA	¾	7½	24	840	45½	1½	32½	45½	21½			3½	10½	66	67½	71½	31	3½	32	
	54	56½	58½	48	10 GA	¾	7½	24	960	45½	1½	36	46	16			3½	12	78	79½	81½	38½	3½	32	
	60	62½	64½	48	10 GA	¾	7½	24	1055	45½	1½	40	62	29½			3½	12½	86	87½	89½	43	3½	32	
	66	69	71½	48	10 GA	¾	7½	24	1150	43½	1½	45				3½	13	92	12	88½	91½	94½	46½	3½	32
	72	75	77½	48	10 GA	¾	7½	24	1465	43½	1½	46				3½	13½	95	12	104	105½	107½	52	3½	32
	78	81½	84½	48	10 GA	¾	7½	24	1605	43½	1½	51				3½	14	104	17	103	106½	109½	54	3½	32
	84	86	90½	48	10 GA	¾	7½	24	1720	43½	1½	53				3½	14½	104	17	103	106½	109½	54	3½	32

4 indicates no block was

Form No. C 2100

336


90029353

90029354

JOY MANUFACTURING COMPANY  
HENRY W. OLIVER BUILDING  
PITTSBURGH 22, PA.

MODEL 45-26 $\frac{1}{2}$ -1750  
SERIES 1000 JOY AXIVANE FAN  
#0 TO #16 BLADE SETTINGS


C-1336



JOY MANUFACTURING COMPANY  
HENRY W. OLIVER BUILDING  
PITTSBURGH 22, PA.

MODEL 45-26 $\frac{1}{2}$ -1750 2-STAGE  
SERIES 1000 JOY AXIVANE FAN  
#0 TO #16 BLADE SETTINGS

C-2446



90029355


338

b2E

JOY MANUFACTURING COMPANY  
HENRY W. OLIVER BUILDING  
PITTSBURGH 22, PA.

C-1339


MODEL 48-26 $\frac{1}{2}$ -1750  
SERIES 1000 JOY AXIVANE FAN  
#0 TO #16 BLADE SETTINGS



9532006

JOY MANUFACTURING COMPANY  
HENRY W. OLIVER BUILDING  
PITTSBURGH 22, PA.

MODEL 4B-262-1750 | 2-STAGE  
SERIES 1000 JOY AXIVANE FAN  
#0 TO #16 BLADE SETTINGS




14

JOY MANUFACTURING COMPANY  
HENRY W. OLIVER BUILDING  
PITTSBURGH 22, PA.

C-1342

MODEL 54-26 $\frac{1}{2}$ -1750  
SERIES 1000 JOY AXIVANE FAN  
#0 TO #16 BLADE SETTINGS




90029358

65562006  
the

JOY MANUFACTURING COMPANY  
338 S. BROADWAY  
NEW PHILADELPHIA, OHIO 44663  
SEPTEMBER 14, 1955

MODEL 54-26 $\frac{1}{2}$ -1750 2-STAGE  
SERIES 1000 JOY AXIVANE FAN  
#0 TO #16 BLADE SETTINGS

C-2606



Mine Structural Analysis

POOR ORIGINAL

90029360

Sept 16, 70

K

## SHAFT PILLAR DESIGN -EVALUATION -

$$\text{Depth} = 2225 \text{ ft}$$

$$\text{Entry Height} = 10 \text{ ft}$$

$$\text{Dens. t.} = 150 \text{ lb/ft}^3$$

$$\text{Pillar Radius} = 1000 \text{ ft}$$

$$\text{Arch Distance} = 0.154 (\text{Depth} - \text{ft}) + 70 = 408.8 \text{ ft}$$

### SHAFT TRIBUTARY-AREA-LOAD-(TAL)

$$\underline{\text{TAL}} = \frac{\pi (1000+408.8)^2 150(2225)}{2000} = \underline{1,040,500,000 \text{ Tons}}$$

### LOAD CARRYING CAPABILITY (L)

#### I. Most Likely Physical Properties

$$\phi = 30^\circ \text{ (Metcalf)} \quad \sigma_c \text{ (cohesion)} = 450 \text{ psi (Bouleby)}$$

$$\hat{\sigma}_v = 7399 \text{ psi} \quad \hat{\gamma} = 8.08 \text{ ft}$$

$$L = 1,660,000,000 \text{ Tons}$$

$$\underline{F.S.} = L / \underline{\text{TAL}} = \underline{1.60}$$

#### II. "Pure" Wilson, A. H. $\sigma_c = 1 \text{ psi}$

$$\phi = 30^\circ \quad \sigma_c = 1 \text{ psi}$$

$$\hat{\sigma}_v = 6950 \text{ psi} \quad \hat{\gamma} = 25.54 \text{ ft}$$

$$L = 1,532,000,000 \text{ Tons} \quad \underline{F.S.} = \underline{1.47}$$

#### III Cohesion Equals Unconfined Compression Strength Divided by Two - SHORT-TERM COHESION

$$\phi = 30^\circ \quad \sigma_c = 1600 \text{ psi}$$

$$\hat{\sigma}_v = 8549 \text{ psi} \quad \hat{\gamma} = 4.84 \text{ ft}$$

$$L = 1,924,000,000 \text{ Tons} \quad \underline{F.S.} = \underline{1.85}$$

31

IV Cohesion for Long-term (Infinite) Pillar Life  
Friction Angle of Repose

$$\phi = 35^\circ \quad \sigma_0 = 450 \text{ psi}$$

$$\hat{\sigma}_v = 0.997 \text{ psi} \quad \hat{y} = 5.80 \text{ ft}$$

$$I = 2,023,000,000 \text{ Tons}$$

$$\underline{FS} = \underline{1.94}$$

V Minimum Unconfined Compression Strength  
for 10-ft High Pillar Rib to Stand

$$\phi = 30^\circ \quad \sigma_0 = 10 \text{ psi}$$

$$\hat{\sigma}_v = 69.59 \text{ psi} \quad \hat{y} = 18.89 \text{ ft}$$

$$I = 1,599,500,000 \text{ Tons} \quad \underline{FS} = \underline{1.48}$$


---

FILLAR RADIUS NEEDED FOR  
FACTOR OF SAFETY OF ONE

$$I_1 = \phi = 30^\circ \quad \sigma_0 = 450 \text{ psi} \quad \underline{R = 52.9 \text{ ft}}$$

$$TAL = \frac{\pi(R+40\pi/8)^2(150)(2225)}{2000} = 524(R^2 + 817.6R + 167,100)$$

$$TAL = 524(R^2 + 817.6R + 167,100) = 524R^2 + 428,600R + 87,610,000$$

$$I = 0.05655\hat{\sigma}_v [4R^2 - 4R\hat{y} + \frac{4}{3}\hat{y}^2]$$

$$I = 418.4[4R^2 - 32.32R + 87.05]$$

$$I = 1674R^2 - 13520R + 36422$$

$$-TAL = -524R^2 - 428,600R - 87,610,000$$

$$I - TAL = 1149R^2 - 442,200R - 87,580,000 = 0$$

$$R = \frac{-b \pm \sqrt{b^2 - 4ac}}{2a} = 528.8 \text{ ft}$$

$$II \quad \phi = 30^\circ \quad \sigma_0 = 1 \text{ psi} \quad \underline{R = 589 \text{ ft}}$$

$$I - TAL = 1048R^2 - 468,800R - 87,270,000 = 0$$

$$R = 588.8 \text{ ft}$$

90030002

344

3

$$\text{III. } \Phi = 30^\circ \quad r_0 = 1600_{\text{psi}} \quad R = 449 \text{ ft}$$

$$L-TAL = 1410 R^2 - 438,000R - 87,600,000 = 0$$

$R = 449.1 \text{ ft}$

$$\text{IV. } \Phi = 35^\circ \quad T_c = 450 \text{ ps} \quad R = 427 \text{ ft}$$

$$I - T A L = 1511 R^2 - 440,400 R - 87,590,000 = 0$$

$$R = 427.2 \text{ ft}$$

$$\text{I. } \theta = 30^\circ \quad \sigma_c = 10 \text{ psi} \quad R = 580 \text{ ft}$$

$$I - TAL = 1050 R^2 - 458,400R - 87,425,000 = 0$$

$R = 580.1 \text{ ft}$

# STORAGE DRIFT PILLAR DESIGN FOR $FS = 1.5$

Depth = 222.5 ft

Room Height = 16.5 ft

$$\text{Density} = 150 \text{ lb/ft}^3$$

Room Width ( $M_{\text{max}}$ ) = 42 ft

Pillar Length = 500ft

$$R = ? \%$$

$$F.S = 1.5 = \frac{I}{T A L} \quad \text{Design for 1-ft Slice}$$

L = 1.5 TAL

## I. Most Likely Physical Properties

$$\Phi = 30^\circ \quad \sigma_0 = 450 \text{ psi} \quad p = \text{pillar width}$$

$$TAL = \frac{(1)(p+42)(150)(2225)}{7900} = 166.9(p+42)$$

TAL = 166.9 p + 7009 Tons

$$L = 0.072 \hat{\sigma} [p - q] = 0.072(7355) [p - 13.34]$$

$$I = 532.7 p - 7104$$

14

$$L = 1.5 \text{ TAL}$$

$$532.7_p - 7109 = 1.5(166.9_p + 7009)$$

$$532.7_p - 7109 = 250.4_p + 10510$$

$$282.4_p = 17620$$

$$\underline{p = 62.4 \text{ ft}}$$

$$\text{II "Pure" Wilson } \Phi = 30^\circ; \sigma_0 = 1 \text{ psi}, \hat{\sigma}_0 = 6950 \text{ psi}$$

$$L = 0.072(6950)[p - 42.14] = 500.4[p - 42.14]$$

$$L = 500.4_p - 21085$$

$$\gamma = 25.54 \text{ ft}$$

$$-1.5 \text{ TAL} = -250.4_p - 10510$$

$$+ 250.0_p - 31595 = 0$$

$$\underline{p = 1264 \text{ ft}} \quad R = 24.9$$

### III. Cohesion Equals Unconfined Compression Strength

Divided by  $\tau_u$  - Short-Term Cohesion

$$\Phi = 30^\circ; \sigma_0 = 1600 \text{ psi}; \hat{\sigma}_0 = 8549 \text{ psi}; \gamma = 4.84 \text{ ft}$$

$$L = 0.072(8549)[p - 7.98]$$

$$L = 615.5_p - 4973$$

$$-1.5 \text{ TAL} = -250.4_p - 10510 = 0$$

$$365.1_p - 15422 = 0$$

$$\underline{p = 42.2 \text{ ft}}$$

### IV Friction Angle of Reuse - Long-Term Cohesion

$$\Phi = 35^\circ; \sigma_0 = 450 \text{ psi}; \hat{\sigma}_0 = 8997 \text{ psi}; \gamma = 9.56 \text{ ft}$$

$$L = 0.072(8997)[p - 9.56]$$

$$L = 647.8_p - 6196$$

$$-1.5 \text{ TAL} = -250.4_p - 10510$$

$$397.9_p - 16706 = 0$$

$$\underline{p = 42.0 \text{ ft}}$$

5

IV. Minimum Uncuffed Compression Strength  
for 16.5-ft High Pillar Rib to Stand

$$\phi = 30^\circ; \sigma_0 = 16.5 \text{ psi}; \hat{\sigma}_v = 6965 \text{ psi}; \gamma = 28.79 \text{ ft}$$

$$I = 0.072(6965) [p - 28.79]$$

$$I = 501.5p - 14440$$

$$-1.5 \text{ STAL} = -250.9p - 10510$$

$$\underline{p = 99.4 \text{ ft}}$$

### MAIN ENTRY PILLAR DESIGN FOR $FS = 1.5$

Depth = 2225 ft

Density = 150 lb/ft<sup>3</sup>

P. Pillar Lengths = 500 ft and "p" from Store, =

Pillar Height-10 ft Drift Design

Room Width = 32 ft

I.  $\phi = 30^\circ; \sigma_0 = 450 \text{ psi}$   
 $\hat{\sigma}_v = 7399 \text{ psi}; \gamma = 8.08 \text{ ft}$   
 $\underline{p = 43.6 \text{ ft}} \quad R = 42.3\%$

II.  $\phi = 30^\circ; \sigma_0 = 1 \text{ psi}$   
 $\hat{\sigma}_v = 6950 \text{ psi}; \gamma = 25.5$   
 $\underline{p = 83.1 \text{ ft}} \quad R = 22$

III.  $\phi = 30^\circ; \sigma_0 = 1600 \text{ psi}$   
 $\hat{\sigma}_v = 8549 \text{ psi}; \gamma = 4.2$   
 $\underline{p = 30.1 \text{ ft}} \quad R = 51.5\%$

IV.  $\phi = 35^\circ; \sigma_0 = 450 \text{ psi}$   
 $\hat{\sigma}_v = 8997 \text{ psi}; \gamma = 5.80 \text{ ft}$

90030005

$\underline{p = 29.6 \text{ ft}}; 51.9\%$

V.  $\phi = 30^\circ; \sigma_0 = 10 \text{ psi}$   
 $\hat{\sigma}_v = 6959 \text{ psi}; \gamma = 18.87 \text{ ft}; \underline{p = 69.7 \text{ ft}}; R = 31.5\%$

	16. 5-ft High	42-ft Wide	Storage	Drafts		
	I.		II.	III.		
FS	p (ft)	R (%)	p (ft)	R (%)	p (ft)	R (%)
1.25	48.95	46.18	102.29	29.11	33.60	55.55
1.50	62.39	40.24	126.36	24.95	42.24	49.86
1.75	80.48	34.29	160.07	20.78	53.11	44.16
2.00	106.16	28.35	210.66	16.62	67.19	38.47
2.25	145.47	22.40	295.05	12.46	86.16	32.77
2.50	213.18	16.46	464.08	8.30	113.13	27.07
	IV	□		V	⊕	
FS	p (ft)	R (%)	p (ft)	R (%)		
1.25	34.05	55.22	79.21	34.65		
1.50	42.04	49.98	99.34	29.71		
1.75	51.89	44.73	127.50	24.78		
2.00	64.36	39.49	169.65	19.84		
2.25	80.66	34.24	239.72	14.91		
2.50	102.84	29.00	379.13	9.97		

200/20.


32 ft OVERALL ENTRY WIDTH

FS	P (ft)	% R
2.0	75.32	29.8
2.5	152.84	17.3
2.25	103.00	23.56
1.5	43.6	42.3
1.75	<del>103</del> 56.72	36.07
1.25	33.88	48.57

FS	P P (ft)	R %	III		P (ft)	A (%)
			P (ft)	R %		
1.25	66.67	32.93	<del>103</del> 23.72	57.43	33.88	48.57
1.50	83.13	27.79	30.09	51.59	43.6	42.3
1.625	93.61	27.46	38.09	45.63	56.72	36.07
1.75	106.19	23.19	48.47	39.76	75.32	29.8
1.875	121.56	20.29	62.46	33.88	<del>2.125</del> 27.89	26.69
2.00	140.78	18.52	82.33	27.95	<del>2.375</del> 103.80	23.56
2.125	165.51	16.70			<del>2.375</del> 104.57	20.99
2.25	192.49	13.89			152.89	17.3
2.50	314.02	9.25				

FS	P P (ft)	R %	IV		P (ft)	R (%)
			P (ft)	R %		
1.25	23.75	57.40	55.20	36.70		
1.50	29.60	51.95	69.71	31.42		
1.75	36.82	46.50	90.01	26.23		
2.00	45.96	41.04	<del>1.875</del> 120.49	20.49		
2.25	57.91	35.59	<del>2.125</del> 142.16	15.76		
2.50	74.17	30.19	171.09	18.37		
2.75	78.16	29.05	272.15	10.52		


Storage Drift Design — 42-ft Room Width




350

90030008

*Entry Design — 32-ft Entry Width*




Storage Drift Design - 42-ft Wide Room



352


90030010

32-ft Entry Width




353

90030011



TRU LEVEL ENTRY DESIGN— 31.50 FT. WIDTH  
10.00 FT. HEIGHT  
2,225.00 FT. DEPTH




TRU STORAGE ROOM DESIGN - 45.00 FT. WIDTH  
 16.54 FT. HEIGHT  
 2,225 FT. DEPTH

90030013

MR Level  
280 ft Depth


ENTRY DESIGN - 31.5 FT. ROOM WIDTH  
10.0 FT. ROOM HEIGHT



21000


90030014 352

① TRU Level Nov. 16, '76 Triaxial Test  
Quasi-static Results - Wawersik



(2)

## TRU LEVEL DESIGNS Cont.



21000000


358

90030016

60030017

650

Depth - 2800 ft; Temperature - Start 305.2°K, at 10 yrs. 373°K, then steady.  
 Pillar Width - 83.5 ft; Room Width - 31.5 ft; Room Height - 10 ft.



Depth 2800 ft ; Temperature - Start 305.2°K, at 10 yrs 373°K, then steady.  
Room Width - 31.5 ft, Room Height - 10 ft




Figure 1: HR Level Convergence Versus Time Since loading

90030018

430

卷之三

卷之三

90030019




FIGURE TRU Level Convergence Versus Elapsed Time

90030020

FENIX & SCISSON, INC.  
LAS VEGAS, NEVADA 89101

COMPUTED BY: JL. AIA

CHECKED BY: \_\_\_\_\_

CALCULATIONS FOR: MINE STABILITY BASED ON HISTORICAL DATA

**DESIGN SHEET**

SHEET 1 OF 28  
PROJECT NO. 288  
DATE: Sept. 17, 1975

THE FOLLOWING DATA POINTS WERE USED TO OBTAIN A  
GENERALIZED EQUATION FOR AN ALLOWABLE EXTRACTION RATE IN MINES  
OPERATING IN SINTERITE DEPOSITS:

	DEPTH (foot)	EXTRACTION RATE (%)
	0	100
HUTCHINSON	695	75
WILMINGTON	811	66
LYONS	1024	68
PETSON	1063	73.5
DETROIT	1100	65
BELLE ISLE	1250	52.8
COTE BLANCHE	1354	56
* GOODRICH	1760	52.2
WHISKEY ISLAND	1775	54
SENACA LAKE	2000	55
MOSS (AVG)	3200	38
ESTERNAY	3400	36.6

\* GOODRICH - THIS DATA POINT NOT USED DUE TO UNSTABILITY.

THE METHOD OF LEAST SQUARES WAS USED TO OBTAIN THE BEST FIT  
OF THE DATA TO THIS EQUATION.

FENIX & SCIBBON, INC.  
LAS VEGAS, NEVADA 89101

DESIGN SHEET

COMPUTED BY: \_\_\_\_\_  
CHECKED BY: \_\_\_\_\_  
CALCULATIONS PER: \_\_\_\_\_

SHEET 5 OF 564  
PROJECT NO. 564  
DATE: Sept. 17 1975

$$q = 10 \text{ (no Godenrich)}$$

13

$$E_A = 17,682$$

19,582

$$E_A^2 = 36,808,732$$

39,906,332

$$E_A^3 = 99,507,990,966$$

99,959,216,986

$$E_A^4 = 279,686,206,979,400$$

289,261,332,739,400

$$E_A^5 = 851,676,759,220,000,000$$

868,569,175,565,680,000

$$E_A^6 = 2,788,521,076,013,000 \times 10^6$$

3,758,348,937,567,000 \times 10^6

$$E_A^7 = 8,889,872,769,326,000 \times 10^9$$

8,988,103,295,661,000 \times 10^9

$$E_A^8 = 89,230,096,506,060,000 \times 10^{12}$$

29,322,48,999,310,000 \times 10^{12}

$$E_y = 739.80$$

730.10

$$E_{xy} = 919,877.50$$

911,599.50

$$E_{yy} = 1,695,132,796.50$$

1,789,875,516.50

$$E_{xy}^2 = 3,870,977,029,239.$$

3,196,529,216,959,

$$E_{yy}^2 = 10,919,093,566,930,000.$$

11,223,006,616,900,000

FENIX & SCISSON, INC.  
LAS VEGAS, NEVADA 89101

COMPUTED BY: \_\_\_\_\_  
CHECKED BY: \_\_\_\_\_  
CALCULATIONS FOR: \_\_\_\_\_

## DESIGN SHEET

SHOOT 5 OF         
PROJECT NO. 888  
DATE Sep 17 1975

in der ersten Hälfte des 20. Jahrhunderts und in den 1920er Jahren wieder aufgenommen. Die Ausgrabungen fanden zwischen 1925 und 1930 statt und wurden von dem Archäologen Carl Schuchhardt geleitet. Die Ergebnisse der Grabungen sind in mehreren Berichten und Monografien publiziert.

Die archäologischen Funde bestehen aus einer Vielzahl von Artefakten, die die soziale Struktur und das kulturelle Leben der Menschen in dieser Zeit wiedergeben. Es handelt sich um Keramik, Metallgegenstände, Glas- und Porzellanteile sowie Textilien. Einige der gefundenen Gegenstände sind sehr gut erhalten und können heute noch besichtigt werden.

Die Ausgrabungen haben nicht nur die Geschichte des Ortes aufgedeckt, sondern auch die Entwicklung der Archäologie in Deutschland. Sie waren ein wichtiger Beitrag zur Erforschung der Vorgeschichte und der Frühgeschichte des Landes. Heute ist die Fundstätte ein geschütztes Kulturgut und ein wichtiger Ort für die Erhaltung und Pflege der kulturellen Identität Deutschlands.

90030023



**FENIX & SCISSON, INC.**  
LAS VEGAS, NEVADA 89101

## **DESIGN SHEET**

COMPUTED BY: \_\_\_\_\_  
CHECKED BY: \_\_\_\_\_  
CALCULATIONS FOR: \_\_\_\_\_

SHEET 5 OF     
PROJECT NO. 200  
DATE 2025-12-1975

20-01-050052/142

10

00066705 2/6/10

$$= \frac{1}{2\pi} \int_{-\infty}^{\infty} \int_{-\infty}^{\infty} e^{-\frac{1}{2}x_1^2 - \frac{1}{2}x_2^2} e^{-(x_1 - x_2)^2} dx_1 dx_2$$

2021-2022 学年第二学期期中考试卷

$$= 0.037125 \times 10^3 \text{ N/m}^2 + 5.020 \times 10^3 \times 10^3 \times 10^3 \times 10^3 \times 10^3 = 5.020 \times 10^3 \text{ N/m}^2$$

7-6

3-6

9-6

**FENIX & SCIBBON, INC.**  
LAS VEGAS, NEVADA 89101

COMPUTED BY: \_\_\_\_\_  
CHECKED BY: \_\_\_\_\_  
CALCULATIONS FOR: \_\_\_\_\_

**DESIGN SHEET**

**DESIGN SHEET**

ENCLIST 6 OF 1  
PROJECT NO. 500  
DATE Sep 17 1975

~~2000.00 + 2000.00 = 4000.00~~

A  
B  
C  
D  
E  
F  
G  
H  
I  
J  
K  
L  
M  
N  
O  
P  
Q  
R  
S  
T  
U  
V  
W  
X  
Y  
Z

$$E = -57.12 / 272.27 \times 10^{-3}$$

0252022258 - = 2024020258

2022-01-01 022201/202201

卷之三

$$= \frac{1}{2} \left( \frac{\partial^2 \phi}{\partial x^2} + \frac{\partial^2 \phi}{\partial y^2} \right) = \frac{1}{2} \left( \frac{\partial^2 \phi}{\partial x^2} + \frac{\partial^2 \phi}{\partial y^2} \right)$$

$$x_2 = 0.5 \cdot 990 / 25325920.0$$

$\theta_3 = -3.0832906283110 \times 10^{-9}$

—/83, 870, 233, 197, 800

5. On a separate sheet write 1-2 per

**FENIX & SCIBBON, INC.**  
LAS VEGAS, NEVADA 89101

COMPUTED BY: \_\_\_\_\_  
CHECKED BY: \_\_\_\_\_  
CALCULATIONS PGS: \_\_\_\_\_

## **DESIGN SHEET**

ВИДІЛ # 1  
УДОСТОІВ № 100  
ДАТА 17.07.1995

FENIX & SCIBBON, INC.  
LAS VEGAS, NEVADA 89101

DESIGN SHEET

COMPUTED BY: \_\_\_\_\_  
CHECKED BY: \_\_\_\_\_  
CALCULATIONS FOR: \_\_\_\_\_

DATE 9/10/68  
PROJECT NO. 548  
DRAFT 54005 10 1978

$$y = 110,0980626707 - 50.5706807602 \times 10^{-3} r + 10.2075 \times 10^{-6} r^2 - 2.2075 \times 10^{-9} r^3$$

$$\text{at } r = 0, y = 110,09806$$

200	90.7250
400	82.7337
600	75.8965
800	70.3478
1000	65.6806
1200	61.0489

$$\text{at } r = 1000, y = 58.7148$$

1000	58.7148
1200	53.8097
1400	52.1857
1600	50.9208
1800	49.7362
2000	48.6225

$$\text{at } r = 2000, y = 44.8506$$

2000	44.8506
3000	42.3839
4000	39.3858
5000	36.7196
6000	34.2487
7000	31.8368
8000	29.3462
9000	26.85185
10000	0.000188

$$y = 96,688039422230 - 34.413163806520 \times 10^{-3} r + 5.05518896852 \times 10^{-6} r^2$$

$$\text{at } r = 0, y = 96,6880$$

200	96.0074
400	87.7316
600	77.8600
800	72.3928
1000	67.3500
1200	62.6716

$$\text{at } r = 1000, y = 58.9176$$

1000	58.9176
1200	54.5681
1400	51.1229
1600	48.0822
1800	45.1458
2000	42.2139
2200	39.3869

$$\text{at } r = 2000, y = 39.9633$$

3000	38.9496
4000	36.3303
5000	33.1209
6000	30.1249
7000	28.3148
8000	26.6472
9000	25.0472

$$y = 89,720720625395 - 15.709729518930 \times 10^{-3}$$

$$\text{at } r = 0, y = 89.7207$$

$$\text{at } r = 2000, y = 53.3113$$


$$\text{at } r = 4000, y = 21.9018$$

371

KODAK 10 X 10 TO 1/2 INCH 46 1322  
7 X 10 INCHES MADE IN U.S.A.  
KEUFFEL & ESSER CO.

SHEET 9 OF 208  
PROJECT NO. 208  
DATE SEPT. 18 1970

90030029



FENIX & SCIBSON, INC.  
TULSA, OKLAHOMA 74112


DESIGN SHEET

COMPUTED BY: J. S. A.

CHECKED BY:

CALCULATIONS FOR: Critical Stress Concentrations for Drawings  
of Various Cross Sections

SHEET 1 OF 1  
PROJECT NO. 368  
DATE Sept 16, 1976



372

90030030

Corner Stresses at Steaming Boundary

Plane 20  
Held in Vert. ANGLE Width to Height Ratio ( $w/h$ ) for Steaming  
Amplitude 10°  
Depth Theoretical 0.50 1.00 2.00 4.00

ELECTRICAL STEAMING

0	0°	1.5	2.0	3.0	5.0	9.0
	90°	-1.0	-1.0	-1.0	-1.0	-1.0
1/3	0°		1.67	2.67	4.33	8.33
	90°	2.3			-0.33	-0.5
1	0°			2.0	8.0	8.0
	90°	3.0	4.0	2.0		

ORBITAL STEAMING

0	0°	1.0	2.0	3.0	3.4	9.85
	90°	-1.0	-0.9	-1.0	-0.9	-1.0
1/3	0°		3.05	2.67	3.15	9.5
	90°	2.1			-0.33	-0.5
1	0°	2.1	3.10	2.0	3.15	9.1
	90°					

Planes 20, 21, 22 and 23 having a Finest

Depth of Steaming Sheet Dimension Ratio of 1:6						
1	CROSS	0.5	2.67	3.15	4.0	5.33
	90°	2.10	-1.0	-1.0	-1.0	-1.0
1/3	CROSS	0.5	3.1	3.15	4.0	5.5
	90°		-0.2	-0.33	-0.5	-0.5
1	CROSS	0.15	4.67	3.15	4.07	6.15
	90°					

90030031

J.C. ASH  
9/20/76

Coeff. Ratios and Total Closure are Isolated Drawings

Use  $\sigma_0 = \sigma_0 e^{-kt} t^{-0.05}$  for first year and then assume to be constant thereafter  
 where  $\sigma_0$  is the creep rock in inches per inch per day  
 $\sigma$  is the initial in situ rock stress in pounds per square inch  
 $t$  is the elapsed time in days  
 $k$  and  $n$  are octahedral strain constants  
 Total Closure =  $\int_{0}^{\infty} \sigma_0 e^{-kt} t^{-0.05} dt = \frac{k \sigma_0 t^{0.05}}{n+1} = 10.5$  in inches per inch

At a density of 150 pounds per cubic foot for the overlying materials  
 $\sigma = \frac{150 \times 2230}{144} = 2325$  psi for the TD level  
 $= \frac{150 \times 2810}{144} = 2920$  psi for the RH level

Taking  $k = 7.75 \times 10^{-5}$  and  $n = 3.55$ ; then for the  
 TD level,  $\sigma_0 = 77,069.913 \times 10^{-5} t^{-0.05}$  and Total Closure =  $513,796.1 \times 10^{-5} t^{0.05}$   
 In the first year plus  $0.514613 \times 10^{-5} \times (t-365)$  minutes  
 TD level,  $\sigma_0 = 119,500.713 \times 10^{-5} t^{-0.05}$  and Total Closure =  $10,973,157 \times 10^{-5} t^{0.05}$   
 + in the first year plus  $1.092631 \times 10^{-5} \times (t-365)$  minutes

t	For $\sigma_0 = 2325$		For $\sigma_0 = 2920$	
	$\sigma_0$	TOTAL CLOSURE	$\sigma_0$	TOTAL CLOSURE
1	$7.7069 \times 10^{-8}$	$5.1380 \times 10^{-3}$	$1.6960 \times 10^{-8}$	$1.0973 \times 10^{-2}$
10	$1.0586 \times 10^{-8}$	$7.2576 \times 10^{-3}$	$2.3559 \times 10^{-8}$	$1.5500 \times 10^{-2}$
100	$1.5377 \times 10^{-5}$	$1.0252 \times 10^{-2}$	$3.2891 \times 10^{-5}$	$2.1899 \times 10^{-2}$
365	$5.1160 \times 10^{-6}$ $(2.1721 \times 10^{-6})$	$1.2999 \times 10^{-2}$ $(1.9981 \times 10^{-2})$	$1.0926 \times 10^{-5}$ $(8.6389 \times 10^{-6})$	$3.6587 \times 10^{-2}$ $(3.0926 \times 10^{-2})$
1000	$5.1160 \times 10^{-6}$	$1.5698 \times 10^{-2}$ $(2.0955 \times 10^{-2})$	$1.0926 \times 10^{-5}$	$3.8525 \times 10^{-2}$ $(4.3609 \times 10^{-2})$
10 <sup>4</sup>		$6.1792 \times 10^{-2}$ $(2.8893 \times 10^{-2})$		$1.3186 \times 10^{-1}$ $(6.706 \times 10^{-2})$
10 <sup>5</sup>		$5.8318 \times 10^{-1}$		$1.1152 \times 10^0$ $(1.0223 \times 10^0)$
	$8.0 \times 10^{-7} \times 10^4$ $1.0 \times 1.837 \times 10^4$	$1.0000 \times 10^0$		

J. L. A.S.A.  
9/22/76

### CROPS RATES AND TOTAL CLOSURE AND ISOLATED OPENINGS

Let  $c_0 = t^{0.01} \cdot 10^6$  during the first year and  $c_0 = t^{0.01}(365)^{-0.05}$  thereafter  
where  $c_0$  is the crop rate in inches per inch per day

$\sigma$  is the initial no cut rock stress in pounds per square inch  
 $t$  is the elapsed time in days

$k$  and  $m$  are established strain constants

The total closure at any time during the first year will then be =

$$\frac{c_0}{10} t^{0.01} \cdot 10^{-6} dt = \frac{t^{0.01} \cdot 10^{15}}{10} \text{ inches per inch and after the first year,}$$

$$\text{it will be } = \frac{t^{0.01}(365)^{-0.05}}{10} + \frac{t^{0.01}(365)^{-0.05}(t-365)}{10} \text{ inches per inch}$$

Taking  $\sigma$  as unity of 100 pounds per cubic foot for the carrying material

$$\sigma = 100 \cdot \text{depth} = \frac{100 \cdot 2230}{1194} = 2325 \text{ psi for the TRU level}$$

$$= \frac{100 \cdot 2920}{1194} = 2920 \text{ psi for the ET level}$$

Taking  $k = 4.76 \times 10^{-6}$  and  $m = 3.33$ , then

$$t^{0.01} = 77.16921406 \times 10^{-5} \text{ for the TRU level}$$


$$= 169.59575796 \times 10^{-5} \text{ for the ET level}$$

Thus we get:

$t$	For $\sigma = 2325$		For $\sigma = 2920$	
	$c_0$	TOTAL CLOSURE	$c_0$	TOTAL CLOSURE
1	$7.7169 \times 10^{-6}$	$5.1380 \times 10^{-3}$	$1.0926 \times 10^{-5}$	$1.3973 \times 10^{-2}$
10	$1.0986 \times 10^{-5}$	$7.2576 \times 10^{-3}$	$2.3250 \times 10^{-5}$	$1.5500 \times 10^{-2}$
100	$1.5377 \times 10^{-6}$	$1.0252 \times 10^{-2}$	$3.2891 \times 10^{-5}$	$2.1809 \times 10^{-2}$
365	$5.1160 \times 10^{-6}$	$1.3949 \times 10^{-2}$	$1.0926 \times 10^{-5}$	$2.6587 \times 10^{-2}$
1000	$5.1160 \times 10^{-6}$	$1.3949 \times 10^{-2}$	$1.0926 \times 10^{-5}$	$3.3525 \times 10^{-2}$
$10^4$	$5.1160 \times 10^{-6}$	$6.1792 \times 10^{-2}$	$1.0926 \times 10^{-5}$	$1.3186 \times 10^{-1}$
$10^5$	$5.1160 \times 10^{-6}$	$5.2218 \times 10^{-1}$	$1.0926 \times 10^{-5}$	$1.1152 \times 10^0$
$1.93031 \times 10^5$		$1.0000 \times 10^0$		
$8.90897 \times 10^6$				$1.0000 \times 10^0$

90030033


COST OF RENT FOR ISOLATED MEETINGS



376

90030034

**46 7522**  
LOGARITHMIC  
TABLES  
KNUFFEL & VESSER CO.




377

90030035

	@ 2325 psi	@ 2920 psi
After 1 day, total closure will be	$5.1380 \times 10^{-3}$	$1.0973 \times 10^{-2}$ inches per side
3 days	6.0584	1.2939
1 week	6.8795	1.4632
2 weeks	7.6333	1.6302
3 weeks	8.1119	1.7324
1 month	8.5755	1.8314
5 months	$9.5151 \times 10^{-3}$	2.0321
2 years	$1.0113 \times 10^{-2}$	2.1595
3 years	1.0538	2.2588
6 years	1.1220	2.3962
10 years	1.1923	2.5968
1 year	1.2999	2.6587
2 years	1.4816	2.8575
3 years	1.6189	2.9563
4 years	1.7151	2.8551
5 years	1.8018	2.8539
6 years	1.8736	2.6527
7 years	2.3258	2.0516
8 years	2.5520	5.4508
9 years	2.7388	5.8992
10 years	2.9255	6.2980
12 years	3.8592	$8.8930 \times 10^{-2}$
15 years	4.7920	$1.0236 \times 10^{-1}$
20 years	$5.7265 \times 10^{-2}$	$1.2230 \times 10^{-1}$

## TOTAL CLOSURE OR ISOLATED OPENINGS



37A-380

90030037

Miscellaneous Underground Calculations


*POOR ORIGINAL*

FENIX & SCISSON, INC.  
TULSA, OKLAHOMA 74112

COMPUTED BY: \_\_\_\_\_  
CHECKED BY: \_\_\_\_\_  
CALCULATIONS FOR: \_\_\_\_\_

DESIGN SHEET

SHEET \_\_\_\_\_ OF \_\_\_\_\_  
PROJECT NO. \_\_\_\_\_  
DATE: \_\_\_\_\_



ASSUMPTIONS:

$$\text{AREA OF LOADING INFLUENCE} = \frac{115(X+186.5)}{43560} \text{ ACRES}$$

TOTAL WASTE STORAGE 1,970,000 CUFT

CANNISTER VOLUME 39 CU FT

TOTAL No. CANS 50513 CANS

Thermal Power 300 WATTS

TOTAL POWER 15154 KILOWATTS

ALLOWABLE LOAD 75 KW/ACRE

AREA REQUIRED 202.05 ACRES PLUS BLOCK & PANEL ENTRIES

X = 522.5 = Length of Storage Space

562.5 = Pillar Length

594 = c-c Distance Between Entries

Area of Influence = 115'W x 709'Lq. = 81535 Sq Ft = 1.8718 Ac

@ 75 KW/Ac = 140,3840 KW/Rm

@ 300 w/can = 468 Cans/Rm

or 107.95, SAY 108 Rms.

or 18,250 CUFT/RM

## FENIX &amp; SCISSION, INC.

TULSA, OKLAHOMA 74112

## DESIGN SHEET

COMPUTED BY: \_\_\_\_\_

CHECKED BY: \_\_\_\_\_

CALCULATIONS FOR: \_\_\_\_\_

## MINED SALT STORAGE

SHEET \_\_\_\_\_ OF \_\_\_\_\_

PROJECT NO. \_\_\_\_\_

DATE: \_\_\_\_\_

Assumptions: Salt density in place      135 lbs/cuft  
                   "                mine run      90      "  
                   "                backfill      68      "

Storage piles are developed using "mine run" salt assumed to have a density of 90 lbs/cu.ft. To backfill, the stored salt would be excavated, crushed and dried, reducing this density to 68 lbs/cu.ft. In the process of backfilling, no compaction is assumed, however it is assumed that 100% of the original mined volume requires backfilling. Salt creep will of course reduce this volume considerably.

	TRUE LEVEL	R.H. LEVEL
MINED VOLUMES (@ 135 #/CF)	2,290,218 TONS	2,965,841 TONS
SPACE EXCAVATED	33,929,156 CUFT	43,938,385 CUFT
RADIWASTE STORED	6,500,136 5,835,020 CUFT	2,337,611 1,970,000 CUFT
VOLUME TO BACKFILL (@ 90 #/CF)	28,094,136 CUFT 27,429,020	41,960,385 CUFT 41,600,774
TOTAL SALT STORED (WGT.) " " " (VOL.)	2,290,218 TONS 50,893,733 CUFT	2,965,841 TONS 65,907,578 CUFT

7.4' x 51' 55' x 80' (28'0" x 39")

$$769,850 \times 2.77 = 2,133,793.74 \text{ cu ft}$$

15.1' x 83.1" 28'0" x 25"

$$15,050 \times 108 = 2,683,973.74 \text{ cu ft}$$

$$19,879,416 \times .50 = 9,937,757.74 \text{ cu ft}$$

13,194 78 x 18 x 89' boxes

$$13,194 \times 112 = 1,472,128 \text{ cu ft}$$

x 26' 10' x 3' x 86 "

$$268 \times 2.77 = 58,600 \text{ cu ft}$$

29.5' x 29'0" x 15' 20' x 15'

$$49,519 \times 15.57 = 742,710 \text{ cu ft}$$

1010 20' x 14'

$$1010 \times \frac{36}{30} = 1,056 \text{ cu ft}$$

$$23,787,056 \text{ cu ft}$$

$$\times .50 = 11,890 \text{ cu ft}$$

387

90030040

## FENIX &amp; SCISSION, INC.

TULSA, OKLAHOMA 74112

## DESIGN SHEET

COMPUTED BY: \_\_\_\_\_


CHECKED BY: \_\_\_\_\_

CALCULATIONS FOR: \_\_\_\_\_

SHEET \_\_\_\_\_ OF \_\_\_\_\_

PROJECT NO. \_\_\_\_\_

DATE: \_\_\_\_\_



FENIX & SCISSION, INC.  
TULSA, OKLAHOMA 74112

DESIGN SHEET

COMPUTED BY: \_\_\_\_\_

CHECKED BY: \_\_\_\_\_

CALCULATIONS FOR: \_\_\_\_\_

SHEET \_\_\_\_\_ OF \_\_\_\_\_  
PROJECT NO.: \_\_\_\_\_  
DATE: \_\_\_\_\_

$W_0 = 0$  WHICH MEANS THE MINIMUM  $L$  IS AT A MAXIMUM AND AT THAT CONDITION

$$b_1 (T_{01} 37^\circ - k_0 c) = b_2 (T_{01} 37^\circ + 0.00c) + 9.9 T_{01} 37^\circ + 0.00008L$$

$$b_1 = 1.059529 b_2 + 9.519968 + 0.00109058L = 109.972868 + 0.10109058L$$

$$+ 0.0009158(100038.86 + L)$$

384

90030042

ASSUMING RH Pile is Pile #1, TRU Pile is Pile #2,  $h_2 = 100$

FENIX & SCISSON, INC.  
TULSA, OKLAHOMA 74112

COMPUTED BY: \_\_\_\_\_  
CHECKED BY: \_\_\_\_\_  
CALCULATIONS FOR: \_\_\_\_\_

DESIGN SHEET

SHEET \_\_\_\_\_ OF \_\_\_\_\_  
PROJECT NO: \_\_\_\_\_  
DATE: \_\_\_\_\_

TRU LEVEL - PILE #2 -  $h = 100$  Assume  $L = 1006.41$  ft.  $\therefore H = h + 0.02L = 120.13$  ft.

VOLUME RAMP =  $\frac{1}{3}(A_1)M$  =  $3,511,710.715$  SAY =  $3,511,711$  CU FT

$A_1 = 0.50(W_3 \tan 37^\circ - 0.04)W_3 + 230h + 0.50(W_4 \tan 37^\circ + 0.04)W_4 = 36,337.74579 \text{ ft}^2$

$$\text{if } W_3 = \frac{h+2.30}{\tan 37^\circ - 0.02} = 139.4580263 \text{ SAY } 139.46 \text{ ft}$$

$$\text{if } W_4 = \frac{h-2.30}{\tan 37^\circ + 0.02} = 126.3001596 \text{ " } 126.30 \text{ ft}$$

$$\therefore M = \frac{h}{0.02 + \tan 18^\circ} = 289.9225562 \text{ " } 289.92 \text{ ft}$$

VOLUME CENTER =  $\frac{1}{2}(A_1 + A_2)L = 41,868,145.93$  SAY  $41,868,146$  CU FT

$$A_1 = 36,337.74579$$

$$A_2 = 0.50(W_3 \tan 37^\circ - 0.04)W_3 + 230H + 0.50(W_4 \tan 37^\circ + 0.04)W_4 = 46,866.04182$$

$$\text{if } W_3 = \frac{H+2.30}{\tan 37^\circ - 0.02} = 166.8973131 \text{ SAY } 166.90 \text{ ft}$$

$$\text{if } W_4 = \frac{H-2.30}{\tan 37^\circ + 0.02} = 152.320578 \text{ SAY } 152.32 \text{ ft}$$

VOLUME END =  $\frac{1}{3}(A_B + A_T + \sqrt{A_B \times A_T})H = 5513877.712$  SAY  $5513878$  CU FT

$$\text{if } A_T = 140^2 \pi \left(\frac{H}{36}\right) - 115(80) = 9614.649336$$

$$A_B = (140^2 - 280m + \frac{18m^2}{11})\pi \left(\frac{H}{36}\right) - 9200 = 97,472.11214$$

$$\text{if } m = \frac{H+1.60}{\tan 37^\circ - 0.02} = 165.9427822 \text{ SAY } 165.94 \text{ ft}$$

TOTAL TRU SALT STORED (when  $L = 1006.41$  ft)  $50,893,725$  CU FT.

RH LEVEL - PILE #1 TOP ELEV. SAME AS PILE #2

Also,  $h_1 = 0.00109058(100638.88 + L) = 111.0704364$  SAY  $111.07$  ft

Assume  $L = 1128.90$  ft  $\therefore H = 133.65$  ft

VOLUME RAMP =  $4,507,709.313$  SAY =  $4,507,709$  CU FT

$$A_1 = 41,994.91181 \text{ ft}^2$$

$$\text{if } W_1 = 154.5495337 \text{ SAY } 154.55 \text{ ft}$$

$$W_2 = 140.6112946 \text{ SAY } 140.61 \text{ ft}$$

$$\therefore M = 322.0182483 \text{ SAY } 322.02 \text{ ft}$$

VOLUME CENTER =  $54,491,076$  CU FT

$$A_1 = 41,994 + \text{ft}^2$$

$$A_2 = 54,543 + \text{ft}^2$$

$$W_1 = 185.53 \text{ ft}$$

$$W_2 = 169.80 \text{ ft}$$

VOLUME END =  $6,908,792$  CU FT

$$\text{if } A_T = 9614 + \text{ft}^2$$

$$A_B = 112568 + \text{ft}^2$$

$$\therefore m = 184.37 \text{ ft}$$

TOTAL RH SALT STORED (when  $L = 1128.90$  ft)  $65,907,577$  CU FT

## FENIX &amp; SCISSON, INC.

TULSA, OKLAHOMA 74112


## DESIGN SHEET

COMPUTED BY: JC ASH

CHECKED BY:

CALCULATIONS FOR:

Preliminary Entry and Room Dimensions

SHEET 1 OF 1  
PROJECT NO. 200  
DATE: Sept 15, 1976

386

LADDER

90030044

FENIX & SCISSON, INC.

TULSA, OKLAHOMA 74112

COMPUTED BY: J L AHN

CHECKED BY

#### CALCULATIONS FOR

### PRELIMINARY ENTRY AND EXIT DIMENSIONS

## **DESIGN SHEET**

SUMMARY 2 OF \_\_\_\_\_

PROJECT NO. 88

BATH 5927 15 1976

CAMPGND: Oct. 5, 1924

327

90030045

J.L. Ross

Geological Observations


Sheet 3 of

Sept. 22, 1976

Corrected Oct. 5, 1976


Time M.S.T.	L	VERTICAL PASSAGES	HORIZONTAL PASSAGES
700 AM - 8	4'-0"	3 for 17'-11" ~ 50.0526 yrs to 18'-6" 18'-5 1/2"	1 for 32'-3" ~ 70.5590 yrs to 19' 2 for 49'-6" ~ 12.3895 yrs to 53' 3 for 66'-9" ~ 29.9188 yrs to 63'
8:15	4'-1"	2 for 16'-6 1/2" ~ 36.1817 yrs to 16'-6" 18'-5 1/2"	2 for 25'-7 1/2" ~ 42.1989 yrs to 33' 3 for 38'-5 1/2" ~ 42.2250 yrs to 35'
8:15	5'-3"	2 for 17'-8 1/2" ~ 8.1618 yrs to 16'-6" 18'-11 1/2"	2 for 25'-7 1/2" 3 for 38'-5 1/2"
8:15	5'-3"	2 for 46'-10 1/2" ~ 27.5725 yrs to 17'-0" 18'-11 1/2"	2 for 25'-7 1/2" 3 for 38'-5 1/2"
8:16	5'-6"	3 for 19'-5 1/2" ~ 37.7536 yrs to 17'-0" 18'-5"	2 for 25'-7 1/2" 3 for 38'-5 1/2"
8:19	5'-9"	3 for 21'-3 1/2" ~ 17.0599 yrs to 19'-6" 18'-9 1/2"	2 for 25'-7 1/2" 3 for 38'-5 1/2"
10:40	5'-1"	2 for 16'-6 1/2" ~ 36.1817 yrs to 18'-6"	2 for 27'-8" ~ 79.6683 yrs to 33' 3 for 40'-6" ~ 14.1673 yrs to 30'
	5'-3"	2 for 17'-8 1/2" ~ 8.1618 yrs to 16'-6"	2 for 27'-8" 3 for 40'-5"
	5'-6"	2 for 18'-10 1/2" ~ 27.5725 yrs to 17'-0"	2 for 27'-8" 3 for 40'-6"
	6'-0"	2 for 21'-3 1/2" ~ 19.9185 yrs to 19'-6" 18'-9 1/2"	2 for 27'-8" 3 for 41'-6"

Type 70046-9 Machines




AT 7'-0" RADIUS

Type 911A Machines




AT 5'-0" RADIUS


Type 1012ACD Machines




AT 5'-0" RADIUS



AT 5'-3" RADIUS




AT 5'-3" RADIUS




AT 5'-6" RADIUS



AT 5'-6" RADIUS



AT 6'-0" RADIUS



AT 6'-3" RADIUS



AT 6'-0" RADIUS

J.L. AKA

J. C. ASA

AARON CO. Oct. 29, 76

Sheet 5 of

Oct. 29, 1976

Let  $r$  be the radius of vertical passes and  $N$  be the number of horizontal passes. Then:

$$\text{Area} = \frac{\pi R^2}{2} + \frac{\pi r^2}{180} \text{Arcsin} \frac{d}{2r} + \frac{cd}{2} + 2(R - \frac{d}{2})c + (R - \frac{d}{2} - c)(c - d) + \frac{99.75}{90} (90 +$$

$$(R - \frac{d}{2} - c)(c - d) + cd + (cd + cd' + \frac{\pi R^2}{180} \text{Arcsin} \frac{d}{2r})(N-1) + [2(a+c)r + \frac{\pi R^2}{180} \text{Arcsin} \frac{d}{2r} +$$

$$(R-d)c + (a+cd)(r-1)](N-1)$$

$$\text{Area} = \frac{\pi R^2}{180} \left\{ 90 \left( 1 + \frac{196}{R^2} \right) + \left( \frac{19}{R} \right)^2 \text{Arcsin} \left( \frac{R - d - c}{2r} \right) + (2N-1) \text{Arcsin} \frac{d}{2r} + (N-1) \text{Arcsin} \frac{c}{R} \right\}$$

$$+ c(a+c)c - \frac{cd}{2} + (R-d)(c-d) + d[a + (a+cd)(N-1) + c](N-1) + [2(a+c)r + (R-d)c](N-1)$$

$$\text{Perimeter} = \pi R + \frac{\pi R^2 \text{Arcsin} \frac{d}{2r}}{90} + \frac{75}{90} \left( 90 + \text{Arcsin} \frac{R - d - c}{2r} \right) + c(a+c) + (N-1) \frac{\pi R^2 \text{Arcsin} \frac{d}{2r}}{90} +$$

$$(N-1) \left[ 2(a+c) + \frac{\pi R^2 \text{Arcsin} \frac{d}{2r}}{90} \right]$$

$$\text{Area} = \frac{\pi R^2}{90} \left\{ 90 \left( 1 + \frac{19}{R^2} \right) + \frac{\pi}{2} \text{Arcsin} \left( \frac{R - d - c}{2r} \right) + (2N-1) \text{Arcsin} \frac{d}{2r} + (N-1) \text{Arcsin} \frac{c}{R} \right\} + 2(a+c)N$$

#### CROSS-SECTIONAL AREAS IN SQUARE FEET AND PERIMETERS IN FEET

THREE 70' X 10' AT 50% SLOP FOR N=1 AND N=1.5	195.9977 ft <sup>2</sup>	AND	62.1377 ft
1	311.0930		71.9732
2	486.7383		81.7088
3	667.8370		106.9081
4	1187.7277		171.2673

THREE 70' X 10' AT 50% SLOP FOR N=1 AND N=1.5	155.5029 ft <sup>2</sup>	AND	57.8057 ft
1	202.1790		70.7594
2	479.6575		88.0573
3	685.8939		119.0060

THREE 70' X 10' AT 50% SLOP FOR N=1 AND N=1.5	102.3779 ft <sup>2</sup>	AND	59.1807 ft
1	295.9290		76.5099
2	597.9238		90.8073
3	719.9983		118.1810
4	929.9701		162.8280

390

90030048

FENIX & SCISSON, INC.  
TULSA, OKLAHOMA 74112

DESIGN SHEET

COMPUTED BY: V.C. ASH

CHECKED BY:

CALCULATIONS FOR: Amoco 1000' TCU Level Entry and Road Configurations

SHEET 6 OF 1

PROJECT NO: 288

DATE: OCT. 19 1976

COMPUTED BY: ASH DATE: OCT. 19 1976

	Front 700' A/W - 8	Front 911/A	Front 1042 A/C O
	AT R = 9'-0"	AT R = 5'-0"	AT R = 5'-0"
H'	1	1	1
H' "	1	1	1
H' "	8'-0"	10'-0"	10'-0"
H'-6"		9'-2 1/2"	9'-2 1/2"
W'	25'-9"	30'-1 1/2"	31'-6"
L'	32'-3"	35'-7 1/2"	37'-6"
X-SPEC			
AIR/4"	195.9977	155.5028	182.1700
H-6@ 3%	7'-5 1/2"	8'-4"	8'-4 1/2"
Y-4@ 5%			
L-4@ 3%	20'-9 1/4"	23'-11"	25'-2 1/4"
Y-4@ 5%"			
	8	8	8
N=	1	2	3
H'	17'-1 1/4"	18'-6 1/4"	18'-6 1/4"
H'-6"	16'-5 3/4"	15'-8 1/4"	15'-8 1/4"
W'	25'-9"	28'-3"	30'-1 1/2"
L'	32'-3"	34'-6"	36'-5 1/2"
X-SPEC			
AIR/4" =	986.7383	897.2330	1187.7277
Y-4@ 5%"	10'	10'	10'
Z-4@ 2%	18.90'	7.76'	5.176'
CAPAC.	18.90'	7.76'	5.176'
VEH/			
CAPAC.	58.0526	36.1817	36.1817
AIR/4"	72.5543	42.3845	49.1673
BURD.	60%	68%	75%
ROCK	81%	117%	163%
PLATE	81%	117%	163%
Safety Factor	2.00	2.00	2.00
Score Length	61'-0"	92'-9"	92'-5"
Total Score	50,200'	29,800'	45,500'
NUMBER Books	156	69	42
NUMBER Panels	12	8	6
Panel Length	48'-0 1/2"	47'-7 1/2"	48'-5 1/2"
Panel Vol.	6,727.72	6,806.58	6,817.52
Total Score	45,128.29	45,7,373.0	46,8,271.0
Total Vol.	50,089.013	49,696.983	49,713.081
Panel Weight	5'-9 1/4"	5'-9 1/4"	5'-11 1/4"
Panel Volume	5'-9 1/4"	5'-11 1/4"	5'-11 1/4"

SHEET 7 OF  
Oct 19, 1970

Let  $x$  = number of cars in a panel

$y$  = number of panels

$a$  = road width

$b$  = road length available for wash storage

$c$  = road length of each panel required for ramping at a 15% grade

$d$  = pillar height between panels

$e$  = pillar width

$f$  = pillar width between pillars

$g$  = distance from end of panels

$h$  = distance from end of pillars

$i$  = road width of entrance area

$j$  = overall length of entrance area

$k$  = total length of panels available for wash storage

$\ell$  = total width of panels

$m$  = the length of each panel required for ramping

$n$  = the distance of maximum width in entrance area

Then

$$M = 2(A+O)x + 3(E+F) - O$$

$$N = (2B + 4C + D + 2E + F - GC) \frac{y}{d} - \frac{G}{d} - \frac{F}{d}$$

$O = E + y$

$$P = (M - G) y + 3N$$

$$Q = C(C - R) xy$$

$$R = (C + \frac{f}{2}) y + (T + \frac{e}{2}) k$$

From these equations we deduce  $MN = PV$

and  $DN = PV$

392

R40026

90030050

SET 8 OF  
Oct. 19, 1976

Case I,  $M = 219.6x + 363.5$

$$N = (0.58 + 18.85)y - 71$$

Case II,  $M = 331.8x + 227.5$

$$N = (0.58 + 127.25)y - 89$$

Case III,  $M = 467.5x + 201.5$

$$N = (0.58 + 140)y - 119.5$$

Case IV,  $M = 482.375x + 325.5$

$$N = (0.58 + 108.875)y - 80$$

Case V,  $M = 363.875x + 303.5$

$$N = (0.58 + 119.375)y - 91$$

Case VI,  $M = 293.8x + 336$

$$N = (0.58 + 111.5)y - 82.5$$

Case VII,  $M = 312x + 315$

$$N = (0.58 + 116.75)y - 93$$

100030051 2487

$$B \leq 500 - 2(0.58y)$$

$$M \leq 3000$$

$$y \leq 3877$$

Then, for Case I,  $B \leq 386$  and  $0.58y \leq 151$  with  $x \leq 12$

Case II,  $B \leq 386$  and  $0.58y \leq 61$  with  $x \leq 8$

Case III,  $B \leq 386$  and  $0.58y \leq 41$  with  $x \leq 6$

Case IV,  $B \leq 386.5$  and  $0.58y \leq 111$  with  $x \leq 11$

Case V,  $B \leq 382.5$  and  $0.58y \leq 59$  with  $x \leq 8$

Case VI,  $B \leq 382.5$  and  $0.58y \leq 111$  with  $x \leq 11$

Case VII,  $B \leq 382.5$  and  $0.58y \leq 62$  with  $x \leq 9$

Corrected: Oct. 29, 1976

Sheet 9 of  
Oct 14, 1976

including the assumptions slightly to obtain more practical  
combinations of  $x$  and  $y$ , then for

Case I at  $x=10$  and  $y=12$ ;  $M = 3052 \text{ ft}$ ,  $N = 2586,9619 \text{ ft}$ ,

$T = 99,733,8856 \text{ ft}$ ,  $U = 17,784 \text{ ft}$ , and  $V = 90,089,013 \text{ ft}^3$

Case II at  $x=8$  and  $y=8$ ;  $M = 3875,5 \text{ ft}$ ,  $N = 2204 \text{ ft}$ ,

$T = 81,76 \text{ ft}$ ,  $U = 7,096 \text{ ft}$ , and  $V = 28,698,903 \text{ ft}^3$

Case III at  $x=7$  and  $y=5$ ;  $M = 3979 \text{ ft}$ ,  $N = 2339,0718 \text{ ft}$ ,

$T = 87,860,2856 \text{ ft}$ ,  $U = 9,788 \text{ ft}$ , and  $V = 27,131,091 \text{ ft}^3$

Case IV at  $x=11$  and  $y=10$ ;  $M = 2902,25 \text{ ft}$ ,  $N = 3125,1136 \text{ ft}$ ,

$T = 90,357,0544 \text{ ft}$ ,  $U = 8,525 \text{ ft}$ , and  $V = 36,708,726 \text{ ft}^3$

Case V at  $x=9$  and  $y=8$ ;  $M = 3438,375 \text{ ft}$ ,  $N = 2400,6667 \text{ ft}$ ,

$T = 33,105,6657 \text{ ft}$ ,  $U = 5,580 \text{ ft}$ , and  $V = 31,989,991 \text{ ft}^3$


Case VI at  $x=6$  and  $y=10$ ;  $M = 3910 \text{ ft}$ ,  $N = 3148,8636 \text{ ft}$ ,

$T = 84,744,4584 \text{ ft}$ ,  $U = 8,525 \text{ ft}$ , and  $V = 38,800,983 \text{ ft}^3$

Case VII at  $x=2$  and  $y=8$ ;  $M = 3811 \text{ ft}$ ,  $N = 3957,6667 \text{ ft}$ ,


$T = 81,317,5667 \text{ ft}$ ,  $U = 8,960 \text{ ft}$ , and  $V = 30,399,706 \text{ ft}^3$

**H. E. REIFFEL & SONS CO.** 46-0702  
10 x 10 to the right  
10 x 10 to the left



90030053

FILE 10 X 10 INCH 46 0702  
- 10 INCHES  
KELFEL & SONS CO



EDDIE

90030054

396

J. L. AEW

Proj. 288, 11-11-76

### Mining Rates for Boeins Machine

GOODMAN 926 CONTINUOUS SCRAPER CUTS A 72" HIGH X 198" WIDE OPENING WITH TWO 250 HP MOTORS. UNDER NORMAL CONDITIONS, THESE MACHINES CAN BE EXPECTED TO MINE AT AN AVERAGE RATE OF 1200  $\frac{\text{Ton}}{\text{day}}$  OR 400  $\frac{\text{Ton}}{\text{shift}}$  FOR 2-PASS OPENINGS.  
1-PASS = 87.122  $\frac{\text{ft}^2}{\text{hr}}$  AND 2-PASS = 146.859  $\frac{\text{ft}^2}{\text{hr}}$

TYPE 1012 A/C MARINETTA MINER CUTS A 120" HIGH X 216" WIDE OPENING WITH TWO 600 HP MOTORS. 1-PASS = 162.3779  $\frac{\text{ft}^2}{\text{hr}}$ , 2-PASS = 295.9290  $\frac{\text{ft}^2}{\text{hr}}$ , 3-PASS = 429.4701  $\frac{\text{ft}^2}{\text{hr}}$ ,  
PUNCH = 719.4933  $\frac{\text{ft}^2}{\text{hr}}$  AND GOOD ENTRANCE AVERAGES  $\frac{929.4701 + 719.4933}{2} = 574.9817 \frac{\text{ft}^2}{\text{hr}}$   
TWO MUNING RATE FOR THE MARINETTA TO BE  $2 \times 600 \times 87.122 \times 300 = 515 \frac{\text{Ton}}{\text{shift}}$  PER 800 OPENINGS.

$$\begin{aligned} \text{AT } 135 \frac{\text{ft}}{\text{ft}^2}, \text{ ENTRIES} &= \frac{395.9290 \times 135}{2000} = 19.9799 \frac{\text{Ton}}{\text{foot}} \text{ per } 142 \text{ ft} \text{ shift } \frac{\text{ft}}{\text{shift}} \text{ ADVANCE} \\ \text{GOOD ENTRANCE} &= \frac{574.9817 \times 135}{2000} = 38.7775 \frac{\text{Ton}}{\text{foot}} \text{ per } 13.2829 \frac{\text{ft}}{\text{shift}} \text{ shift } \frac{\text{ft}}{\text{shift}} \text{ ADVANCE} \\ \text{ROOM} &= \frac{719.4933 \times 135}{2000} = 48.5658 \frac{\text{Ton}}{\text{foot}} \text{ per } 10.6050 \frac{\text{ft}}{\text{shift}} \text{ shift } \frac{\text{ft}}{\text{shift}} \text{ ADVANCE} \\ \text{ROOM EXIT} &= \frac{429.4701 \times 135}{2000} = 28.9892 \frac{\text{Ton}}{\text{foot}} \text{ per } 17.7679 \frac{\text{ft}}{\text{shift}} \text{ shift } \frac{\text{ft}}{\text{shift}} \text{ ADVANCE} \end{aligned}$$

USE 20  $\frac{\text{Ton}}{\text{foot}}$ , 300  $\frac{\text{Ton}}{\text{shift}}$  AND 25  $\frac{\text{ft}}{\text{shift}}$  = 525  $\frac{\text{ft}}{\text{month}}$  ADVANCE PER MINER PER SHIFT

$$\begin{aligned} \text{FOR ENTRIES} \\ \frac{38.75(38.7775) + 426.25(48.5658) + 15.00(28.9892)}{38.75 + 426.25 + 15.00} &= \frac{32,638.6389}{480} = 71.1638 \frac{\text{Ton}}{\text{foot}} \text{ per } 142 \\ \text{HAVE} &= 10.8210 \frac{\text{ft}}{\text{shift}} \text{ ADVANCE. USE } 47.2 \frac{\text{Ton}}{\text{foot}}, 500 \frac{\text{Ton}}{\text{shift}} \text{ AND } 10.6 \frac{\text{ft}}{\text{shift}} = \\ &322.6 \frac{\text{ft}}{\text{month}} \text{ ADVANCE PER MINER PER SHIFT FOR ROOMS (USE } 45.283 \frac{\text{ft}}{\text{room}}). \end{aligned}$$

HAVE 64 ROOMS AND 31,800 FEET OF ENTRIES IN THE STORAGE AREA OF THE TCU LEVEL 50, USING TYPE 1012 A/C MARINETTA MINERS, WILL REQUIRE  
 $64(45.283) + \frac{31,800}{25} = 4170$  shifts TO MINE THE STORAGE AREA. ON A 31-DAY PER MONTH BASIS, THIS WILL REQUIRE 16 years, 6 months and 12 days FOR ONE MINER  
OR 8 years, 3 months and 6 days WITH TWO MINERS.

AERIAL EXTENT OF NAVING LEVELS

$$\begin{aligned}
 \text{1st Level Area} &= 3006.50(3919.63) + (3006.50 - 992.73)(533.56 + 532.10) + (2919.69 - \\
 &\quad 992.73)533.56 + 2919.69(992.73) + 0.5(992.73)533.56 + 0.5(532.10)532.10 + \\
 &\quad 0.5(532.10)(992.73)533.56 + 0.5(532.10 + 50.56)^2 \{ 1000^2 - [0.5(532.10 + 50.56)^2]^{1/2} \}^{1/2} + \\
 &\quad 1000^2 (400 \times 46) + 360 = 10,851,053.60 + 1,786,533.1380 + 1,867,583.1222 + \\
 &\quad 2,716,928.1890 + 57,578.5099 + 13,451,4800 + 239,915.9136 + 257,527.9090 + \\
 &\quad 100,103.8948 = 17,453,239.81 \text{ ft}^2 = 933.65 \text{ acres}
 \end{aligned}$$

$$\begin{aligned}
 \text{2nd Level Area used for storage} &= 8599(1080 + 1080.8) + 6,519,000 \text{ ft}^2 = 149,660 \text{ acres} \\
 &\text{or } 3,735.44 \text{ ha or } 93,746 \text{ m}^2
 \end{aligned}$$

$$\begin{aligned}
 \text{3rd Level Area} &= 3006.50(5565.50) + 1091.69(5565.50 - 2291.73) + (1091.69 + 1095.95 + \\
 &\quad 707.59)(2291.73 - 621.73) + 1091.69(621.73) + 0.5(621.73)1095.95 + 0.5(707.59)1091.69 + \\
 &\quad 1091.69(707.59) + 0.5(707.59)(1091.69) + 9,557,171.178 + 9,557,171.178 + \\
 &\quad 89,240.57 + 3,412,372.1178 + 3,787.181,519 + 1,323,683.557 + 24,941,259.16 \text{ ft}^2 = \\
 &\quad 571,95 \text{ acres}
 \end{aligned}$$


$$\begin{aligned}
 \text{4th Level Area used for storage} &= 1433.5(2269.5) + 2836.0(19)115.2 + \\
 &\quad 2(0.99 \times 0.98)115.2 = 9,228,363.75 + 6,196,662.00 + 103,071.00 = 9,488,193.75 \text{ ft}^2 \\
 &\quad 220.11 \text{ acres or } 30,988.3 \text{ m}^2 \text{ or the total}
 \end{aligned}$$

$$\begin{aligned}
 \text{Total Aerial Extent of Naving Areas} &= 532(1050) = 919,112.4 \text{ ft}^2 = 20,985.1 \text{ acres in volume} \\
 &= 532(1530) = 663,512.4 \text{ ft}^2 = 15,233.1 \text{ acres} \\
 &= 1433.5(3390) = 3,287,812.4 \text{ ft}^2 = 76,479.2 \text{ acres including}
 \end{aligned}$$

dry land area

90030056

398



$$\alpha = 29.5667^\circ$$

$$\beta = 95.5379^\circ$$

$$\gamma = 59.0959^\circ$$

$$\delta = 70.5152^\circ$$

$$\epsilon = 29.5575^\circ$$

$$\zeta = 74.4999^\circ$$

$$\eta = 57.7640^\circ$$

$$\iota = 59.1645^\circ$$

$$\rho = 5.9279^\circ$$

399


SC0001

90030057

AREA COMMON TO BOTH LEVELS =  $882.15(2914.69) + 599.52(2914.69 - 800.36) + (2914.69 -$   
 $621.73 - 599.52 - 932.15)(2914.69 - 800.36 - 50.56) + 1030.81(2914.69 - 136.37 - 1095.93 - 729.59 -$   
 $800.36 - 50.56) + 136.37(621.73) + 998.72(599.52 - 2291.73 - 5806.96 + 5565.50) +$   
 $0.5(621.73)1095.93 + 0.5(1030.81)729.59 + 0.5(333.56)998.72 + 0.5(532.10)50.56 +$   
 $0.5(599.52)800.36 + 0.5(532.10 + 50.56^2)^{1/2} \{ 1000 - [0.5(532.10 + 50.56^2)^{1/2}] \}^{2/3} +$   
 $1260^2 \pi (36) + 360 + 1000^2 \pi (\pm 0 + \pm 6) + 360 + 2291.73(5806.96 - 2914.69 - 2751.19 + 2666.25)$   
 $2,716,920,289 + 1,267,583,122 + 1,571,127,968 + 110,172,972.8 + 89,785,32 + 873,382,781.2 +$   
 $390,686,2795 + 373,457,309 + 15,722.8,5094 + 13,351,988 + 239,815,9136 + 257,527,9099 +$   
 $1,323,622,537 + 762,023,8914 + 16,512,7716 = 10,107,906.50 \text{ ft}^2 = 232.03 \text{ acres}$

$$\begin{aligned}
 \text{TOTAL AREA} &= 17,951,239.81 + 29,914,298.06 - 10,107,906.50 = 32,259,126.37 \text{ ft}^2 = \\
 &790.57 \text{ acres} \\
 &= 5565.50(2751.19 + 2914.69) + 3806.50(5806.96 - 5565.50) = 31,533,170.87 + \\
 &725,949.49 = 32,259,126.36 \text{ ft}^2 = 790.57 \text{ acres}
 \end{aligned}$$

$$\begin{aligned}
 \text{TOTAL AREA USED FOR STORAGE} &= 6,519,000 + 9,508,093.75 - 15,512,7716 = \\
 &16,091,580.98 \text{ ft}^2 = 369.91 \text{ acres OR } 49.0828\% \text{ OF THE TOTAL} \\
 &+ 914,112 \text{ ft}^2 = 20,985.1 \text{ acres OR } 8.0337\% \text{ OF THE TOTAL FOR THE} \\
 &\text{EXPERIMENTAL AREA} \\
 &= 17,005,698.98 \text{ ft}^2 = 390,397 \text{ acres OR } 52.7159\% \text{ OF THE TOTAL FOR BOTH}
 \end{aligned}$$



RECEIVED

January 7, 1977

JAN 14 1977

Fenix & Scissom, Inc.  
Post Office Box 15609  
Tulsa, Oklahoma 74115

FENIX &amp; SCISSOM, INC.

ATTENTION: MR. GEORGE SCHAEFER

SUBJECT: Hoist Estimates

**Process Machinery  
Division**

P.O. Box 383  
Milwaukee, WI 53201  
414/744-2345  
TELEX 2-6601

Dear Sir:

The following information will confirm what was provided to you via our phone conversation of 1/4/77:

HOIST DATA

DESCRIPTION	PRODUCTION	SERVICE	PRU SHAFT	RH SHAFT	ESCAPE
TYPE HOIST	D.D.	S.D.	S.D.	S.D.	S.D.
DISTANCE (FT)	3100	3000	2700	3000	3000
TPH	300	N.A.	N.A.	N.A.	N.A.
SAFETY FACTOR	5	5	5	4.5	5
ACC (FT/SEC <sup>2</sup> )	1	2	2	2	2
RETARD (FT/SEC <sup>2</sup> )	2	2	2	2	2
CREEP (SEC)	6	8	8	8	8
REST (SEC)	22	30	30	30	30
SKIP CAGE LOAD (TON)	13.12	12.5	12.5	10	1
VELOCITY (FPS)	28.72	8.33	8.33	8.33	8.33
SKIP (CAGE) WT. (TON)	9.84	9.37	15	7.5	0.75
ROPE (INCH)	2.0	1.875	2.125	1.625	0.75
DRUM DIA (INCH)	160	150	170	130	60
RMS H.P.	1859	188	308	723	87
PEAK H.P.	3120	387	765	961	133
MOTOR H.P.	900	400	400	700	Hyd. Drive
# OF MOTORS	2	1	1	1	1
1 LAYER WIDTH (INCH)	174	188	178	187	165
NORM CWT (TON)	N.A.	15.62	21.25	N.A.	N.A.
MAX. LOAD (TON)	N.A.	19.00	N.A.	N.A.	N.A.
MAX. CWT (TON)	N.A.	18.87	N.A.	N.A.	N.A.
ESTIMATED COST	\$1,297,000	\$568,000	\$644,000	\$567,000	\$215,000

We hope that this information will be of use to you in your work, and if any questions should arise, please do not hesitate to call. The delivery date can

(CONTINUED)

Fenix & Scianon  
Page 2  
1/17/77

be expected for the double drum hoist is 18-20 months-on all the other hoists, approximately 12 months. The estimated costs indicated above include the hoist mechanicals and the drive equipment.

Reynold is looking forward to working with you on this project and hopes to either be hearing from you or meeting with you in the near future.

Respectfully

William S. Brown  
Senior Sales Application Engineer  
Reynold Inc.  
Process Machinery Division  
Mine Hoist Department

RECEIVED

WEHAA

1/17/77

cc: Tom Kennedy

1/17/77 2:30 PM, P.D.

Enclosures

90030060



## RECEIVED

2-2-1977

February 28, 1977

Fenix & Scisson Inc.  
5805 East Fifteenth Street  
Tulsa, Oklahoma 74112

ATTENTION: MR. GEORGE SCHAEFER

SUBJECT: Hoist Estimate  
RE: Your Letter of 2/9/77

Dear Sir:

For purposes of hoist estimating your items A through F inclusive are part of our hoist estimate you received on 1/7/77. Under the paragraph titled "Production Hoist", the 3000' hoisting distance and the 3100' hoisting distance, we calculated would result in the same estimated hoist. The drum of 160" shown by us is with one layer; if you desire 96 inches, that would be in two layers with no change in the estimated cost. All other items in this paragraph are included in the estimate.

Under the paragraph entitled "Service Hoist" please find the following data:

HOIST DATA

<u>DESCRIPTION</u>	<u>SERVICE HOIST</u>	<u>TRU</u>
TYPE HOIST	Divided S.D.	S.D.
DISTANCE (FT)	3,000	2,300
SAFETY FACTOR	4.6	5
ACC (FT/SEC <sup>2</sup> )	2	2
RETARD (FT/SEC <sup>2</sup> )	2	2
CREEP (SEC)	8	8
REST (SEC)	60	300
CAGE LOAD (TON)	12.5	12.5
VELOCITY (FPS)	8.33	8.33
CAGE WGT (TON)	15	15
ROPE (INCH)	2	2
DRUM SIA (INCH)	160	160
TOTAL MOTOR H.P.	500	800
FACE WIDTH (INCH)	97	155
NORM CWT (TON)	21.25	N.A.
MAX LOAD (TON)	19	N.A.
MAX CWT (TON)	24.5	N.A.
ESTIMATING COST	\$634,000	\$718,000

(CONTINUED)

90030061

Fenix & Scisson  
Page Two  
2/28/77

RECEIVED

APR 2 1977

Under paragraph TRU Shaft and in regard to your question, the mine escape hoist in our letter of 1/7/77 is a single drum hoist with two ropes. If the second rope is a problem, why not go with an "out of balance" condition and eliminate the second rope and counterweight. The hoist that would meet this requirement is shown above and is much less expensive than a two drum arrangement.

Paragraphs "RH Shaft" and "Escape Hoist", please find the following:

<u>HOIST DATA</u>		
<u>DESCRIPTION</u>	<u>R.H. SHAFT</u>	<u>ESCAPE HOIST</u>
TYPE HOIST	Unbalanced S.D.	Unbalanced S.D.
DISTANCE (FT)	3000	3000
SAFETY FACTOR	4.5	5
ACC (FT/SEC <sup>2</sup> )	2	2
RETARD (FT/SEC <sup>2</sup> )	2	2
CREEP (SEC)	8	8
REST (SEC)	300	300
CAGE LOAD (TON)	12.5	1
VELOCITY (FPS)	8.33	8.33
CAGE WGT (TON)	9.375	1.4
ROPE (INCH)	1.75	0.75
DRUM DIA. (INCH)	140	60
TOTAL MOTOR H.P.	700	100
FACE WIDTH	95 (2 layers)	56 (3 layers)
ESTIMATED COST	\$592,000	\$245,000

The hydraulic escape hoist remains as shown in our 1/7/77 letter at an estimated \$215,000.

All estimated costs are considered as of April 1, 1977 including those provided in our January 7, 1977 letter.

We will be sending the mechanical and electrical components dimension data in a few days when they become available.

We trust that this information will be of use to you in your work.

Very truly yours,

William F. Brown  
Senior Sales Application Engineer  
Rexnord Inc.  
Process Machinery Division  
Mine Hoist Department

cc: T. Armesy  
B. Elsner

4041

90030062

Storage cycle for TRU Waste: Number of \*14,000

the skid carrying 24 drums will require the most

Step 1. clamp Lift-O-Matics onto 4 drums and 1.

Step 2. tram the 4 drums from the skid a maximum  
100 ft. @

Step 3. position to unclamp drums at storage

Step 4. lift load to maximum height and unclamp

Step 5. lower mast

Step 6. travel 100 ft. back to skid

Step 7. position to clamp 4 drums

Skid load is 24 drums

\*haulage times  
from "Haulage Cycle  
For TRU Waste"

- A. Haulage vehicle unloads loaded skid in storage room within 100 ft.
- B. Haulage vehicle trams empty skid out of room 1 min.
- C. Haulage vehicle travels between storage room and TRU shaft @ 0
- D. Haulage vehicle unloads empty skid at TRU shaft and loads loaded
- E. Haulage vehicle travels between TRU shaft and storage room @ 080
- F. Haulage vehicle trams loaded skid from storage room entrance to placement

This figure, 1980 ft., means that entrance to the storage room is less the time the haulage vehicle is ready to wait. However it would make no sense to shaft is the bottleneck. If the haulage room, it would be waiting on the cage all but the 3½ min. the haulage vehicle fork lift time. Therefore as long as the is not upset. One 14,000# capacity fork the TRU level for back up.

900300 63

\*see "Size of Fork Lift Required"

16. capacity fork lifts required

11/5/76 JHO

time to unload

ft off skid      elapsed time      3 sec.

m distance of  
78 fpm (5 mph)      14 sec.

site      10 sec.

drums      4 sec.

              3 sec.

              14 sec.

10 sec.

total time per 4 drums      58 sec.

to be conservative use 116 sec / 4 drums

24 drums /  $\frac{1}{4}$  drums/trip = 6 trips

116 sec/trip  $\times$  6 trips = 696 sec. = 11.6 min.

Note: the manufacturer of the Lift-O-Matic states that 80 drums can be unloaded out of a closed van two drums at a time and trammed 100 ft. in about 30 min.

80 drums /  $\frac{1}{2}$  drums/trip = 40 trips

$\frac{30 \text{ min}}{40 \text{ trips}} = .75 \text{ min/trip} = 45 \text{ sec/trip}$

Consider 12 min. the maximum time to unload skid with one fork lift




of placement site, and loads empty skid       $3\frac{1}{2}$  min.

80 fpm      X min.  
skid       $5\frac{1}{2}$  min. }  
fpm      X min. } time fork lift has to unload skid  
site      1 min. }

$$2X + 7\frac{1}{2} \text{ min.} \leq 12 \text{ min.}$$

$$2X \leq 4.5 \text{ min.} \rightarrow X \leq 2.25 \text{ min.} \quad 2.25 \text{ min} \times 880 \text{ fpm} = 1,980 \text{ ft.}$$


when the haulage distance between the TRU shaft and the then 1980 ft., the fork lift will not have the skid unloaded by return to the TRU shaft. The haulage vehicle would have to add another fork lift to unload more quickly, because the vehicle wasn't waiting on the fork lift in the storage the TRU shaft. During the 28 min. hoist cycle time, pounds loading and unloading skids in the storage room is effective fork lift can unload a skid in  $2\frac{1}{2}$  minutes, the cycle ft is adequate. A second fork truck will be kept on



Storage


Step  
Step  
Step  
Step  
Step  
tot

Consider  
empty pallet  
TRU shaft  
time : 5.5 m



Step 2: turn truck around (outside turning radius should be about 17.5 ft., so no problem) and position to back up and unload full pallet

elapsed time = 60 sec.



Step 3: unload full pallet convenient to fork lift, pull ahead and prepare to back over empty pallet

elapsed time = 60 sec.

#### room cycle

p 1	60 sec.
p 2	60 sec.
o 3	60 sec.
4	90 sec.
5	60 sec.
<u>all</u>	<u>330 sec. = 5.5 min.</u>

Use 5.5 min.

For the operation of unloading the truck and loading a full one at the storage room, it will require the same amount of time.

Unload empty pallet and load full one at TRU shaft	5.5 min.
Unload full pallet and load empty one at storage room	5.5 min.
Round trip travel time	X
total	<u>(11+X)</u> min.

Hoist cycle  $\approx$  28 min.  
Longest possible round trip travel time  $X = 28 - 11 = 17$  min.

use 10 mph = 880 ft/min

$$17 \text{ min} \times 880 \text{ ft/min} = 14,960 \text{ ft.} = 2.83 \text{ miles}$$

The longest round trip distance in the proposed facility is less than 2 miles, so one truck and trailer are adequate. A second truck and trailer will be kept on the TRU level for back up.

10/29/76  
JHO

#### Haulage Cycle For TRU Waste

90030066