

Central File

DEC 20 1979

Task Action Plan A-8

Docket Nos.: 50-358, 50-352/353, 50-367, 50-373/374, 50-387/388, 50-410,
50-322, 50-297

MEMORANDUM FOR: S. H. Hanauer, Director, Unresolved Safety Issues Program,
NRR

FROM: C. J. Anderson, A-8 Task Manager, Containment Systems Branch,
DSS

APPLICANT: Members of MARK II Owners Group

SUBJECT: MEETING WITH MARK II OWNERS TO DISCUSS LONG TERM PROGRAM STATUS

Background

The staff recently completed the review of alternate loads proposed by the MARK II owners as a part of the MARK II Lead Plant Program. With the completion of the review of these remaining Lead Plant Tasks, the staff has turned its attention to the review of the MARK II Long Term Program. The function of this meeting was to discuss the status of several of the Long Term Program tasks in advance of the final documentation of these tasks. These discussions were conducted to provide the staff and our consultants an opportunity to identify task problems prior to completion of the task.

The significant items discussed in the meeting included: the Creare multivent tests, the 4T condensation oscillation tests, the dynamics lateral load model, the improved chugging load, foreign tests and load combinations.

An attendance list and a copy of the meeting handouts are enclosed.

Summary

A summary of the discussions of the Long Term Program Tasks is provided below.

1. Generic Program Status Summary

Mr. Davis of General Electric provided an overview of the MARK II generic long term program. The total generic program, including the lead and Long Term Program (LTP), was approximately 85% complete at the end of October 1979. A detailed schedule was presented to show the status of milestones for several of the more important LTP tasks. A table of the LTP task documentation was also discussed. Documentation for the LTP LOCA related steam tests will not be available until the

OFFICE

SURNAME

DATE

8001250121

DEC 20 1979

S. H. Hanauer

- 2 -

third quarter of 1980. These late dates for task documentation jeopardize the staff's October 1979 schedule for completion of the LTP review.

Mr. Sobon of General Electric discussed the generic positions of the MARK II owners for the LTP. He identified those areas where the owner proposed deviating from the staff's lead plant acceptance criteria.

2. Creare Multivent Test Program - Task A.11

Mr. Patel of Creare discussed the status of the Creare multivent steam tests. The objective of this program is 1) to establish the trend of chugging wall loads with the number of vents to confirm that the lead plant approach utilizing single vent data is conservative and 2) to quantify the multivent effect in the LTP to allow refinement of the lead plant bounding load in the LTP. The first phase of this test program is complete. This includes multivent tests at 1/10 and 1/6 scale. The phase I test report will be submitted to the NRC in June 1980. The staff questioned the ability of the Creare tests to address phasing questions raised as a result of preliminary observations of related foreign tests.

3. Main Vent Lateral Loads - Task A.13

Mr. Davis of General Electric discussed the status of the A.13 vent lateral loads task. The lead plant criteria for lateral loads includes a very conservative static and dynamic load specification. The MARK II owners proposed a less conservative single vent dynamic lateral load for the LTP. The results of several large scale single and double vent tests were studied by the MARK II owners to confirm the MARK II owners' load specification. Preliminary results of the confirmatory study indicate that the proposed LTP dynamic lateral load is conservative.

In addition to the single vent dynamic lateral load studies, the MARK II owners have also conducted studies to extend the single vent dynamic lateral load for application to 28 in. downcomers and to multiple vents. A review of tests in different facilities with varying vent diameters (12 to 24 in.) indicates that the dynamic lateral load can be extrapolated to 28 in. vents. In addition, a statistical procedure similar to that utilized in the lead plant program was used to extend the single vent lateral load to a multivent dynamic lateral load specification.

A report documenting the results of the various dynamic lateral load subtasks is in preparation and will be submitted to the NRC in December 1979.

4. Generic Improved Chugging Load - A.16

The MARK II owners discussed the status of the milestones associated with completion of the generic improved chugging load task. The major task milestones have been completed. A final report documenting this task is currently scheduled to be submitted in February 1980. The staff stated that confirmation of the methodology, considering the results of the large scale multivent Japanese test, was important to resolve staff questions raised during previous meetings with the MARK II owners.

OFFICE

SURNAME

DATE

DEC 20 1979

S. H. Hanauer

- 3 -

5. 4T CO Tests - A.17

The purpose of these additional 4T tests is to resolve questions raised by the staff in NUREG 0487 dealing with vent length effects in establishing the condensation oscillation load specification.

Modification of the original 4T test facility has been completed. The shakedown tests and 9 scheduled tests have been completed. The total test matrix includes 23 tests at varying conditions of vent submergence, initial drywell air, content pool temperature, break size, break submergence and break type (i.e., steam and liquid). In addition, tests will be conducted to investigate the effect of a vent riser. The testing program is scheduled to be completed in February 1980. The MARK II owners plan to discuss preliminary observations from these tests some time during the first quarter of 1980. Preliminary observations from other related test programs indicate that some vent length related modifications to the original CO load specifications may be appropriate. This modification would probably consist of a load specification at frequencies in the 7 to 20 HZ range. However, insufficient analyses have been performed related to the foreign tests to establish the necessity of a change in the original CO load.

6. GKSS Tests

The GKSS large scale multivent, steam tests were discussed with the MARK II owners. This included a description of the test facility, the test matrix, testing schedule and preliminary observations of the completed shakedown tests. The staff noted the close phasing of the chugging events and the similarity of chugging events occurring at the exit of each vent during gross pool chugging. The staff emphasized the need for a MARK II generic task to include a review of the foreign large scale multivent tests to confirm the lead plant loads and provide a basis for the proposed LTP reduced loads.

7. Load Combinations - SRSS

A draft copy of the Brookhaven studies on response combination methodologies was released by the staff for comment in October 1979. The MARK II owners' comments related to the BNL report were presented by Dr. Kennedy. A copy of the presentation slides is attached. Dr. Hou of NRC stated that additional BNL studies would be required before Criterion 2 of the Newmark-Kennedy criteria could be accepted. However, he was optimistic about the ultimate acceptability of criterion 2. He stated that further efforts to evaluate the modified criterion 2 would probably be included in a future review program.

The MARK II owners stated that February 1980 appeared to be the best time for the next generic MARK II owners/NRC staff meeting. This meeting would probably include most of the topics discussed in this meeting.

Clifford J. Anderson, A-3 Task Manager

Containment Systems Branch
Division of Systems Safety

CSB:DSS

6Anderson:jpf

12/20/79 CJA

OFFICE

Enclosure:

As stated

DATE

Distribution:

See attached pages

Meeting Notice Distribution

Distribution:

Docket Files
NRR Reading File
CSB Reading file

H. Denton
E. Case
R. Boyd
R. DeYoung
D. Skovholt
W. Haass
R. W. Houston
P. Collins
D. Vassallo
J. Stolz
R. Baer
S. Varga
W. Gammill
C. Heltemes
T. Speis
D. Eisenhut
D. Crutchfield
P. Check
G. Lainas
A. Schwencer
D. Ziemann
B. Grimes
G. Knighton
T. Ippolito
R. Reid
J. Miller
R. Clark
F. Pagano
R. Mattson
F. Schroeder
J. Knight
R. Bosnak
S. Pawlicki
F. Schauer

D. Ross
T. Novak
K. Kniel
Z. Rosztoczy
R. Tedesco
S. Hanauer
V. Benaroya
W. Butler
R. Satterfield
F. Rosa
D. Muller
R. Voittmer
W. Kreyer
V. Moore
R. Ballard
W. Regan
M. Ernst
G. Lear
J. Youngblood
R. Denise
C. Stepp
J. Kudrick
J. Shapaker
NRC PDR
Local PDR
Receptionist
OELD
OSD
I&E (3)
R. Fraley, ACRS (3)
T. Su
C. Tan
C. Grimes
S. Fabic
R. Cudlin
M. Aycock
C. Anderson
A. Thadani

Mr. Earl A. Borgmann
Vice President - Engineering
The Cincinnati Gas and Electric Company
P. O. Box 960
Cincinnati, Ohio 45201

cc: Troy B. Conner, Jr., Esq.
Conner, Moore & Corber
1747 Pennsylvania Avenue, N. W.
Washington, D. C. 20006

Mr. William J. Moran
General Counsel
The Cincinnati Gas and Electric
Company
P. O. Box 960
Cincinnati, Ohio 45201

Mr. William G. Porter, Jr.
Porter, Stanley, Arthur
and Platt
37 West Broad Street
Columbus, Ohio 43215

Mr. Peter H. Forster, Vice
President
Energy Resources
The Dayton Power and Light
Company
P. O. Box 1247
Dayton, Ohio 45401

J. Robert Newlin, Counsel
The Dayton Power and Light
Company
P. O. Box 1034
Dayton, Ohio 45401

Mr. James D. Flynn
Manager, Licensing
Environmental Affairs
The Cincinnati Gas and
Electric Company
P. O. Box 960
Cincinnati, Ohio 45201

Mr. J. P. Fenstermaker
Senior Vice President - Operations
Columbus and Southern Ohio
Electric Company
215 North Front Street
Columbus, Ohio 43215

David B. Fankhauser, PhD
3569 Nine Mile Road
Cincinnati, Ohio 45230

Thomas A. Luebbers, Esq.
Cincinnati City Solicitor
Room 214, City Hall
Cincinnati, Ohio 45202

Mr. Stephen Schumacher
Miami Valley Power Project
P. O. Box 252
Dayton, Ohio 45401

Ms. Augusta Prince, Chairperson
601 Stanley Avenue
Cincinnati, Ohio 45226

Mr. Norman W. Curtis
Vice President - Engineering
and Construction
Pennsylvania Power and Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

Mr. Earle M. Mead
Project Engineering Manager
Pennsylvania Power & Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

Jay Silberg, Esq.
Shaw, Pittman, Potts &
Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Mr. William E. Barberich,
Nuclear Licensing Group Supervisor
Pennsylvania Power & Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

Edward M. Magel, Esquire
General Counsel and Secretary
Pennsylvania Power & Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

Bryan Snapp, Esq.
Pennsylvania Power & Light Company
901 Hamilton Street
Allentown, Pennsylvania 18101

Robert M. Gallo
Resident Inspector
P. O. Box 52
Shickshinny, Pennsylvania 18655

Susquehanna Environmental Advocates
c/o Gerald Schultz, Esq.
500 South River Street
Wilkes-Barre, PA 18702

John L. Anderson
Oak Ridge National Laboratory
Union Carbide Corporation
Bldg. 3500, P. O. Box X
Oak Ridge, Tennessee 37830

Mr. Robert J. Shovlin
Project Manager
Pennsylvania Power and Light Co.
2 North Ninth Street
Allentown, Pennsylvania 18101

Alan R. Yuspeh, Esq.
Shaw, Pittman, Potts &
Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Dr. Judith H. Johnsrud
Co-Director
Environmental Coalition on
Nuclear Power
433 Orlando Avenue
State College, PA 16801

Mr. Thomas M. Gerusky, Director
Bureau of Radiation Protection
Department of Environmental
Resources
Commonwealth of Pennsylvania
P. O. Box 2063
Harrisburg, PA 17120

Ms. Colleen Marsh
Box 538A, RD#4
Mountain Top, PA 18707

Mrs. Irene Lemanowicz, Chairperson
The Citizens Against Nuclear
Dangers
P. O. Box 377
RD#1
Berwick, PA 18503

Mr. Byron Lee, Jr.
Vice President
Commonwealth Edison Company
P. O. Box 757
Chicago, Illinois 60690

cc: Richard E. Powell, Esq.
Isham, Lincoln & Beale
One First National Plaza
2400
Chicago, Illinois 60670

Niagara Mohawk Power Corporation

ccs:

Arvin E. Upton, Esq.
LeBoeuf, Lamb, Leiby & MacRae
1757 M Street, N. W.
Washington, D. C. 20036

Anthony Z. Roisman, Esq.
Natural Resources Defense Council
917 15th Street, N. W.
Washington, D. C. 20005

Mr. Richard Goldsmith
Syracuse University
College of Law
E. I. White Hall Campus
Syracuse, New York 13210

T. K. DeBoer, Director
Technological Development Programs
New York State Energy Office
Swan Street Building
Core 1 - 2nd Floor
Empire State Plaza
Albany, New York 12223

Niagara Mohawk Power Corporation
ATTN: Mr. Gerald K. Rhode, Vice President
System Project Management
300 Erie Boulevard West
Syracuse, New York 13202

Northern Indiana Public Service Company

CCS:

Meredith Hemphill, Jr. Esq.
Assistant General Counsel
Bethlehem Steel Corporation
701 East Third Street
Bethlehem, Pennsylvania 18016

Northern Indiana Public Service Company
ATTN: Mr. H. P. Lyle, Vice President
Electric Production & Engineering
5265 Hohman Avenue
Hammond, Indiana 46325

William H. Eichhorn, Esq.
Eichhorn, Morrow & Eichhorn
5243 Hohman Avenue
Hammond, Indiana 46320

Edward W. Osann, Jr., Esq.
Wolfe, Hubbard, Leydid, Voit & Osann, Ltd.
Suite 4600
One IBM Plaza
Chicago, Illinois 60611

Robert J. Vollen, Esq.
109 North Dearborn Street
Chicago, Illinois 60602

Porter County, Izaak Walton
League of America, Inc.
Box 438
Chesterton, Illinois 46304

Michael I. Swygert, Esq.
25 East Jackson Boulevard
Chicago, Illinois 60604

Richard L. Robbins, Esq.
Lake Michigan Federation
53 West Jackson Boulevard
Chicago, Illinois 60604

Maurice Axelrad, Esq.
Lowenstein, Newman, Reis & Axelrad
1025 Connecticut Avenue, N. W.
Washington, D. C. 20036

James N. Cahan, Esq.
Russell Eggert, Esq.
Office of the Attorney General
188 Randolph Street
Chicago, Illinois 60602

Long Island Lighting Company

ccs:

Howard L. Blau, Esq.
Blau and Cohn, P.C.
217 Newbridge Road
Hicksville, New York 11801

Jeffrey Cohen, Esq.
Deputy Commissioner and Counsel
New York State Energy Office
Agency Building 2
Empire State Plaza
Albany, New York 12223

Energy Research Group, Inc.
400-1 Totten Pond Road
Waltham, Massachusetts 02154

Irving Like, Esq.
Reilly, Like and Schnieder
200 West Main Street
Babylong, New York 11702

J. P. Novarro
Project Manager
Shoreham Nuclear Power Station
P. O. Box 618
Wading River, New York 11792

W. Taylor Reveley, III, Esq.
Hunton & Williams
P. O. Box 1535
Richmond, Virginia 23212

Ralph Shapiro, Esq.
Cammer & Shapiro
No. 9 East 40th Street
New York, New York 10016

Edward J. Walsh, Esq.
General Attorney
Long Island Lighting Company
250 Old Country Road
Mineola, New York 11501

Mr. Edward G. Bauer, Jr.
Vice President & General Counsel
Philadelphia Electric Company
2301 Market Street
Philadelphia, Pennsylvania 19101

cc: Troy B. Conner, Jr., Esq.
Conner, Moore & Corber
1747 Pennsylvania Avenue, N. W.
Washington, D. C. 20006

W. William Anderson, Esq.
Deputy Attorney General
Room 512, Main Capitol Building
Harrisburg, Pennsylvania 17120

Frank R. Clokey, Esq.
Special Assistant Attorney General
Room 218, Towne House Apartments
P. O. Box 2063
Harrisburg, Pennsylvania 17105

Honorable Lawrence Coughlin
House of Representatives
Congress of the United States
Washington, D. C. 20515

Roger B. Reynolds, Jr., Esq.
324 Swede Street
Norristown, Pennsylvania 19401

Willard C. Hetzel, Esq.
312 Main Street
East Greenville, Pennsylvania 18041

Lawrence Sager, Esq.
Sager & Sager Associates
45 High Street
Pottstown, Pennsylvania 19464

Joseph A. Smyth
Assistant County Solicitor
County of Montgomery
Courthouse
Norristown, Pennsylvania 19404

Mr. Edward G. Bauer, Jr.

cc: Eugene J. Bradley
Philadelphia Electric Company
Associate General Counsel
2301 Market Street
Philadelphia, Pennsylvania 19101

Washington Public Power Supply System

cc:

Joseph B. Knotts, Jr., Esq.
Debevoise & Liberman
1200 Seventeenth Street, N. W.,
Washington, D. C. 20036

Richard Q. Quigley, Esq.
Washington Public Power Supply System
3000 George Washington Way
P. O. Box 968
Richland, Washington 99352

Nicholas Lewis, Chairman
Energy Facility Site Evaluation Council
820 East Fifth Avenue
Olympia, Washington 98504

Mr. O. K. Earle
Licensing Engineer
P. O. Box 968
Richland, Washington 99352

Mr. Neil O. Strand
Washington Public Power Supply System
3000 George Washington Way
P. O. Box 968
Richland, Washington 99352

MARK II Meeting
MARK II Owners Group/NRC
November 14, 1979

<u>Name</u>	<u>Organization</u>
C. J. Anderson	NRC/DSS/CSB
W. M. Davis	GE
P. D. Hedgecock	WPPSS
J. A. Weyandt	Bechtel Power Corp.
D. F. Roth	Penna. Power & Light
D. L. Baker	Burns and Roe, Inc.
E. L. McFarland	Bechtel Power Corp.
D. M. O'Connor	Bechtel Power Corp.
H. W. Vollmer	Philadelphia Electric Co.
R. F. McClelland	GE
C. A. Malovrn	Stone & Webster
R. L. O'Mara	Stone & Webster
J. C. Black	GE
R. D. Hoagland	GE
C. Calderon	CNSNS
B. R. Patel	Creare, Inc.
C. Arredondo	CNSNS/Mexico
L. C. Ruth	NRC/DSS/CSB
J. A. Kudrick	NRC/DSS/CSB
W. R. Butler	NRC/DSS/CSB
R. Trevino	CNSNS/Mexico
L. V. Sobon	GE
M. R. Granback	NIPSCO
J. E. Metcalf	S&W
J. C. Herman	Cincinnati Gas & Elec. Co.
K. J. Green	Sargent and Lundh
R. J. Muzzy	GE
A. J. Bilanin	Continuum Dynamics
Ain A. Sonin	MIT (for BNL)
John R. Lehner	BNL
John E. Torbeck	GE
Harry R. Johnson	Ebasco
T. Zozueta	CFE
G. T. Kitz	S&L
F. C. Rally	GE
G. Avellone	Burns & Roe
T. Y. Chow	S&W
R. K. Mattu	NRC/DSS/MEB
T. Trocki	GE
J. Ogden	NMPC
C. V. Subramanian	GE
J. S. Abel	Commonwealth Edison
L. Memula	Bechtel Power Corp.
Dr. Kennedy	EDAC
R. Bosnak	NRC/DSS/MEB
Shou-hien Hou	NRC/DSS/MEB
H. Chau	Long Island Lighting Co.
L. C. S. Nien	Stone & Webster

MARK II OWNERS GROUP/NRC
MEETING AGENDA

DATE: NOVEMBER 14, 1979

TIME: 8:30 A.M. - 4:00 P.M.

PLACE: BETHESDA, MD. MARYLAND NATIONAL BANK BLDG. , Room 6110

<u>TIME</u>	<u>TOPIC</u>
8:30 AM	o GENERIC PROGRAM STATUS SUMMARY <ul style="list-style-type: none">• FLOW CHARTS AND OVERALL SCHEDULE• NRC CRITERIA POSITIONS
10:00 AM	o A.11 CREARE MULTIVENT - STATUS <ul style="list-style-type: none">• OVERVIEW• TEST DATA UPDATE
10:20 AM	o BREAK
10:30 AM	o A.13 MAIN VENT LATERAL LOADS <ul style="list-style-type: none">• RESULTS OF DATA CORRELATION• MULTIVENT APPLICATION
12:00 NOON	o LUNCH
1:00 PM	o A.16 IMPROVED CHUG LOAD DEFINITION - STATUS
1:15 PM	o A.17 4T C.O. TEST - STATUS <ul style="list-style-type: none">• OVERVIEW• RESULTS TO DATE
1:45 PM	o ATWS - "T" QUENCHER INFORMATION

WMD/DH 11/79

MK II OWNERS GROUP/NRC - MEETING AGENDA
NOVEMBER 14, 1979 - BETHESDA, MD.

<u>TIME</u>	<u>TOPIC</u>
2:00 PM	o BREAK
2:30 PM	o GKSS STAFF DISCUSSION
2:45 PM	o LOAD COMBINATIONS
	o SRSS
3:15 PM	o NRC POSITIONS ON MK II SUBMITTALS
	o NUREG 0487 UPDATE
	o USE OF "B" LIMITS FOR NSSS FATIGUE EVALUATION OF LOAD CASE 2
	o FUNCTIONAL CAPABILITY
	o SRSS SCHEDULE FOR RESOLUTION

WMD/HD
11/79

MARK II CONTAINMENT PROGRAM

TASK STRUCTURE SUMMARY

TOTAL NUMBER OF TASKS _____ ~ 101

<u>MARK II PLANT APPLICATION</u>	<u>% OF TOTAL TASKS</u>
LEAD PLANT SER	8
NON-LEAD PLANT	32
COMBINATION OF PLANT CATEGORIES	34
CONFIRMATORY	12
INFORMATIONAL	14
TOTAL	<u>100%</u>


NOV 1979 COMPLETION STATUS:

(BASED ON COST WEIGHTING)

o OVERALL PROGRAM 85%

WMD:PES/837
10/26/79


PK II CONTAINMENT PROGRAM



64/01
0351

HK II CONTAINMENT PROGRAM

☐ EFFORT COMPLETE
☐ EFFORT IN PROCESS



ANALYTICAL
MODELS

LOCA/RADIATION
AIR BUBBLE
A.5
NEGO/NEOE-21471
APPLIC. MEMO. 21730 CH.2

LOCA/RADIATION
WATER JET
A.5
NEGO/NEOE-21472
APPLIC. MEMO. 21730 CH.3



QUENCHER WATER JET
PLANT UNIQUE

QUENCHER
AIR BUBBLE
A.5
PLANT UNIQUE


LOCA STEAM
CONDENSATION
PLANT UNIQUE

TRAINING VORTEX
MODEL APPROACH
A.5.5 LTR. REPT.

DFFR
C.1

 EFFORT COMPLETE
 EFFORT IN PROCESS

RESCUE ACTIVITIES




EFFORT COMPLETE
EFFORT IN PROCESS

MARK II GENERIC PROGRAM SCHEDULE

LOCA RELATED ACTIVITIES

A.5.5 RING VORTEX MODEL




1981
60% COMPLETE

A.11 SUBSCALE MULTIVENT TESTING




82% COMPLETE

A.13 EXTENSION-LATERAL LOADS ANAL.



90% COMPLETE

A.16 IMPROVED CHUG LOADS



90% COMPLETE


A.17 CONDENSATION OSCILLATION TESTS



55% COMPLETE

S/RV RELATED ACTIVITIES


B.5 CAORSO QUENCHER TESTS



90% COMPLETE


MISCELLANEOUS ACTIVITIES

C.0 PROGRAM ACTION PLAN UPDATE



100% COMPLETE

C.5.3 H/K SRSS SUPPLEMENT




92% COMPLETE

C.6 NRC ROUND 2 QUESTIONS




90% COMPLETE

C.9 WORLD TEST MONITORING




95% COMPLETE

C.12 NRC QUESTIONS 20.43/20.59



97% COMPLETE

C.15 NRC SUBMERGED STRUCTURES CRITERIA



WMD:PES/CP-75, SH 5

10/26/79

MARK II CONTAINMENT - SUPPORTING PROGRAM
LOCA-RELATED TASKS

TASK NUMBER	ACTIVITY	ACTIVITY TYPE	TARGET COMPLETION	DOCUMENTATION	DATE DOC/SUBM	LEAD PLANT SER/ INTERMED PLANT
A. 1	"41" TEST PROGRAM	Phase I Test Report Phase I Appl Memo Phase II & III Test Rpt Application Memorandum	Completed Completed Completed Completed	NEBO/NEDE 13442-P-01 Application Memo NEBO/NEDE 13468-P NEBO/NEDE 23678-P	5/76 - 5/76 6/76 - 6/76 12/76 - 1/77 1/77 - 2/77	IP SER/IP IP SER/IP IP SER/IP IP SER/IP
A. 2	POOL SWELL MODEL REPORT	Model Report	Completed	NEBO/NEDE 21544-P	12/76 - 2/77	IP SER/IP
A. 3	IMPACT TESTS	PSIF 1/3 Scale Tests Mark I 1/12 Scale Tests	Completed Completed	NEBO/NEDE 13426-P NEBO/NEDE 20989-2P	8/75 - 9/75 9/75 - 11/75	IP SER/IP IP SER/IP
A. 4	IMPACT MODEL	PSIF 1/3 Scale Tests Mark I 1/12 Scale Tests	Completed Completed	NEBO/NEDE 13426-P NEBO/NEDE 20989-2P	8/75 - 9/75 9/75 - 11/75	IP SER/IP IP SER/IP
A. 5	LOADS ON SUBMERGED STRUCTURES	LOCA/RI Air Bubble Model LOCA/RI Water Jet Model Ring Vortex Model Applications Methods 1/4 Scaling Tests Steam Condensation Methods	Completed Completed Completed Completed Complete -	NEBO/NEDE 21471-P NEBO/NEDE 21472-P Letter Report Topical Report NEBO/NEDE 21730-P NEDE 23817-P Plant DAR's	9/77 - 1/78 9/77 - 1/78 5/79 - 5/79 12/77 - 1/78 9/78 - 12/78	IP SER/IP IP SER/IP IP/IP IP IP SER/IP Info IP SER/IP
A. 6	CHUGGING ANALYSIS AND TESTING	Single Cell Report Multivent Model 41 LSI Report	Completed Completed Completed	NEBO/NEDE 23703-P NEBO/NEDE 21669-P NEBO/NEDE 23710-P	9/77 - 11/77 2/78 - 3/78 4/78 - 3/78	IP SER IP IP SER
A. 7	CHUGGING SINGLE VENT	CRACK Report	Completed	NEBO/NEDE 23851-P	5/78 - 7/78	Info.
A. 9	EPRI TEST EVALUATION	EPRI-41 Comparison	Completed	NEBO 21667	8/77 - 9/77	IP SER*
-	EPRI 1/13 SCALE TESTS	3D Tests	Completed	EPRI NP-441	4/77 - --	IP SER*
-	EPRI SINGLE CELL TESTS	Unit Cell Tests	4Q 79	EPRI Report		Info
A. 11	MULTIVENT SUBSCALE TESTING AND ANALYSIS	Preliminary MV Prog Plan MV Test Program Plan & Proc. - Phase I Phase I Test Report MV Test Prog Plan & Proc. - Phase II Phase II Test Report CORMAP Tests NRI Verification 1/10 Scale	Completed Completed 4Q 79 4Q 79 2Q 80 Completed Completed Completed	NEBO 23697 NEBO 23697 Rev 1 Report NEBO 23697, Rev. 1, Supp. 1 Report Report NEDE 25116-P	12/77 - 1/78 1/79 - 4/79 6/79 - 8/79 5/79 - 7/79	IP SER/IP IP IP IP Info. Info.
A. 13	SINGLE VENT LATERAL LOADS	Dynamic Analysis Summary Report Summary Report (Extension)	Completed Completed 4Q 79	NEBO 24106-P NEDE 23806-P Report	3/78 - 7/78 10/78 - 11/78	IP IP
A. 16	IMPROVED CHUGGING LOAD DEFINITION	Impulse Evaluation Improved Chug Load Defn.	Completed 1Q 80	Letter Report Report	6/78 - 7/78	IP SER* IP
A. 17	STEAM CONDENSATION OSCILL. CO LOAD DEFINITION	41 C.O. Test C.O. Data Evaluation	3Q 80 3Q 80	Report Report		IP IP/IP

MARK II CONTAINMENT - SUPPORTING PROGRAM
SRV - RELATED TASKS

TASK NUMBER	ACTIVITY	ACTIVITY TYPE	TARGET COMPLETION	DOCUMENTATION	DATE DOC/SUBM	LEAD PLANT SER/ INTERMED PLANT
B.1	QUENCHER EMPIRICAL MODEL	DIFR Model Supporting Data	Completed Completed	NEBO/NEDE 21061-P NEBO/NEDE 21078-P	9/76 - 9/76 5/75 - 7/75	IP IP
B.2	RAMSHED MODEL	DIFR Model Supporting Data Analysis	Completed Completed Completed	NEBO/NEDE 21061-P NEBO/NEDE 21062-P NEBO/NEDE 20942-P	9/76 - 9/76 7/75 - 10/75 5/75 - 7/75	IP SER IP SER IP SER
B.3	MONTICELLO IN-PLANT S/RV TESTS	Preliminary Test Rpt. Hydrodynamic Report	Completed Completed	NEBO/NEBC 21465-P NEBO/NEBC 21581-P	12/76 - 1/77 8/77 - 8/77	IP SER IP SER
B.5	S/RV QUENCHER IN-PLANT CAHNSO TESTS	Test Plan Test Plan Addendum 1 Test Plan Addendum 2 Test Summary Test Report Test Report	Completed Completed Completed Completed Completed In Prog	NEBM 20988 Rev. 2 NEBM 20988 Rev. 2, Add 1 NEBM 20988 Rev. 2, Add 2 Letter Report NEBO/NEDE-25100-P Report	12/76 - 3/77 10/77 - 3/78 4/78 - 7/78 3/79 - 3/79 5/79 - 6/79	IP IP IP IP IP IP
B.6	THERMAL MIXING MODEL	Analytical Model	Completed	NEBO/NEBC 23689-P	3/78 - 3/78	Info.
B.10	MONTICELLO FSI	Analysis of FSI	Completed	NEBO 23834	6/78 - 7/78	IP SER
B.11	DIFFER RAMSHED MODEL TO MONTICELLO DATA	Data/Model Comparison	Completed	NSC-GIN 0394	9/77 - 10/77	IP SER
B.12	RAMSHED SRV METHODOLOGY SUMMARY	Analytical Methods	Completed	NEBO 24070	10/77 - 11/77	IP SER



MARK II CONTAINMENT - SUPPORTING PROGRAM
MISCELLANEOUS TASKS

TASK NUMBER	ACTIVITY	ACTIVITY TYPE	TARGET COMPLETION	DOCUMENTATION	DATE DOC/SUBM	LEAD PLANT SER/ INTERMED PLANT
C. 8	SUPPORTING PROGRAM	Supp Prog Rpt Supp Prog Rpt Rev. 1 Supp Prog Rpt Rev. 2 →	Completed Completed 2Q00	NE DO 21297 NE DO 21297 - Rev. 1 NE DO 21297 - Rev. 2	5/76 - 6/76 4/78 - 4/78	- -
C. 1	DIR REVISIONS	Revision 1 Revision 2 Revision 3	Completed Completed Completed	NE DO/NE DE 21061-P Rev. 1 NE DO/NE DE 21061-P Rev. 2 NE DO/NE DE 21061-P Rev. 3	9/75 - 4/76 9/76 - 9/76 6/78 - 6/78	- - -
C. 3	NRC ROUND 1 QUESTIONS	DIR Rev. 2 DIR Rev. 2 Amendment 1 DIR Rev. 3, Appendix A	Completed Completed Completed	NE DO/NE DE 21061-P Rev. 2 NE DO/NE DE 21061-P Rev. 2 Amend. 1 NE DO/NE DE 21061-P Rev. 3 Appendix A	9/75 - 9/76 12/76 - 2/77 6/78 - 5/79	IP SER*/IP IP SER*/IP IP SER*/IP
C. 5	SRSS JUSTIFICATION	Interim Report SRSS Report SRSS Exec. Report SRSS Criteria Appl. SRSS Bases SRSS Justification Suppl. →	Completed Completed Completed Completed Completed 4Q 79	(NE DE 24010) NE DO/NE DE 24010-P Summary Report NE DO/NE DE 24010-P Suppl. 1 NE DO/NE DE 24010-P Suppl. 2 Report	4/77 - 3/77 7/77 - 8/77 4/78 - 5/78 10/78 - 11/78 12/78 - 2/79	IP SER*/IP IP SER*/IP IP SER*/IP IP/IP IP/IP
C. 6	NRC ROUND 2 QUESTIONS	DIR Amendment 2 DIR Amend 2, Suppl 1 DIR Amend 2, Suppl 2 DIR Rev. 3, Appendix A →	Completed Completed Completed 4Q 79	NE DO/NE DE 21061-P Rev. 2 Amend. 2 NE DO/NE DE 21061-P Rev. 2 Amend. 2 Suppl. 1 NE DO/NE DE 21061-P Rev. 2 Amend. 2 Suppl. 2 NE DO/NE DE 21061-P, Rev. 3 Appendix A	6/77 - 7/77 8/77 - 9/77 9/77 - 11/77	IP SER*/IP IP SER*/IP IP SER*/IP IP SER*/IP
C. 7	JUSTIFICATION OF "41" BOUNDING LOADS	Chugging loads Justification	Complete Complete Complete Complete Complete Complete Complete	NE DO/NE DE 23617-P NE DO/NE DE 24013-P NE DO/NE DE 24014-P NE DO/NE DE 24015-P NE DO/NE DE 24016-P NE DO/NE DE 24017-P NE DO/NE DE 23627-P	7/77 - 8/77 6/77 - 8/77 6/77 - 8/77 6/77 - 8/77 6/77 - 8/77 6/77 - 8/77 6/77 - 8/77	IP SER/IP IP SER/IP IP SER/IP IP SER/IP IP SER/IP IP SER/IP IP SER/IP
C. 8	S/RV AND CHUGGING ISI	Prestressed Concrete Reinforced Concrete Steel	Completed	NE DO/NE DE 21936-P	7/78-7/78	IP SER/IP
C. 9	EXHIBITOR WORLD TESTS	Monitor Tests →	2Q00	None		
C. 13	LOAD COMBINATIONS & FUNCTIONAL CAPABILITY CRITERIA	Criteria Justification	Completed	NE DO 21985	9/78 - 12/78	IP
C. 14	NRC ROUND 3 QUESTIONS	Letter Report DIR Rev. 3, Appendix A	Completed	Letter Report NE DO/NE DE 21061-P Rev. 3 Appendix A	6/78 - 6/78 6/78 - 5/79	IP SER*/IP IP SER*/IP
C. 15	SUBMERGED STRUCTURE CRITERIA	NRC Question responses →	4Q 79	Letter Report		IP

* Submitted in response to NRC question.

IP SER: Zimmer, LaSalle, Shoreham
IP: All Other Plants

NRC ACCEPTANCE CRITERIA
MARK II POOL DYNAMIC LOADS
(NUREG 0487, 10/78)

MARK II PROGRAM CLOSURE STATUS

I. LOCA RELATED HYDRODYNAMIC LOADS

A. SUBMERGED BOUNDARY LOADS DURING VENT CLEARING
33 psi over-pressure added to local hydrostatic
below vent exit (walls and basemat) - linear
attenuation to pool surface.

B. POOL SWELL LOADS

1. Pool Swell Analytical Model (PSAM)

- a. Air Bubble Pressure - Use PSAM described
in NEDE-21544-P.
- b. Pool Swell Elevation - Use PSAM described
in NEDE-21544-P with polytropic exponent
of 1.2 for wetwell air compression.
- c. Pool Swell Velocity - Use PSAM described
in NEDE-21544-P multiplied by a factor
of 1.1.
- d. Pool Swell Acceleration - Use PSAM
described in NEDE-21544-P.
- e. Wetwell Air Compression - Use PSAM
described in NEDE-21544-P.
- f. Drywell Pressure History - Unique based
on NEDM-10320 or equivalent model.

I.A. 24 psi overpressure statically applied with
hydrostatic pressure to surfaces below vent
exit (attenuate to 0 psi at pool surface)
for period of vent clearing per March 20,
1979 letter from GE.

I.B.1.a. NUREG 0487 acceptable, no additional NRC
review anticipated.

I.B.1.b. Use PSAM with polytropic exponent of 1.2
to a maximum swell height which is the
greater of 1.5 vent submergence or the
elevation corresponding to the drywell
floor uplift ΔP used for design assess-
ment per response to question 020.68 and
February 16, 1979 letter from Shoreham.

I.B.1.c. NUREG 0487 acceptable, no additional NRC
review anticipated.

I.B.1.d. NUREG 0487 acceptable, no additional NRC
review anticipated.

I.B.1.e. NUREG 0487 acceptable, no additional NRC
review anticipated.

I.B.1.f. NUREG 0487 acceptable, no additional NRC
review anticipated.

NRC ACCEPTANCE CRITERIA
MARK II POOL DYNAMIC LOADS
(NUREG 0487, 10/78)

MARK II PROGRAM CLOSURE STATUS

I.B. POOL SWELL LOADS (cont.)

2. Loads on Submerged Boundaries

Maximum bubble pressure predicted by PSAM is to be added uniformly to local hydrostatic below vent exit (walls and basemat) and linear attenuation to pool surface. Apply to walls up to maximum pool swell elevation.

3. Impact Loads

- a. Small Structures - (For horizontal pipes, I-beams, and other similar structures having one dimension < 20 in.) The loading function shall have the versed sine shape:

$$p(t) = 0.5 P_{\max} (1 - \cos 2\pi \frac{t}{\tau})$$

where: p = pressure acting on the projected area of the structure, psi

$$P_{\max} = 1.35 \frac{2 I_p}{\tau}, \text{ psi-sec}$$

where: $I_p = \frac{M_H}{A} \cdot \frac{V}{(32.2)(144)} \text{ psi-sec}$

$\frac{M_H}{A}$ = hydrodynamic mass per unit area obtained from Figure 6-8 in NEDE-13426-P

V = impact velocity from I.B.1.c.

I.B.2 NUREG 0487 acceptable, no additional NRC review anticipated.

I.B.3.a. NUREG 0487 acceptable, no additional NRC review anticipated. See Table 1 for plant unique information.

NRC ACCEPTANCE CRITERIA
MARK II POOL DYNAMIC LOADS
(NUREG 0487, 10/78)

MARK II PROGRAM CLOSURE STATUS

I.B POOL SWELL LOADS (cont.)

$$r = \frac{0.0463D}{V}, \text{ for cylindrical targets}$$

$$r = \frac{0.011W}{V}, \text{ for flat targets with } > 7 \text{ ft/sec}$$

$$r = 0.016W, \text{ for flat targets with } < 7 \text{ ft/sec}$$

D = diameter of cylindrical pipe, feet
W = width of flat structure, feet

NOTE: The masses of the impacted structures to be adjusted by adding the hydrodynamic masses of impact when performing the structural dynamic analysis with "rigid body" impact loads applied.

b. Large Structures - Plant unique calculation required where applicable.

c. Grating - The static drag load, F_{SS} , is to be calculated by forming the product of ΔP from Figure 4-40 of NEDO-21060, Rev. 2, and the total area of the grating. To account for the dynamic nature of the initial loading, the static drag load is increased by a multiplier given by:

$$\frac{F_{SE}}{D} = 1 + \sqrt{1 + (0.0064Wt)^2}$$

I.B.3.b. NUREG 0487 criteria not applicable, no large structures in pool swell zone.

I.B.3.c. NUREG 0487 acceptable, no additional NRC review anticipated. See Table 1 for plant unique information.

NRC ACCEPTANCE CRITERIA
MARK II POOL DYNAMIC LOADS
(NUREG 0487, 10/78)

MARK II PROGRAM CLOSURE STATUS

I.B.3 Impact Loads (cont.)

where: F_{SE} = static equivalent load
 W = width of grating bars, inches
 f = natural frequency of lowest mode, Hz
 D = static drag load

NOTE: Applies for grating with open area $\geq 60\%$ and $Wf < 2000$ in/sec

4. Wetwell Air Compression

- a. Wall loads - Directly apply the PSAM calculated pressure due to wetwell compression.
- b. Diaphragm Upward Load - Calculate ΔPUP using the correlation:

$$\Delta PUP = 8.2 - 44F, \text{ for } 0 \leq F \leq 0.13$$

$$\Delta PUP = 2.5 \text{ psi, for } F > 0.13$$

$$\text{where: } F = \frac{AB \cdot AP \cdot VS}{VD \cdot (AV)^2}$$

AB = break area

AP = net pool area

AV = total vent area

VS = initial wetwell air space volume

VD = drywell volume

- I.B.4.a. NUREG 0487 acceptable, no additional NRC review anticipated.
- I.B.4.b. NUREG 0487 acceptable, no additional NRC review anticipated.

NRC ACCEPTANCE CRITERIA
MARK II POOL DYNAMIC LOADS
(NUREG 0487, 10/78)

MARK II PROGRAM CLOSURE STATUS

I.B POOL SWELL LOADS (cont.)

5. Asymmetric Load

Apply the maximum air bubble pressure calculated from PSAM and a minimum air bubble pressure (zero increase) in a worst case distribution to the wetwell wall.

I.B.5 Use twice the 10% of maximum bubble pres. statically applied to 1/2 of the submerged boundary (with hydrostatic pressure) proposed in March 16, 1979 letter from GE.

I.C STEAM CONDENSATION AND CHUGGING LOADS

1. Downcomer Lateral Loads

a. Single Vent Loads

- A static equivalent load of 8.8 KIPs shall be used provided:
 - (i) the downcomer is 24 inches in diameter
 - (ii) the downcomer dominant natural frequency is ≤ 7 Hz, submerged
 - (iii) the downcomer is unbraced or braced at or above approx. 8 ft. from the exit
- A static equivalent load of 8.8 KIPs multiplied by the ratio of the natural frequency and 7 Hz for dominant natural frequencies between 7 and 14 Hz. Other restrictions in (i) and (iii) apply.
- If the natural frequency of the downcomer is > 14 Hz or if bracing is closer than 8 ft. above the exit, a plant specific dynamic structural calculation shall be performed using a dynamic load defined by:

I.C.1.a. Task A. 13, "Single Vent Lateral Loads" for dynamic analysis. NEDE 24106-P has been submitted to NRC. Supplemental information is scheduled for submittal in 4Q79. See Table 1 for plant unique information.

NRC ACCEPTANCE CRITERIA
MARK II POOL DYNAMIC LOADS
(NUREG 0487, 10/78)

MARK II PROGRAM CLOSURE STATUS

I.C.1 Downcomer Lateral Loads (cont.)

a. cont.

$$F(t) = F_0 \sin \frac{\pi t}{\tau}; 0 < t < \tau$$

$$= 0; \text{ for } t < 0 \text{ and } t > \tau$$

where: 2 msec < τ < 10 msec, and the impulse
 $I = 2 F_0 (\tau/\pi)$ is 200 lbf-sec.
Restriction (i) also applies.

b. Multiple Vent Loads

Use the load specified in Figure 4-10b of NEDE-21061-P, Rev. 2, multiplied by a factor of 1.26 for downcomers with natural frequencies that are ≤ 7 Hz. For natural frequencies > 7 Hz, apply an additional multiplier equal to the ratio of its frequency and 7 Hz.

2. Submerged Boundary Loads

a. High Steam Flux Loads

Sinusoidal pressure fluctuation added to local hydrostatic. Amplitude uniform below vent exit, linear attenuation to pool surface. 4.4 psi peak to peak amplitude. 2-7 Hz frequencies. NEDE-21061-P, Rev. 2.

b. Medium Steam Flux Loads

Sinusoidal pressure fluctuation added to local hydrostatic. Amplitude uniform below vent exit, linear attenuation to pool surface. 7.5 psi peak to peak amplitude. 2-7 Hz frequencies. NEDE-21061-P, Rev. 2.

I.C.1.b. Statistical distribution of loads, based on test observations, Task A.13, "Multi-vent Lateral Loads" to be used in a dynamic analysis. NEDE 24106-P has been submitted to NRC. Supplemental information is scheduled for submittal in 4Q79.

I.C.2.a. NUREG 0487 criteria used as interim spec.
& b. pending completion of Task A.17 "Steam Condensation Oscillation Test." Additional frequency ranges also being evaluated. A 4T C.O. test report is scheduled for submittal in 3Q80 with data evaluation for load application scheduled for submittal in 3Q80. See Table 1 for plant unique information.

NRC ACCEPTANCE CRITERIA
MARK II POOL DYNAMIC LOADS
(NUREG 0487, 10/78)

MARK II PROGRAM CLOSURE STATUS

I.C.2 Submerged Boundary Loads (cont.)

c. Chugging

- Uniform Loading Condition - Maximum amplitude uniform below vent exit, linear attenuation to pool surface. +4.8 psi max overpressure, -4.0 psi max underpressure 20-30 Hz frequency. (Pending of FSI concerns) NEDE-21061-P, Rev. 2.
- Asymmetric Loading Condition - Maximum amplitude uniform below vent exit - linear attenuation to pool surface. +20 psi max overpressure, -14 psi max underpressure, 20-30 Hz frequency, peripheral variation of amplitude follows observed statistical distribution with maximum and minimum diametrically opposed. NEDE-21061-P, Rev. 2.

II. SRV-RELATED HYDRODYNAMIC LOADS

A. POOL TEMPERATURE LIMITS

All Mark II facilities shall use quencher type devices. The suppression pool local temperature shall not exceed 200°F for all plant transients involving SRV operations. Measurements from temperature sensors located on the containment wall in the sector containing the discharge device at the same elevation as the device can be used as local indication.

I.C.2.c. NUREG 0487 criteria used as interim spec. pending completion of Task A.16 "Improve Chugging Load Definition". A report is scheduled for submittal in 1Q80. See Table 1 for plant unique information.

II.A NUREG 0487 criteria regarding the use of a quencher device is acceptable. The plant temperature monitoring system will be described in separate plant unique documents.

Document will be prepared using additional PP&L test data to support no (Local) temperature limit for quenchers. Report to be submitted 1Q80.

NRC ACCEPTANCE CRITERIA
MARK II POOL DYNAMIC LOADS
(NUREG 0487, 10/78)

MARK II PROGRAM CLOSURE STATUS

II. SRV-RELATED HYDRODYNAMIC LOADS (cont.)

B. AIR CLEARING LOADS

- (a) Methodology for Bubble Load Prediction
T-Quencher - Use ramshead methodology
described in Sec. 3.2 of NEDO-21061-P,
Rev. 2.

X-Quencher - Use Sec. 3.3 of NEDO-21061-P
Rev. 2.

(b) SRV Discharge Load Cases

The following load cases shall be considered for design evaluation of containment structures and equipment inside the containment:

1. Single valve, first and subsequent actuation
2. ADS valve actuation
3. Two adjacent valve first actuation
4. All valves discharged sequentially by setpoint
5. All valves discharged simultaneously by assuming all bubbles are oscillating in phase.

(c) Bubble Frequency

T-Quencher - a range of bubble frequency of 4-12 Hz is the minimum range that shall be evaluated. The range shall be increased if required to include the frequency predicted by the ramshead methodology together with $\pm 50\%$ margin.

- II.B(a) T-Quencher Load prediction methods presented in Susquehanna DAR, Sec. 4.1.3. See Table 1 for plant unique information.

- II.B(b) Load Case 4 is not included for T-Quencher evaluation. It is bounded by Susquehanna DAR sections 4.1.3.1 and 4.1.3.2. See Table 1 for plant unique information.

- II.B(c) Method for applying plant unique T-Quencher bubble frequency is presented in Susquehanna DAR, Section 4.1.3. See Table 1 for plant unique X-Quencher information.

NRC ACCEPTANCE CRITERIA
MARK II POOL DYNAMIC LOADS
(NUREG 0487, 10/78)

MARK II PROGRAM CLOSURE STATUS

II.B AIR CLEARING LOADS (cont.)

X-Quencher - a range of bubble frequency of 4-12 Hz shall be evaluated.

C. QUENCHER ARM AND TIE DOWN LOADS

1. Quencher Arm Loads

Vertical and lateral arm loads are to be developed on the basis of bounding assumptions for air/water discharge from the quencher and conservative combinations of maximum/minimum bubble pressures acting on the quencher per NEDE-21061-P, Rev. 2.

2. Quencher Tie-down Loads

The vertical and lateral arm load transmitted to the basemat via the tie-down plus vertical transient wave and thrust loads calculated from a standard momentum balance are to be calculated based on conservative clearing assumptions per NEDE-21061-P, Rev. 2.

III. LOCA/SRV SUBMERGED STRUCTURE LOADS

A. LOCA/SRV JET LOADS

1. LOCA Downcomer Jet Load

Calculate based on methods described in NEDE-21730 and the following constraints and modifications:

II.C.1. T-Quencher arm loads are presented in Susquehanna DAR, Section 4.1.2.5.

NUREG 0487 criteria for X-Quencher arm loads acceptable, no additional NRC review anticipated.

II.C.2. T-Quencher tie-down loads are presented in Susquehanna DAR Section 4.1.2.5.

NUREG 0487 criteria for X-Quencher tie down loads acceptable, no additional NRC review anticipated.

III.A.1. Ring Vortex Model including potential function for induced flow being finalized. More appropriate acceleration drag consideration to be identified. Basic model description has been submitted to NRC and final report is scheduled for submittal in 1Q80. See Table 1 for plant unique information.

III.A.1 LOCA Downcomer Jet Loads (cont.)

- (a) Standard drag at the time the jet first encounters the structure must be multiplied by the factor:

$$1 + \frac{6 V_a}{C_D A_X R_i}$$

where: V_a = acceleration volume as defined in NEDE-21730
 C_D = drag coefficient as defined in NEDE-21730
 A_X = projected area as defined in NEDE-21730
 R_i = vent exit radius

- (b) Forces in the vicinity of the jet front shall be computed on the basis of Formula 2-12 and 2-13 of NEDE-21730. The local velocity, U_∞ , and acceleration, U_∞ , are to be conservatively calculated by the methods of NEDE-21471 from the potential function:

$$\phi = \frac{-3}{8\pi} \cdot U_j \cdot V_W \frac{\cos \theta}{r^2}$$

where: r & θ = spherical coordinates from jet front
 U_j = jet velocity from NEDE-21730
 V_W = initial volume of water in the vent

NRC ACCEPTANCE CRITERIA
MARK II POOL DYNAMIC LOADS
(NUREG 0487, 10/78)

MARK II PROGRAM CLOSURE STATUS

III.A.1 LOCA Downcomer Jet Load (cont.)

- (c) After the last fluid particle has reached the jet front a spherical vortex continues propagating. The drag on structures in its vicinity can be bounded by using the flow field from the formula for ϕ above with U_j as the jet front velocity from NEDE-21730 at time $t = t_f$.

2. SRV Quencher Jet Loads

This load may be neglected for those structures located outside a zone of influence which is a sphere circumscribed around the quencher arms. If there are holes in the end caps, the radius of the sphere should be increased by 10 hole diameters. (Confirmation during Long Term Program required.)

B. LOCA/SRV AIR BUBBLE DRAG LOADS

1. LOCA Air Bubble Loads

Calculate based on the analytical model of the bubble charging process and drag calculations of NEDE-21471 until the bubbles coalesce. After bubble contact, the pool swell analytical model, together with the drag computation procedure NEDE-21471 shall be used. Use of this methodology shall be subject to the following constraints and modifications:

- (a) A conservative estimate of bubble asymmetry shall be added by increasing accelerations and velocities computed

- III.A.2. The P5.5 pressure transducer data from the T-Quencher test program presented in Section 8.0 of the Susquehanna DAR shows no water jet effect thus no loads are specified beyond a 5 ft. cylindrical zone of influence.

NUREG 0487 criteria acceptable for X-Quenchers, no additional NRC review anticipated.

- III.B.1 See Table 1 for plant unique information.

- III.B.1(a) NUREG 0487 criteria acceptable, no additional NRC review anticipated.

NRC ACCEPTANCE CRITERIA
MARK II POOL DYNAMIC LOADS
(NUREG 0487, 10/78)

MARK II PROGRAM CLOSURE STATUS

III.B.1 LOCA Air Bubble Loads

in step 12 of Section 2.2 of NEDE-21730 by 10%. If the alternate steps 5A, 12A, and 13A are used the acceleration drag shall be directly increased by 10% while the standard drag shall be increased by 20%.

- (b) Modified coefficients C_D from accelerating flows as presented in Kenlegan & Carpenter and Sarpkaya references shall be used with transverse forces included, or an upper bound of a factor of three times the standard drag coefficients shall be used for structures with no sharp corners or with stream-wise dimensions at least twice the width.
- (c) The equivalent uniform flow velocity and acceleration for any structure or structural segment shall be taken as the maximum values "seen" by that structure not the value at the geometric center.
- (d) For structures that are closer together than three characteristic dimensions of the larger one, either a detailed analysis of the interference effects must be performed or a conservative multiplication of acceleration and drag forces by a factor of four must be performed.
- (e) If significant blockage from downcomer bracing exists relative to the net pool area, the standard drag coefficients shall be modified by conventional methods (Pankhurst & Holder reference).

- III.B.1(b) Drag coefficients have been presented in Appendix C.4 (Rev. 6, 10/79) of the LaSalle DAR and in Attachment I.K of the Zimmer FSAR.
- III.B.1(c) Justification for application of load at geometric center addressed in Appendix C.4 (Rev. 6, 10/79) of the LaSalle DAR and in Attachment I.K of the Zimmer FSAR.
- III.B.1(d) Interference effects are addressed in Appendix C.4 (Rev. 6, 10/79) of the LaSalle DAR and in Attachment I.K of the Zimmer FSAR.
- III.B.1(e) Blockage effects will be evaluated and addressed in future documentation.

NRC ACCEPTANCE CRITERIA
MARK II POOL DYNAMIC LOADS
(NUREG 0487, 10/78)

MARK II PROGRAM CLOSURE STATUS

III.B.1 LOCA Air Bubble Loads (cont.)

(f) Formula 2-23 of NEDE-21730 shall be modified by replacing M_H by $\rho_{FB} V_A$ where V_A is obtained from Tables 2-1 and 2-2.

2. SRV Ramshead Air Bubble Loads

Use the methodology described in NEDE-21471 subject to the following constraints and modifications:

(a) Standard drag shall not be neglected without first estimating its order of magnitude using the following equation:

$$\frac{F_{SM}}{F_{AM}} = f \frac{P_{max}}{P_{\infty}} \frac{C_D^*}{\pi} \cdot \frac{R_{min}}{d} \frac{R_{min}}{r}^2$$

where: F_{SM} = maximum standard drag
 F_{AM} = maximum acceleration drag
 C_D^* = cycle-averaged effective drag coefficient
 d = dia. of cylindrical structure
 R_{min} = minimum bubble radius
 r_{min} = distance from bubble center to the structure

and: $f \frac{P_{max}}{P_{\infty}} \sim 8/3$ for $\frac{P_{max}}{P_{\infty}} \leq 30$

(b) Constraints of III.B.1 also apply.

3. SRV Quencher Air Bubble Loads

(a) T-Quencher - Loads may be computed on the basis of the above ramshead methodology using 25% of the calculated ramshead bubble pressure and assuming the bubble to be located at the center of the quencher device having a bubble radius equal to the quencher radius.

III.B.1(f) NUREG 0487 acceptable, no additional NRC review anticipated.

III.B.2.a NUREG 0487 criteria not applicable,
 & b ramshead devices not installed.

III.B.3.a T-Quencher bubble pressure prediction methodology is presented in Susquehanna DAR, Section 4.1.3. See Table 1 for plant unique information.

NRC ACCEPTANCE CRITERIA
MARK II POOL DYNAMIC LOADS
(NUREG 0487, 10/78)

MARK II PROGRAM CLOSURE STATUS

III.B.3 SRV Quencher Air Bubble Loads (cont.)

- (b) X-Quencher - Loads may be computed on the basis of the above ramshead methodology using bubble pressures calculated by the methods of NEDE-21061-P, Rev. 2, for the X-Quencher.

C. STEAM CONDENSATION DRAG LOADS

Review will be conducted on a plant unique basis.

- III.B.3.b Burns & Roe X-Quencher load definition to be based on a combination of resolution of certain aspects now being discussed with the NRC generically and plant unique methods given in WNP-2 DAR.

III.C See Table 1 for plant unique information.

TABLE 1

NRC CRITERIA	PLANT UNIQUE CLOSURE
I.B.3.a & c (Pool Swell Impact Loads)	HANFORD - Burns & Roe has documented plant unique methods in WNP-2 DAR
I.C.1.a (Single Vent Lateral Loads)	SUSQUEHANNA - Plant unique ^{generic} lateral bracing loads will be confirmed by GKM-IIM test data.
I.C.2.a & b (C.O. Boundary Loads)	SUSQUEHANNA - Lead plant NRC criteria acceptable. Higher amplitude (3.5 & 10 psi) loads used. Confirmation of design loads to be based on plant unique GKM-IIM tests.
I.C.2.c (Chugging Boundary Load)	HANFORD - Burns and Roe chugging load definition has been documented in reports submitted April 13 and June 15, 1979.
II.B.a, b & c (SRV Air Clearing Load)	HANFORD - Burns and Roe is developing a unique X-Quencher load definition based largely on Caorso data. Loads will be presented in WNP-2 DAR.
III.A.1 (LOCA Water Jet Loads)	BAILLY - Methodology which meets the intent of NUREG-0487 criteria will be used. The method is documented in Appendix C.3 of the LaSalle DAR and in Attachment I.J.3 of the Zimmer FSAR.
	SUSQUEHANNA - Same as stated above for Bailly.
	LIMERICK - Same as stated above for Bailly.
III.B.1 (LOCA Air Bubble Loads)	SUSQUEHANNA - LOCA air bubble source term at the vent exit will be applied in a modified IWECS/MARS Code to establish acceleration and velocity flow fields. Application of the flow fields will follow the Mark II Program Closure Status positions (a) through (f). Possible source term is being investigated using NEDE-21471 method to determine the bubble formation with the exception that time dependent drywell pressure history is used to determine bubble pressure. Report to be submitted April 1980.
	LIMERICK - Same as stated above for Susquehanna.
	HANFORD - Burns & Roe LOCA load definition to be based on a combination of resolution of certain aspects now being discussed with the NRC generically and plant unique methods given in WNP-2 DAR.

TABLE 1 (CONTINUED)

III.B.3
(SRV Air Bubble Loads)

BAILLY - Ramshead methodology (as modified by lead plants in response to NUREG-0487) is used with bubble location and radius defined appropriately for T-Quenchers. Bubbles are located near the arms. Bubble size is predicted from the discharge line air volume. Method is the same as for LaSalle and Zimmer.

III.C
(Steam Condensation Loads)

BAILLY - The lead plant methods documented in the LaSalle and Zimmer closure reports will be used as an interim methodology pending results from Task A.16 or A.17 which would reduce source strengths.

SUSQUEHANNA - C.O. and chugging source term defined from Task A.16 and A.17 at the vent exit will be applied in a modified IWECS/MARS Code to establish acceleration and velocity flow fields. Application of flow fields will be made with appropriate drag coefficients. Report to be submitted April 1980.

LIMERICK - Same as stated above for Susquehanna.

HANFORD - Generic source as given in I.C.2 used as described in WNP-2 DAR.

NINE MILE POINT - Load sources will be derived from generic tasks (A.16 and A.17). The flow field resulting from these sources along with appropriate drag coefficients as specified for LOCA air bubble drag loads will be used to determine the load.

4

A.11 MULTIVENT TEST PROGRAM

OVERALL OBJECTIVES

- OBTAIN A SINGLE-VENT/MULTIVENT CHUGGING DATA BASE TO ESTABLISH TRENDS IN POOL WALL LOADS WITH NUMBER OF VENTS
- DEMONSTRATE THAT THE MULTIVENT TRENDS OBSERVED IN SUBSCALE TESTS ARE VALID BY:
 - COMPARING SINGLE VENT DATA AT FOUR SUBSCALES
 - COMPARING MULTIVENT DATA AT TWO SUBSCALES

TASK A.11

SCALED MULTIVENT TEST PROGRAM PROGRAM STATUS/SCHEDULE

PHASE 1

- | | |
|-----------------------------------|----------|
| o TESTS, DATA REDUCTION, ANALYSIS | COMPLETE |
| o PHASE 1 REPORT TO NRC | DECEMBER |

PHASE 2

- | | |
|---------------------------------|----------|
| o PROGRAM PLAN | COMPLETE |
| o TESTS | |
| o 5/12, 1/4 SCALE | COMPLETE |
| o 1/10 SCALE, 19 VENTS | COMPLETE |
| o COMPLETE 1/6 SCALE, 7 VENTS | NOVEMBER |
| o COMPLETE PHASE 1 FROUDE SCALE | DECEMBER |
| o DATA REDUCTION | MARCH 80 |
| o ANALYSIS | |
| o FSI | DECEMBER |
| o SCALING | APRIL 80 |
| o FINAL RE TO NRC | JUNE 80 |

TASK A.11

SCALED MULTIVENT TEST PROGRAM

OVERVIEW OF TEST PROGRAM

HIGHLIGHTS

	<u>PHASE 1</u>	<u>PHASE 2</u>
GEOMETRIES:	14	5
SCALE-VENTS:	1/10- 1, 3, 7 VENT 1/6 - 1, 3 VENT	1/4 - 1 VENT 5/12 - 1 VENT 1/10 - 19 VENT 1/6 - 7 VENT
VESSEL DIA:	10, 18, 28, 30	28, 44
VARIABLES:	PRESSURE (4.5 TO 45 PSIA) STEAM MASS FLUX (.1 TO 16 LB ¹ /FT ² SEC) TEMPERATURE (90° TO 200°) AIR CONTENT (.1 TO .5%)	
ADDITIONAL EFFECTS:	DRYWELL VOLUME OFFSET VENT LARGE DRYWELL POOL/VENT AREA RATIO	- - - -
NUMBER OF RUNS	452	297
STATUS	COMPLETE	IN PROCESS
REPORT	DEC. '79	JUNE '80

11/14/79

5
10/79

TASK OBJECTIVE

- o TO PERFORM STATISTICAL AND BOUNDING LOAD ANALYSIS OF INDEPENDENT DATA BASES TO CONFIRM OR MODIFY THE 4T LATERAL LOAD DEFINITION AS REQUIRED.

SUMMARY OF RESULTS

- o GOOD CORRELATION WITH MAXIMUM OBSERVED VALUES IN OTHER DATA BASES.
- o GOOD STATISTICAL CORRELATION BETWEEN 4T AND THE REFERENCE DATA BASES.
- o REFERENCE DATA #2 REPRESENTS THE MOST APPROPRIATE COMPARISON TESTS FOR 4T VERIFICATION.

THE DYNAMIC LATERAL LOAD FUNCTION DEFINED IN NEDE 24106-P HAS BEEN CONFIRMED AS THE PROPER DESIGN LOAD CRITERION FOR MAIN VENT DOWNCOMER STRUCTURES.


10/79

LATERAL LOAD FUNCTION


$$F(t) = A \sin \frac{\pi t}{\tau}, \text{ LATERAL LOAD (LB}_F\text{)}$$

WHERE: $10^4 < A < 3 \times 10^4$, MAXIMUM AMPLITUDE (LB_F)

AND $3 < \tau < 6$, APPLICATION PERIOD (MSEC)



10/79




4T TEST FACILITY

DYNAMIC LATERAL LOAD DEFINITION


- o COMPARISON BETWEEN 4T DATA AND TEST RESULTS
REPORTED BY TWO INDEPENDENT REFERENCE TESTS.
- o REFERENCE TEST #1. LARGE TANK, STEADY STATE
MASS FLUX.
- o REFERENCE TEST #2. SINGLE CELL, TRANSIENT
BLOWDOWN.

10/79




REFERENCE TEST #1
TEST SET-UP AND INSTRUMENTATION

10/79



REF. TEST #1

10/79



TEST SET-UP AND INSTRUMENTATION;
600 MM VENTS, HORIZONTAL SECTION

EVALUATION OF REFERENCE DATA


o APPROACH

- . NUMERICAL SIMULATION OF SUBJECT TEST FACILITY
- . DETERMINATION OF BRACE LOAD AMPLITUDE AND RESPONSE PERIOD AS FUNCTION OF:
 - _ APPLIED LOAD PERIOD
 - _ POOL TEMPERATURE
 - _ MASS FLUX
- . STATISTICAL ANALYSIS OF RESPONSE DATA ON 4T EQUIVALENT BASIS.
- . COMPARISON OF REFERENCE DATA RESULTS WITH 4T

SPECIFIC CORRELATION PROCEDURE


- o SIMULATE DYNAMIC LATERAL RESPONSE OF REFERENCE FACILITY TO FORCING FUNCTION DEFINED BY 4T DATA.
- o CALCULATE RESULTING BRACE LOADS AND ACCELERATION RESPONSES AS MEASURED IN THE SUBJECT TESTS.
- Compare*
- o ~~CORRELATE~~ SIMULATED AND EXPERIMENTAL BRACE STRESS AND/OR ACCELERATION TIME HISTORIES TO DETERMINE AMPLITUDE AND HALF PERIOD OF THE LATERAL LOAD FUNCTION WHICH REPRODUCES THE MEASURED RESPONSE DATA.

10/79




10/79

LATERAL BOUNDING LOAD FOR ALL TESTS.



10/79



DIAMETER DEPENDENCY

- o 4T AND REFERENCE #1 SUGGEST THAT THE FOLLOWING GENERAL EXPRESSION DEFINES THE DEPENDENCY OF LATERAL LOAD UPON DIAMETER:

$$F = F_0 [D/D_0]^N$$

WHERE: F IS TIP LOAD AT ANY DIAMETER D
F₀ BOUNDING LOAD AMPLITUDE AT D₀
N, EXPERIMENTAL COEFF.

- o 4T DATA SHOWS VALUES OF N RANGING FROM .5 TO 1.7, BUT HAS LIMITED PARAMETRIC ACCURACY DUE TO THE SMALL DIFFERENCES IN TEST DIAMETERS, 20 TO 24 IN.
- o REFERENCE #1 DATA SHOWS A VALUE OF N=.7, GOOD PARAMETRIC ACCURACY WAS OBTAINED FROM THESE TESTS, 12 AND 24 IN.

THE USE OF EITHER OF THE TWO MAXIMUM EXPONENT VALUES WITH THE CORRESPONDING REFERENCE BOUNDING LOAD YIELDS A DYNAMIC DESIGN LOAD OF 40,000 LBF. FOR 28 INCH DOWNCOMERS.

STATUS OF MULTIVENT
LATERAL LOAD METHODOLOGY

OBJECT - DEVELOP A CONSERVATIVE MULTIVENT
LATERAL LOAD SPECIFICATION

~~APPROACH~~ -- ~~USE STATISTICS OF 4-T CHUGGING~~
LATERAL LOADS (AS ANALYZED BY
PRETECH) TO DETERMINE THE TIP
IMPULSE AS A FUNCTION OF NUMBER OF
DOWNCOMERS

C.D.I.
11/14/79


• PRETECH BOUNDING DYNAMIC LOAD

$$F(t) = A(\tau) \sin \frac{t\pi}{\tau} \quad \text{for } 0 < t < \tau$$

$$A(\tau) = -20\text{k lbf} \left(\frac{\tau}{3\text{ms}}\right) + 50\text{k lbf} \quad \text{for } 3\text{ms} < \tau < 6\text{ms}$$

$$I = \int_0^{\tau} A(\tau) \sin \frac{t\pi}{\tau} dt$$

• CHUGGING TIP IMPULSE PROBABILITY DENSITY





- THE ANGLE OF THE CHUGGING TIP IMPULSE HAS A DENSITY FUNCTION UNIFORMLY DISTRIBUTED OVER 2π RADIANS IN THE HORIZONTAL PLANE.

FOR A GROUP OF N DOWNCOMERS, COMPUTE THE PROBABILITY P THAT THE RESULTANT TIP IMPULSE ON THE GROUP OF DOWNCOMERS WILL FALL WITHIN A GIVEN TIP IMPULSE INTERVAL.

THEN, IF P_1 IS THE CUMULATIVE PROBABILITY THAT THE RESULTANT TIP IMPULSE WILL NOT EXCEED THE IMPULSE VALUE AT THE UPPER BOUNDARY OF THE INTERVAL IN ONE CHUG, $1 - (P_1)^M$ IS THE PROBABILITY OF EXCEEDING THE GIVEN TIP IMPULSE MAGNITUDE AFTER M CHUGS.

PRELIMINARY,
NOT DESIGN VERIFIED,
SHOULD NOT BE USED FOR
DESIGN PURPOSES.





Tip impulse normalized by the one downcomer value of 56.8klbf-ms vs number of downcomers for a probability level of exceedance.

PRELIMINARY CONCLUSIONS

A MULTIVENT DYNAMIC LATERAL LOAD SPECIFICATION HAS BEEN DEVELOPED WHICH USES STATISTICS OF 4-T CHUGGING LATERAL LOADS TO DETERMINE THE TIP IMPULSE.

CONSERVATISMS EXIST IN THE SPEC

- THE IMPULSE FUNCTION COMPUTED FROM PRETECH'S LOADING FUNCTION BOUNDS ALL 4-T DATA.
- NO CREDIT IS TAKEN FOR LACK OF SYNCHRONIZATION BETWEEN VENTS.

(3)

A.16 PHASE II CHUGGING STATUS

- PROGRAM OBJECTIVES
 - CONFIRM DFFR LOAD IS CONSERVATIVE FOR
LEAD PLANT APPLICATION
 - JUSTIFY IMPROVED LOAD FOR NON-LEAD
PLANT APPLICATION

11/79

A.16 PHASE II CHUGGING STATUS

COMPLETED
SCHEDULE
ITEMS

• KEY MILESTONES

- ANALYZED 137 CHUGS FROM 4T --
- DEVELOPED ACOUSTIC MODEL TO SIMULATE
TYPICAL CHUGS --
- AVERAGED PSD OF 137 CHUGS --
- DEVELOPED CRITERIA FOR ENVELOPING
PSD --
- USED ACOUSTIC MODEL TO INFER VENT
SOURCE THAT ENVELOPED PSD --
- DEFINED SYMMETRIC AND ASYMMETRIC
LOAD CASES --
- COMPUTED MK II RIGID WALL RESPONSES
USING DESIGN SOURCE --
- COMPUTED MK II RESPONSES USING
TYPICAL MK II STRUCTURAL MODEL AND
COMPARED TO DFFR --
- NRC TECHNICAL MEETING IN HA ER JULY '79

A.16 PHASE II CHUGGING STATUS

TARGET SCHEDULE

• KEY MILESTONES

- VERIFY TREATMENT OF FSI BY NASTRAN NOV. '79
 MODEL OF 4T
- VERIFY USE OF TYPICAL MK II STRUCTURAL NOV. '79
 MODEL USING NASTRAN MODEL OF MK II
- FINAL REPORT MODIFIED AND EXPANDED FEB. '80
 BASED ON NRC JULY INPUT

11/79

9

4T CO TEST PROGRAM

OBJECTIVES

- RESOLVE VENT LENGTH EFFECT
- COMPARE DATA TO EXISTING DFFR C.O. SPECIFICATION
- MODIFIED 4T FACILITY
- PROTOTYPICAL CONFIGURATION
- VARYING TEST CONDITIONS

11/79

4TCO TEST PROGRAM

SCHEDULE & MILESTONES

<u>MILESTONE</u>	<u>COMPLETION DATE</u>
FACILITY DESIGN	COMPLETE
TEST PLAN	COMPLETE
TEST FREEZE	COMPLETE
FACILITY MODIFICATION	COMPLETE
SHAKEDOWN TESTING	COMPLETE
MATRIX TESTS - 23 TOTAL	
• 9 TESTS	COMPLETE
• COMPLETE TESTING	FEBRUARY '80
DATA REDUCTION	MAY ' 80
FINAL TEST REPORT	3Q80

4TCO TEST MATRIX

<u>RUN NO.</u>	<u>BREAK TYPE</u>	<u>BREAK SIZE (IN)</u>	<u>POOL TEMP. (°F)</u>	<u>VENT SUBMER. (FT.)</u>	<u>VENT RISER</u>	<u>INITIAL DRYWELL AIR (%)</u>
16	STEAM	3.00	70	11	YES	100
2	LIQUID	3.00	70	11	NO	100
3	LIQUID	3.82	70	11	NO	100
4	LIQUID	3.82	70	11	YES	100
5	LIQUID	-- *	80	11	NO	100
6	LIQUID	3.82	70	11	NO	~ 50
7	LIQUID	-- *	90	11	NO	100
8	LIQUID	3.82	110	11	NO	100
9	LIQUID	3.00	110	11	NO	100
10	LIQUID	-- *	70	9	NO	100
11	LIQUID	-- *	70	13.5	NO	100
12	LIQUID	2.50	110	11	NO	100
13	LIQUID	2.125	110	11	NO	100
14	LIQUID	2.125	70	11	NO	100
15	LIQUID	2.125	70	11	YES	100
16	STEAM	3.00	70	11	NO	100
17	STEAM	3.00	70	9	NO	100
18	STEAM	3.00	70	13.5	NO	100
19	STEAM	3.00	70	13.5	NO	100
20	STEAM	2.50	70	11	NO	100
21	STEAM	2.50	70	11	NO	100
22	REPEAT	(LATER)				
23	REPEAT	(LATER)				

* Break sizes for these tests to be specified after evaluation of initial results.

TEST MATRIX OBJECTIVES

- DUPLICATE PREVIOUS 4T TEST CONDITIONS
 - TESTS 17, 1, 18, 20
- OBTAIN DATA AT C.O. CONDITIONS FOR RANGE OF MARK II FLOW RATE/POOL TEMPERATURES
 - TESTS 3, 5, 7, 8, 2, 9, 12, 14, 13
- PARAMETER RANGE FOR MARK II
 - AIR CONTENT AND POOL TEMPERATURE
 - TESTS 3, 5, 7, 8, 6
 - VENT SUBMERGENCE
 - TESTS 17, 1, 18, 10, 2, 11
 - VENT RISER
 - TESTS 4, 3, 15, 14, 16, 1
- REPEATABILITY
 - TESTS 18, 19, 20, 21, 22, 23


4T CO INSTRUMENTATION

<u>LOCATION</u>	<u>INSTRUMENT TYPE</u>	<u>MEASUREMENT</u>	<u>NO.</u>
Wetwell & Suppression Pool	Flush Mount Press. xocr	Pool Boundary Press.	11
		Wetwell airspace press.	1
	Accelerometers	Fac. Response	6
	Strain gages	Fac. Comp. Response	3
	Thermocouples	Pool temperature	11
		Freespace temperature	1
	Cavity Press. xocr	Liquid Level	1
Downcomer	Flush Mount Press. xocr	Vent acoustics	5
	Cavity ΔP xocr	Vent flow	1
	Cavity press. xocr	Vent: flow	1
	Level probe	Chug initiation	1
	Accelerometers	Chug initiation	2
	Thermocouples	Vent flow & temp.	1
Drywell	Flush Mount Press. xocr	Acoustics	1
	Cavity press. xocr	Static press.	1
	Capacitance Probe	Liquid retention	1
	Thermocouples	Drywell temperature	1
Blowdown Line	Cavity press. xocr	Blowdown flow	1
	Thermocouples	Blowdown line exit temp.	1
Steam Vessel	Cavity ΔP xocr	Liquid blowdown flow	8
	Cavity press. xocr	Vessel pressure	1
Vacuum Breaker	Potentiometer	Valve opening	1

Other Instrumentation


- o Air Content (grab sample and continuous air monitoring)

TEST CONFIGURATION FOR MARK II 4T CONDENSATION OSCILLATION (4TCO) TESTS



- △ FLUSH MOUNT PRESSURE TRANSDUCER
- ▽ CAVITY PRESSURE TRANSDUCER
- THERMOCOUPLE
- ACCELEROMETER
- CONDUCTIVITY PROBE

- ⊙ REPLAY (1000 SAMPLES/SEC)
- REAL TIME (100 SAMPLES/SEC)



ORIENTATION

ACCELEROMETER

HORIZONTAL TANGENT
TO DOWNCOMER

NOTE: PRESSURE
TRANSDUCER AND
CONDUCTIVITY PROBE
ON BOTTOM OF DOWNCOMER
ARE LOCATED AS CLOSE
TOGETHER AS POSSIBLE.

DOWNCOMER INSTRUMENTATION

- ▽ CAVITY PRESSURE TRANSDUCER
- △ FLUSH MOUNT PRESSURE TRANSDUCER
- ACCELEROMETER
- ▲ UNIAXIAL STRAIN GAGE

- ⊙ REPLAY (1000 SAMPLES/SEC)
- REAL TIME (100 SAMPLES/SEC)


ORIENTATION

ACCELEROMETERS

- WETWELL O.D. - RADIAL
- BASEPLATE - VERTICAL

STRAIN GAGES

- WETWELL O.D. - HOOP
- BASEPLATE - RADIAL



WETWELL AND SUPPRESSION POOL INSTRUMENTATION
PRESSURE, ACCELERATION, AND STRAIN

4T CO DATA INTERPRETATION

ELEMENTS

USAGE

- | | |
|------------------------------|--|
| ● VENT PRESSURE
HISTORIES | - DETERMINATION OF
STANDING WAVE PRESENCE |
| ● POOL WALL
PRESSURES | - ESTABLISH CO AMPLITUDE
vs FREQUENCY CONTENT

- INTERPRETATION FOR
MARK II APPLICATION

- COMPARE TO DFFR |

RJM 11/79

TESTS CONDUCTED

NO.	BREAK TYPE	BREAK SIZE (IN)	POOL TEMP. (°F)	SPECIAL FEATURES	
				VENT RISER	INITIAL DRYWELL AIR
16	STEAM	3.0	70	YES	100%
2	LIQUID	3.0	70	NO	100%
3	LIQUID	3.82	70	NO	100%
4	LIQUID	3.82	70	YES	100%
6	LIQUID	3.82	70	NO	~50%
8	LIQUID	3.82	110	NO	100%
9	LIQUID	3.0	110	NO	100%
12	LIQUID	2.5	110	NO	100%
13	LIQUID	2.125	110	NO	100%

BROOKHAVEN THEORETICAL STUDIES



(CHAPTER 2 AND 3)

- STUDIED LIGHTLY DAMPED & UNDAMPED SINE WAVES
- CONCLUDED THAT WHEN YOU COMBINE TWO WAVES OF SIGNIFICANTLY DIFFERENT FREQUENCIES, THE NEP OF SRSS CAN BE LOW
- NOT RELEVANT TO TRANSIENT RESPONSE
 - LIGHTLY DAMPED SINE WAVES ONLY REPRESENT RESPONSE DURING FREE VIBRATION AFTER TERMINATION OF INPUT
 - FOR NUCLEAR PLANT TYPE STRUCTURES SUBJECT TO REAL INPUT, PEAK RESPONSE NEARLY ALWAYS OCCURS DURING TRANSIENT RESPONSE STAGE
- IF CONCLUSION WERE TRUE, WE WOULD BE UNABLE TO COMBINE EARTHQUAKE RESPONSES BY SRSS. EXPERIENCE HAS INDICATED THAT FOR EARTHQUAKE-LIKE INPUT, WIDE FREQUENCY VARIATION DOES NOT LEAD TO LOW NEP FOR SRSS.

MULTIPLE RESPONSE TIME HISTORIES

1. TIME HISTORIES HAVE RANDOM RELATIVE START TIMES.
(UNCORRELATED)
2. TIME HISTORIES ALSO HAVE RANDOM AMPLITUDES.
3. DESIGN AMPLITUDES ARE DEFINED TO BE AT THE 84% NON-EXCEEDANCE PROBABILITY BY CRITERIA.

(A)



4. HOW SHOULD PEAK INDIVIDUAL RESPONSE BE COMBINED?

BASIC ASSUMPTION BEHIND CRITERIA
FOR SRSS COMBINATION OF RESPONSES

- MANY SOURCES OF CONSERVATISM EXIST IN DESIGN AND EVALUATION PROCESS.
 - ADDITIONAL CONSERVATISM DOES NOT HAVE TO BE INCORPORATED WITHIN THE RESPONSE COMBINATION PROCESS.
 - IT IS NOT NECESSARY FOR THE COMBINED RESPONSE TO HAVE A LOWER PROBABILITY OF EXCEEDANCE THAN THE INDIVIDUAL RESPONSES.
-

CRITERION 2

- R_{SRSS84} = SRSS COMBINED RESPONSE WHERE EACH INDIVIDUAL RESPONSE HAS BEEN DEFINED CONSERVATIVELY AT 84TH PERCENTILE OR F-MEDIAN.
- R_{T84} = RANDOM TIME PHASE COMBINED RESPONSE WHERE ALL AMPLITUDES DEFINED AT 84TH PERCENTILE.
- R = COMBINED RESPONSE CONSIDERING BOTH RANDOM AMPLITUDE AND TIME PHASING.
-

GOAL OF SRSS COMBINATION

$$P [R \leq R_{SRSS84}] \geq 84\% \quad (1)$$

CRITERION 2 REQUIREMENT

$$P [R_{T84} \leq R_{SRSS84}] \geq 50\% \quad (2)$$

3

$$P [R_{T84} \leq 1.2 R_{SRSS84}] \geq 85\% \quad (3)$$




FIGURE 2-1. COMPARISON OF RANDOM TIME PHASE ONLY CURVES WITH RANDOM TIME PHASE AND AMPLITUDE CURVES

CUMULATIVE DISTRIBUTION FUNCTION

$P(R < R_s)$




FIGURE 2-66 CASE 3: RHA-WETWELL OBS + SPRING M_0 (POSITIVE)
INFLUENCE OF SHAPE OF AMPLITUDE

CONCLUSION OF STUDY OF CRITERION 2

- IN MOST CASES, CRITERION 2 LEADS TO A NEP FOR SRSS COMBINED RESPONSES OF APPROXIMATELY 84%
- IN SOME CASES, CRITERION MORE CONSERVATIVE THAN NECESSARY
- IN NO CASE CAN THE 84% NEP PEAK COMBINED RESPONSE EXCEED THE SRSS COMBINED RESPONSE BY MORE THAN 9%
- THUS, CRITERION 2 IS AN ADEQUATE, SLIGHTLY CONSERVATIVELY BIASED CRITERION

CORNELL STUDIES

- DR. CORNELL HAS BEEN INDEPENDENTLY ENGAGED TO EVALUATE ADEQUACY OF CRITERION 2
- HE HAS CONCLUDED THAT CDF CURVES CAN BE ACCURATELY GENERATED FROM A KNOWLEDGE OF THE FOLLOWING RESPONSE CHARACTERISTICS
 - UPCROSSING RATES (NUMBER OF PEAKS)
 - MARGINALS (TOTAL DURATION OF PEAKS)
- IMPLICATIONS ARE:
 - WE WILL BE ABLE TO DIRECTLY GENERATE CDF FROM SIMPLE CHARACTERISTICS OF RESPONSES
 - WE MAY EVENTUALLY BE ABLE TO DIRECTLY GENERATE CDF FROM SIMPLE CHARACTERISTICS OF INPUT
- HE HAS MADE MANY ADDED STUDIES OF CRITERION 2 AND REINFORCES OUR CONCLUSION THAT IT ACHIEVES ITS GOAL IN EVERY CASE !

BROOKHAVEN STUDY CRITERION 2

- THEY STATE THEIR RESULTS DO NOT AGREE WITH GE BUT DO NOT PRESENT BASIS FOR THIS CONCLUSION
- IN THEIR EXAMPLES, EVERY CASE WHICH MEETS CRITERION 2 ALSO MEETS ITS INTENT
- THEY CLAIM LACK OF UNIQUENESS. HOWEVER, WHEN COMBINED WITH ASME CODE, APPENDIX N PROCEDURE FOR GENERATING CDF, CRITERION IS UNIQUE.
- WE BELIEVE THAT IT IS EXTREMELY IMPORTANT TO HAVE A CRITERION LIKE CRITERION 2 AND WISH TO WORK WITH THE NRL TO RESOLVE ANY BROOKHAVEN CONCERNS ON THIS CRITERION

CRITERIA 1 REQUIREMENTS:

- RESPONSE COMPONENTS FROM INDEPENDENT EVENTS OR RANDOM PHASING
- LIMITED NUMBER OF NEAR PEAK EXCURSION
NO MORE THAN 5 EXCEEDING 75% OF THE MAXIMUM, OR
NO MORE THAN 10 EXCEEDING 60% OF THE MAXIMUM
- LIMITED DURATION
10 SECONDS OR LESS
- APPROXIMATELY ZERO MEAN

JUSTIFICATION OF CRITERION 1

- CRITERION 1 IS INTENDED TO ASSURE THAT RESPONSE IS EARTHQUAKE-LIKE
- FOR CERTAIN STATIONARY STOCHASTIC PROCESSES THE PROBABILITY OF EXCEEDANCE OF SRSS COMBINED RESPONSE CAN BE SHOWN TO BE EQUAL TO THE PROBABILITY OF EXCEEDANCE OF THE INDIVIDUAL RESPONSES

$$P[R \leq R_{SRSS_{84}}] = 84\%$$

- EARTHQUAKE-LIKE RESPONSES HAVE BEEN SHOWN TO BE REASONABLY APPROXIMATED AS STATIONARY STOCHASTIC PROCESSES AND CAN BE EVEN BETTER APPROXIMATED AS NON-STATIONARY PROCESSES

- FOR NON-STATIONARY PROCESSES:

$$P[R \leq R_{SRSS_{84}}] \geq 84\% \quad (1)$$

- EARTHQUAKE-LIKE RESPONSE EXPECTED TO MEET EQUATION 1
- EARTHQUAKE-LIKE RESPONSE REQUIRES LESS NEAR-MAX. PEAKS (MORE NON-STATIONARY) THAN FOR EARTHQUAKE RESPONSE, APPROXIMATELY ZERO MEAN, AND RANDOM PHASING
- RANDOM PHASING AUTOMATICALLY ACHIEVED BY RANDOM START TIME. TO BE CONSIDERED RANDOM, RELATIVE START TIMES MUST BE CONSIDERED UNKNOWN WITHIN A TIME INTERVAL GREATER THAN ABOUT 2 TO 5 TIMES THE NATURAL PERIOD OF THE STRUCTURE

JUSTIFICATION OF CRITERION 1 (CON'T.)

- JUSTIFICATION OF CRITERION 1 CONSIDERABLY BOLSTERED BY FACT THAT OUT OF 235 MARK II RESPONSE COMBINATIONS WHICH MEET CRITERION 1, 100% OF CASES (ALL 235) ALSO MET CRITERION 2

- MEETING CRITERION 1 PROVIDES HIGH CONFIDENCE THAT CRITERION 2 WOULD BE MET

RESPONSES TO QUESTIONS ON CRITERION 1

1. HOW TO ASSURE SUFFICIENTLY RAPID VARIATION OF TIME HISTORIES.

- RAPID VARIATION IS ASSURED BY:

- A) LIMITING THE NUMBER OF NEAR MAXIMUM PEAKS
AND

- B) ASSURING A NEAR ZERO RATIO OF MEAN TO
MAXIMUM RESPONSE OVER A TIME DURATION LESS
THAN THE UNCERTAINTY IN THE LAG TIME.

- A RATIO OF MEAN TO MAXIMUM LESS THAN ABOUT
0.1 TO 0.2 MEETS REQUIREMENT OF NEAR ZERO MEAN.


2. WHY CAN LOADING TIME HISTORY BE USED IN LIEU OF RESPONSE TIME HISTORY.

- IF LOADING TIME-HISTORY IS EARTHQUAKE-LIKE THEN
RESPONSE TIME-HISTORY WILL AUTOMATICALLY BE
EARTHQUAKE-LIKE FOR LINEAR ELASTIC STRUCTURES
(I.E.) IF LOADING HAS LESS NEAR PEAK EXCURSIONS
THAN FOR EARTHQUAKE, THE RESPONSE TO LOADING WILL
AUTOMATICALLY HAVE LESS NEAR PEAK EXCURSION THAN
IT WOULD HAVE FROM EARTHQUAKE TIME HISTORY.

- IF LOADING HAS NEAR-ZERO MEAN, RESPONSE AUTOMATICALLY
HAS NEAR-ZERO MEAN FOR LINEAR ELASTIC SYSTEMS.

- NOT PRACTICAL TO LIMIT CRITERIA TO RESPONSE. FOR
MANY CASES, RESPONSE TIME HISTORIES ARE NOT GENER-
ATED. NEED A CRITERIA WHICH CAN BE APPLIED AT THE
LOADING LEVEL.

OBE TIME HISTORY



SRV TIME HISTORY




FIGURE 1-1. DYNAMIC EVENT LOADING FUNCTIONS




FIGURE 3-8. ELASTIC RESPONSE TO UNSCALED OBE, 16 HZ MODEL, 2 PERCENT DAMPING

* Time for peak elastic response.




FIGURE 3-9. ELASTIC RESPONSE TO UNSEALED SRV, 16 HZ MODEL, 2 PERCENT DAMPING

* Time for peak elastic response.

BROOKHAVEN STUDY - CRITERION 2
LOAD VERSUS RESPONSE TIME HISTORIES

- BROOKHAVEN CLAIMS THAT OUR BASIS FOR RECOMMENDING THAT CRITERION 1 CAN BE USED AT THE LOAD LEVEL IS BASED ON OUR BELIEF THAT THERE ARE LESS PEAKS TO THE RESPONSE THAN THERE ARE FOR THE INPUT.
- WE HAVE NEVER MADE SUCH A CLAIM. IN FACT, ON TWO PREVIOUS OCCASIONS WE HAVE EXPLAINED TO BROOKHAVEN OUR BASIS FOR CRITERION 1, BUT THEY HAVE BEEN UNWILLING TO REVISE THEIR STATEMENT.
- BROOKHAVEN HAS ERECTED A "STRAWMAN" SO THEY COULD TEAR IT DOWN AND THEN HAS USED THIS AS THEIR BASIS FOR REJECTING A VALID CRITERION.
- OUR CRITERION 1 IS BASED ON THE CHARACTERISTICS OF EARTHQUAKE INPUT AND OUR KNOWLEDGE THAT WHEN THE INPUT HAS LESS PEAKS THAN FOR EARTHQUAKE INPUT, THE RESPONSES WILL HAVE LESS PEAKS THAN EARTHQUAKE RESPONSE.
- THUS, IF EARTHQUAKE RESPONSES CAN BE COMBINED SRSS, THESE OTHER RESPONSES SHOULD ALSO BE ABLE TO BE COMBINED SRSS.

BROOKHAVEN STUDY - CRITERION 1
NUMBER OF PEAKS VERSUS TOTAL DURATION OF PEAKS

- BROOKHAVEN HAS DEMONSTRATED THAT THE TOTAL DURATION OF PEAKS IS MORE SIGNIFICANT THAN NUMBER OF PEAKS FOR DETERMINING THE NEP OF SRSS COMBINED RESPONSE. WE AGREE.
- WE HAVE PREVIOUSLY PRESENTED A PROPOSED MODIFICATION TO CRITERION 1 TO CORRECT FOR THIS POTENTIAL DEFICIENCY IN CRITERION 1 AND ASKED BROOKHAVEN TO CONSIDER ITS GENERIC APPLICABILITY. THEY APPEAR TO HAVE NOT DONE SO.
- FOR MARK II APPLICATIONS, WE HAVE DEMONSTRATED THAT THE UNMODIFIED CRITERION 1 IS MORE STRINGENT THAN CRITERION 2 AND DOES NOT HAVE TO BE MODIFIED. HOWEVER, FOR GENERIC APPLICATION WE RECOMMEND CRITERION 1 BE MODIFIED TO CORRECT FOR THIS POTENTIAL DEFICIENCY.

REVISED CRITERION 1

Dynamic or transient responses of structures, components, and equipment arising from combinations of dynamic loading or motions may be combined by SRSS provided that each of the dynamic inputs or responses has characteristics similar to those of earthquake ground motions, and that the individual component inputs can be considered to be relatively uncorrelated. This similarity involves a limited number of peaks of force or acceleration, with approximately zero mean.

- UNCORRELATED OR RANDOM START TIME

- NEAR ZERO MEAN

- ANY OF THE FOLLOWING:

1) RESPONSES

$$\text{ALL } \frac{T_{50}}{\Delta T} \leq 0.08 \quad \text{AND} \quad \frac{T_{75}}{\Delta T} \leq 0.02$$

2) INPUT (LOAD)


$$\text{ALL } \frac{T_{50}}{\Delta T} \leq 0.04 \quad \text{AND} \quad \frac{T_{75}}{\Delta T} \leq 0.01$$

3) RESPONSES

$$\left(\frac{T_{50}}{\Delta T} \right)_e \leq 0.08, \quad \left(\frac{T_{75}}{\Delta T} \right)_e \leq 0.02$$

WHERE


$$\left(\frac{T_{75}}{\Delta T} \right)_e = \frac{\sqrt{\sum_{i=1}^n \left(\rho_{mT_{75}} / \Delta T \right)_i^2}}{\sqrt{\sum_{i=1}^n \left(\dot{r}_m \right)_i^2}}$$



$$T_{+75} = \sum \text{time that response exceeds } R_{+75}$$

$$T_{-75} = \sum \text{time that response less than } R_{-75}$$

$$T_{75} = \sum \text{larger of } T_{+75} \text{ or } T_{-75}$$



$$\underline{T_1 \geq T_2} ; \Delta T = T_1$$

FIGURE 1: Definition of Notation

FROM BROOKHAVEN

$$\underline{\underline{\frac{\sigma}{R_{\max}}} \lesssim 0.36 \quad \text{FOR SRSS COMBINATION}}$$

REQUIREMENT OF CRITERION 1

- RESPONSE HAS MEAN ZERO CENTERED
IF NORMALLY DISTRIBUTED :

$$\underline{R_x = f_x \cdot \sigma}$$

IF $\underline{\sigma = 0.36 R_{\max}}$

$$f_x = \frac{R_x}{\sigma} = \left(\frac{R_x}{R_{\max}} \right) \frac{1}{0.36} = \left(\frac{R_x}{R_{\max}} \right) (2.78)$$


$$\therefore \text{FOR } R_{50}/R_{\max} = 0.50 \rightarrow f_{50} = 1.39 \rightarrow P\left[\frac{R_{50}}{R_{\max}} > 0.50\right] = 0.082$$

$$\rightarrow \boxed{\frac{T_{50}}{\Delta T} \leq 0.08}$$

$$\text{FOR } R_{75}/R_{\max} = 0.75 \rightarrow f_{75} = 2.08 \rightarrow P\left[\frac{R_{75}}{R_{\max}} > 0.75\right] = 0.019$$

$$\rightarrow \boxed{\frac{T_{75}}{\Delta T} \leq 0.02}$$

DERIVATION OF NEW CRITERION 1



INT. EARTHQUAKE

$$\left\{ \begin{array}{l} \frac{T_{75}}{\Delta T} = 0.0083 \\ \frac{T_{50}}{\Delta T} = 0.0420 \end{array} \right.$$

CONCLUSIONS

- ③ RECENT SUPPORTIVE MK II/G.E. EFFORTS HAVE CONFIRMED THAT NEWMARK/KENNEDY CRITERION 2 REPRESENTS A CONSERVATIVE BASIS FOR JUDGING THE ACCEPTABILITY FOR THE SRSS COMBINATION OF RESPONSES.
- ③ PREVIOUS STUDIES USING REAL MK II RESPONSE TIME HISTORIES HAVE DEMONSTRATED THAT THE NEWMARK/KENNEDY CRITERION 1 IS MORE CONSERVATIVE THAN CRITERION 2. MEETING CRITERION 1 PROVIDES GOOD ASSURANCE OF MEETING CRITERION 2 FOR THE TYPES OF DYNAMIC LOADS EVALUATED IN THE MK II SRSS STUDY.
- ③ RECENT FINDINGS HAVE INDICATED SOME POTENTIAL AMBIGUITIES IN CRITERION 1 IF THE NEWMARK/KENNEDY CRITERIA IS TO BE APPLIED AS A GENERIC STANDARD. HOWEVER, N/K CRITERION 1 STILL REMAINS A CONSERVATIVE JUSTIFIABLE BASIS FOR JUDGING THE ACCEPTABILITY OF SRSS FOR THE TYPES OF LOADING COMBINATIONS CONSIDERED IN THE MK II SRSS STUDY.