

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-V-88-21 Date: 03-16-88

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information presented is as initially received without verification or evaluation and is basically all that is known by Region V staff on this date.

FACILITY: SACRAMENTO MUNICIPAL UTILITY DISTRICT
RANCHO SECO UNIT 1
DOCKET NO. 50-312
HERALD, CA

Emergency Classification
☒ Notification of Unusual Event
☐ Alert
☐ Site Area Emergency
☐ General Emergency
☐ Not Applicable

SUBJECT: COOLANT LEAK IN THE LETDOWN SYSTEM

On March 15, 1988 at 2230 PST, with the reactor in Hot Shutdown at normal operating temperature and pressure, a leak of about 100 gpm occurred from a downstream pressure relief valve (PSV 22021) while opening the upstream isolation valve to the 'A' Letdown Cooler (SFV 22005) for MOV testing. The leak was within the capacity of the Makeup Pump.

The leak started when SFV 22005 was opened, allowing RCS pressure (about 2200 psi) to be seen at the Cooler relief valve, PSV 22021. The relief setpoint of PSV 22021 is 2500 psi. In addition to blowdown through the tailpipe discharge to the Reactor Building Sump, the relief valve also blew a bonnet gasket which allowed leakage into the local containment atmosphere. The licensee shut SFV 22005 and isolated the leak at about 2237. Due to the valve testing in progress, the leak was initially thought to be a packing leak from SFV 22005. Inspection subsequent to the event determined the leak was from PSV 22021. Based on containment sump drainage, it was estimated that about 650 gallons of water was released. An Unusual Event was declared at 2249 and terminated at 2317 PST.

No radioactivity was released as a result of the leak.

The licensee is investigating the cause of the relief valve malfunction, and is in the process of repairing the valve. The licensee does not expect this to impact the restart schedule. The Senior Resident Inspector responded to the site upon the initial notification, and the resident inspection staff is continuing to review the event.

This information is current as of 10:00 a.m. PST.

CONTACT: L. Miller
FTS 463-3700

DISTRIBUTION BY 5520:

Date 3/16 Time 11:30

Chairman Zech	EDO	RI
Comm. Roberts	AEOD	RII
Comm. Bernthal	PAO	RIII
Comm. Carr	SLITP	RIV
Comm. Rogers	NRR	
SECY	NMSS	
CA	ARM	
PDR	OI	
OGC	OIA	
ACRS	RES	
GPA		

FAX TO:

Date _____ Time _____

INPO
NSAC
LICENSEE
RESIDENT INSPECTOR
HQS. OPERATIONS OFFICER

MAIL TO:

DCS (Original)
DOT: (Trans. Only, Applicable State)

8803220312 880316
PDR I&E
PNO-V-88-021 DCD

RV FORM 211
Revised: 8/19/87

0/1
IE-34