

(414) 221-2345

VPNFD-88-117 NRC-88-017

February 29, 1988

U.S. NUCLEAR REGULATORY COMMISSION Document Control Desk Washington, D.C. 20555

Attention: Mr. David H. Wagner, Project Manager Project Directorate III-3

Gentlemen:

DOCKETS NO. 50-266 AND 50-301 FIRE PROTECTION REQUIREMENT - 4160 VOLT SWITCHGEAR ROOM (TAC NOS. 60839 and 60840) POINT BEACH NUCLEAR PLANT UNITS 1 & 2

Your letter dated November 10, 1987, requested that we provide additional information regarding our proposed modifications to provide capability to bypass the 4160 volt vital switchgear room for remote shutdown system. Specifically, you requested that we describe how the proposed dedicated shutdown capability for the 4160 volt switchgear room meets each requirement of 10 CFR 50, Appendix R, Section III.L. We have provided this information in the attached report. As suggested, NRC stuff guidance on alternate/dedicated shutdown capability, as discussed in your Generic Letter 86-10, has also been considered in our evaluation.

Please contact us if you have any questions concerning our report.

Very truly yours,

C. W. Fay Vice President Nuclear Power

Attachment

A006

Copies to NRC Regional Administrator, Region III NRC Resident Inspector

8803	230230	880229
PDR		05000266
F		DCD