



5

ARKANSAS POWER & LIGHT COMPANY  
POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000

October 13, 1978

1-173-4

Mr. K. V. Seyfrit, Director  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region IV  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

Subject: Arkansas Nuclear One - Unit 1  
Docket No. 50-313  
License No. DPR-51  
Reportable Occurrence  
Report Nos. 50-313/78-25,  
50-313/78-26, and 50-313/  
78-27  
(File: 0520)

Gentlemen:

In accordance with Arkansas Nuclear One-Unit 1 Technical Specifications 6.2.3.2, we have attached three (3) Reportable Occurrence Reports concerning: The rod index being out of limits (78-25); the BWST boron concentration being out of limits (78-26); and the condensate storage tank level being below the 16.3 feet level (78-26).

Very truly yours,

A handwritten signature in cursive script that reads "Daniel H. Williams".

Daniel H. Williams  
Manager, Licensing

DHW:REI:vb

Attachments

781106 0115

A002  
5/11