

# VOGTLE ELECTRIC GENERATING PLANT

## UNITS 1 & 2

### SECOND 10 -YEAR INTERVAL

### PUMP INSERVICE TEST PROGRAM

| R<br>E<br>V | DATE     | DESCRIPTION                                  | ITS<br>PREP'D<br>BY | ITS<br>REV'D<br>BY | ITS<br>APPV'D<br>BY | VNMS<br>APPV'D<br>BY |
|-------------|----------|--|---------------------|--------------------|---------------------|----------------------|
| 0           | 12/06/96 | INITIAL ISSUE TO VEGP FOR REVIEW & APPROVAL. | <i>DMS</i>          | <i>WDM</i>         | <i>DMS</i>          | <i>TU6</i>           |

| VEGP IST APPROVAL |   |
|-------------------|---|
| IST Engr:         | <i>[Signature]</i> 5/6/97                   |
| Engr. Supv:       | <i>W Burmiste</i> 5-7-97                    |
| Mgr. Engr:        | <i>W Burmiste</i> 5-7-97                    |
| ANLI:             | <i>Frank E. Bellamy</i> ANIE HSAI416 5-8-97 |
| PRB: Mtg. No:     | <i>APB 97-38</i> <i>[Signature]</i>         |
| Date:             | <i>5/13/97</i>                              |
| Gen. Mgr:         | <i>[Signature]</i> 5/15/97                  |

9706030209 970529  
PDR ADOCK 05000424  
P PDR

Vogtle Electric Generating Plant  
Route 2, Box 299-A  
Waynesboro, GA 30830

6/3-209

## DISTRIBUTION LIST

### HOLDER

### MANUAL NUMBER

|                                      |   |
|--------------------------------------|---|
| K. G. Lowery (SCS)                   | 1 |
| T. M. Hickox                         | 2 |
| J. J. Churchwell                     | 3 |
| SNC Site Document Control Supervisor | 4 |
| SNC Site Performance Supervisor      | 5 |
| K. L. Glandon                        | 6 |
| J. C. McWhorter                      | 7 |
| ITS Department Shelf Copy            | 8 |

**TABLE OF CONTENTS**  
(See Active Page List for Current Revision)

| <u>SECTION</u>                        | <u>PAGES</u>               |
|---------------------------------------|----------------------------|
| PROGRAM INTRODUCTION                  | 1-1 thru 1-2               |
| ABBREVIATIONS LIST                    | 2-1 thru 2-2               |
| PUMP INTRODUCTION                     | 3-1 thru 3-9               |
| VEGP 1 PUMP TABLES                    | 4-1 thru 4-8               |
| NSCW PUMPS<br>NSCW PUMP TEST DIAGRAMS | 5-1 thru 5-10<br>8 pages   |
| CCW PUMPS<br>CCW PUMP TEST DIAGRAMS   | 6-1 thru 6-7<br>6 pages    |
| SI PUMPS<br>SI PUMP TEST DIAGRAMS     | 7-1 thru 7-3<br>2 pages    |
| RHR PUMPS<br>RHR PUMP TEST DIAGRAMS   | 8-1 thru 8-3<br>2 pages    |
| CS PUMPS<br>CS PUMP TEST DIAGRAMS     | 9-1 thru 9-3<br>2 pages    |
| CVCS PUMPS<br>CVCS PUMP TEST DIAGRAMS | 10-1 thru 10-3<br>2 pages  |
| BAT PUMPS<br>BAT PUMP TEST DIAGRAMS   | 11-1 thru 11-3<br>2 pages  |
| AFW PUMPS<br>AFW PUMP TEST DIAGRAMS   | 12-1 thru 12-6<br>3 pages  |
| ESF PUMPS<br>ESF PUMP TEST DIAGRAMS   | 13-1 thru 13-3<br>2 pages  |
| VEGP-2 PUMP TABLES                    | 14-1 thru 14-8             |
| NSCW PUMPS<br>NSCW PUMP TEST DIAGRAMS | 15-1 thru 15-10<br>8 pages |
| CCW PUMPS<br>CCW PUMP TEST DIAGRAMS   | 16-1 thru 16-7<br>6 pages  |

Table of Contents (cont.)

|                         |                |
|-------------------------|----------------|
| SI PUMPS                | 17-1 thru 17-3 |
| SI PUMP TEST DIAGRAMS   | 2 pages        |
| RHR PUMPS               | 18-1 thru 18-3 |
| RHR PUMP TEST DIAGRAMS  | 2 pages        |
| CS PUMPS                | 19-1 thru 19-3 |
| CS PUMP TEST DIAGRAMS   | 2 pages        |
| CVCS PUMPS              | 20-1 thru 20-3 |
| CVCS PUMP TEST DIAGRAMS | 2 pages        |
| BAT PUMPS               | 21-1 thru 21-3 |
| BAT PUMP TEST DIAGRAMS  | 2 pages        |
| AFW PUMPS               | 22-1 thru 22-6 |
| AFW PUMP TEST DIAGRAMS  | 3 pages        |
| ESF PUMPS               | 23-1 thru 23-3 |
| ESF PUMP TEST DIAGRAMS  | 2 pages        |
| RELIEF REQUESTS         | 24-1 thru 24-5 |

## ACTIVE PAGE LIST

| <u>Page No.</u> | <u>Rev. No.</u> | <u>Page No.</u> | <u>Rev. No.</u> |
|-----------------|-----------------|-----------------|-----------------|
| 1 - 1           | 0               | 6 - 6           | 0               |
| 1 - 2           | 0               | 6 - 7           | 0               |
| 2 - 1           | 0               | ISI-D-209       | 2               |
| 2 - 2           | 0               | ISI-D-210       | 2               |
| 3 - 1           | 0               | ISI-D-211       | 2               |
| 3 - 2           | 0               | ISI-D-212       | 2               |
| 3 - 3           | 0               | ISI-D-213       | 2               |
| 3 - 4           | 0               | ISI-D-214       | 2               |
| 3 - 5           | 0               | 7 - 1           | 0               |
| 3 - 6           | 0               | 7 - 2           | 0               |
| 3 - 7           | 0               | 7 - 3           | 0               |
| 3 - 8           | 0               | ISI-D-215       | 3               |
| 3 - 9           | 0               | ISI-D-216       | 3               |
| 4 - 1           | 0               | 8 - 1           | 0               |
| 4 - 2           | 0               | 8 - 2           | 0               |
| 4 - 3           | 0               | 8 - 3           | 0               |
| 4 - 4           | 0               | ISI-D-217       | 6               |
| 4 - 5           | 0               | ISI-D-218       | 6               |
| 4 - 6           | 0               | 9 - 1           | 0               |
| 4 - 7           | 0               | 9 - 2           | 0               |
| 4 - 8           | 0               | 9 - 3           | 0               |
| 5 - 1           | 0               | ISI-D-219       | 3               |
| 5 - 2           | 0               | ISI-D-220       | 3               |
| 5 - 3           | 0               | 10 - 1          | 0               |
| 5 - 4           | 0               | 10 - 2          | 0               |
| 5 - 5           | 0               | 10 - 3          | 0               |
| 5 - 6           | 0               | ISI-D-221       | 5               |
| 5 - 7           | 0               | ISI-D-222       | 5               |
| 5 - 8           | 0               | 11 - 1          | 0               |
| 5 - 9           | 0               | 11 - 2          | 0               |
| 5 - 10          | 0               | 11 - 3          | 0               |
| ISI-D-201       | 2               | ISI-D-228       | 3               |
| ISI-D-202       | 2               | ISI-D-229       | 3               |
| ISI-D-203       | 2               | 12 - 1          | 0               |
| ISI-D-204       | 2               | 12 - 2          | 0               |
| ISI-D-205       | 2               | 12 - 3          | 0               |
| ISI-D-206       | 2               | 12 - 4          | 0               |
| ISI-D-207       | 3               | 12 - 5          | 0               |
| ISI-D-208       | 3               | 12 - 6          | 0               |
| 6 - 1           | 0               | ISI-D-223       | 2               |
| 6 - 2           | 0               | ISI-D-224       | 2               |
| 6 - 3           | 0               | ISI-D-225       | 2               |
| 6 - 4           | 0               | 13 - 1          | 0               |
| 6 - 5           | 0               | 13 - 2          | 0               |

| <u>Page No.</u> | <u>Rev. No.</u> | <u>Page No.</u> | <u>Rev. No.</u> |
|-----------------|-----------------|-----------------|-----------------|
| 13 - 3          | 0               | 17 - 4          | 0               |
| ISI-D-226       | 3               | ISI-D-264       | 2               |
| ISI-D-227       | 3               | ISI-D-265       | 2               |
| 14 - 1          | 0               | 18 - 1          | 0               |
| 14 - 2          | 0               | 18 - 2          | 0               |
| 14 - 3          | 0               | 18 - 3          | 0               |
| 14 - 4          | 0               | 18 - 4          | 0               |
| 14 - 5          | 0               | ISI-D-266       | 3               |
| 14 - 6          | 0               | ISI-D-267       | 3               |
| 14 - 7          | 0               | 19 - 1          | 0               |
| 14 - 8          | 0               | 19 - 2          | 0               |
| 15 - 1          | 0               | 19 - 3          | 0               |
| 15 - 2          | 0               | ISI-D-268       | 4               |
| 15 - 3          | 0               | ISI-D-269       | 4               |
| 15 - 4          | 0               | 20 - 1          | 0               |
| 15 - 5          | 0               | 20 - 2          | 0               |
| 15 - 6          | 0               | 20 - 3          | 0               |
| 15 - 7          | 0               | ISI-D-270       | 5               |
| 15 - 9          | 0               | ISI-D-271       | 2               |
| 15 - 8          | 0               | 21 - 1          | 0               |
| 15 - 10         | 0               | 21 - 2          | 0               |
| ISI-D-250       | 5               | 21 - 3          | 0               |
| ISI-D-251       | 2               | ISI-D-277       | 2               |
| ISI-D-252       | 2               | ISI-D-278       | 2               |
| ISI-D-253       | 2               | 22 - 1          | 0               |
| ISI-D-254       | 2               | 22 - 2          | 0               |
| ISI-D-255       | 2               | 22 - 3          | 0               |
| ISI-D-256       | 2               | 22 - 4          | 0               |
| ISI-D-257       | 3               | 22 - 5          | 0               |
| 16 - 1          | 0               | 22 - 6          | 0               |
| 16 - 2          | 0               | ISI-D-272       | 2               |
| 16 - 3          | 0               | ISI-D-273       | 2               |
| 16 - 4          | 0               | ISI-D-274       | 2               |
| 16 - 5          | 0               | 23 - 1          | 0               |
| 16 - 6          | 0               | 23 - 2          | 0               |
| 16 - 7          | 0               | 23 - 3          | 0               |
| ISI-D-258       | 2               | ISI-D-275       | 3               |
| ISI-D-259       | 2               | ISI-D-276       | 3               |
| ISI-D-260       | 2               | 24 - 1          | 0               |
| ISI-D-261       | 2               | 24 - 2          | 0               |
| ISI-D-262       | 2               | 24 - 3          | 0               |
| ISI-D-263       | 2               | 24 - 4          | 0               |
| 17 - 1          | 0               | 24 - 5          | 0               |
| 17 - 2          | 0               |                 |                 |
| 17 - 3          | 0               |                 |                 |

## 1.0 PUMP IST PROGRAM INTRODUCTION

### 1.1 GENERAL

This document describes the Pump Inservice Testing (IST) Program for the Vogtle Electric Generating Plant (VEGP), Units 1 and 2. Provided below are important dates relative to the IST Program.

|                       | VEGP-1                    | VEGP-2                     |
|-----------------------|---------------------------|----------------------------|
| Construction Permit:  | 06-28-74                  | 06-28-74                   |
| Commercial Operation: | 05-31-87                  | 05-20-89                   |
| 1st 10-Year Interval: | 05-31-87 to<br>05-30-97   | 05-20-89 to<br>05-30-97*   |
| 2nd 10-Year Interval: | 05-31-97 to<br>05-30-2007 | 05-31-97* to<br>05-30-2007 |

\* VEGP-2 was updated at the same time as VEGP-1 for the 2nd 10-Year Interval in order to utilize the same Code edition for both units (See Relief Request RR-G-2 which is included in the Valve IST Program document).

The edition of 10 CFR 50.55a current on May 31, 1996, was used to determine the applicable Code(s) of record for this program update. 10 CFR 50.55a identified the ASME Section XI Code, 1989 Edition, as the applicable Code. The 1989 edition of ASME XI references OM Part 6 (IWP) as being applicable for pump testing. 10 CFR 50.55a(b)(2)(viii) references the OMa-1988 Addenda to the OM-1987 Edition of ANSI/ASME part 6 for pump testing.

ASME issued the OM Code-1990 Edition which included requirements for pump, valve, relief valve and dynamic restraint inservice testing, and subsequently issued the Omb-1992 Addenda, the OMc-1994 Addenda, the OM-1995 Edition and the OMa-1996 Addenda. Therefore, the below listed Code version is being utilized for pump IST at VEGP as described in Relief Request RR-G-1. (RR-G-1 is included in the Valve IST Program document.) The NRC approved the use of the ASME OM Code-1990 Edition for pump testing at Plant Vogtle in a letter dated November 27, 1996.

#### ASME OM Code -1990 Edition Subsections ISTA and ISTB

This program document includes IST requirements for safety-related ASME Code Class 1, 2 and 3 pumps. NRC Generic Letter 89-04 and Supplement 1 (NRC NUREG-1482) were used, to the extent practical, for guidance in the development of this program.

### 1.2 EFFECTIVE DATE

The Pump IST Program, for the 2nd 10-Year Interval, will become effective on May 31, 1997 and will be utilized through May 30, 2007 unless federal regulations are revised otherwise.

### 1.3 SCOPE

This document is a description of the Pump IST Program to be implemented for Units 1 and 2 at VEGP. This document describes only the IST surveillance testing applicable to safety-related ASME Code Class 1, 2 and 3 pumps included in the program.

### 1.4 SUBSEQUENT PROGRAM REVISIONS

It is anticipated that this document will be reviewed again near the end of the 120 month interval and compared to a later NRC approved version of the ASME Code applicable for IST. At that time, the program will be modified, if required, to comply to the extent practical with the later Code edition. Any additional relief requests for impractical requirements will be submitted in accordance with the applicable regulations.

### 1.5 RESPONSIBILITY

Southern Nuclear Operating Company, being license holder and agent for Georgia Power Company (Owner), bears the overall responsibility for the implementation of the inservice testing activities contained in this program per the ASME OM Code - 1990 Edition, Subsection ISTA 1.4.

### 1.6 RECORDS

Records and documentation of information and testing results, which provide the basis for evaluation and which facilitate comparison with results from previous and subsequent tests, will be maintained and available for the active life of the component or system in accordance with the ASME OM Code - 1990 Edition, Subsection ISTA 3.

### 1.7 METHODS OF TESTING

The method of testing applicable to each pump is listed adjacent to the component identification in the Pump IST Program Tables. The ASME OM Code does not stipulate any specific training/certification requirements for personnel involved in pump testing. At Plant Vogtle, all pump testing is performed by operations, maintenance or engineering personnel who have been trained to perform specific testing tasks.

### 1.8 STANDARDS FOR TESTING EVALUATION

The acceptance criteria applicable for each pump to be tested have been developed in accordance with the ASME OM Code requirements as modified by any applicable relief requests. Acceptance criteria are not provided in the IST Program document, but are provided in the applicable surveillance testing procedures which are available for review at the plant site.



## ABBREVIATIONS LIST

| <u>Abbreviation</u> | <u>Definition</u>                        |
|---------------------|--|
| Acc                 | Accuracy                                 |
| AFW                 | Auxiliary Feedwater                      |
| Amp.                | Amplitude                                |
| ASME                | American Society of Mechanical Engineers |
| atm                 | Atmospheric                              |
| Aux                 | Auxiliary                                |
| Bldg                | Building                                 |
| CC                  | ASME Code Class                          |
| CCW                 | Component Cooling Water                  |
| Coord.              | Coordinate                               |
| CS                  | Containment Spray                        |
| CVCS                | Chemical Volume & Control System         |
| $\Delta P$          | Pump Differential Pressure               |
| $\Delta Pr$         | Reference Differential Pressure          |
| Differ.             | Differential                             |
| ECCS                | Emergency Code Cooling System            |
| ESF                 | Engineered Safety Feature                |
| F                   | Fahrenheit                               |
| FI                  | Flowrate Indicator                       |
| ft                  | Feet                                     |
| Freq.               | Frequency                                |
| GPC                 | Georgia Power Company                    |
| gpm                 | Gallons Per Minute                       |
| Hz                  | Hertz                                    |
| I.D.                | Identification                           |
| in/s                | Inches Per Second                        |
| IST                 | Inservice Testing                        |
| kW                  | Kilowatt                                 |
| LOCA                | Loss Of Coolant Accident                 |
| LI                  | Level Indicator                          |
| NA                  | Not Applicable                           |
| N                   | Speed                                    |
| No.                 | Number                                   |
| NPSH                | Net Positive Suction Head                |
| NSCW                | Nuclear Service Cooling Water            |
| OM                  | ASME OM Code                             |
| PC                  | Vogtle Plant Project Class               |
| P&ID                | Piping & Instrumentation Diagram         |
| Pi                  | Pump Inlet Pressure                      |
| PI                  | Pressure Indicator                       |
| Po                  | Pump Outlet Pressure                     |
| psig                | Pounds Per Square Inch                   |

Abbreviations (cont.)

Abbreviation

Definition

|      |                                    |
|------|------------------------------------|
| Q    | Pump Flowrate                      |
| Qtr. | Quarterly                          |
| Qr   | Reference Flowrate                 |
| RCS  | Reactor Coolant System             |
| Ref. | Reference                          |
| Req. | Required                           |
| RHR  | Residual Heat Removal              |
| rpm  | Revolutions Per Minute             |
| RR   | Relief Request                     |
| SI   | Safety Injection                   |
| SI   | Speed Indicator                    |
| SNC  | Southern Nuclear Operating Company |
| V    | Vibration                          |
| VEGP | Vogtle Electric Generating Plant   |
| Vib. | Vibration                          |
| Vr   | Reference Vibration Amplitude      |

## INTRODUCTION

### A. Regulatory Position

This document defines the testing requirements for the pumps included for inservice testing (IST) at Southern Nuclear Operating Company's (SNC) Vogtle Electric Generating Plant (VEGP) Unit 1 and 2. This Pump IST Program was developed to comply with the provisions of 10 CFR 50.55a. The Code of record applicable for this program is the ASME OM Code - 1990 Edition. NRC Generic Letter 89-04 and its Supplement 1 (NUREG-1482) were used for guidance, to the extent practical, in the development of this program document.

### B. Scope

In accordance with 10 CFR 50.55a and NRC Regulatory Guide 1.26 (water, steam and radioactive waste containing systems), ASME Code Class 1, 2 and 3 safety-related pumps which perform a function required in; 1) shutting the reactor down to the cold shutdown condition, 2) maintaining the cold shutdown condition, 3) or mitigating the consequences of an accident, and are provided with an emergency power source, are included in this program document for inservice testing.

It was recognized that 10 CFR 50, Appendix A, General Design Criteria 1, and Appendix B, Criterion XI, intended that all pumps necessary for safe operation of the plant be tested to demonstrate that they will perform satisfactorily in service. The subject testing is to be performed to a level commensurate with the safety significance of the pump. For those non-ASME Code Class 1, 2 and 3 pumps, this testing is performed in accordance with the plant technical specifications and/or other plant testing programs and is not included in this program document.

The determination as to whether a pump should be included in this testing program was performed by review and evaluation of the Updated Final Safety Analysis Reports (UFSAR) and other design and licensing documents. These documents were reviewed to determine which pumps are required to respond to the design basis accident scenarios and provide a function required to shutdown the reactor, maintain the shutdown condition, or mitigate the consequences of the accident.

### C. Testing Requirements

A description of the ASME OM Code testing requirements applicable to pumps is provided in each section. The ASME OM Code-1990 Edition should be used in conjunction with this description to ensure a complete identification of the testing requirements. Subsection ISTB of the ASME OM Code is applicable for pump inservice testing and the applicable ISTB paragraph is listed in parenthesis for cross reference.

#### 1. **Definitions (ISTB 1.3)**

The below listed definitions are provided for easy reference as they are applicable to VEGP and are used in subsequent sections of this introduction.

*inservice test* - a test to determine the operational readiness of a pump

*instrument accuracy* - the allowable inaccuracy of an instrument loop based on the square root of the sum of the square of the inaccuracies of each instrument or component in the loop

*instrument loop* - two or more instruments or components working together to provide a single output (e.g., a vibration probe and its associated signal conditioning and readout devices)

*operational readiness* - the ability of a pump to perform its intended function

*preservice test period* - the period of time after completion of construction activities related to the pump and before first electrical generation by nuclear heat, in which component and system testing take place

*pump* - a mechanical device used to move liquid

*reference values* - one or more values of test parameters measured or determined when the equipment is known to be operating acceptably

*routine servicing* - the performance of planned, preventative maintenance (e.g., replacing or adjusting valves in reciprocating pumps, changing oil, flushing the cooling system, adjusting packing, adding packing rings or mechanical seal maintenance or replacement)

*system resistance* - the hydraulic resistance to flow in a system

## 2. Reference Information (ISTB 2)

The hydraulic and mechanical condition of a pump relative to a previous condition can be determined by attempting to duplicate by test a set of reference values. Deviations detected are symptoms of changes and, depending upon the degree of deviation, indicate need for further tests or corrective action.

## 3. Owner's Responsibility (ISTB 3.1)

Each pump to be tested in accordance with this program shall be identified by the Owner and listed in the plant records.

## 4. Testing Requirements (ISTB 4)

### A. Preservice Testing (ISTB 4.1)

Each pump shall be tested during the preservice test period. These tests shall be conducted under conditions as near as practical to those expected during subsequent inservice testing. Only one preservice test is required for each pump, except when a pump is repaired or replaced (see C.4.D).

#### B. Inservice Testing (ISTB 4.2)

Inservice testing shall commence when the pump is required to be operable (see C.5.C).

#### C. Reference Values (ISTB 4.3)

Initial reference values shall be determined from the results of the preservice test or from the results of the first inservice test.

Reference values shall be established at points of operation readily duplicated during subsequent testing.

All subsequent test results shall be compared to these initial reference values or to new reference values as appropriate (see C.4.E).

Reference values shall only be established when the pump is known to be operating acceptably.

If the particular parameter being measured or determined can be significantly influenced by other related conditions, then these conditions shall be analyzed.

#### D. Effect of Pump Replacement, Repair, and Maintenance on Reference Values (ISTB 4.4)

When a reference value or set of reference values may have been affected by repair, replacement, or routine servicing of a pump, a new reference value or set of reference values shall be established in accordance with C.4.C above (ISTB 4.3), or the previous value(s) reconfirmed by an inservice test run before declaring the pump operable.

Deviations between the previous and new reference value(s) shall be evaluated, and verification that the new reference value(s) represent acceptable pump operation shall be placed in the record of tests.

#### E. Establishment of Additional Set of Reference Values (ISTB 4.5)

If necessary or desirable, for some reason other than stated in C.4.D above, to establish an additional set of reference values, an inservice test shall be run at the conditions of an existing set of reference values and the results analyzed. If operation is acceptable per C.5.B (ISTB 6.2), then a second test run at new reference conditions shall follow as soon as practical. The results of this test shall establish the additional set of reference values.

Whenever new reference values are established, the reason for doing so shall be documented in the record of tests.

#### F. Instrumentation (ISTB 4.6)

Instrument accuracy shall be within the limits of the below table (Table ISTB 4.6.1-1). Station instruments meeting these requirements are acceptable.

#### **ACCEPTABLE INSTRUMENT ACCURACY (Table ISTB 4.6.1-1)**

| <b>Quantity</b>       | <b>Percent<br/>[Note (1)]</b> |
|-----------------------|-------------------------------|
| Pressure              | ± 2%                          |
| Flow Rate             | ± 2%                          |
| Speed                 | ± 2%                          |
| Vibration             | ± 5%                          |
| Differential Pressure | ± 2%                          |

**NOTE:**

(1) Percent of full scale for individual analog instruments, percent of total loop accuracy for a combination of instruments, or over the calibrated range for digital instruments.

The full-scale range of analog instruments shall not be greater than three times the reference value.

Digital instruments shall be selected such that the reference value does not exceed 70% of the calibrated range of the instrument.

Vibration instruments are excluded from the range requirements stated above. The frequency response range of vibration measuring transducers and their readout system shall be from one-third minimum pump operating speed to at least 1000 Hz.

The Owner shall be responsible for establishing the location of instruments used for inservice testing. The location shall be appropriate for the parameter being measured and the same location shall be used for subsequent tests. Instruments that are position-sensitive shall be either permanently mounted, or provisions shall be made to duplicate their position during each test.

Instruments and instrument loops shall be calibrated in accordance with the Owner's quality assurance program. New or repaired instruments shall be calibrated before test use.

#### G. Pressure Measurements (ISTB 4.6.2)

Differential pressure across a pump may be determined using a differential pressure gage or a differential pressure transmitter that provides direct measurement of pressure difference, or the difference between pump discharge pressure and pump inlet pressure shall be used.

#### H. Rotational Speed Measurements (ISTB 4.6.3)

Rotational speed measurements of variable speed pumps shall be measured by a method that meets the instrument accuracy requirements of the above instrument accuracy table (C.4.F).

#### I. Vibration Measurements (ISTB 4.6.4)

On centrifugal pumps, vibration measurements shall be taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing. Measurement shall also be taken in the axial direction on each accessible pump thrust bearing housing.

On vertical line shaft pumps, measurements shall be taken on the upper motor-bearing housing in three orthogonal directions, one of which is the axial direction.

If portable vibration instruments are used, the measurement points shall be clearly identified on the pump to permit repeatability in both location and plane.

#### J. Flow Rate Measurements (ISTB 4.6.5)

Flow rate shall be measured using a rate or quantity meter installed in the pump test circuit. If the meter does not indicate flow rate directly, the record of tests shall include the method used to reduce the data.

### 5. **Testing Methods (ISTB 5)**

#### A. Frequency of Inservice Tests (ISTB 5.1)

An inservice test shall be performed on each pump nominally every 3 months except for pumps that are declared inoperable or are not required to be operable.

#### B. Test Procedure (ISTB 5.2)

An inservice tests shall be conducted with the pump operating at specified test reference conditions. The test parameters listed in the below tables shall be determined and recorded.

**INSERVICE TEST PARAMETERS (Table ISTB 5.2-1)**

| Quantity                          | Remarks  |
|-----------------------------------|--|
| Speed, N                          | If variable speed pump                                 |
| Differential Pressure, $\Delta P$ | Centrifugal pumps, including vertical line shaft pumps |
| Discharge Pressure, P             | Positive displacement pumps                            |
| Flow Rate, Q                      | All pumps  |
| Vibration                         |  |
| Displacement, Vd                  | Peak-to-Peak   |
| Velocity, Vv                      | Peak   |

The pump shall be operated at nominal motor speed for a constant speed driver or at a speed adjusted to the reference point for variable speed drivers.

The resistance of the system shall be adjusted until the flow rate equals the reference value. The differential pressure shall then be determined and compared to the reference value. Alternately, the flow rate shall be varied until the differential pressure equals the reference value and the flow rate determined and compared to the reference flow rate value.

If system resistance cannot be varied, flow rate and pressure shall be determined and compared to their respective reference values.

Pressure, flow rate, and vibration shall be determined and compared with the corresponding reference values. All deviations from the reference values shall be compared with the acceptance criteria listed below and corrective action shall be taken as specified in Section C.6.

Vibration measurements shall be broad band (unfiltered). Velocity measurements shall be peak and displacement amplitudes shall be peak-to-peak respectfully.



### VIBRATION ACCEPTANCE CRITERIA (Table ISTB 5.2-2a)

| Pump Type                                  | Pump Speed     | Test Parameter | Acceptable Range | Alert Range  | Required Action Range              |
|--|----------------|----------------|------------------|--|------------------------------------|
| Centrifugal & Vertical Line Shaft (Note 2) | <600 rpm       | Vd or Vv       | $\leq 2.5V_r$    | >2.5V <sub>r</sub> to 6V <sub>r</sub> or<br>>10.5 to 22 mils     | >6V <sub>r</sub> or<br>>22 mils    |
| Centrifugal & Vertical Line Shaft (Note 2) | $\geq 600$ rpm | Vv or Vd       | $\leq 2.5V_r$    | >2.5V <sub>r</sub> to 6V <sub>r</sub> or<br>>0.325 to 0.7 in/sec | >6V <sub>r</sub> or<br>>0.7 in/sec |
| Reciprocating                              |                | Vd or Vr       | $\leq 2.5V_r$    | >2.5V <sub>r</sub> to 6V <sub>r</sub>                            | >6V <sub>r</sub>                   |

**NOTES:**

- (1) V<sub>r</sub> is reference vibration value in selected units.
- (2) Refer to OM Code Figure ISTB 5.2-1 to establish displacement limits for pumps with speeds  $\geq 600$  rpm or velocity limits for pumps with speeds  $\leq 600$  rpm.

### HYDRAULIC ACCEPTANCE CRITERIA (Table ISTB 5.2-2b)

| Test Parameter  | Acceptable Range           | Alert Range                 | Required Action Range |                     |
|---|----------------------------|-----------------------------|-----------------------|---------------------|
|   |                            |                             | Low                   | High                |
| P (Positive Displacement Pumps)                         | 0.93 to 1.10P <sub>r</sub> | 0.90 to <0.93P <sub>r</sub> | <0.90P <sub>r</sub>   | >1.10P <sub>r</sub> |
| $\Delta P$ (Vertical Line Shaft Pumps)                  | 0.95 to 1.10 $\Delta P_r$  | 0.93 to <0.95 $\Delta P_r$  | <0.93 $\Delta P_r$    | >1.10 $\Delta P_r$  |
| Q (Positive Displacement and Vertical Line Shaft Pumps) | 0.95 to 1.10Q <sub>r</sub> | 0.93 to <0.95Q <sub>r</sub> | <0.93Q <sub>r</sub>   | >1.10Q <sub>r</sub> |
| $\Delta P$ (Centrifugal Pumps)                          | 0.90 to 1.10 $\Delta P_r$  | none                        | <0.90 $\Delta P_r$    | >1.10 $\Delta P_r$  |
| Q (Centrifugal Pumps)                                   | 0.90 to 1.10Q <sub>r</sub> | none                        | <0.90Q <sub>r</sub>   | >1.10Q <sub>r</sub> |

#### C. Pumps In Systems Out of Service (ISTB 5.4)

For a pump in a system declared inoperable or not required to be operable, the test schedule need not be followed. However, within 3 months before the system is placed in an operable status, the pump shall be tested. Pumps that can only be tested during plant operation shall be tested within 1 week following startup.

#### D. Duration of Tests (ISTB 5.6)

After pump conditions are as stable as the system permits, each pump shall be run for at least 2 minutes prior to measuring any of the required test parameters.

**6. Analysis and Evaluation (ISTB 6)**

**A. Acceptance Criteria (ISTB 6.1)**

If the measured test parameter values fall within the alert range of the applicable table (see C.5 above), the frequency of testing shall be doubled until the cause of the deviation is determined and the condition is corrected.

If the measured test parameter values fall within the required action range of the applicable table (see C.5 above), the pump shall be declared inoperable until either the cause of the deviation has been determined and the condition corrected. (See Relief Request RR-P-2)

When a test shows measured parameter values that fall outside the acceptable ranges that have resulted from an identified system error (e.g. improper system lineup, inaccurate instruments) the test shall be rerun after correcting the error.

**B. Time Allowed for Analysis of Tests (ISTB 6.2)**

All test data shall be analyzed within 96 hours after completion of test.

**7. Records and Reports (ISTB 7)**

**A. Pump Records (ISTB 7.1)**

The Owner shall maintain a record, for each pump included in the program, that includes the following information:

- (a) the manufacturer and the manufacturer's model and serial number or other identification number;
- (b) a copy or summary of the manufacturer's acceptance test report if available; and
- (c) a copy of the pump manufacturer's operating limits.

**B. Inservice Test Plans (ISTB 7.2)**

The Owner shall maintain a record of test plans and procedures that shall include the following:

- (a) the hydraulic circuit to be used;
- (b) the location and type of measurements for the required test parameters;
- (c) the reference values; and
- (d) the method of determining test parameter values that are not directly measured by instrumentation.

This Pump IST Program document in conjunction with the pump surveillance test procedures satisfy the above requirement.

### C. Record of Tests (ISTB 7.3)

The Owner shall maintain a record of each test that shall include the following:

- (a) pump identification;
- (b) date of test;
- (c) reason for test (e.g. post-maintenance, routine inservice test, or establishing new reference values);
- (d) values of measured parameters;
- (e) identification of instruments used;
- (f) comparisons with allowable ranges of test values and analysis of deviations;
- (g) requirements for corrective action;
- (h) evaluation and justification for changes to reference values; and
- (i) signature of the person(s) responsible for conducting and analyzing the test data.

This Pump IST Program document in conjunction with the pump surveillance test procedures satisfy the above requirement.

### D. Record of Corrective Action (ISTB 7.4)

The Owner shall maintain records of corrective action that shall include a summary of the corrections made, the subsequent inservice tests and confirmation of operational adequacy, and the signature of the individual(s) responsible for corrective action and verification of results.

VEGP-1 PUMP TEST TABLE

Nuclear Service Cooling Water - System 1202

| <u>LD. Number</u> | <u>CC/PC</u> | <u>P&amp;ID-Sheet No.</u> | <u>Coord.</u> | <u>Description</u> | <u>Measured Parameters &amp; Frequency</u> |                    |                   |                      |                   | <u>RR/Remarks</u> |
|-------------------|--------------|---------------------------|---------------|--------------------|--|--------------------|-------------------|----------------------|-------------------|-------------------|
|                   |              |                           |               |                    | <u>P<sub>o</sub></u><br>(psig)             | <u>ΔP</u><br>(psf) | <u>Q</u><br>(gpm) | <u>V</u><br>(in/sec) | <u>N</u><br>(rpm) |                   |
| 1-1202-P4-001     | 3/313        | 1X4DB133-1                | C-8           | NSCW Pump          | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 1-1202-P4-002     | 3/313        | 1X4DB133-2                | C-6           | NSCW Pump          | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 1-1202-P4-003     | 3/313        | 1X4DB133-1                | C-5           | NSCW Pump          | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 1-1202-P4-004     | 3/313        | 1X4DB133-2                | C-5           | NSCW Pump          | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 1-1202-P4-005     | 3/313        | 1X4DB133-1                | C-7           | NSCW Pump          | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 1-1202-P4-006     | 3/313        | 1X4DB133-2                | C-7           | NSCW Pump          | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 1-1202-P4-007     | 3/313        | 1X4DB133-1                | C-6           | NSCW Transfer Pump | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 1-1202-P4-008     | 3/313        | 1X4DB133-2                | C-6           | NSCW Transfer Pump | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |

Test Frequency: QTR = Quarterly Pump Test

**VEGP-1 PUMP TEST TABLE**

Component Cooling Water - System 1203

| <u>LD. Number</u> | <u>CC/PC</u> | <u>P&amp;ID-Sheet No.</u> | <u>Coord.</u> | <u>Description</u> | <u>Measured Parameters &amp; Frequency</u> |                    |                   |                      |                   | <u>RR/Remarks</u> |
|-------------------|--------------|---------------------------|---------------|--------------------|--|--------------------|-------------------|----------------------|-------------------|-------------------|
|                   |              |                           |               |                    | <u>P<sub>0</sub></u><br>(psig)             | <u>ΔP</u><br>(psf) | <u>Q</u><br>(gpm) | <u>V</u><br>(in/sec) | <u>N</u><br>(rpm) |                   |
| 1-1203-P4-001     | 3/313        | 1X4DB136                  | H-4           | CCW Pump           | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 1-1203-P4-002     | 3/313        | 1X4DB136                  | D-4           | CCW Pump           | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 1-1203-P4-003     | 3/313        | 1X4DB136                  | G-4           | CCW Pump           | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 1-1203-P4-004     | 3/313        | 1X4DB136                  | C-4           | CCW Pump           | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 1-1203-P4-005     | 3/313        | 1X4DB136                  | F-4           | CCW Pump           | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 1-1203-P4-006     | 3/313        | 1X4DB136                  | B-4           | CCW Pump           | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |

Test Frequency: QTR = Quarterly Pump Test

**VEGP-1 PUMP TEST TABLE**

Safety Injection - System 1204

| <u>LD. Number</u> | <u>CC/PC</u> | <u>P&amp;ID-Sheet No.</u> | <u>Coord.</u> | <u>Description</u> | <u>Measured Parameters &amp; Frequency</u> |                    |                   |                      |                   | <u>RR/Remarks</u> |
|-------------------|--------------|---------------------------|---------------|--------------------|--|--------------------|-------------------|----------------------|-------------------|-------------------|
|                   |              |                           |               |                    | <u>P<sub>o</sub></u><br>(psig)             | <u>ΔP</u><br>(psf) | <u>Q</u><br>(gpm) | <u>V</u><br>(in/sec) | <u>N</u><br>(rpm) |                   |
| 1-1204-P6-003     | 2/212        | 1X4DB121                  | E-2           | SI Pump            | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 1-1204-P6-004     | 2/212        | 1X4DB121                  | C-2           | SI Pump            | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |

Test Frequency: QTR = Quarterly Pump Test

VEGP-1 PUMP TEST TABLE

Residual Heat Removal - System 1205

| <u>LD. Number</u> | <u>CC/PC</u> | <u>P&amp;ID-Sheet No.</u> | <u>Coord.</u> | <u>Description</u> | <u>Measured Parameters &amp; Frequency</u> |                    |                   |                      |                   | <u>RR/Remarks</u> |
|-------------------|--------------|---------------------------|---------------|--------------------|--|--------------------|-------------------|----------------------|-------------------|-------------------|
|                   |              |                           |               |                    | <u>P<sub>o</sub></u><br>(psig)             | <u>ΔP</u><br>(psf) | <u>Q</u><br>(gpm) | <u>V</u><br>(in/sec) | <u>N</u><br>(rpm) |                   |
| 1-1205-P6-001     | 2/212        | 1X4DB122                  | F-4           | RHR Pump           | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 1-1205-P6-002     | 2/212        | 1X4DB122                  | G-4           | RHR Pump           | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |

Test Frequency: QTR = Quarterly Pump Test

**VEGP-1 PUMP TEST TABLE**

Containment Spray - System 1206

| <u>ID. Number</u> | <u>CC/PC</u> | <u>P&amp;ID-Sheet No.</u> | <u>Coord.</u> | <u>Description</u> | <u>Measured Parameters &amp; Frequency</u> |                    |                   |                                    |                   | <u>RR/Remarks</u> |
|-------------------|--------------|---------------------------|---------------|--------------------|--|--------------------|-------------------|------------------------------------|-------------------|-------------------|
|                   |              |                           |               |                    | <u>P<sub>0</sub></u><br>(psig)             | <u>ΔP</u><br>(psf) | <u>Q</u><br>(gpm) | <u>V</u><br>(ft <sup>3</sup> /sec) | <u>N</u><br>(rpm) |                   |
| 1-1206-P6-001     | 2/212        | 1X4DB131                  | G-4           | CS Pump            | QTR  | QTR                | QTR               | QTR                                | NA                | RR-P-2            |
| 1-1206-P6-002     | 2/212        | 1X4DB131                  | C-4           | CS Pump            | QTR  | QTR                | QTR               | QTR                                | NA                | RR-P-2            |

Test Frequency: QTR = Quarterly Pump Test



VEGP-1 PUMP TEST TABLE

Chemical & Volume Control - System 1208

| <u>ID. Number</u> | <u>CC/PC</u> | <u>P&amp;ID-Sheet No.</u> | <u>Coord.</u> | <u>Description</u>               | <u>Measured Parameters &amp; Frequency</u> |                    |                   |                      |                   | <u>RR/Remarks</u> |
|-------------------|--------------|---------------------------|---------------|----------------------------------|--|--------------------|-------------------|----------------------|-------------------|-------------------|
|                   |              |                           |               |                                  | <u>P<sub>0</sub></u><br>(psig)             | <u>ΔP</u><br>(psi) | <u>Q</u><br>(gpm) | <u>V</u><br>(in/sec) | <u>N</u><br>(rpm) |                   |
| 1-1208-P6-002     | 2/212        | 1X4DB116-2                | G-4           | CVCS - Centrifugal Charging Pump | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 1-1208-P6-003     | 2/212        | 1X4DB116-2                | C-4           | CVCS - Centrifugal Charging Pump | QTR  | QTR                | QTR               | QTR                  | NA                | RR-F-2            |
| 1-1208-P6-006     | 3/313        | 1X4DB118                  | D-4           | CVCS - Boric Acid Transfer Pump  | QTR  | QTR                | QTR               | QTR                  | NA                | RR-F-1, RR-P-2    |
| 1-1208-P6-007     | 3/313        | 1X4DB118                  | B-4           | CVCS - Boric Acid Transfer Pump  | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-1, RR-P-2    |

Test Frequency: QTR = Quarterly Pump Test

**VEGP-1 PUMP TEST TABLE**

**Auxiliary Feedwater - System 1302**

| <u>LD. Number</u> | <u>CC/PC</u> | <u>P&amp;ID-Sheet No.</u> | <u>Coord.</u> | <u>Description</u>         | <u>Measured Parameters &amp; Frequency</u> |                    |                   |                                    |                   | <u>RR/Remarks</u> |
|-------------------|--------------|---------------------------|---------------|----------------------------|--|--------------------|-------------------|------------------------------------|-------------------|-------------------|
|                   |              |                           |               |                            | <u>P<sub>o</sub></u><br>(psig)             | <u>ΔP</u><br>(psi) | <u>Q</u><br>(gpm) | <u>V</u><br>(in <sup>3</sup> /sec) | <u>N</u><br>(rpm) |                   |
| 1-1302-P4-001     | 3/313        | 1X4DB161-2                | F-6           | AFW Pump<br>Turbine Driven | QTR  | QTR                | QTR               | QTR                                | NA                | RR-P-2            |
| 1-1302-P4-002     | 3/313        | 1X4DB161-2                | D-6           | AFW Pump<br>Motor Driven   | QTR  | QTR                | QTR               | QTR                                | NA                | RR-P-2            |
| 1-1302-P4-003     | 3/313        | 1X4DB161-2                | B-6           | AFW Pump<br>Motor Driven   | QTR  | QTR                | QTR               | QTR                                | NA                | RR-P-2            |

**Test Frequency:** QTR = Quarterly Pump Test

VEGP-1 PUMP TEST TABLE

Safety Related (ESF) Chillers - System 1592

| <u>ID. Number</u> | <u>CC/PC</u> | <u>P&amp;ID-Sheet No.</u> | <u>Coord.</u> | <u>Description</u>     | <u>Measured Parameters &amp; Frequency</u> |                    |                   |                      |                   | <u>RR/Remarks</u> |
|-------------------|--------------|---------------------------|---------------|------------------------|--|--------------------|-------------------|----------------------|-------------------|-------------------|
|                   |              |                           |               |                        | <u>P<sub>o</sub></u><br>(psig)             | <u>ΔP</u><br>(psf) | <u>Q</u><br>(gpm) | <u>V</u><br>(in/sec) | <u>N</u><br>(rpm) |                   |
| 1-1592-P7-001     | 3/313        | 1X4DB221                  | F-5           | ESF Chilled Water Pump | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 1-1592-P7-002     | 3/313        | 1X4DB221                  | C-5           | ESF Chilled Water Pump | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |

Test Frequency: QTR = Quarterly Pump Test

NSCW Pumps  
(1-1202-P4-001, 002, 003, 004, 005, & 006)

|                          |  |
|--------------------------|--|
| System Function          | Provide cooling water for the containment coolers, control building essential chiller condensers, various engineered safety feature pump motor and lube oil coolers, and the component cooling water and auxiliary component cooling water diesel generator jacket water heat exchangers and transfers the heat removed to the ultimate heat sink. |
| Quantity                 | 6  |
| Type                     | Vertical Line Shaft, 2 stage, self lubricated  |
| Manufacturer/Model       | Bingham-Willamette/18x27B VCM  |
| Rated Capacity           | 8600 gpm (each)  |
| Rated Total Dynamic Head | 230 feet   |
| Driver                   |  |
| Type                     | Electric Motor   |
| Horsepower               | 700  |
| Speed                    | 1180 rpm   |
| Power Supply             | 4160 <sup>v</sup> , 60 Hz, 3 phase   |
| Code Class               | 3  |
| Project Class            | 313  |
| Outline Drawing          | 1X4AF02-32   |
| Instruction Book         | 1X4AF02-93   |
| Physical Location        | NSCW Pump House  |
| P&ID                     | 1X4DB133-1, -2   |
| Surveillance Procedure   | 14802-1  |
| Pump Test Loop Diagrams  | 1SI-D-201 through 1SI-D-206  |
| Test Parameter Sheets    | Page 5-3 through 5-8   |

NSCW Transfer Pumps  
(1-1202-P4-007, 008)

|                          |   |
|--------------------------|---|
| System Function          | Provides capability to transfer water between cooling tower basins. |
| Quantity                 | 2   |
| Type                     | Vertical Line Shaft, 2 stage, self lubricated                       |
| Manufacturer/Model       | Bingham-Willamette/18x12A VCM                                       |
| Rated Capacity           | 600 gpm (each)  |
| Rated Total Dynamic Head | 110 feet  |
| Driver                   |   |
| Type                     | Electric Motor  |
| Horsepower               | 30  |
| Speed                    | 1765 rpm  |
| Power Supply             | 480V, 60 Hz, 3 phase  |
| Code Class               | 3   |
| Project Class            | 313   |
| Outline Drawing          | 1X4AF02-3   |
| Instruction Book         | 1X4AF02-95  |
| Physical Location        | NSCW Pump House   |
| P&ID                     | 1X4DB133-1, -2  |
| Surveillance Procedure   | 14801-1   |
| Pump Test Loop Diagrams  | ISI-D-207 and ISI-D-208   |
| Test Parameter Sheet     | Page 5-9 and 5-10   |

**Test Parameter Table - Pump 1-1292-P4-001**

(Figure ISI-D-201)

| Parameter             | Test Freq. | Instrumentation Utilized |             |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(4)              | Range       | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA          | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | LI-1606                  | NA          | (1)       | NA         | NA               | NA                             | NA                   | Measure basin level                |
| Outlet Pressure (Po)  | Qtr        | PI-2148                  | 0-200 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | (2)                      | NA          | ± 2%      | ΔPr        | .95 - 1.10ΔPr    | .93 - <.95ΔPr                  | <.93 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-11760                 | 0-15000 gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(5)      | Qtr        | (3)                      | NA          | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | 1.A                                |

**Notes:**

1. Basin level indicator is utilized to determine level in feet.
2. Differential pressure is calculated using basin level (to determine suction head) and outlet pressure.
3. Portable vibration instruments are utilized.
4. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
5. Measurements are taken on the upper motor-bearing housing in three orthogonal directions, one of which is the axial direction.

**Test Parameter Table - Pump 1-1202-P4-002**  
(Figure ISI-D-202)

| Parameter             | Test Freq. | Instrumentation Utilized |             |           | Ref. Value     | Acceptable Range    | Alert Range  | Action Range                     | Comments                           |
|-----------------------|------------|--------------------------|-------------|-----------|----------------|---------------------|--|----------------------------------|------------------------------------|
|                       |            | I.D. No.(4)              | Range       | Req. Acc. |                |                     |  |                                  |                                    |
| Speed (N)             | NA         | NA                       | NA          | NA        | NA             | NA                  | NA   | NA                               | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | LI-1607                  | NA          | (1)       | NA             | NA                  | NA   | NA                               | Measure basin level                |
| Outlet Pressure (Po)  | Qtr        | PI-2149                  | 0-200 psig  | ± 2%      | NA             | NA                  | NA   | NA                               | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | (2)                      | NA          | ± 2%      | ΔPr            | .95 - 1.10ΔPr       | .93 - <.95ΔPr  | <.93 or >1.10ΔPr                 | NA                                 |
| Flowrate (Q)          | Qtr        | FI-11763                 | 0-15000 gpm | ± 2%      | Qr             | NA                  | NA   | NA                               | Flowrate is set at reference value |
| Vib. Amp. (V)(5)      | Qtr        | (3)                      | NA          | ± 5%      | V <sub>i</sub> | ≤ 2.5V <sub>r</sub> | > 2.5V <sub>r</sub> - 6V <sub>r</sub><br>or >.325 in/s | >6V <sub>r</sub> or<br>>.70 in/s | NA                                 |

**Notes:**

1. Basin level indicator is utilized to determine level in feet.
2. Differential pressure is calculated using basin level (to determine suction head) and outlet pressure.
3. Portable vibration instruments are utilized.
4. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
5. Measurements are taken on the upper motor-bearing housing in three orthogonal directions, one of which is the axial direction.

**Test Parameter Table - Pump 1-1202-P4-003**

(Figure ISI-D-203)

| Parameter             | Test Freq. | Instrumentation Utilized |                |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|----------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(4)              | Range          | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA             | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | LI-1606                  | NA             | (1)       | NA         | NA               | NA                             | NA                   | Measure basin level                |
| Outlet Pressure (Po)  | Qtr        | PI-2152                  | 0-200<br>psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | (2)                      | NA             | ± 2%      | ΔPr        | .95 - 1.10ΔPr    | .93 - <.95ΔPr                  | <.93 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-11762                 | 0-15000<br>gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(5)      | Qtr        | (3)                      | NA             | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Basin level indicator is utilized to determine level in feet.
2. Differential pressure is calculated using basin level (to determine suction head) and outlet pressure.
3. Portable vibration instruments are utilized.
4. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
5. Measurements are taken on the upper motor-bearing housing in three orthogonal directions, one of which is the axial direction.



**Test Parameter Table - Pump 1-1202-P4-004**  
(Figure ISI-D-204)

| Parameter             | Test Freq. | Instrumentation Utilized |             |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(4)              | Range       | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA          | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | LI-1607                  | NA          | (1)       | NA         | NA               | NA                             | NA                   | Measure basin level                |
| Outlet Pressure (Po)  | Qtr        | PI-2153                  | 0-200 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | (2)                      | NA          | ± 2%      | ΔPr        | .95 - 1.10ΔPr    | .93 - <.95ΔPr                  | <.93 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-11765                 | 0-15000 gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(5)      | Qtr        | (3)                      | NA          | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Basin level indicator is utilized to determine level in feet.
2. Differential pressure is calculated using basin level (to determine suction head) and outlet pressure.
3. Portable vibration instruments are utilized.
4. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
5. Measurements are taken on the upper motor-bearing housing in three orthogonal directions, one of which is the axial direction.

**Test Parameter Table - Pump 1-1202-P4-005**

**(Figure ISI-D-205)**

| Parameter             | Test Freq. | Instrumentation Utilized |             |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(4)              | Range       | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA          | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | LI-1606                  | NA          | (1)       | NA         | NA               | NA                             | NA                   | Measure basin level                |
| Outlet Pressure (Po)  | Qtr        | PI-2150                  | 0-200 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | (2)                      | NA          | ± 2%      | ΔPr        | .95 - 1.10ΔPr    | .93 - <.95ΔPr                  | <.93 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-11761                 | 0-15000 gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(5)      | Qtr        | (3)                      | NA          | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Basin level indicator is utilized to determine level in feet.
2. Differential pressure is calculated using basin level (to determine suction head) and outlet pressure.
3. Portable vibration instruments are utilized.
4. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
5. Measurements are taken on the upper motor-bearing housing in three orthogonal directions, one of which is the axial direction.

**Test Parameter Table - Pump 1-1202-P4-006**

(Figure ISI-D-206)

| Parameter             | Test Freq. | Instrumentation Utilized |                |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|----------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(4)              | Range          | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA             | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | LI-1607                  | NA             | (1)       | NA         | NA               | NA                             | NA                   | Measure basin level                |
| Outlet Pressure (Po)  | Qtr        | PI-2151                  | 0-200<br>psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | (2)                      | NA             | ± 2%      | ΔPr        | .95 - 1.10ΔPr    | .93 - <.95ΔPr                  | <.93 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-11764                 | 0-15000<br>gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(5)      | Qtr        | (3)                      | NA             | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Basin level indicator is utilized to determine level in feet.
2. Differential pressure is calculated using basin level (to determine suction head) and outlet pressure.
3. Portable vibration instruments are utilized.
4. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
5. Measurements are taken on the upper motor-bearing housing in three orthogonal directions, one of which is the axial direction.

**Test Parameter Table - Pump 1-1202-P4-007  
(Figure ISI-D-207)**

| Parameter             | Test Freq. | Instrumentation Utilized |            |           | Ref. Value | Acceptable Range | Alert Range                    | Action               |                                    |
|-----------------------|------------|--------------------------|------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(4)              | Range      | Req. Acc. |            |                  |                                | Range                | Comments                           |
| Speed (N)             | NA         | NA                       | NA         | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | LI-1606                  | NA         | (1)       | NA         | NA               | NA                             | NA                   | Measure basin level                |
| Outlet Pressure (Po)  | Qtr        | PI-8895                  | 0-60 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | (2)                      | NA         | ± 2%      | ΔPr        | .95 - 1.10ΔPr    | .93 - <.95ΔPr                  | <.93 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-2156                  | 0-1000 gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(5)      | Qtr        | (3)                      | NA         | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr cr<br>>.70 in/s | NA                                 |

**Notes:**

1. Basin level indicator is utilized to determine level in feet.
2. Differential pressure is calculated using basin level (to determine suction head) and outlet pressure.
3. Portable vibration instruments are utilized.
4. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
5. Measurements are taken on the upper motor-bearing housing in three orthogonal directions, one of which is the axial direction.


**Test Parameter Table - Pump i-1202-P4-008  
(Figure ISI-D-208)**

| Parameter             | Test Freq. | Instrumentation Utilized |            |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(4)              | Range      | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA         | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | LI-1607                  | NA         | (1)       | NA         | NA               | NA                             | NA                   | Measure basin level                |
| Outlet Pressure (Po)  | Qtr        | PI-8894                  | 0-60 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | (2)                      | NA         | ± 2%      | ΔPr        | .95 - 1.10ΔPr    | .93 - <.95ΔPr                  | <.93 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-2157                  | 0-1000 gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(5)      | Qtr        | (3)                      | NA         | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**


1. Basin level indicator is utilized to determine level in feet.
2. Differential pressure is calculated using basin level (to determine suction head) and outlet pressure.
3. Portable vibration instruments are utilized.
4. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
5. Measurements are taken on the upper motor-bearing housing in three orthogonal directions, one of which is the axial direction.

NOTE: THIS IS A SIMPLIFIED DIAGRAM  
USED TO DEPICT A TEST CIRCUIT.  
REFER TO THE P&ID FOR DETAILS.



| REV.   | DATE    | BY  | CHK'D          | DESCRIPTION                     | APPR.1 | APPR.2    | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|--|---------|-----|----------------|---------------------------------|--------|-----------|--------|--------|--------|---------|
| 0  | 5-24-84 | BGS | VS             | ISSUED FOR PST                  | FT     |           |        |        |        |         |
| 1  | 7-24-86 | CSB | CVD            | UPDATE TO REV 16 OF (X408133-1) | JJC    |           |        |        |        |         |
| 2  | 12-2-96 | JVB |                | REDRAWN IN ACAD13               | DMS    |           |        |        |        |         |
| Southern Company Services, Inc. FOR Southern Nuclear Operating Company                 |         |     |                |                                 |        |           |        |        |        |         |
| VOGTLE ELECTRIC GENERATING PLANT<br>UNIT 1   |         |     |                |                                 |        |           |        |        |        |         |
| PUMP INSERVICE TESTING LOOP FOR<br>NUCLEAR SERVICE COOLING WATER<br>PUMP 1-1202-P4-001 |         |     |                |                                 |        |           |        |        |        |         |
| DESIGNED FT  |         |     |                | DRAWN IRC                       |        |           |        |        |        |         |
| TYPE   |         |     |                | CHECKED VS                      |        |           |        |        |        |         |
| SCALE NONE   |         |     |                | CONTINUED ON SHEET              |        |           |        |        |        |         |
| PREJ.D.  |         |     | DRAWING NUMBER |                                 |        | SHEET     |        | REV.   |        |         |
| N/A  |         |     | N/A            |                                 |        | ISI-D-201 |        | 1 OF 1 |        | 2       |


NOTE: THIS IS A SIMPLIFIED DIAGRAM  
USED TO DEPICT A TEST CIRCUIT.  
REFER TO THE P&ID FOR DETAILS.



| REV. | DATE    | BY  | CHK'D | DESCRIPTION                    | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|--------------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 5-24-84 | BUS | WS    | ISSUED FOR PST                 | FT     |        |        |        |        |         |
| 1    | 7-24-86 | CSB | CVD   | UPDATE TO REV 18 OF 1X4DB133-2 | JJC    |        |        |        |        |         |
| 2    | 12-2-96 | JVB |       | REDRAWN IN ACAD3               | DMS    |        |        |        |        |         |

|  |          |                |                    |
|--|----------|----------------|--------------------|
| Southern Company Services, Inc. FOR Southern Nuclear Operating Company |          |                |                    |
| VOGTE ELECTRIC GENERATING PLANT<br>UNIT 1                              |          | DESIGNED FT    | DRAWN BPC          |
|  |          | TYPED          | CHECKED VS         |
|  |          | SCALE NONE     | CONTINUED ON SHEET |
|  | PROJ. ID | DRAWING NUMBER | SHEET REV.         |
|  | N/A      | ISI-D-202      | 1 OF 1 2           |

NOTE: THIS IS A SIMPLIFIED DIAGRAM  
USED TO DEPICT A TEST CIRCUIT.  
REFER TO THE P&ID FOR DETAILS.



| REV. | DATE    | BY  | CHK'D | DESCRIPTION                    | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|--------------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 5-24-84 | BGS | WS    | ISSUED FOR PST                 | FT     |        |        |        |        |         |
| 1    | 7-24-86 | CSB | CVB   | UPDATE TO REV 16 OF 1X00B133-1 | JJC    |        |        |        |        |         |
| 2    | 12-2-96 | JVB |       | REDRAWN IN ACAB13              | QNS    |        |        |        |        |         |


Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
UNIT 1  
PUMP INSERVICE TESTING LOOP FOR  
NUCLEAR SERVICE COOLING WATER  
PUMP 1-1202-P4-003

|          |         |                    |            |
|----------|---------|--------------------|------------|
| DESIGNED | FT      | DRAWN              | ORC        |
| TYPED    |         | CHECKED            | WS         |
| SCALE    | NONE    | CONTINUED ON SHEET |            |
|          | PREL.D. | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A     | ISI-D-203          | 1 OF 2     |



NOTE: THIS IS A SIMPLIFIED DIAGRAM  
USED TO DEPICT A TEST CIRCUIT.  
REFER TO THE P&ID FOR DETAILS.




| REV. | DATE    | BY  | CHK'D | DESCRIPTION                    | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|--------------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 5-14-84 | BGS | WS    | ISSUED FOR PST                 |        | FT     |        |        |        |         |
| 1    | 7-24-86 | CSB | CVD   | UPDATE TO REV 18 OF 1X408123-2 |        | JJC    |        |        |        |         |
| 2    | 12-2-96 | JVB |       | RE-DRAWN IN ACAB10             |        | DYS    |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
UNIT 1  
PUMP INSERVICE TESTING LOOP FOR  
NUCLEAR SERVICE COOLING WATER  
PUMP 1-1202-P4-004


|          |          |                    |            |
|----------|----------|--------------------|------------|
| DESIGNED | FT       | DRAWN              | IRC        |
| TYPE     |          | CHECKED            | VS         |
| SCALE    | NONE     | CONTINUED ON SHEET |            |
|          | PROJ. ID | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A      | ISI-D-204          | 1 OF 1 2   |

NOTE: THIS IS A SIMPLIFIED DIAGRAM  
USED TO DEPICT A TEST CIRCUIT.  
REFER TO THE P&ID FOR DETAILS.



| REV.   | DATE    | BY  | CHK'D | DESCRIPTION                    | APPR.1             | APPR.2    | APPR.3 | APPR.4 | APPR.5 | REMARKS |  |
|--|---------|-----|-------|--------------------------------|--------------------|-----------|--------|--------|--------|---------|--|
| 0  | 5-24-84 | BGS | VS    | ISSUED FOR PST                 | FT                 |           |        |        |        |         |  |
| 1  | 7-24-86 | CSB | CVD   | UPDATE TO REV 16 OF 1X40B133-1 | JJC                |           |        |        |        |         |  |
| 2  | 12-2-96 | JVB |       | REDRAWN IN ACAB13              | DMS                |           |        |        |        |         |  |
| Southern Company Services, Inc. FOR Southern Nuclear Operating Company                 |         |     |       |                                |                    |           |        |        |        |         |  |
| VOGTLE ELECTRIC GENERATING PLANT<br>UNIT 1   |         |     |       |                                |                    |           |        |        |        |         |  |
| PUMP INSERVICE TESTING LOOP FOR<br>NUCLEAR SERVICE COOLING WATER<br>PUMP 1-1202-P4-005 |         |     |       |                                |                    |           |        |        |        |         |  |
|  |         |     |       | DESIGNED FT                    | DRAWN DRC          |           |        |        |        |         |  |
|  |         |     |       | TYPE                           | CHECKED VS         |           |        |        |        |         |  |
|  |         |     |       | SCALE NONE                     | CONTINUED ON SHEET |           |        |        |        |         |  |
|  |         |     |       | PROJ.11                        | DRAWING NUMBER     | SHEET     | REV.   |        |        |         |  |
|  |         |     |       | N/A                            | N/A                | ISI-D-205 | 1 OF 1 | 2      |        |         |  |

NOTE: THIS IS A SIMPLIFIED DIAGRAM  
USED TO DEPICT A TEST CIRCUIT.  
REFER TO THE P&ID FOR DETAILS.



| REV. | DATE    | BY  | CHK'D | DESCRIPTION                    | APPR.1     | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|--------------------------------|------------|--------|--------|--------|--------|---------|
| 0    | 5-24-84 | BGS | VS    | ISSUED FOR PST                 | FT         |        |        |        |        |         |
| 1    | 7-24-86 | CSB | CWB   | UPDATE TO REV 10 OF IX4DR133-2 | JJC        |        |        |        |        |         |
| 2    | 12-2-96 | JVB |       | REDRAWN IN ACAB3               | <i>DMS</i> |        |        |        |        |         |


Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VDGTE ELECTRIC GENERATING PLANT  
UNIT 1

PUMP INSERVICE TESTING LOOP FOR  
NUCLEAR SERVICE COOLING WATER  
PUMP 1-1202-P4-006

|          |          |                    |            |
|----------|----------|--------------------|------------|
| DESIGNED | FT       | DRAWN              | DRG        |
| TYPED    |          | CHECKED            | VS         |
| SCALE    | NONE     | CONTINUED ON SHEET |            |
|          | PROJ. ID | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A      | ISI-D-206          | 1 OF 1 2   |

NOTE: THIS IS A SIMPLIFIED DIAGRAM  
USED TO DEPICT A TEST CIRCUIT.  
REFER TO P&ID FOR DETAILS




| REV. | DATE    | BY  | CHK'D | DESCRIPTION                                       | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|---|--------|--------|--------|--------|--------|---------|
| 0    | 5-24-84 | BGR | /JS   | ISSUED FOR PST                                    | FT     |        |        |        |        |         |
| 1    | 7-24-86 | CSB | CVD   | UPDATE TO 1X408133-1 REV 16 AND 1X408133-2 REV 18 | JJC    |        |        |        |        |         |
| 2    | 6-14-88 | CSB | VS    | ADDED PI 8894, 8895                               | MLV    | RB     |        |        |        |         |
| 3    | 12-2-96 | JVB |       | REDRAWN IN ACAB12                                 | DW5    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
UNIT 1  
PUMP INSERVICE INSPECTION LOOP  
FOR TRANSFER PUMP  
1-1202-P4-007

|          |          |                    |            |
|----------|----------|--------------------|------------|
| DESIGNED | FT       | DRAWN              | ERC        |
| TYPED    |          | CHECKED            | WS         |
| SCALE    | NONE     | CONTINUED ON SHEET |            |
|          | PROJ. ID | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A      | ISI-D-207          | 1 OF 1 3   |

NOTE: THIS IS A SIMPLIFIED DIAGRAM  
USED TO DEPICT A TEST CIRCUIT.  
REFER TO P&ID FOR DETAILS



| REV. | DATE    | BY  | CHK'D | DESCRIPTION                                       | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|---|--------|--------|--------|--------|--------|---------|
| 0    | 5-24-84 | BGS | VS    | ISSUED FOR P&ID                                   | FT     |        |        |        |        |         |
| 1    | 7-24-86 | CSB | CVD   | UPDATE TO IX408133-1 REV 16 AND IX408133-2 REV 18 | JJC    |        |        |        |        |         |
| 2    | 6-14-88 | CSB | VS    | ADDED PI 8894, 8895, CHANGED PI 2155 TO 2154      | VLV    | HB     |        |        |        |         |
| 3    | 12-2-96 | JVB |       | REDRAWN IN ACAD13                                 | QMS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLÉ ELECTRIC GENERATING PLANT  
UNIT 1  
PUMP INSERVICE INSPECTION LOOP  
FOR TRANSFER PUMP  
1-1202-P4-008

|          |           |                    |            |
|----------|-----------|--------------------|------------|
| DESIGNED | FT        | DRAWN              | DRG        |
| TYPE     |           | CHECKED            | VS         |
| SCALE    | NONE      | CONTINUED ON SHEET |            |
|          | PROJ.L.D. | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A       | ISI-D-208          | 1 OF 1 3   |

CC'W Pumps  
(1-1203-P4-001, 002, 003, 004, 005, & 006)

|                          |  |
|--------------------------|--|
| System Function          | Remove waste heat from the spent fuel pool heat exchangers, RHR heat exchangers and the RHR pump seal coolers during plant operation, plant cooldown and during a postulated post-accident condition. This heat energy is then transferred by the component cooling water heat exchangers to the NSCWS. The CCWS functions as an intermediate system between a radioactive fluid system and the non-radioactive NSCWS, which operates at a higher system pressure. This arrangement greatly reduces the probability of radioactive fluid leakage to the environment by means of the NSCWS. |
| Quantity                 | 6  |
| Type                     | Horizontal, centrifugal, single-stage, split volute with mechanical seals  |
| Manufacturer/Model       | Ingersoll-Rand/10x18 SE  |
| Rated Capacity           | 5000 gpm (each)  |
| Rated Total Dynamic Head | 160 feet   |
| Driver                   |  |
| Type                     | Electric Motor, Westinghouse, LAC-LLD, 5008-S  |
| Horsepower               | 300  |
| Speed                    | 1761 rpm   |
| Power Supply             | 4160V, 60 Hz, 3 phase  |
| Code Class               | 3  |
| Project Class            | 313  |
| Outline Drawing          | 1X4AF01-67 & 1X4AF01-70  |
| Instruction Book         | X4AF01-136   |
| Physical Location        | Aux Bldg, Level A, Rooms R-A03 & R-A05   |
| P&ID                     | 1X4DB136   |
| Surveillance Procedure   | 14803-1  |
| Pump Test Loop Diagrams  | ISI-D-209 through ISI-D-214  |
| Test Parameter Sheets    | Page 6-2 through 6-7   |

**Test Parameter Table - Pump 1-1203-P4-001**  
(Figure ISI-D-209)

| Parameter             | Test Freq. | Instrumentation Utilized |             |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range       | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA          | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-1878                  | 0-60 psig   | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-1858                  | 0-200 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA          | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-11794                 | 0-10000 gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA          | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.

**Test Parameter Table - Pump 1-1203-P4-002**  
(Figure ISI-D-210)

| Parameter             | Test Freq. | Instrumentation Utilized |             |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range       | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA          | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-1881                  | 0-60 psig   | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-1859                  | 0-200 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA          | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-11795                 | 0-10000 gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA          | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.



**Test Parameter Table - Pump 1-1203-P4-003**

(Figure ISI-D-211)

| Parameter             | Test Freq. | Instrumentation Utilized |             |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range       | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA          | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-1879                  | 0-60 psig   | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-1860                  | 0-200 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA          | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-11796                 | 0-10000 gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA          | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.

**Test Parameter Table - Pump 1-1203-P4-004**

(Figure ISI-D-212)

| Parameter             | Test Freq.   | Instrumentation Utilized |                |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|--------------|--------------------------|----------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |              | L.D. No.(3)              | Range          | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA           | NA                       | NA             | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr<br>BC(2) | PI-1882                  | 0-60<br>psig   | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr          | PI-1861                  | 0-200<br>psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr          | NA(1)                    | NA             | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr          | FI-11797                 | 0-10000<br>gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr          | (2)                      | NA             | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.

**Test Parameter Table - Pump 1-1203-P4-005**  
(Figure ISI-D-213)

| Parameter             | Test Freq. | Instrumentation Utilized |             |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range       | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA          | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-1880                  | 0-60 psig   | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-1862                  | 0-200 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA          | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-11798                 | 0-10000 gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA          | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**


1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.

**Test Parameter Table - Pump 1-1203-P4-006**  
(Figure ISI-D-214)

| Parameter             | Test Freq. | Instrumentation Utilized |             |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range       | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA          | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-1883                  | 0-60 psig   | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-1863                  | 0-200 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA          | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-11799                 | 0-10000 gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (5)                      | NA          | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.




| REV. | DATE    | BY  | CHK'D | DESCRIPTION                | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|----------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 5-21-84 | BGS | VS    | ISSUED FOR PST             |        |        |        |        |        |         |
| 1    | 7-24-86 | CSB | CVB   | UPDATED TO 18488136 REV 19 | FT     |        |        |        |        |         |
| 2    | 12-2-96 | JVB | DMS   | REDRAWN IN ACADIS          | JJC    |        |        |        |        |         |
|      |         |     |       |                            | DMS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
UNIT 1

PUMP INSERVICE TESTING LOOP FOR  
COMPONENT COOLING WATER PUMP  
1-1203-P4-001

|          |         |                    |            |
|----------|---------|--------------------|------------|
| DESIGNED | FT      | DRAWN              | DRC        |
| TYPE     |         | CHECKED            | VS         |
| SCALE    | NONE    | CONTINUED ON SHEET |            |
|          | PRELIM. | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A     | ISI-D-209          | 1 OF 2     |



NOTE: THIS IS A SIMPLIFIED DIAGRAM USED TO DEPICT A TEST CIRCUIT. REFER TO THE P&ID FOR DETAILS.


| REV. | DATE    | BY  | CHK'D | DESCRIPTION                | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|----------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 5-24-84 | BOS | VS    | ISSUED FOR PST             |        |        |        |        |        |         |
| 1    | 7-24-86 | CSB | CVB   | UPDATED TO 1X48B136 REV 19 | JJC    |        |        |        |        |         |
| 2    | 12-2-96 | JVB | DMS   | REBRASH IN ACBIS           | DMS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
UNIT 1

PUMP INSERVICE TESTING LOOP FOR  
COMPONENT COOLING WATER PUMP  
1-1203-P4-002

|          |           |                    |            |
|----------|-----------|--------------------|------------|
| DESIGNED | FT        | DRAWN              | BRC        |
| TYPE     |           | CHECKED            | VS         |
| SCALE    | NONE      | CONTINUED ON SHEET |            |
|          | PROJ. NO. | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A       | ISI-D-210          | 1 OF 2     |



NOTE: THIS IS A SIMPLIFIED DIAGRAM USED TO DEPICT A TEST CIRCUIT. REFER TO THE P&ID FOR DETAILS.


| REV. | DATE    | BY  | CHK'D | DESCRIPTION                | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|----------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 5-24-84 | BGS | VS    | ISSUED FOR PST             | FT     |        |        |        |        |         |
| 1    | 7-24-84 | CSB | CVB   | UPDATED TO 1X488136 REV 19 | JJC    |        |        |        |        |         |
| 2    | 12-2-96 | JVB | DMS   | REBORN IN ACADIS           | DMS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT UNIT 1

PUMP INSERVICE TESTING LOOP FOR COMPONENT COOLING WATER PUMP 1-1203-P4-003

|          |            |                    |           |
|----------|------------|--------------------|-----------|
| DESIGNED | FT         | DRAWN              | DK        |
| TYPED    |            | CHECKED            | VS        |
| SCALE    | NONE       | CONTINUED ON SHEET |           |
|          | PROJ. I.D. | DRAWING NUMBER     | SHEET REV |
| N/A      | N/A        | ISI-D-211          | 1 OF 1 2  |



NOTE: THIS IS A SIMPLIFIED DIAGRAM USED TO DEPICT A TEST CIRCUIT. REFER TO THE P&ID FOR DETAILS.

| REV. | DATE    | BY  | CHK'D | DESCRIPTION                | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|----------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 5-24-84 | BGE | VS    | ISSUED FOR PST             | FT     |        |        |        |        |         |
| 1    | 7-24-86 | CSB | CVD   | UPDATED TO 1248B136 REV 19 | JJC    |        |        |        |        |         |
| 2    | 12-2-96 | JVB | DMS   | RE-DRAWN IN ACAD13         | DMS    |        |        |        |        |         |


Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTE ELECTRIC GENERATING PLANT  
UNIT 1

PUMP INSERVICE TESTING LOOP FOR  
COMPONENT COOLING WATER PUMP  
1-1203-P4-004

|          |          |                    |            |
|----------|----------|--------------------|------------|
| DESIGNED | FT       | DRAWN              | DRC        |
| TYPE     |          | CHECKED            | VS         |
| SCALE    | NONE     | CONTINUED ON SHEET |            |
|          | PROJ.1.B | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A      | ISI-D- 212         | 1 OF 1 2   |





NOTE: THIS IS A SIMPLIFIED DIAGRAM USED TO DEPICT A TEST CIRCUIT. REFER TO THE P&ID FOR DETAILS.


| REV. | DATE    | BY  | CHK'D | DESCRIPTION                | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|----------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 5-24-84 | BGS | VS    | ISSUED FOR PST             |        |        |        |        |        |         |
| 1    | 7-24-86 | RMS | CVB   | UPDATED TO IX488136 REV 19 | FT     |        |        |        |        |         |
| 2    | 12-2-96 | JVB | QMS   | REDRAWN IN ACADIS          | JJC    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
UNIT 1

PUMP INSERVICE TESTING LOOP FOR  
COMPONENT COOLING WATER PUMP  
1-1203-P4-005

|          |           |                    |            |
|----------|-----------|--------------------|------------|
| DESIGNED | FT        | DRAWN              | BRC        |
| TYPE     |           | CHECKED            | VS         |
| SCALE    | NONE      | CONTINUED ON SHEET |            |
|          | PROJ. NO. | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A       | ISI-D-213          | 1 OF 1 2   |



| REV. | DATE    | BY  | CHK'D | DESCRIPTION               | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|---------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 5-24-84 | BOS | VS    | ISSUED FOR PST            | FT     |        |        |        |        |         |
| 1    | 7-24-86 | RHE | CVS   | UPDATED TO 1X48136 REV 13 | JJC    |        |        |        |        |         |
| 2    | 12-2-96 | JVS | DMS   | REBORN IN ACADIS          | DMS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLÉ ELECTRIC GENERATING PLANT  
UNIT 1

PUMP INSERVICE TESTING LOOP FOR  
COMPONENT COOLING WATER PUMP  
1-1203-P4-006

|          |         |                    |            |
|----------|---------|--------------------|------------|
| DESIGNED | FT      | DRAWN              | BRC        |
| TYPED    |         | CHECKED            | VS         |
| SCALE    | NONE    | CONTINUED ON SHEET |            |
|          | PROJ.13 | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A     | ISI-D-214          | 1 OF 2     |

SI Pumps  
(1-1204-P6-003, & 004)

|                         |  |
|-------------------------|--|
| System Function         | The SI system provides emergency core cooling and serves no other purpose.<br><br>The primary function of the ECCS is to remove the stored and fission product decay heat from the reactor core following an accident in order to prevent fuel rod damage. |
| Quantity                | 2  |
| Type                    | Horizontal, centrifugal, 11-stage  |
| Manufacturer/Model      | Pacific Model 3-j 1., JHF  |
| Rated Capacity          | 440 gpm  |
| Rated Head              | 2680 ft.   |
| Driver                  |  |
| Type                    | Electric Motor, Westinghouse, Frame 5809 H   |
| Horsepower              | 450  |
| Speed                   | 3600 rpm   |
| Power Supply            | 4160V, 60 Hz, 3 phase  |
| Code Class              | 2  |
| Project Class           | 212  |
| Outline Drawing         | 1X6AG02-10, 13 & 15  |
| Instruction Book        | 1X6AG02-016  |
| Physical Location       | Aux Bldg, Level B, Rooms R-B15 & R-B19   |
| P&ID                    | 1X4DB121   |
| Surveillance Procedure  | 14804-1  |
| Pump Test Loop Diagrams | ISI-D-215 & ISI-D-216  |
| Test Parameter Sheets   | Page 7-2 & 7-3   |

**Test Parameter Table - Pump 1-1204-P6-003**  
**(Figure ISI-D-215)**

| Parameter             | Test Freq. | Instrumentation Utilized |            |           | Ref. Value | Acceptable Range         | Alert Range                | Action Range     | Comments                           |
|-----------------------|------------|--------------------------|------------|-----------|------------|--------------------------|----------------------------|------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range      | Req. Acc. |            |                          |                            |                  |                                    |
| Speed (N)             | NA         | NA                       | NA         | NA        | NA         | NA                       | NA                         | NA               | Constant speed driver              |
| Inlet Pressure (Pi)   | Qr         | PI-0977                  | 0-100 psig | ± 2%      | NA         | NA                       | NA                         | NA               | NA                                 |
| Outlet Pressure (Po)  | Qtr        | Test Gage                | NA         | ± 2%      | NA         | NA                       | NA                         | NA               | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA         | ± 2%      | ΔPr        | .90 - 1.10ΔPr            | NA                         | <.90 or >1.10ΔPr | NA                                 |
| Flowrate (Q)          | Qtr        | FI-0968                  | 0-100 gpm  | ± 2%      | Qr         | NA                       | NA                         | NA               | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA         | ± 5%      | Vr         | ≤ 2.5Vr<br>or >.325 in/s | > 2.5Vr - 6Vr<br>>.70 in/s | >6Vr or          | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.


**Test Parameter Table - Pump 1-1204-P4-004**  
(Figure ISI-D-216)

| Parameter             | Test Freq. | Instrumentation Utilized |            |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range      | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA         | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-0978                  | 0-100 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | Test Gage                | NA         | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA         | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-0968                  | 0-100 gpm  | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA         | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.

NOTE: THIS IS A SIMPLIFIED DIAGRAM USED TO DEPICT A TEST CIRCUIT. REFER TO THE P&ID FOR DETAILS.




| REV. | DATE     | BY  | CHK'D | DESCRIPTION                     | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|----------|-----|-------|---------------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 5-24-84  | BGS | VS    | ISSUED FOR PST                  | FT     |        |        |        |        |         |
| 1    | 7-24-86  | RMS | CVD   | UPDATED TO 1X488021 REV 16      | JJC    |        |        |        |        |         |
| 2    | 10-29-87 | CSB | VS    | ADDED PRESSURE TEST CONNECTIONS | MB     |        |        |        |        |         |
| 3    | 12-2-96  | JVB | DMS   | REBRAIN IN ACAD13               | DMS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
UNIT 1  
PUMP INSERVICE TESTING LOOP  
FOR SAFETY INJECTION PUMP  
1-1204-P6-003

|           |        |                |           |
|-----------|--------|----------------|-----------|
| DESIGNED  | FT     | DRAWN          | DRG       |
| TYPED     |        | CHECKED        | VS        |
| SCALE     | NONE   | CONTINUED      | ON SHEET  |
| PROJ. NO. | N/A    | DRAWING NUMBER | ISI-D-215 |
| SHEET     | 1 OF 1 | REV.           | 3         |

NOTE: THIS IS A SIMPLIFIED DIAGRAM USED TO DEPICT A TEST CIRCUIT. REFER TO THE P&ID FOR DETAILS.



| REV. | DATE     | BY  | CHK'D      | DESCRIPTION                     | APPR.1     | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|----------|-----|------------|---------------------------------|------------|--------|--------|--------|--------|---------|
| 0    | 5-24-84  | BGS | VS         | ISSUED FOR PST                  | FT         |        |        |        |        |         |
| 1    | 7-24-86  | RHS | CVD        | UPDATED TO IX488121 REV 16      | JJC        |        |        |        |        |         |
| 2    | 10-29-87 | CSB | VT         | ADDED PRESSURE TEST CONNECTIONS |            |        |        |        |        |         |
| 3    | 12-2-96  | JVB | <i>QMS</i> | REDRAWN IN ACAD13               | <i>QMS</i> |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
UNIT 1

PUMP INSERVICE TESTING LOOP  
FOR SAFETY INJECTION PUMP  
1-1204-P6-004

|               |                          |
|---------------|--------------------------|
| DESIGNED FT   | DRAWN DRG                |
| TYPED         | CHECKED VS               |
| SCALE NONE    | CONTINUED ON SHEET       |
| PROJ. NO. N/A | DRAWING NUMBER ISI-D-216 |
|               | SHEET REV. 1 OF 3        |

RHR Pumps  
(1-1205-P6-001, & 002)

|                         |   |
|-------------------------|---|
| System Function         | The primary function is to remove heat energy from the reactor core and reactor coolant system during plant cooldown and refueling operations. As a secondary function, RHR is used to transfer refueling water between the refueling water storage tank and the refueling cavity at the beginning and end of refueling operations. |
|                         | Portions of the RHR system also serve as part of the ECCS during the injection and recirculation phases of a LOCA.  |
| Quantity                | 2   |
| Type                    | Vertical, centrifugal, single stage   |
| Manufacturer/Model      | Ingersoll-Dresser, 8X20WDF  |
| Rated Capacity          | 3000 gpm  |
| Rated Head              | 375 ft.   |
| Driver                  |   |
| Type                    | Westinghouse LLD squirrel-cage induction motor  |
| Horsepower              | 400   |
| Speed                   | 1780 rpm  |
| Power Supply            | 4160V, 60 Hz, 3 phase   |
| Code Class              | 2   |
| Project Class           | 212   |
| Outline Drawing         | AX6AF02-20007   |
| Instruction Book        | AX6AF02-20030   |
| RHR Pumps (cont)        |   |
| Physical Location       | Aux Bldg, Level D, Rooms R-D48 & R-D49  |
| P&ID                    | 1X4DB122  |
| Surveillance Procedure  | 14805-1 & 14812-1   |
| Pump Test Loop Diagrams | ISI-D-215 & ISI-D-216   |
| Test Parameter Sheets   | Page 8-2 & 8-3  |



**Test Parameter Table - Pump 1-1205-P6-001**  
(Figure ISI-D-217)

| Parameter             | Test Freq. | Instrumentation Utilized |            |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range      | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA         | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-8884                  | 0-100 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-8886                  | 0-400 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA         | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-0618A                 | 0-5000 gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA         | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.


**Test Parameter Table - Pump 1-1205-P6-002**  
**(Figure ISI-D-216)**

| Parameter             | Test Freq. | Instrumentation Utilized |            |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range      | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA         | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-8885                  | 0-100 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-8887                  | 0-400 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA         | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-0619A                 | 0-5000 gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA         | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.

NOTE: THIS IS A SIMPLIFIED DIAGRAM USED TO DEPICT A TEST CIRCUIT. REFER TO THE P&ID FOR DETAILS.




| REV. | DATE     | BY  | CHK'D | DESCRIPTION                    | APPR1 | APPR2 | APPR3 | APPR4 | APPR5 | REMARKS |
|------|----------|-----|-------|--------------------------------|-------|-------|-------|-------|-------|---------|
| 0    | 5-24-84  | BMS | VS    | ISSUED FOR PST                 | FI    |       |       |       |       |         |
| 1    | 7-24-86  | BMS | CVR   | UPDATE TO 1X488122 REV 19      | JJC   |       |       |       |       |         |
| 2    | 8-30-87  | BST | VS    | CHANGED TEST CIRCUIT           | CWD   |       |       |       |       |         |
| 3    | 11-10-87 | CSB | VS    | CHANGED TEST CIRCUIT           | MB    |       |       |       |       |         |
| 4    | 6-14-88  | CSB | VS    | ADDED P18984, 8885, 8886, 8887 | WLV   | MB    |       |       |       |         |
| 5    | 5-17-89  | VS  | BMS   | DELETED MINIFLOW TEST          | MB    |       |       |       |       |         |
| 6    | 12-2-96  | JVB |       | REDRAWN IN ACAD13              | QMS   |       |       |       |       |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
UNIT 1  
PUMP INSERVICE TESTING LOOP  
FOR RESIDUAL HEAT REMOVAL PUMP  
1-1205-P6-001

| DESIGNED | FT      | DRAWN              | IRC       |
|----------|---------|--------------------|-----------|
| TYPED    |         | CHECKED            | VS        |
| SCALE    | NONE    | CONTINUED ON SHEET |           |
|          | PROJ.ID | DRAWING NUMBER     | SHEET REV |
| N/A      | N/A     | ISI-D-217          | 1 OF 1 6  |

NOTE: THIS IS A SIMPLIFIED  
 DIAGRAM USED TO DEPICT  
 A TEST CIRCUIT. REFER  
 TO THE P&ID FOR DETAILS.



| REV. | DATE     | BY  | CHK'D | DESCRIPTION                   | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|----------|-----|-------|-------------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 5-24-84  | BHS | VS    | ISSUED FOR PST                | FT     |        |        |        |        |         |
| 1    | 7-24-86  | BHS | CVD   | UPDATE TO 1X488022 REV 19     | JJC    |        |        |        |        |         |
| 2    | 6-30-87  | RST | VS    | CHANGED TEST CIRCUIT          | CWS    |        |        |        |        |         |
| 3    | 11-10-87 | CSB | VS    | CHANGED TEST CIRCUIT          | MB     |        |        |        |        |         |
| 4    | 6-14-88  | CSB | VS    | ADDED P1884, 8885, 8886, 8887 | WLW    | MB     |        |        |        |         |
| 5    | 5-17-89  | VS  | VS    | DELETED MINIFLOW TEST         | MB     |        |        |        |        |         |
| 6    | 12-2-96  | JVB |       | REDRAWN IN ACAD13             | 245    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
 UNIT 1

PUMP INSERVICE TESTING LOOP  
 FOR RESIDUAL HEAT REMOVAL PUMP  
 1-1205-P6-002

|          |           |                    |            |
|----------|-----------|--------------------|------------|
| DESIGNED | FT        | DRAWN              | BRC        |
| TYPED    |           | CHECKED            | VS         |
| SCALE    | NONE      | CONTINUED ON SHEET |            |
|          | PROJ. ID. | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A       | ISI-D-218          | 1 OF 6     |

CS Pumps  
(1-1206-P6-001, & 002)

|                         |  |
|-------------------------|--|
| System Function         | Containment spray limits the peak pressure in the containment to less than design pressure following a LOCA or a main steam line break inside containment. Trisodium phosphate is mixed with recirculated spray water in the containment sump region for pH control and to enhance absorption of the airborne fission product iodine and to retain the iodine in the containment sump solution to limit calculated offsite doses to less than 10CFR100 limits. |
| Quantity                | 2  |
| Type                    | Horizontal, centrifugal  |
| Manufacturer/Model      | Goulds Model 3415  |
| Capacity                | 2600 gpm   |
| Total Dynamic Head      | 450 ft.  |
| Driver                  |  |
| Type                    | Westinghouse electric motor, Frame 5010S   |
| Horsepower              | 400  |
| Speed                   | 1777 rpm   |
| Power Supply            | 4160V, 60 Hz, 3 phase  |
| Code Class              | 2  |
| Project Class           | 212  |
| Outline Drawing         | 1X6AD02-11   |
| Instruction Book        | X6AD02-18  |
| Physical Location       | Aux Bldg, Level D, Rooms R-D76 & R-D77   |
| P&ID                    | 1X4DB131   |
| Surveillance Procedure  | 14806-1  |
| Pump Test Loop Diagrams | ISI-D-219 & ISI-D-220  |
| Test Parameter Sheets   | Page 9-2 & 9-3   |

**Test Parameter Table - Pump 1-1206-P6-001**  
(Figure ISI-D-219)

| Parameter             | Test Freq. | Instrumentation Utilized |            |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range      | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA         | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-0972                  | 0-100 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-0974                  | 0-300 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA         | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-0929                  | 0-400 gpm  | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA         | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.


**Test Parameter Table - Pump 1-1206-P6-002**  
(Figure ISI-D-220)

| Parameter             | Test Freq. | Instrumentation Utilized |            |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | L.D. No.(3)              | Range      | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA         | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-0973                  | 0-100 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-0975                  | 0-300 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA         | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-0929                  | 0-400 gpm  | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA         | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.

NOTE: THIS IS A SIMPLIFIED  
DIAGRAM USED TO DEPICT  
A TEST CIRCUIT. REFER  
TO THE P&ID FOR DETAILS.



| REV. | DATE    | BY  | CHK'D | DESCRIPTION               | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|---------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 5-24-84 | BGS | VS    | ISSUED FOR P&I            | FT     |        |        |        |        |         |
| 1    | 7-24-86 | BMS | CVD   | UPDATED TO 1248B13 REV 13 | JJC    |        |        |        |        |         |
| 2    | 4-28-89 | BGS | VS    | UPDATED TO 1248B13 REV 19 | JJC    |        |        |        |        |         |
| 3    | 12-2-96 | JVB | AKS   | REDRAWN IN AC483          | AKS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company


VOGTLE ELECTRIC GENERATING PLANT  
UNIT 1

PUMP INSERVICE TESTING LOOP  
FOR CONTAINMENT SPRAY PUMP  
1-1206-P6-001

| DESIGNED | DRAWN              |                |
|----------|--------------------|----------------|
| TYPED    | CHECKED            | VS             |
| SCALE    | CONTINUED ON SHEET |                |
|          | PRJ.LLB            | DRAWING NUMBER |
|          |                    | SHEET          |
|          |                    | REV            |
| N/A      | N/A                | ISI-D-219      |
|          |                    | 1 OF 1         |
|          |                    | 3              |



NOTE: THIS IS A SIMPLIFIED  
DIAGRAM USED TO DEPICT  
A TEST CIRCUIT. REFER  
TO THE P&ID FOR DETAILS.



| REV. | DATE    | BY  | CHK'D | DESCRIPTION                | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|----------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 5-24-84 | BGS | VS    | ISSUED FOR PST             |        |        |        |        |        |         |
| 1    | 7-27-86 | RMS | CVD   | UPDATED TO I&488131 REV 12 | FT     |        |        |        |        |         |
| 2    | 4-28-89 | BGS | VS    | UPDATED TO I&488131 REV 19 | JJC    |        |        |        |        |         |
| 3    | 12-2-96 | JVS | DMS   | REBRWN IN ACAD13           | MB     |        |        |        |        |         |
|      |         |     |       |                            | DMS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VDGTE ELECTRIC GENERATING PLANT  
UNIT 1  
PUMP INSERVICE TESTING LOOP  
FOR CONTAINMENT SPRAY PUMP  
1-1206-P6-002

| DESIGNED | BY       | DRWN               | BY         |
|----------|----------|--------------------|------------|
| FT       |          | BRC                |            |
| TYPED    |          | CHECKED            | VS         |
| SCALE    | NONE     | CONTINUED ON SHEET |            |
|          | PROJ.LD. | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A      | ISI-D-220          | 1 OF 1 3   |

CVCS Pumps  
CENTRIFUGAL CHARGING PUMPS  
(1-1208-P6-002, & 003)

|                         |   |
|-------------------------|---|
| System Function         | <p>The primary functions of the CVCS are to:</p> <ul style="list-style-type: none"> <li>• Regulate reactor coolant chemistry for reactivity and corrosion control</li> <li>• Maintains the water level in the pressurizer of the RCS</li> <li>• Maintains seal-water injection flow to the reactor coolant pump</li> <li>• Provide a means of filling, draining and pressure testing the RCS</li> <li>• Provide injection flow to the RCS following actuation of SIS</li> </ul> |
| Quantity                | 2   |
| Type                    | Horizontal, centrifugal, 11 stage   |
| Manufacturer/Model      | Pacific, IJ 2-1/2 in., RL   |
| Capacity                | 150 gpm   |
| Total Dynamic Head      | 5800 ft.  |
| Driver                  |   |
| Type                    | Westinghouse electric motor   |
| Horsepower              | 600   |
| Speed                   | 1800 rpm  |
| Power Supply            | 4160V, 60 Hz, 3 phase   |
| Code Class              | 2   |
| Project Class           | 212   |
| Outline Drawing         | 1X6AH02-101   |
| Instruction Book        | 1X6AH02-85  |
| Physical Location       | Aux Bldg, Level C, Rooms R-C115 & R-C118  |
| P&ID                    | 1X4DB116-2  |
| Surveillance Procedure  | 14808-1   |
| Pump Test Loop Diagrams | ISI-D-221& ISI-D-222  |
| Test Parameter Sheets   | Page 10-2 & 10-3  |

**Test Parameter Table - Pump 1-1208-P6-002**

(Figure ISI-D-221)

| Parameter             | Test Freq. | Instrumentation Utilized |             |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range       | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA          | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-8891                  | 0-100 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-8472                  | 0-4000 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA          | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-10120                 | 0-80 gpm    | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA          | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**


1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.

**Test Parameter Table - Pump 1-1208-P6-003**  
(Figure ISI-D-222)

| Parameter             | Test Freq. | Instrumentation Utilized |             |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | L.D. No.(3)              | Range       | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA          | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-8892                  | 0-100 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-8473                  | 0-4000 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA          | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-10121                 | 0-80 gpm    | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA          | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.




NOTE: THIS IS A SIMPLIFIED DIAGRAM USED TO DEPICT A TEST CIRCUIT. REFER TO THE P&I.D. FOR DETAILS.

| REV. | DATE     | BY  | CHK'D | DESCRIPTION   | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|----------|-----|-------|---|--------|--------|--------|--------|--------|---------|
| 0    | 5-24-84  | BOS | VS    | ISSUED FOR PST  | FT     |        |        |        |        |         |
| 1    | 7-24-86  | RHS | CVD   | UPDATED TO 1K49816-2 REV 10   | JJC    |        |        |        |        |         |
| 2    | 5-14-88  | CEB | VS    | ADDED PI 8891, 8892   | WLV    | MB     |        |        |        |         |
| 3    | 12-16-93 | VS  | DRG   | ADDED FD-10118 AND FD-10122   | MB     |        |        |        |        |         |
| 4    | 11-13-95 | VS  | RHS   | ADDED VALVES HV 8508A AND HV 8508B PLUS ASSOCIATED PIPING CHANGED PI 118 TO PI 8472 AND PI 119 TO PI 8473 | DMS    |        |        |        |        |         |
| 5    | 12-2-96  | JVB | DMS   | REDRAWN BY ACAD12   | DMS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
UNIT 1  
PUMP INSERVICE TESTING LOOP  
FOR CENTRIFUGAL CHARGING PUMP  
1-1208-P6-002

|             |                    |                |            |
|-------------|--------------------|----------------|------------|
| DESIGNED FT | DRAWN DRC          |                |            |
| TYPE        | CHECKED VS         |                |            |
| SCALE       | CONTINUED ON SHEET |                |            |
|             | PROJ.LB.           | DRAWING NUMBER | SHEET REV. |
| N/A         | N/A                | ISI-D-221      | 1 OF 1 5   |



NOTE: THIS IS A SIMPLIFIED DIAGRAM USED TO DEPICT A TEST CIRCUIT. REFER TO THE P&I.D. FOR DETAILS.

| REV. | DATE     | BY  | CHK'D | DESCRIPTION   | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|----------|-----|-------|---|--------|--------|--------|--------|--------|---------|
| 0    | 5-24-84  | BGS | VS    | ISSUED FOR PST  | FT     |        |        |        |        |         |
| 1    | 7-24-86  | BMS | CVB   | UPDATED TO 1X48B16-2 REV 10   | LJC    |        |        |        |        |         |
| 2    | 6-14-88  | CSB | VS    | ADDED PI 8891, 8898   | WLV    | MB     |        |        |        |         |
| 3    | 12-16-93 | VS  | BRG   | ADDED FD-10118 AND FD-10122   | MB     |        |        |        |        |         |
| 4    | 11-13-95 | VS  | BMS   | ADDED VALVES HV 8508A AND HV 8508B PLUS ASSOCIATED PIPING CHANGED PI 118 TO PI 8472 AND PI 119 TO PI 8473 | DMS    |        |        |        |        |         |
| 5    | 12-2-96  | JVB | DMS   | REDRAWN IN ACAD13   | DMS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTE ELECTRIC GENERATING PLANT  
UNIT 1  
PUMP IN SERVICE TESTING LOOP  
FOR CENTRIFUGAL CHARGING PUMP  
1-1208-P6-003

|             |                |                    |          |
|-------------|----------------|--------------------|----------|
| DESIGNED FT |                | DRAWN BRC          |          |
| TYPED       |                | CHECKED VS         |          |
| SCALE NONE  |                | CONTINUED ON SHEET |          |
| PROJ.15     | DRAWING NUMBER | SHEET              | REV.     |
| N/A         | N/A            | ISI-D-222          | 1 OF 1 5 |

BORIC ACID TRANSFER PUMPS  
(1-1208-P6-006 & 007)

|                         |   |
|-------------------------|---|
| System Function         | Provides boric acid to the CVCS for use in RCS inventory control and makeup to systems requiring reactor grade boric acid. The boric acid transfer system also provides boric acid for emergency boration of the RCS. |
| Quantity                | 2   |
| Type                    | Canned motor  |
| Manufacturer/Model      | Chempump Model GVH-1K   |
| Design Flowrate         | 75 gpm  |
| Design Head             | 235 ft.   |
| Driver                  |   |
| Type                    | Electric motor  |
| kW                      | 15.5  |
| Speed                   | 3450 rpm  |
| Power Supply            | 4160V, 60 Hz, 3 phase   |
| Code Class              | 3   |
| Project Class           | 313   |
| Outline Drawing         | 1X6AH02-45  |
| Instruction Book        | 2X6AA07-10  |
| Physical Location       | Aux Bldg, Level D   |
| P&ID                    | 1X4DB118  |
| Surveillance Procedure  | 14811-1   |
| Pump Test Loop Diagrams | ISI-D-228& ISI-D-229  |
| Test Parameter Sheets   | Page 11-2 & 11-3  |

**Test Parameter Table - Pump 1-1208-P6-006**  
(Figure ISI-D-228)

| Parameter             | Test Freq. | Instrumentation Utilized |                 |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-----------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | LD. No.(3)               | Range           | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA              | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-10115                 | -15 to +15 psig | ± 2%      | NA         | NA               | NA                             | NA                   | Relief Request RR-P-1              |
| Outlet Pressure (Po)  | Qtr        | PI-0113                  | 0-160 psig      | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA              | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-40001                 | 0-100 gpm       | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA              | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
1. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.




**Test Parameter Table - Pump 1-1208-P6-007  
(Figure ISI-D-229)**

| Parameter             | Test Freq. | Instrumentation Utilized |                 |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-----------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range           | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA              | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-10116                 | -15 to +15 psig | ± 2%      | NA         | NA               | NA                             | NA                   | Relief Request RR-P-1              |
| Outlet Pressure (Po)  | Qtr        | PI-0114                  | 0-160 psig      | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA              | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-40001                 | 0-100 gpm       | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA              | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.

NOTE THIS IS A SIMPLIFIED DIAGRAM USED TO DEPICT A TEST CIRCUIT. REFER TO P&I.D. 1X4DB118 FOR DETAILS.



| REV. | DATE     | BY  | CHK'D | DESCRIPTION          | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|----------|-----|-------|----------------------|--------|--------|--------|--------|--------|---------|
| 0    | 10-21-86 | MAC | VS    | ISSUED FOR PST / IST | CWD    | JJC    |        |        |        |         |
| 1    | 6-14-88  | CSB | VS    | ADDED FI 40001       | W/L    | MB     |        |        |        |         |
| 2    | 5-17-89  | VS  | RLD   | EXTENDED TEST LOOP   | MB     |        |        |        |        |         |
| 3    | 12-2-96  | JVB | QMS   | REDRAWN IN ACADIS    | QMS    |        |        |        |        |         |


Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VDGTE ELECTRIC GENERATING PLANT  
UNIT 1

PUMP INSERVICE TESTING LOOP FOR  
BORIC ACID TRANSFER PUMP  
1-1208-P6-005

|          |        |                    |            |
|----------|--------|--------------------|------------|
| DESIGNED | MAC    | DRAWN              | MAC        |
| TYPE     |        | CHECKED            | VS         |
| SCALE    | NONE   | CONTINUED ON SHEET |            |
|          | PRELIM | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A    | ISI-D-228          | 1 OF 1 3   |

NOTE THIS IS A SIMPLIFIED DIAGRAM USED TO DEPICT A TEST CIRCUIT. REFER TO P&I.D. 1X4DB118 FOR DETAILS.



| REV. | DATE     | BY  | CHK'D | DESCRIPTION          | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|----------|-----|-------|----------------------|--------|--------|--------|--------|--------|---------|
| 0    | 10-21-86 | NAC | VS    | ISSUED FOR PST / IST | CWD    | JJC    |        |        |        |         |
| 1    | 6-14-88  | CSB | VS    | ADDED FI 40001       | WLB    | MB     |        |        |        |         |
| 2    | 5-17-89  | VE  | ARO   | EXTENDED TEST LOOP   | MB     |        |        |        |        |         |
| 3    | 12-2-96  | JVB | DMS   | REBRAIN IN ACAD2     | DMS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
UNIT 1

PUMP INSERVICE TESTING LOOP FOR  
BORIC ACID TRANSFER PUMP  
1-1208-P6-007

|          |          |                    |            |
|----------|----------|--------------------|------------|
| DESIGNED | NAC      | DRAWN              | NAC        |
| TYPED    |          | CHECKED            | VS         |
| SCALE    | NONE     | CONTINUED ON SHEET |            |
|          | PROJ.LB. | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A      | ISI-D-229          | 1 OF 1 3   |

AFW Pumps  
(1-1302-P4-001, 002 & 003)

System Function

Supply water to the steam generators whenever the reactor coolant temperature is above 350°F and the main feedwater system is not in operation, i.e., during startup, cooldown, or emergency conditions resulting in a loss of main feedwater.

Automatically provides feedwater for the removal of reactor core decay heat following a loss of main feedwater. This prevents damage to the reactor core until the reactor coolant temperature is brought from a hot standby condition to the point at which RHR may be placed into operation.

AFW supplies feedwater to the steam generators at a flowrate sufficient to support normal low-power transients such as startup, cooldown, and hot standby.

Turbine Driven AFW Pump (1-1302-P4-001)

|                    |  |
|--------------------|--|
| Quantity           | 1  |
| Type               | Horizontal, centrifugal, 5 stage, split-case                               |
| Manufacturer/Model | Ingersoll-Rand, Model 6HMTA  |
| Capacity           | 1175 gpm   |
| Total Dynamic Head | 3500 ft.   |
| Driver             |  |
| Type               | Terry Turbine, Model GS-2N, non-condensing, single-stage, mechanical drive |
| Horsepower         | 1603   |
| Speed              | 4250 rpm   |
| Power Supply       | Steam  |
| Code Class         | 3  |
| Project Class      | 313  |
| Outline Drawing    | 1X4AF03-83   |
| Instruction Book   | 1X4AF03-20033  |

Turbine Driven AFW Pump (1-1302-P4-001) (cont)

|                         |                |
|-------------------------|----------------|
| Physical Location       | AFW pump house |
| P&ID                    | 1X4DB161-2     |
| Surveillance Procedure  | 14810-1        |
| Pump Test Loop Diagrams | ISI-D-223      |
| Test Parameter Sheets   | Page 12-4      |

Motor-Driven AFW Pumps (1-1302-P4-002 & 003)

|                         |  |
|-------------------------|--|
| Quantity                | 2  |
| Type                    | - Horizontal, centrifugal, 6 stage, split-case |
| Manufacturer/Model      | Ingersoll-Rand, Model 4HMTB                    |
| Design Flowrate         | 630 gpm  |
| Total Dynamic Head      | 3500 ft.                                       |
| Driver                  |  |
| Type                    | Westinghouse electric motor, LLD 5810 H        |
| Horsepower              | 900  |
| Speed                   | 3600 rpm                                       |
| Power Supply            | 4160V, 60 Hz, 3 phase                          |
| Code Class              | 3  |
| Project Class           | 313  |
| Outline Drawing         | 1X4AF03-81                                     |
| Instruction Book        | 1X4AF03-20032                                  |
| Physical Location       | AFW pump house                                 |
| P&ID                    | 1X4DB161-2                                     |
| Surveillance Procedure  | 14807-1  |
| Pump Test Loop Diagrams | ISI-D-224& ISI-D-225                           |
| Test Parameter Sheets   | Page 12-5 & 12-6                               |

**Test Parameter Table - Pump 1-1302-P4-001  
(Figure ISI-D-223)**

| Parameter             | Test Freq. | Instrumentation Utilized |             |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range       | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | Qtr        | SI-15109A                | 0-6000      | ± 2%      | Nr         | NA               | NA                             | NA                   | Speed is set to reference value    |
| Inlet Pressure (Pi)   | Qtr        | PI-5110A                 | 0-30 psig   | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-5107A                 | 0-2000 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA          | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-15100                 | 0-200 gpm   | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA          | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.


**Test Parameter Table - Pump 1-1302-P4-002**  
(Figure ISI-D-224)

| Parameter             | Test Freq. | Instrumentation Utilized |             |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range       | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA          | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-5128A                 | 0-30 psig   | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-5140A                 | 0-2000 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA          | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-15101                 | 0-200 gpm   | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA          | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.





NOTE: THIS IS A SIMPLIFIED DIAGRAM USED TO DEPICT A TEST CIRCUIT. REFER TO THE P&I.D. FOR DETAILS.


| REV. | DATE    | BY  | CHK'D | DESCRIPTION                  | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|------------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 5-24-84 | RGS | VS    | ISSUED FOR PST               | FT     |        |        |        |        |         |
| 1    | 7-24-86 | RMS | CVB   | UPDATED TO 2K4DB161-E REV 16 | JJC    |        |        |        |        |         |
| 2    | 12-2-96 | JVB | DMS   | REDRAWN IN ACAD3             | DMS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
UNIT 1

PUMP INSERVICE TESTING LOOP  
FOR AUXILLARY FEEDWATER PUMP  
1-1302-P4-001

|           |                |                    |          |
|-----------|----------------|--------------------|----------|
| DESIGNED  | FT             | DRAWN              | DRG      |
| TYPED     |                | CHECKED            | VS       |
| SCALE     | NONE           | CONTINUED ON SHEET |          |
| PROJ.L.D. | DRAWING NUMBER | SHEET              | REV.     |
| N/A       | N/A            | ISI-D-223          | 1 OF 1 2 |



NOTE: THIS IS A SIMPLIFIED DIAGRAM USED TO DEPICT A TEST CIRCUIT. REFER TO THE P&I.D. FOR DETAILS.


| REV. | DATE    | BY  | CHK'D | DESCRIPTION                  | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|------------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 5-24-84 | BGS | VS    | ISSUED FOR PST               | FT     |        |        |        |        |         |
| 1    | 7-24-86 | RMS | CWB   | UPDATED TO 1X4DR161-2 REV 16 | JFC    |        |        |        |        |         |
| 2    | 12-2-96 | JVB | QMS   | REDRAWN IN ACAD3             | QMS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
UNIT 1

PUMP INSERVICE TESTING LOOP  
FOR AUXILLARY FEEDWATER PUMP  
1-1302-P4-002

|           |      |                    |            |
|-----------|------|--------------------|------------|
| DESIGNED  | FT   | DRAWN              | DRC        |
| TYPED     |      | CHECKED            | VS         |
| SCALE     | NONE | CONTINUED ON SHEET |            |
| PROJ.L.B. |      | DRAWING NUMBER     | SHEET REV. |
| N/A       | N/A  | ISI-D- 224         | 1 OF 1 2   |



NOTE: THIS IS A SIMPLIFIED DIAGRAM USED TO DEPICT A TEST CIRCUIT. REFER TO THE P&I.D. FOR DETAILS.

| REV. | DATE    | BY  | CHK'D | DESCRIPTION                 | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|-----------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 5-24-84 | BGS | VS    | ISSUED FOR PST              |        |        |        |        |        |         |
| 1    | 7-24-86 | RHS | CVB   | UPDATED TO 1X4081A-E REV 16 | FT     |        |        |        |        |         |
| 2    | 12-2-96 | JVB | QMS   | REDRAWN IN ACAD3            | JJC    |        |        |        |        |         |
|      |         |     |       |                             | DMS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
UNIT 1  
PUMP INSERVICE TESTING LOOP  
FOR AUXILLARY FEEDWATER PUMP  
1-1302-P4-003

|             |                    |
|-------------|--------------------|
| DESIGNED FT | DRAWN BRC          |
| TYPE        | CHECKED VS         |
| SCALE NONE  | CONTAINED ON SHEET |
| PROJECT     | DRAWING NUMBER     |
| SHEET       | REV.               |
| N/A         | N/A                |
| ISI-D- 225  | 1 OF 1 2           |

ESF Pumps  
(1-1592-P7-001, & 002)

|                         |   |
|-------------------------|---|
| System Function         | During normal operation, the ESF chilled-water system is in standby mode; it is activated during emergency conditions upon receipt of a safety injection signal, containment ventilation isolation, or control room isolation signal. The ESF chilled-water system serves air handling units located in the safety-related areas of the plant to ensure the integrity of the cooling system during plant emergency situation. |
| Quantity                | 2   |
| Type                    | Centrifugal   |
| Manufacturer            | Goulds  |
| Capacity                | 600 gpm   |
| Total Dynamic Head      | 125 ft.   |
| Driver                  |   |
| Type                    | Westinghouse electric motor   |
| Horsepower              | 30  |
| Speed                   | 1800 rpm  |
| Power Supply            | 480V, 60 Hz, 3 phase  |
| Code Class              | 3   |
| Project Class           | 313   |
| Outline Drawing         | 1X4AJ05-27  |
| Instruction Book        | AX4AJ05-86  |
| Physical Location       | Control Bldg, EL. 260 ft., Rooms R-313 & R320   |
| P&ID                    | 1X4DB221  |
| Surveillance Procedure  | 14809-1   |
| Pump Test Loop Diagrams | ISI-D-226 & ISI-D-227   |
| Test Parameter Sheets   | Page 13-2 & 13-3  |

**Test Parameter Table - Pump 1-1592-P7-001**  
(Figure ISI-D-226)

| Parameter             | Test Freq. | Instrumentation Utilized |            |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range      | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA         | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-22410                 | 0-30 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-22414                 | 0-200 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA         | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-22425                 | 0-750 gpm  | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA         | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**


1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.

**Test Parameter Table - Pump 1-1592-P7-002**  
(figure ISI-D-227)

| Parameter             | Test Freq. | Instrumentation Utilized |            |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range      | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA         | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-22411                 | 0-30 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-22415                 | 0-200 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA         | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-22426                 | 0-750 gpm  | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA         | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.



NOTE: 1. THIS IS A SIMPLIFIED DIAGRAM USED TO DEPICT A TEST CIRCUIT. REFER TO THE P&ID FOR DETAILS.  
 2. VALVE INTERNALS REMOVED PER DCP 90-VIN0067-0-1


| REV. | DATE    | BY  | CHK'D      | DESCRIPTION                 | APPR.1     | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|------------|-----------------------------|------------|--------|--------|--------|--------|---------|
| 0    | 4-30-84 | BGS | VS         | ISSUED FOR PST              | FT         |        |        |        |        |         |
| 1    | 7-24-86 | RHS | CVB        | UPDATED TO (K45002) REV 13  | JJC        |        |        |        |        |         |
| 2    | 1-21-91 | VGS | VLV        | REMOVED VALVE 186 INTERNALS | MB         |        |        |        |        |         |
| 3    | 12-2-96 | JVB | <i>AKS</i> | REDRAWN IN ACAD3            | <i>AKS</i> |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
 UNIT 1

PUMP INSERVICE TESTING LOOP  
 FOR CB ESF CHILLED WATER PUMP  
 TRAIN 'A' 1-1592-P7-001-000

|          |      |                    |            |
|----------|------|--------------------|------------|
| DESIGNED | FT   | DRAWN              | BGS        |
| TYPE     |      | CHECKED            | VS         |
| SCALE    | NONE | CONTINUED ON SHEET |            |
| PROJ.1.B |      | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A  | ISI-D-226          | 1 OF 1 3   |



NOTE: 1. THIS IS A SIMPLIFIED DIAGRAM USED TO DEPICT A TEST CIRCUIT. REFER TO THE P&ID FOR DETAILS.  
 2. VALVE INTERNALS REMOVED PER DCP 90-VIN0067-0-1

| REV. | DATE    | BY  | CHK'D      | DESCRIPTION                 | APPR.1     | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|------------|-----------------------------|------------|--------|--------|--------|--------|---------|
| 0    | 4-30-84 | BGS | VS         | ISSUED FOR PST              | FT         |        |        |        |        |         |
| 1    | 7-24-86 | BMS | CWB        | UPDATED TO 1X488021 REV 13  | JC         |        |        |        |        |         |
| 2    | 1-21-91 | VGS | WLV        | REMOVED VALVE 186 INTERNALS | MB         |        |        |        |        |         |
| 3    | 12-2-96 | JVB | <i>DMS</i> | REDRAWN IN ACAD13           | <i>DMS</i> |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
 UNIT 1

PUMP INSERVICE TESTING LOOP  
 FOR CB ESF CHILLED WATER PUMP  
 TRAIN "B" 1-1592-P7-002-000

|           |      |                    |        |
|-----------|------|--------------------|--------|
| DESIGNED  | FT   | DRAWN              | BGS    |
| TYPE      |      | CHECKED            | VS     |
| SCALE     | NONE | CONTINUED ON SHEET |        |
| PROJ.1.B. | N/A  | DRAWING NUMBER     | SHEET  |
|           |      | ISI-D-227          | 1 OF 1 |
|           |      |                    | 3      |



VEGP-2 PUMP TEST TABLE

Nuclear Service Cooling Water - System 1202

| <u>LD. Number</u> | <u>CC/PC</u> | <u>P&amp;ID-Sheet No.</u> | <u>Coord.</u> | <u>Description</u> | <u>Measured Parameters &amp; Frequency</u> |                    |                   |                      |                   | <u>RR/Remarks</u> |
|-------------------|--------------|---------------------------|---------------|--------------------|--|--------------------|-------------------|----------------------|-------------------|-------------------|
|                   |              |                           |               |                    | <u>P<sub>o</sub></u><br>(psig)             | <u>ΔP</u><br>(psi) | <u>Q</u><br>(gpm) | <u>V</u><br>(in/sec) | <u>N</u><br>(rpm) |                   |
| 2-1202-P4-001     | 3/313        | 2X4DB133-1                | C-8           | NSCW Pump          | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 2-1202-P4-002     | 3/313        | 2X4DB133-2                | C-8           | NSCW Pump          | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 2-1202-P4-003     | 3/313        | 2X4DB133-1                | C-5           | NSCW Pump          | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 2-1202-P4-004     | 3/313        | 2X4DB133-2                | C-5           | NSCW Pump          | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 2-1202-P4-005     | 3/313        | 2X4DB133-1                | C-7           | NSCW Pump          | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 2-1202-P4-006     | 3/313        | 2X4DB133-2                | C-7           | NSCW Pump          | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 2-1202-P4-007     | 3/313        | 2X4DB133-1                | C-6           | NSCW Transfer Pump | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 2-1202-P4-008     | 3/313        | 2X4DB133-2                | C-6           | NSCW Transfer Pump | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |

Test Frequency: QTR = Quarterly Pump Test

VEGP-2 PUMP TEST TABLE

Component Cooling Water - System 1203

| <u>L.D. Number</u> | <u>CC/PC</u> | <u>P&amp;ID-Sheet No.</u> | <u>Coord.</u> | <u>Description</u> | <u>Measured Parameters &amp; Frequency</u> |                    |                   |                      |                   | <u>RR/Remarks</u> |
|--------------------|--------------|---------------------------|---------------|--------------------|--|--------------------|-------------------|----------------------|-------------------|-------------------|
|                    |              |                           |               |                    | <u>P<sub>o</sub></u><br>(psig)             | <u>ΔP</u><br>(psf) | <u>Q</u><br>(gpm) | <u>V</u><br>(in/sec) | <u>N</u><br>(rpm) |                   |
| 2-1203-P4-001      | 3/313        | 2X4DB136                  | G-4           | CCW Pump           | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 2-1203-P4-002      | 3/313        | 2X4DB136                  | D-4           | CCW Pump           | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 2-1203-P4-003      | 3/313        | 2X4DB136                  | G-4           | CCW Pump           | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 2-1203-P4-004      | 3/313        | 2X4DB136                  | C-4           | CCW Pump           | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 2-1203-P4-005      | 3/313        | 2X4DB136                  | F-4           | CCW Pump           | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 2-1203-P4-006      | 3/313        | 2X4DB136                  | B-4           | CCW Pump           | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |

Test Frequency: QTR = Quarterly Pump Test

VEGP-2 PUMP TEST TABLE

Safety Injection - System 1204

| <u>LD. Number</u> | <u>CC/PC</u> | <u>P&amp;iD-Sheet No.</u> | <u>Coord.</u> | <u>Description</u> | <u>Measured Parameters &amp; Frequency</u> |                    |                   |                      |                   | <u>RR/Remarks</u> |
|-------------------|--------------|---------------------------|---------------|--------------------|--|--------------------|-------------------|----------------------|-------------------|-------------------|
|                   |              |                           |               |                    | <u>P<sub>o</sub></u><br>(psig)             | <u>ΔP</u><br>(psf) | <u>Q</u><br>(gpm) | <u>V</u><br>(in/sec) | <u>N</u><br>(rpm) |                   |
| 2-1204-P6-003     | 2/212        | 2X4DB121                  | E-3           | SI Pump            | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 2-1204-P6-004     | 2/212        | 2X4DB121                  | C-3           | SI Pump            | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |

Test Frequency: QTR = Quarterly Pump Test

VEGP-2 PUMP TEST TABLE

Residual Heat Removal - System 1205

| <u>LD. Number</u> | <u>CC/PC</u> | <u>P&amp;ID-Sheet No.</u> | <u>Coord.</u> | <u>Description</u> | <u>Measured Parameters &amp; Frequency</u> |                    |                   |                                    |                   | <u>RR/Remarks</u> |
|-------------------|--------------|---------------------------|---------------|--------------------|--|--------------------|-------------------|------------------------------------|-------------------|-------------------|
|                   |              |                           |               |                    | <u>P<sub>o</sub></u><br>(psig)             | <u>ΔP</u><br>(psi) | <u>Q</u><br>(gpm) | <u>V</u><br>(ft <sup>3</sup> /sec) | <u>N</u><br>(rpm) |                   |
| 2-1205-P6-001     | 2/212        | 2X4DB122                  | G-4           | RHR Pump           | QTR  | QTR                | QTR               | QTR                                | NA                | RR-P-2            |
| 2-1205-P6-002     | 2/212        | 2X4DB122                  | D-4           | RHR Pump           | QTR  | QTR                | QTR               | QTR                                | NA                | RR-P-2            |

Test Frequency: QTR = Quarterly Pump Test

VEGP-2 PUMP TEST TABLE

Containment Spray - System 1206

| <u>I.D. Number</u> | <u>CC/PC</u> | <u>P&amp;ID-Sheet No.</u> | <u>Coord.</u> | <u>Description</u> | <u>Measured Parameters &amp; Frequency</u> |                    |                   |                      |                   | <u>RR/Remarks</u> |
|--------------------|--------------|---------------------------|---------------|--------------------|--|--------------------|-------------------|----------------------|-------------------|-------------------|
|                    |              |                           |               |                    | <u>P<sub>o</sub></u><br>(psig)             | <u>ΔP</u><br>(psf) | <u>Q</u><br>(gpm) | <u>V</u><br>(ln/sec) | <u>N</u><br>(rpm) |                   |
| 2-1206-P6-001      | 2/212        | 2X4DB131                  | G-4           | CS Pump            | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 2-1206-P6-002      | 2/212        | 2X4DB131                  | C-4           | CS Pump            | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |

Test Frequency: QTR = Quarterly Pump Test

VEGP-2 PUMP TEST TABLE

Chemical & Volume Control - System 1208

| <u>LD. Number</u> | <u>CC/PC</u> | <u>P&amp;ID-Sheet No.</u> | <u>Coord.</u> | <u>Description</u>             | <u>Measured Parameters &amp; Frequency</u> |                    |                   |                      |                   | <u>RR/Remarks</u> |
|-------------------|--------------|---------------------------|---------------|--------------------------------|--|--------------------|-------------------|----------------------|-------------------|-------------------|
|                   |              |                           |               |                                | <u>P<sub>o</sub></u><br>(psig)             | <u>ΔP</u><br>(psi) | <u>Q</u><br>(gpm) | <u>V</u><br>(ln/sec) | <u>N</u><br>(rpm) |                   |
| 2-1208-P6-002     | 2/212        | 2X4DB116-2                | G-4           | CVCS Centrifugal Charging Pump | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 2-1208-P6-003     | 2/212        | 2X4DB116-2                | C-4           | CVCS Centrifugal Charging Pump | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 2-1208-P6-006     | 3/313        | 2X4DB118                  | D-4           | CVCS Boric Acid Transfer Pump  | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-1, RR-P-2    |
| 2-1208-P6-007     | 3/313        | 2X4DB118                  | B-4           | CVCS Boric Acid Transfer Pump  | QTR  | QTR                | QTR               | QTR                  | NA                | R. P-1, RR-P-2    |

Test Frequency: QTR = Quarterly Pump Test

VEGP-2 PUMP TEST TABLE

Auxiliary Feedwater - System 1302

| <u>LD. Number</u> | <u>CC/PC</u> | <u>P&amp;ID-Sheet No.</u> | <u>Coord.</u> | <u>Description</u>         | <u>Measured Parameters &amp; Frequency</u> |                    |                   |                      |                   | <u>RR/Remarks</u> |
|-------------------|--------------|---------------------------|---------------|----------------------------|--|--------------------|-------------------|----------------------|-------------------|-------------------|
|                   |              |                           |               |                            | <u>P<sub>0</sub></u><br>(psig)             | <u>ΔP</u><br>(psi) | <u>Q</u><br>(gpm) | <u>V</u><br>(in/sec) | <u>N</u><br>(rpm) |                   |
| 2-1302-P4-001     | 3/313        | 2X4DB161-2                | F-6           | AFW Pump<br>Turbine Driven | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 2-1302-P4-002     | 3/313        | 2X4DB161-2                | D-6           | AFW Pump<br>Motor Driven   | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 2-1302-P4-003     | 3/3          | 2X4DB161-2                | B-6           | AFW Pump<br>Motor Driven   | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |

Test Frequency: QTR = Quarterly Pump Test

VEGP-2 PUMP TEST TABLE

Safety Related (ESF) Chillers - System 1592

| <u>LD. Number</u> | <u>CC/PC</u> | <u>P&amp;ID-Sheet No.</u> | <u>Coord.</u> | <u>Description</u>     | <u>Measured Parameters &amp; Frequency</u> |                    |                   |                      |                   | <u>RR/Remarks</u> |
|-------------------|--------------|---------------------------|---------------|------------------------|--|--------------------|-------------------|----------------------|-------------------|-------------------|
|                   |              |                           |               |                        | <u>P<sub>G</sub></u><br>(psig)             | <u>ΔP</u><br>(psf) | <u>Q</u><br>(gpm) | <u>V</u><br>(in/sec) | <u>N</u><br>(rpm) |                   |
| 2-1592-P7-001     | 3/313        | 2X4DB221                  | F-5           | ESF Chilled Water Pump | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |
| 2-1592-P7-002     | 3/313        | 2X4DB221                  | C-5           | ESF Chilled Water Pump | QTR  | QTR                | QTR               | QTR                  | NA                | RR-P-2            |

Test Frequency: QTR = Quarterly Pump Test



NSCW Pumps  
(2-1202-P4-001, 002, 003, 004, 005, & 006)

|                          |  |
|--------------------------|--|
| System Function          | Provide cooling water for the containment coolers, control building essential chiller condensers, various engineered safety feature pump motor and lube oil coolers, and the component cooling water and auxiliary component cooling water diesel generator jacket water heat exchangers and transfers the heat removed to the ultimate heat sink. |
| Quantity                 | 6  |
| Type                     | Vertical Line Shaft, 2 stage, self lubricated  |
| Manufacturer/Model       | Bingham-Willamette/18x27B VCM  |
| Rated Capacity           | 8600 gpm (each)  |
| Rated Total Dynamic Head | 230 feet   |
| Driver                   |  |
| Type                     | Electric Motor   |
| Horsepower               | 700  |
| Speed                    | 1180 rpm   |
| Power Supply             | 4160V, 60 Hz, 3 phase  |
| Code Class               | 3  |
| Project Class            | 313  |
| Outline Drawing          | 2X4AF02-33   |
| Instruction Book         | 2X4AF02-94   |
| Physical Location        | NSCW Pump House  |
| P&ID                     | 2X4DB133-1, -2   |
| Surveillance Procedure   | 14802-2  |
| Pump Test Loop Diagrams  | ISI-D-250 through ISI-D-255  |
| Test Parameter Sheets    | Page 15-3 through 15-8   |

NSCW Transfer Pumps  
(2-1202-P4-007, 008)

|                          |   |
|--------------------------|---|
| System Function          | Provides capability to transfer water between cooling tower basins. |
| Quantity                 | 2   |
| Type                     | Vertical Line Shaft, 2 stage, self lubricated                       |
| Manufacturer/Model       | Bingham-Willamette/18x12A VCM                                       |
| Rated Capacity           | 600 gpm (each)  |
| Rated Total Dynamic Head | 110 feet  |
| Driver                   |   |
| Type                     | Electric Motor  |
| Horsepower               | 30  |
| Speed                    | 1765 rpm  |
| Power Supply             | 480V, 60 Hz, 3 phase  |
| Code Class               | 3   |
| Project Class            | 313   |
| Outline Drawing          | 2X4AF02-136   |
| Instruction Book         | 2X4AF02-96  |
| Physical Location        | NSCW Pump House   |
| P&ID                     | 2X4DB133-1, -2  |
| Surveillance Procedure   | 14801-2   |
| Pump Test Loop Diagrams  | ISI-D-256 and ISI-D-257   |
| Test Parameter Sheet     | Page 15-9 and 15-10   |

**Test Parameter Table - Pump 2-1202-P4-001**  
(Figure ISI-D-250)

| Parameter             | Test Freq. | Instrumentation Utilized |             |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | LD. No.(4)               | Range       | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA          | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | LI-1606                  | NA          | (1)       | NA         | NA               | NA                             | NA                   | Measure basin level                |
| Outlet Pressure (Po)  | Qtr        | PI-2148                  | 0-200 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | (2)                      | NA          | ± 2%      | ΔPr        | .95 - 1.10ΔPr    | .93 - <.95ΔPr                  | <.93 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-11760                 | 0-15000 gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(5)      | Qtr        | (3)                      | NA          | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Basin level indicator is utilized to determine level in feet.
2. Differential pressure is calculated using basin level (to determine suction head) and outlet pressure.
3. Portable vibration instruments are utilized.
4. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
5. Measurements are taken on the upper motor-bearing housing in three orthogonal directions, one of which is the axial direction.

**Test Parameter Table - Pump 2-1202-P4-002  
(Figure ISI-D-251)**

| Parameter             | Test Freq. | Instrumentation Utilized |             |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | L.D. No.(4)              | Range       | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA          | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | LI-1607                  | NA          | (1)       | NA         | NA               | NA                             | NA                   | Measure basin level                |
| Outlet Pressure (Po)  | Qtr        | PI-2149                  | 0-200 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | (2)                      | NA          | ± 2%      | ΔPr        | .95 - 1.10ΔPr    | .93 - <.95ΔPr                  | <.93 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-11763                 | 0-15000 gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(5)      | Qtr        | (3)                      | NA          | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Basin level indicator is utilized to determine level in feet.
2. Differential pressure is calculated using basin level (to determine suction head) and outlet pressure.
3. Portable vibration instruments are utilized.
4. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
5. Measurements are taken on the upper motor-bearing housing in three orthogonal directions, one of which is the axial direction.

**Test Parameter Table - Pump 2-1202-P4-003**  
(Figure ISI-D-252)

| Parameter             | Test Freq. | Instrumentation Utilized |             |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | LD. No.(4)               | Range       | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA          | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | LI-1606                  | NA          | (1)       | NA         | NA               | NA                             | NA                   | Measure basin level                |
| Outlet Pressure (Po)  | Qtr        | PI-2152                  | 0-200 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | (2)                      | NA          | ± 2%      | ΔPr        | .95 - 1.10ΔPr    | .93 - <.95ΔPr                  | <.93 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-11762                 | 0-15000 gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(5)      | Qtr        | (3)                      | NA          | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Basin level indicator is utilized to determine level in feet.
2. Differential pressure is calculated using basin level (to determine suction head) and outlet pressure.
3. Portable vibration instruments are utilized.
4. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
5. Measurements are taken on the upper motor-bearing housing in three orthogonal directions, one of which is the axial direction.

**Test Parameter Table - Pump 2-1202-P4-004  
(Figure ISI-D-253)**

| Parameter             | Test Freq. | Instrumentation Utilized |             |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(4)              | Range       | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA          | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | LI-1607                  | NA          | (1)       | NA         | NA               | NA                             | NA                   | Measure basin level                |
| Outlet Pressure (Po)  | Qtr        | PI-2153                  | 0-200 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | (2)                      | NA          | ± 2%      | ΔPr        | .95 - 1.10ΔPr    | .93 - <.95ΔPr                  | <.93 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-11765                 | 0-15000 gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(5)      | Qtr        | (3)                      | NA          | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Basin level indicator is utilized to determine level in feet.
2. Differential pressure is calculated using basin level (to determine suction head) and outlet pressure.
3. Portable vibration instruments are utilized.
4. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
5. Measurements are taken on the upper motor-bearing housing in three orthogonal directions, one of which is the axial direction.

**Test Parameter Table - Pump 2-1202-P4-005**

**(Figure ISI-D-254)**

| Parameter             | Test Freq. | Instrumentation Utilized |             |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(4)              | Range       | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA          | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | LI-1606                  | NA          | (1)       | NA         | NA               | NA                             | NA                   | Measure basin level                |
| Outlet Pressure (Po)  | Qtr        | PI-2150                  | 0-200 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | (2)                      | NA          | ± 2%      | ΔPr        | .95 - 1.10ΔPr    | .93 - <.95ΔPr                  | <.93 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-11761                 | 0-15000 gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(5)      | Qtr        | (3)                      | NA          | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Basin level indicator is utilized to determine level in feet.
2. Differential pressure is calculated using basin level (to determine suction head) and outlet pressure.
3. Portable vibration instruments are utilized.
4. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
5. Measurements are taken on the upper motor-bearing housing in three orthogonal directions, one of which is the axial direction.

**Test Parameter Table - Pump 2-1202-P4-006**

**(Figure ISI-D-255)**

| Parameter             | Test Freq. | Instrumentation Utilized |             |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(4)              | Range       | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA          | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | LI-1607                  | NA          | (1)       | NA         | NA               | NA                             | NA                   | Measure basin level                |
| Outlet Pressure (Po)  | Qtr        | PI-2151                  | 0-200 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | (2)                      | NA          | ± 2%      | ΔPr        | .95 - 1.10ΔPr    | .93 - <.95ΔPr                  | <.93 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-11764                 | 0-15000 gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(5)      | Qtr        | (3)                      | NA          | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Basin level indicator is utilized to determine level in feet.
2. Differential pressure is calculated using basin level (to determine suction head) and outlet pressure.
3. Portable vibration instruments are utilized.
4. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
5. Measurements are taken on the upper motor-bearing housing in three orthogonal directions, one of which is the axial direction.



**Test Parameter Table - Pump 2-1202-P4-007**  
(Figure ISI-D-256)

| Parameter             | Test Freq. | Instrumentation Utilized |            |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(4)              | Range      | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA         | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | LI-1606                  | NA         | (1)       | NA         | NA               | NA                             | NA                   | Measure basin level                |
| Outlet Pressure (Po)  | Qtr        | PI-2154                  | 0-100 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | (2)                      | NA         | ± 2%      | ΔPr        | .95 - 1.10ΔPr    | .93 - <.95ΔPr                  | <.93 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-2156                  | 0-1000 gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(5)      | Qtr        | (3)                      | NA         | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Basin level indicator is utilized to determine level in feet.
2. Differential pressure is calculated using basin level (to determine suction head) and outlet pressure.
3. Portable vibration instruments are utilized.
4. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
5. Measurements are taken on the upper motor-bearing housing in three orthogonal directions, one of which is the axial direction.


**Test Parameter Table - Pump 2-1202-P4-008**  
(Figure ISI-D-257)

| Parameter             | Test Freq. | Instrumentation Utilized |            |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(4)              | Range      | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA         | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | LI-1607                  | NA         | (1)       | NA         | NA               | NA                             | NA                   | Measure basin level                |
| Outlet Pressure (Po)  | Qtr        | PI-2155                  | 0-100 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | (2)                      | NA         | ± 2%      | ΔPr        | .95 - 1.10ΔPr    | .93 - <.95ΔPr                  | <.93 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-2157                  | 0-1000 gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(5)      | Qtr        | (3)                      | NA         | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Basin level indicator is utilized to determine level in feet.
2. Differential pressure is calculated using basin level (to determine suction head) and outlet pressure.
3. Portable vibration instruments are utilized.
4. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
5. Measurements are taken on the upper motor-bearing housing in three orthogonal directions, one of which is the axial direction.


NOTE: THIS IS A SIMPLIFIED DIAGRAM  
USED TO DEPICT A TEST CIRCUIT.  
REFER TO P&ID FOR DETAILS.



| REV. | DATE    | BY  | CHK'D | DESCRIPTION                     | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|---------------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 9-5-84  | BGS | VS    | ISSUED FOR PST                  | FT     |        |        |        |        |         |
| 1    | 1-26-88 | MSS | RLB   | UPDATED TO REV 20 OF 2X40R133-1 | JTC    |        |        |        |        |         |
| 2    | 12-2-96 | DWR |       | REBORN IN ACAD13                | QMS    |        |        |        |        |         |

|  |         |                |                    |
|--|---------|----------------|--------------------|
| Southern Company Services, Inc. FOR Southern Nuclear Operating Company |         |                |                    |
| VOGTLÉ ELECTRIC GENERATING PLANT<br>UNIT 2                             |         | DESIGNED FT    | DRAWN DRG          |
|  |         | TYPEB          | CHECKED VS         |
|  |         | SCALE NONE     | CONTINUED ON SHEET |
|  | PROJ.LD | DRAWING NUMBER | SHEET REV.         |
| N/A  | N/A     | ISI-D-250      | 1 OF 1 2           |

NOTE: THIS IS A SIMPLIFIED DIAGRAM  
USED TO DEPICT A TEST CIRCUIT.  
REFER TO THE P&ID FOR DETAILS.



| REV. | DATE    | BY  | CHK'D | DESCRIPTION                    | APPR.1     | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|--------------------------------|------------|--------|--------|--------|--------|---------|
| 0    | 9-5-84  | BGS | VS    | ISSUED FOR PST                 | FT         |        |        |        |        |         |
| 1    | 1-26-88 | MSS | RLB   | UPDATE TO REV 19 OF 2X488133-2 | JJC        |        |        |        |        |         |
| 2    | 12-2-96 | DVR |       | REDRAWN IN ACAB13              | <i>DYS</i> |        |        |        |        |         |


Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
UNIT 2

PUMP INSERVICE TESTING LOOP FOR  
NUCLEAR SERVICE COOLING WATER  
PUMP 2-1202-P4-002


|          |            |                    |            |
|----------|------------|--------------------|------------|
| DESIGNED | FT         | DRAWN              | BRC        |
| TYPED    |            | CHECKED            | VS         |
| SCALE    | NONE       | CONTINUED ON SHEET |            |
|          | PROJ. I.D. | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A        | ISI-D-251          | 1 OF 1 2   |

NOTE: THIS IS A SIMPLIFIED DIAGRAM  
USED TO DEPICT A TEST CIRCUIT.  
REFER TO THE P&ID FOR DETAILS.



| REV.   | DATE    | BY  | CHK'D | DESCRIPTION                     | APP'R.1 | APP'R.2 | APP'R.3   | APP'R.4 | APP'R.5  | REMARKS |
|--|---------|-----|-------|---------------------------------|---------|---------|-----------|---------|----------|---------|
| 0  | 9-5-84  | BGS | VS    | ISSUED FOR PST                  |         |         |           |         |          |         |
| 1  | 1-26-88 | HSS | RLB   | UPDATED TO REV 20 OF 2X40B133-1 | J.E.    |         |           |         |          |         |
| 2  | 12-2-96 | DVR |       | REDRAWN IN ACAD13               | DMS     |         |           |         |          |         |
| Southern Company Services, Inc. FOR Southern Nuclear Operating Company                 |         |     |       |                                 |         |         |           |         |          |         |
| VOGTLE ELECTRIC GENERATING PLANT<br>UNIT 2   |         |     |       |                                 |         |         |           |         |          |         |
| PUMP INSERVICE TESTING LOOP FOR<br>NUCLEAR SERVICE COOLING WATER<br>PUMP 2-1202-P4-003 |         |     |       |                                 |         |         |           |         |          |         |
| DESIGNED FT  |         |     |       | DRAWN BRC                       |         |         |           |         |          |         |
| TYPED  |         |     |       | CHECKED VS                      |         |         |           |         |          |         |
| SCALE NONE   |         |     |       | CONTINUED ON SHEET              |         |         |           |         |          |         |
| PROJ. I.D.   |         |     |       | DRAWING NUMBER                  |         |         | SHEET     |         | REV.     |         |
| N/A  |         |     |       | N/A                             |         |         | ISI-D-252 |         | 1 OF 1 2 |         |

NOTE: THIS IS A SIMPLIFIED DIAGRAM  
USED TO DEPICT A TEST CIRCUIT.  
REFER TO THE P&ID FOR DETAILS.




| REV. | DATE    | BY  | CHK'D | DESCRIPTION                    | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|--------------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 9-5-84  | BGS | WS    | ISSUED FOR PST                 | FT     |        |        |        |        |         |
| 1    | 1-26-98 | RSS | RLB   | UPDATE TO REV 19 OF 2X408133-2 | JJC    |        |        |        |        |         |
| 2    | 12-2-96 | DVR |       | REDRAWN IN ACAD13              | DYS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
UNIT 2  
PUMP INSERVICE TESTING LOOP FOR  
NUCLEAR SERVICE COOLING WATER  
PUMP 2-1202-P4-004

| DESIGNED | FT       | DRAWN              | IRC        |
|----------|----------|--------------------|------------|
| TYPED    |          | CHECKED            | WS         |
| SCALE    | NONE     | CONTINUED ON SHEET |            |
|          | PROJ.ID. | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A      | ISI-D-253          | 1 OF 1 2   |


NOTE: THIS IS A SIMPLIFIED DIAGRAM  
USED TO DEPICT A TEST CIRCUIT.  
REFER TO THE P&ID FOR DETAILS.



| REV. | DATE    | BY  | CHK'D | DESCRIPTION                     | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|---------------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 9-5-64  | BGS | HS    | ISSUED FOR PST                  | FT     |        |        |        |        |         |
| 1    | 1-26-68 | NSS | RLB   | UPDATED TO REV 26 OF 2X408133-1 | JJC    |        |        |        |        |         |
| 2    | 12-2-96 | DVR |       | REDRAWN IN ACAD13               | QMS    |        |        |        |        |         |

|  |     |             |                    |
|--|-----|-------------|--------------------|
| Southern Company Services, Inc. FOR Southern Nuclear Operating Company                 |     |             |                    |
| VOGTLE ELECTRIC GENERATING PLANT<br>UNIT 2   |     | DESIGNED FT | DRAWN DRC          |
| PUMP INSERVICE TESTING LOOP FOR<br>NUCLEAR SERVICE COOLING WATER<br>PUMP 2-1202-P4-005 |     | TYPED       | CHECKED WS         |
|  |     | SCALE NONE  | CONTINUED ON SHEET |
|  |     | PROJ.10     | DRAWING NUMBER     |
| N/A  | N/A | ISI-D-254   | 1 OF 2             |

NOTE: THIS IS A SIMPLIFIED DIAGRAM  
USED TO DEPICT A TEST CIRCUIT.  
REFER TO THE P&ID FOR DETAILS.



| REV. | DATE    | BY  | CHK'D | DESCRIPTION                    | APPR1 | APPR2 | APPR3 | APPR4 | APPR5 | REMARKS |
|------|---------|-----|-------|--------------------------------|-------|-------|-------|-------|-------|---------|
| 0    | 9-5-84  | NSS | VS    | ISSUED FOR PST                 | FT    |       |       |       |       |         |
| 1    | 1-26-89 | NSS | RLB   | UPDATE TO REV 19 OF 2X408133-2 | JJC   |       |       |       |       |         |
| 2    | 12-2-96 | DVR |       | REDRAWN IN ACAD13              | DYJ   |       |       |       |       |         |


Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
UNIT 2  
PUMP INSERVICE TESTING LOOP FOR  
NUCLEAR SERVICE COOLING WATER  
PUMP 2-1202-P4-006

| DESIGNED | BY        | DRAWN              | BY         |
|----------|-----------|--------------------|------------|
| FT       |           | DRG                |            |
| TYPED    |           | CHECKED            | VS         |
| SCALE    | NONE      | CONTINUED ON SHEET |            |
|          | PROJ.I.D. | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A       | ISI-D-255          | 1 OF 1 2   |



NOTE: THIS IS A SIMPLIFIED DIAGRAM  
USED TO DEPICT A TEST CIRCUIT.  
REFER TO THE P&ID FOR DETAILS




| REV. | DATE    | BY  | CHK'D | DESCRIPTION  | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|--|--------|--------|--------|--------|--------|---------|
| 0    | 9-5-84  | BGS | VS    | ISSUED FOR PST                                     | FT     |        |        |        |        |         |
| 1    | 1-26-88 | MSJ | RLS   | UPDATED TO REV. 29 EX48B133-1 & REV. 19 EX48B133-2 | JJC    |        |        |        |        |         |
| 2    | 6-14-88 | TEV | JMA   | ADDED PI-8894 & P-8895; DELETED NSCW HEADERS       | JJC    |        |        |        |        |         |
| 3    | 12-2-96 | DVR | QMS   | REDRAWN IN ACAD13                                  | DMS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
UNIT 2  
PUMP INSERVICE INSPECTION LOOP  
FOR TRANSFER PUMP  
2-1202-P4-007

|          |          |                    |            |
|----------|----------|--------------------|------------|
| DESIGNED | FT       | DRAWN              | BRC        |
| TYPED    |          | CHECKED            | VS         |
| SCALE    | NONE     | CONTINUED ON SHEET |            |
|          | PROJ.LB. | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A      | ISI-D- 256         | 1 OF 3     |

NOTE: THIS IS A SIMPLIFIED DIAGRAM  
USED TO DEPICT A TEST CIRCUIT.  
REFER TO THE P&ID FOR DETAILS



| REV. | DATE    | BY  | CHK'D | DESCRIPTION  | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|--|--------|--------|--------|--------|--------|---------|
| 0    | 9-5-84  | BOS | VS    | ISSUED FOR PST                                     | FT     |        |        |        |        |         |
| 1    | 1-26-88 | HSS | RLS   | UPDATED TO REV. 20 EX48B133-1 & REV. 19 EX48B133-2 | JJC    |        |        |        |        |         |
| 2    | 4-19-89 | TEV | JAK   | ADDED PI-8894 & P-8895; DELETED NSCW HEADERS       | JJC    |        |        |        |        |         |
| 3    | 12-2-96 | DVR | AKS   | REDRAWN IN ACAD13                                  | AKS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VDGTLE ELECTRIC GENERATING PLANT  
UNIT 2  
PUMP INSERVICE INSPECTION LOOP  
FOR TRANSFER PUMP  
2-1202-P4-008

|          |          |                    |            |
|----------|----------|--------------------|------------|
| DESIGNED | FT       | DRAWN              | DRG        |
| TYPED    |          | CHECKED            | VS         |
| SCALE    | NONE     | CONTAINED ON SHEET |            |
|          | PROJ.LB. | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A      | ISI-D- 257         | 1 OF 1 3   |

CCW Pumps  
(2-1203-P4-001, 002, 003, 004, 005, & 006)

|                          |  |
|--------------------------|--|
| System Function          | Remove waste heat from the spent fuel pool heat exchangers, RHR heat exchangers and the RHR pump seal coolers during plant operation, plant cooldown and during a postulated post-accident condition. This heat energy is then transferred by the component cooling water heat exchangers to the NSCWS. The CCWS functions as an intermediate system between a radioactive fluid system and the non-radioactive NSCWS, which operates at a higher system pressure. This arrangement greatly reduces the probability of radioactive fluid leakage to the environment by means of the NSCWS. |
| Quantity                 | 6  |
| Type                     | Horizontal, centrifugal, single-stage, split volute with mechanical seals  |
| Manufacturer/Model       | Ingersoll-Rand/10x18 SE  |
| Rated Capacity           | 5000 gpm (each)  |
| Rated Total Dynamic Head | 160 feet   |
| Driver                   |  |
| Type                     | Electric Motor, Westinghouse, LAC-LLD, 5008-S  |
| Horsepower               | 300  |
| Speed                    | 1761 rpm   |
| Power Supply             | 4160V, 60 Hz, 3 phase  |
| Code Class               | 3  |
| Project Class            | 313  |
| Outline Drawing          | 2X4AF01-109 & 2X4AF01-110  |
| Instruction Book         | 2X4AF01-137  |
| Physical Location        | Aux Bldg, Level A, Rooms R-A96 & R-A98   |
| P&ID                     | 2X4DB136   |
| Surveillance Procedure   | 14803-2  |
| Pump Test Loop Diagrams  | ISI-D-258 through ISI-D-263  |
| Test Parameter Sheets    | Page 16-3 through 16-8   |

**Test Parameter Table - Pump 2-1203-P4-001**  
(Figure ISI-D-258)

| Parameter             | Test Freq. | Instrumentation Utilized |             |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range       | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA          | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-1878                  | 0-60 psig   | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-1858                  | 0-200 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA          | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-11794                 | 0-10000 gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA          | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

- Differential pressure is calculated as,  $\Delta P = P_o - P_i$
- Portable vibration instruments are utilized.
- At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
- Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.

**Test Parameter Table - Pump 2-1203-P4-002**  
(Figure ISI-D-259)

| Parameter             | Test Freq. | Instrumentation Utilized |             |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range       | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA          | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-1881                  | 0-60 psig   | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-1859                  | 0-200 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA          | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-11795                 | 0-10000 gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA          | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.

**Test Parameter Table - Pump 2-1203-P4-003**

**(Figure ISI-D-260)**

| Parameter             | Test Freq. | Instrumentation Utilized |             |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range       | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA          | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-1879                  | 0-60 psig   | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-1860                  | 0-200 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA          | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-11796                 | 0-10000 gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA          | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

- Differential pressure is calculated as,  $\Delta P = P_o - P_i$
- Portable vibration instruments are utilized.
- At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
- Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.

**Test Parameter Table - Pump 2-1203-P4-004**  
(Figure ISI-D-261)

| Parameter             | Test Freq. | Instrumentation Utilized |             |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range       | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA          | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-1882                  | 0-60 psig   | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-1861                  | 0-200 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA          | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-11797                 | 0-10000 gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA          | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.

**Test Parameter Table - Pump 2-1203-P4-005**  
(Figure ISI-D-262)

| Parameter             | Test Freq. | Instrumentation Utilized |             |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range       | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA          | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-1880                  | 0-60 psig   | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-1862                  | 0-200 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA          | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-11798                 | 0-10000 gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA          | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.




**Test Parameter Table - Pump 2-1203-P4-006**

(Figure ISI-D-263)

| Parameter             | Test Freq. | Instrumentation Utilized |             |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range       | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA          | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-1883                  | 0-60 psig   | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-1863                  | 0-200 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA          | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-11799                 | 0-10000 gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA          | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.



NOTE: THIS IS A SIMPLIFIED DIAGRAM USED TO DEPICT A TEST CIRCUIT. REFER TO THE P&ID FOR DETAILS.

TRAIN 'A'


| REV. | DATE    | BY  | CHK'D | DESCRIPTION                    | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|--------------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 9-5-84  | BGS | VS    | ISSUED FOR PST                 | FT     |        |        |        |        |         |
| 1    | 1-26-88 | HSS | RLB   | UPDATED TO REV. 14 OF 2X488136 | JJC    |        |        |        |        |         |
| 2    | 12-2-96 | BVR | DMS   | REDRAWN IN ACADIS              | DMS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
UNIT 2

PUMP INSERVICE TESTING LOOP FOR  
COMPONENT COOLING WATER PUMP  
2-1203-P4-001

|          |          |                    |            |
|----------|----------|--------------------|------------|
| DESIGNED | FT       | DRAWN              | BRC        |
| TYPED    |          | CHECKED            | VS         |
| SCALE    | NONE     | CONTINUED ON SHEET |            |
|          | PROJ.118 | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A      | ISI-D-258          | 1 OF 2     |




| REV. | DATE    | BY  | CHK'D | DESCRIPTION                    | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|--------------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 9-9-84  | BGE | VS    | ISSUED FOR PST                 | FT     |        |        |        |        |         |
| 1    | 1-05-89 | HSS | RLS   | UPDATED TO REV. 14 OF EX400136 | JJC    |        |        |        |        |         |
| 2    | 12-2-96 | BVR | DMS   | REDRAWN IN ACADIS              | DMS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTE ELECTRIC GENERATING PLANT  
UNIT 2

PUMP INSERVICE TESTING LOOP FOR  
COMPONENT COOLING WATER PUMP  
2-1203-P4-002

|          |           |                    |            |
|----------|-----------|--------------------|------------|
| DESIGNED | FT        | DRAWN              | DRC        |
| TYPED    |           | CHECKED            | VS         |
| SCALE    | NONE      | CONTAINED ON SHEET |            |
|          | PROJ. LB. | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A       | ISI-D- 259         | 1 OF 1 2   |



TRAIN 'A'


| REV. | DATE    | BY  | CHK'D | DESCRIPTION                    | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|--------------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 9-5-84  | BGS | VS    | ISSUED FOR PST                 | FT     |        |        |        |        |         |
| 1    | 1-26-88 | HSS | RLB   | UPDATED TO REV. 14 OF 2X10B136 | JJC    |        |        |        |        |         |
| 2    | 12-2-96 | DVR | WMS   | REDRAWN IN ACAD13              | DMS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
UNIT 2

PUMP INSERVICE TESTING LOOP FOR  
COMPONENT COOLING WATER PUMP  
2-1203-P4-003

|          |           |                    |            |
|----------|-----------|--------------------|------------|
| DESIGNED | FT        | DRAWN              | BRC        |
| TYPE     |           | CHECKED            | VS         |
| SCALE    | NONE      | CONTAINED ON SHEET |            |
|          | PROJ. NO. | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A       | ISI-D-260          | 1 OF 1 2   |



TRAIN 'B'


| REV. | DATE    | BY  | CHK'D | DESCRIPTION                    | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|--------------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 9-5-84  | BGS | VS    | ISSUED FOR PST                 | FT     |        |        |        |        |         |
| 1    | 1-25-88 | CL  | RLB   | UPDATED TO REV. 14 OF EX408136 | JJC    |        |        |        |        |         |
| 2    | 12-2-96 | BVR | DMS   | REBRAIN IN ACADIS              | DMS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
UNIT 2

PUMP INSERVICE TESTING LOOP FOR  
COMPONENT COOLING WATER PUMP  
2-1203-P4-004


|          |            |                    |            |
|----------|------------|--------------------|------------|
| DESIGNED | FT         | DRAWN              | IRC        |
| TYPED    |            | CHECKED            | VS         |
| SCALE    | NONE       | CONTINUED ON SHEET |            |
|          | REG. 1.1.B | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A        | ISI-D-261          | 1 OF 1 2   |



TRAIN 'A'

| REV. | DATE    | BY  | CHK'D | DESCRIPTION                    | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|--------------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 9-5-64  | DGS | VS    | ISSUED FOR PST                 | FT     |        |        |        |        |         |
| 1    | 1-26-68 | CL  | RLB   | UPDATED TO REV. 14 OF 2X188136 | LIC    |        |        |        |        |         |
| 2    | 12-2-96 | BVR | DMS   | REDRAWN IN ACAD13              | DMS    |        |        |        |        |         |

|  |         |                    |            |
|--|---------|--------------------|------------|
| Southern Company Services, Inc. FOR Southern Nuclear Operating Company |         |                    |            |
| VOGTLE ELECTRIC GENERATING PLANT<br>UNIT 2                             |         | DESIGNED FT        | DRAWN BRC  |
|  |         | CHECKED WS         |            |
|  |         | CONTINUED ON SHEET |            |
| SCALE NONE   | PROJ.13 | DRAWING NUMBER     | SHEET REV. |
| N/A  | N/A     | ISI-D-262          | 1 OF 1 2   |



| REV. | DATE    | BY  | CHK'D | DESCRIPTION                    | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|--------------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 9-5-84  | BGE | VS    | ISSUED FOR PST                 | FT     |        |        |        |        |         |
| 1    | 1-26-88 | CL  | RLB   | UPDATED TO REV. 14 OF EX188136 | JJC    |        |        |        |        |         |
| 2    | 12-2-96 | BVR | AKS   | RE-DRAWN IN ACADIS             | AKS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
UNIT 2

PUMP INSERVICE TESTING LOOP FOR  
COMPONENT COOLING WATER PUMP  
2-1203-P4-006

|            |      |                 |            |
|------------|------|-----------------|------------|
| DESIGNED   | FT   | DRAWN           | BRC        |
| TYPED      |      | CHECKED         | VS         |
| SCALE      | NONE | CONT'D ON SHEET |            |
| PROJ. I.B. |      | DRAWING NUMBER  | SHEET REV. |
| N/A        | N/A  | ISI-D-263       | 1 OF 1 2   |

SI Pumps  
(2-1204-P6-003, & 004)

|                         |  |
|-------------------------|--|
| System Function         | The SI system provides emergency core cooling and serves no other purpose.<br><br>The primary function of the ECCS is to remove the stored and fission product decay heat from the reactor core following an accident in order to prevent fuel rod damage. |
| Quantity                | 2  |
| Type                    | Horizontal, centrifugal, 11-stage  |
| Manufacturer/Model      | Pacific Model 3-in., JHF   |
| Rated Capacity          | 440 gpm  |
| Rated Head              | 2630 ft.   |
| Driver                  |  |
| Type                    | Electric Motor, Westinghouse, Frame 5809 H   |
| Horsepower              | 450  |
| Speed                   | 3600 rpm   |
| Power Supply            | 4160V, 60 Hz, 3 phase  |
| Code Class              | 2  |
| Project Class           | 212  |
| Outline Drawing         | 2X6AG02-10, 13 & 15  |
| Instruction Book        | 2X6AG02-016  |
| Physical Location       | Aux Bldg, Level B, Rooms R-B117 & R-B119   |
| P&ID                    | 2X4DB121   |
| Surveillance Procedure  | 14804-2  |
| Pump Test Loop Diagrams | ISI-D-264 & ISI-D-265  |
| Test Parameter Sheets   | Page 17-2 & 17-3   |



**Test Parameter Table - Pump 2-1204-P6-003**  
(Figure ISI-D-264)

| Parameter             | Test Freq. | Instrumentation Utilized |            |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range      | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA         | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-0977                  | 0-100 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | Test Gage                | NA         | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA         | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-0968                  | 0-100 gpm  | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA         | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

- Differential pressure is calculated as,  $\Delta P = P_o - P_i$
- Portable vibration instruments are utilized.
- At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
- Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.


**Test Parameter Table - Pump 2-1204-P4-004**  
(Figure ISI-D-265)

| Parameter             | Test Freq. | Instrumentation Utilized |            |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range      | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA         | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-0978                  | 0-100 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | Test Gage                | NA         | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA         | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-0968                  | 0-100 gpm  | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA         | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.

NOTE: THIS IS A SIMPLIFIED  
DIAGRAM USED TO DEPICT  
A TEST CIRCUIT. REFER  
TO THE P&ID FOR DETAILS.




| REV. | DATE    | BY  | CHK'D | DESCRIPTION                   | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|-------------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 5-24-84 | BGS | VS    | ISSUED FOR PST                | FT     |        |        |        |        |         |
| 1    | 1-26-88 | CL  | RLB   | UPDATED TO REV. 29 OF 2X48821 | JJC    |        |        |        |        |         |
| 2    | 12-2-96 | DVR | QVS   | REBRANN IN ACAD13             | AMS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
UNIT 2  
PUMP INSERVICE TESTING LOOP  
FOR SAFETY INJECTION PUMP  
2-1204-P6-003

|                    |                |
|--------------------|----------------|
| DESIGNED FT        | DRAWN BRC      |
| TYPED              | CHECKED VS     |
| CONTINUED ON SHEET |                |
| SCALE NONE         |                |
| PROJ.LB            | DRAWING NUMBER |
| SHEET              | REV.           |
| N/A                | N/A            |
| 1                  | OF 1           |
| 2                  |                |

NOTE: THIS IS A SIMPLIFIED  
DIAGRAM USED TO DEPICT  
A TEST CIRCUIT. REFER  
TO THE P&ID FOR DETAILS.



| REV. | DATE    | BY  | CHK'D | DESCRIPTION                    | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|--------------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 5-24-84 | BGS | WS    | ISSUED FOR PST                 | FT     |        |        |        |        |         |
| 1    | 1-05-88 | CL  | RLB   | UPDATED TO REV. 20 OF EX-88102 | JJC    |        |        |        |        |         |
| 2    | 12-2-96 | BVR | DMS   | REBRAIN IN ACADIS              | DMS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTE ELECTRIC GENERATING PLANT  
UNIT 2

PUMP INSERVICE TESTING LOOP  
FOR SAFETY INJECTION PUMP  
2-1204-P6-004

|          |         |                    |            |
|----------|---------|--------------------|------------|
| DESIGNED | FT      | DRAWN              | DRG        |
| TYPED    |         | CHECKED            | VS         |
| SCALE    | NONE    | CONTINUED ON SHEET |            |
|          | PROL.B. | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A     | ISI-D-265          | 1 OF 1 2   |

RHR Pumps  
(2-1205-P6-001, & 002)

|                         |   |
|-------------------------|---|
| System Function         | The primary function is to remove heat energy from the reactor core and reactor coolant system during plant cooldown and refueling operations. As a secondary function, RHR is used to transfer refueling water between the refueling water storage tank and the refueling cavity at the beginning and end of refueling operations. |
|                         | Portions of the RHR system also serve as part of the ECCS during the injection and recirculation phases of a LOCA.  |
| Quantity                | 2   |
| Type                    | Vertical, centrifugal, single stage   |
| Manufacturer/Model      | Ingersoll-Dresser, 8X20WDF  |
| Rated Capacity          | 3000 gpm  |
| Rated Head              | 375 ft.   |
| Driver                  |   |
| Type                    | Westinghouse LLD squirrel-cage induction motor  |
| Horsepower              | 400   |
| Speed                   | 1780 rpm  |
| Power Supply            | 4160V, 60 Hz, 3 phase   |
| Code Class              | 2   |
| Project Class           | 212   |
| Outline Drawing         | AX6AF02-20007   |
| Instruction Book        | AX6AF02-20030   |
| Physical Location       | Aux Bldg, Level D, Rooms R-D21 & R-D22  |
| P&ID                    | 2X4DB122  |
| Surveillance Procedure  | 14805-2 & 14812-2   |
| Pump Test Loop Diagrams | ISI-D-266 & ISI-D-267   |
| Test Parameter Sheets   | Page 18-2 & 18-3  |

**Test Parameter Table - Pump 2-1205-P6-001**

(Figure ISI-D-266)

| Parameter             | Test Freq. | Instrumentation Utilized |            |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range      | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA         | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-8884                  | 0-100 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-8886                  | 0-400 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA         | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-0618A                 | 0-5000 gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA         | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.

**Test Parameter Table - Pump 2-1205-P6-002**  
(Figure ISI-D-216)

| Parameter             | Test Freq. | Instrumentation Utilized |            |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range      | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA         | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-8885                  | 0-100 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-8887                  | 0-400 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA         | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-0619A                 | 0-5000 gpm | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA         | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the O-I Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.

**Test Parameter Table - Pump 2-1205-P6-002**  
(Figure ISI-D-216)


| <u>Parameter</u>      | <u>Test Freq.</u> | <u>Instrumentation Utilized</u> |              |                  | <u>Ref. Value</u> | <u>Acceptable Range</u> | <u>Alert Range</u>             | <u>Action Range</u>  | <u>Comments</u>                    |
|-----------------------|-------------------|---------------------------------|--------------|------------------|-------------------|-------------------------|--------------------------------|----------------------|------------------------------------|
|                       |                   | <u>I.D. No.(3)</u>              | <u>Range</u> | <u>Req. Acc.</u> |                   |                         |                                |                      |                                    |
| Speed (N)             | NA                | NA                              | NA           | NA               | NA                | NA                      | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr               | PI-8885                         | 0-100 psig   | ± 2%             | NA                | NA                      | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr               | PI-8887                         | 0-400 psig   | ± 2%             | NA                | NA                      | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr               | NA(1)                           | NA           | ± 2%             | ΔPr               | .90 - 1.10ΔPr           | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr               | FI-0619A                        | 0-5000 gpm   | ± 2%             | Qr                | NA                      | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr               | (2)                             | NA           | ± 5%             | Vr                | ≤ 2.5Vr                 | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of GPC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.



NOTE: THIS IS A SIMPLIFIED DIAGRAM USED TO DEPICT A TEST CIRCUIT. REFER TO THE P&ID FOR DETAILS.




| REV. | DATE    | BY  | CHK'D | DESCRIPTION   | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|---|--------|--------|--------|--------|--------|---------|
| 0    | 9-5-84  | BGS | VS    | ISSUED FOR PST  | FT     |        |        |        |        |         |
| 1    | 1-26-88 | CL  | RLB   | UPDATED TO REV.17 OF 2X48B122                                     | JJC    |        |        |        |        |         |
| 2    | 4-19-89 | TEV | JHA   | ADDED PI - 8884, & 8885, & 8886, & 8887<br>DELETED MINI-FLOW TEST | JJC    |        |        |        |        |         |
| 3    | 12-2-96 | JVB |       | RETRAVN IN ACAD13   | DMS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
UNIT 2  
PUMP INSERVICE TESTING LOOP  
FOR RESIDUAL HEAT REMOVAL PUMP  
2-1205-P6-001

|          |           |                    |            |
|----------|-----------|--------------------|------------|
| DESIGNED | FT        | DRAWN              | IRC        |
| TYPED    |           | CHECKED            | VS         |
| SCALE    | NONE      | CONTINUED ON SHEET |            |
|          | PROJ.I.D. | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A       | ISI-D- 266         | 1 OF 1 3   |

NOTE: THIS IS A SIMPLIFIED  
DIAGRAM USED TO DEPICT  
A TEST CIRCUIT. REFER  
TO THE P&ID FOR DETAILS.



| REV. | DATE    | BY  | CHK'D | DESCRIPTION  | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|--|--------|--------|--------|--------|--------|---------|
| 0    | 9-5-84  | BGS | VS    | ISSUED FOR PST   |        |        |        |        |        |         |
| 1    | 1-26-88 | CL  | RLB   | UPDATED TO REV J7 OF 2X4DB122                                    |        |        |        |        |        |         |
| 2    | 4-19-89 | TEV | JMA   | ADDED PI - 8884, & 8885, & 8886, & 8887<br>DELETED MDI-FLDY TEST |        |        |        |        |        |         |
| 3    | 12-2-96 | BWR |       | REDRAWN IN ACAB3   |        |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
UNIT 2  
PUMP INSERVICE TESTING LOOP  
FOR RESIDUAL HEAT REMOVAL PUMP  
2-1205-P6-002

|            |      |                |            |
|------------|------|----------------|------------|
| DESIGNED   | FT   | DRAWN          | DRG        |
| TYPED      |      | CHECKED        | VE         |
| SCALE      | NONE | CENTRIFIED     | FIN SHEET  |
| PROJ. I.D. |      | DRAWING NUMBER | SHEET REV. |
| N/A        | N/A  | ISI-D-267      | 1 OF 1 3   |

CS Pumps  
(2-1206-P6-001, & 002)

|                         |  |
|-------------------------|--|
| System Function         | Containment spray limits the peak pressure in the containment to less than design pressure following a LOCA or a main steam line break inside containment. Trisodium phosphate is mixed with recirculated spray water in the containment sump region for pH control and to enhance absorption of the airborne fission product iodine and to retain the iodine in the containment sump solution to limit calculated offsite doses to less than 10CFR100 limits. |
| Quantity                | 2  |
| Type                    | Horizontal, centrifugal  |
| Manufacturer/Model      | Goulds Model 3415  |
| Capacity                | 2600 gpm   |
| Total Dynamic Head      | 450 ft.  |
| Driver                  |  |
| Type                    | Westinghouse electric motor, Frame 5010S   |
| Horsepower              | 400  |
| Speed                   | 1777 rpm   |
| Power Supply            | 4160V, 60 Hz, 3 phase  |
| Code Class              | 2  |
| Project Class           | 212  |
| Outline Drawing         | 2X6AD02-10   |
| Instruction Book        | 2X6AD02-18   |
| Physical Location       | Aux Bldg, Level D, Rooms R-D04 & R-D05   |
| P&ID                    | 2X4DB131   |
| Surveillance Procedure  | 14806-2  |
| Pump Test Loop Diagrams | ISI-D-268 & ISI-D-269  |
| Test Parameter Sheets   | Page 19-2 & 19-3   |

**Test Parameter Table - Pump 2-1206-P6-001**  
(Figure ISI-D-268)

| Parameter             | Test Freq. | Instrumentation Utilized |            |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range      | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA         | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-0972                  | 0-100 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-0974                  | 0-300 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA         | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-0929                  | 0-400 gpm  | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA         | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.


**Test Parameter Table - Pump 2-1206-P6-002**  
**(Figure ISI-D-269)**

| Parameter             | Test Freq. | Instrumentation Utilized |            |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range      | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA         | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-0973                  | 0-100 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-0975                  | 0-300 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA         | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-0929                  | 0-400 gpm  | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA         | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.

NOTE: THIS IS A SIMPLIFIED  
 DIAGRAM USED TO DEPICT  
 A TEST CIRCUIT. REFER  
 TO THE P&ID FOR DETAILS.




| REV. | DATE     | BY  | CHK'D | DESCRIPTION  | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|----------|-----|-------|--|--------|--------|--------|--------|--------|---------|
| 0    | 5-5-84   | BOS | VS    | ISSUED FOR P&T   | FT     |        |        |        |        |         |
| 1    | 1-05-88  | CL  | RLB   | UPDATED TO REV. 15 OF EX400131   | JJC    |        |        |        |        |         |
| 2    | 1-19-89  | TEV | JMA   | REVISED VALVES - 006, 007 & 151  | JJC    |        |        |        |        |         |
| 3    | 11-13-90 | VS  | DMS   | REMOVED SPRAY ADDITIVE TK & VALVES 029, 0994A AND B<br>CHANGED FI 0930 TO FI 10936 | DMS    |        |        |        |        |         |
| 4    | 12-2-96  | BVR | QMS   | REBRN IN ACAD13  | QMS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
 UNIT 2  
 PUMP INSERVICE TESTING LOOP  
 FOR CONTAINMENT SPRAY PUMP  
 2-1206-P6-001

|           |      |                    |            |
|-----------|------|--------------------|------------|
| DESIGNED  | FT   | DRAWN              | DRG        |
| TYPED     |      | CHECKED            | VS         |
| SCALE     | NONE | CONTINUED ON SHEET |            |
| PROJ. ID. | N/A  | DRAWING NUMBER     | SHEET REV. |
|           | N/A  | ISI-D-268          | 1 OF 4     |

NOTE: THIS IS A SIMPLIFIED  
 DIAGRAM USED TO DEPICT  
 A TEST CIRCUIT. REFER  
 TO THE P&ID FOR DETAILS.



| REV. | DATE     | BY  | CHK'D | DESCRIPTION  | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|----------|-----|-------|--|--------|--------|--------|--------|--------|---------|
| 0    | 9-5-84   | BGS | VS    | ISSUED FOR P&ID  | FT     |        |        |        |        |         |
| 1    | 1-05-88  | CL  | RLB   | UPDATED TO REV.15 OF 2448813   | JJC    |        |        |        |        |         |
| 2    | 4-19-89  | TEV | JMA   | REVISED VALVES - 006,007 & 151   | JJC    |        |        |        |        |         |
| 3    | 11-13-90 | VS  | DMS   | REMOVED SPRAY ADDITIVE TX & VALVES 029, 0994A AND B<br>CHANGED FI 0930 TO FI 10936 | DMS    |        |        |        |        |         |
| 4    | 12-2-96  | DVR | DMS   | REDRAWN IN ACAD13  | DMS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
 UNIT 2  
 PUMP INSERVICE TESTING LOOP  
 FOR CONTAINMENT SPRAY PUMP  
 2-1206-P6-002

|          |           |                    |            |
|----------|-----------|--------------------|------------|
| DESIGNED | FT        | DRAWN              | DRC        |
| TYPED    |           | CHECKED            | VS         |
| SCALE    | NONE      | CONTINUED ON SHEET |            |
|          | PROJ.L.S. | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A       | ISI-D- 269         | 1 OF 1 4   |

CVCS Pumps  
CENTRIFUGAL CHARGING PUMPS  
(2-1208-P6-002, & 003)

|                         |   |
|-------------------------|---|
| System Function         | <p>The primary functions of the CVCS are to:</p> <ul style="list-style-type: none"> <li>• Regulate reactor coolant chemistry for reactivity and corrosion control</li> <li>• Maintains the water level in the pressurizer of the RCS</li> <li>• Maintains seal-water injection flow to the reactor coolant pump</li> <li>• Provide a means of filling, draining and pressure testing the RCS</li> <li>• Provide injection flow to the RCS following actuation of SIS</li> </ul> |
| Quantity                | 2   |
| Type                    | Horizontal, centrifugal, 11 stage   |
| Manufacturer/Model      | Pacific, IJ 2-1/2 in., RL   |
| Capacity                | 150 gpm   |
| Total Dynamic Head      | 5800 ft.  |
| Driver                  |   |
| Type                    | Westinghouse electric motor   |
| Horsepower              | 600   |
| Speed                   | 1800 rpm  |
| Power Supply            | 4160V, 60 Hz, 3 phase   |
| Code Class              | 2   |
| Project Class           | 212   |
| Outline Drawing         | 2X6AH02-100   |
| Instruction Book        | 2X6AH02-85  |
| Physical Location       | Aux Bldg, Level C, Rooms R-C16 & R-C17  |
| P&ID                    | 2X4DB116-2  |
| Surveillance Procedure  | 14808-2   |
| Pump Test Loop Diagrams | ISI-D-270 & ISI-D-271   |
| Test Parameter Sheets   | Page 20-2 & 20-3  |



**Test Parameter Table - Pump 2-1208-P6-002**  
(Figure ISI-D-270)

| Parameter             | Test Freq. | Instrumentation Utilized |             |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range       | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA          | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-8891                  | 0-100 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-8472                  | 0-4000 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA          | ± 2%      | ΔPr        | 90 - 1.10ΔPr     | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-10120                 | 0-80 gpm    | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA          | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**


1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing

**Test Parameter Table - Pump 2-1208-P6-003  
(Figure ISI-D-271)**

| Parameter             | Test Freq. | Instrumentation Utilized |             |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range       | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA          | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-8892                  | 0-100 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-8473                  | 0-4000 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA          | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <90 or >1.10ΔPr      | NA                                 |
| Flowrate (Q)          | Qtr        | FI-10121                 | 0-80 gpm    | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA          | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.




NOTE: THIS IS A SIMPLIFIED DIAGRAM USED TO DEPICT A TEST CIRCUIT. REFER TO THE P&I.D. FOR DETAILS.

| REV. | DATE     | BY  | CHK'D | DESCRIPTION                                      | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|----------|-----|-------|--|--------|--------|--------|--------|--------|---------|
| 0    | 9-5-84   | BGS | VS    | ISSUED FOR PST                                   | FT     |        |        |        |        |         |
| 1    | 1-26-88  | CL  | RLB   | UPDATED TO REV.15 OF EX-0816-2                   | JJC    |        |        |        |        |         |
| 2    | 4-19-89  | TEV | JMA   | ADDED PI 8891, 8892                              | JJC    |        |        |        |        |         |
| 3    | 12-6-93  | VS  | MRG   | RELOCATED 2" BRANCH CONN'S; ADDED PS 8508A & B   | MB     |        |        |        |        |         |
| 4    | 11-13-95 | VS  | DMS   | CHANGED PI 118 AND PI 119 TO PI 8472 AND PI 8473 | DMS    |        |        |        |        |         |
| 5    | 12-2-96  | DVR | DMS   | REDRAWN IN ACAD13                                | DMS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTELE ELECTRIC GENERATING PLANT  
UNIT 2  
PUMP INSERVICE TESTING LOOP  
FOR CENTRIFUGAL CHARGING PUMP  
2-1208-P6-002

| DESIGNED | FT       | DRAWN              | DRG        |
|----------|----------|--------------------|------------|
| TYPE     |          | CHECKED            | VS         |
| SCALE    | NONE     | CONTINUED ON SHEET |            |
|          | PROJ. LB | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A      | ISI-D-270          | 1 OF 5     |



NOTE: THIS IS A SIMPLIFIED DIAGRAM USED TO DEPICT A TEST CIRCUIT. REFER TO THE P&I.D. FOR DETAILS.

| REV. | DATE     | BY  | CHK'D | DESCRIPTION                                      | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|----------|-----|-------|--|--------|--------|--------|--------|--------|---------|
| 0    | 9-5-84   | BGS | VS    | ISSUED FOR PST                                   | FT     |        |        |        |        |         |
| 1    | 1-26-88  | CL  | RLB   | UPDATED TO REV.15 OF PX48816-2                   | JJC    |        |        |        |        |         |
| 2    | 4-19-89  | TEV | JWA   | ADDED PI 8891, 8892                              | JJC    |        |        |        |        |         |
| 3    | 12-2-90  | VS  | BNG   | RELOCATED 2' BRANCH COMPS; ADDED PS 8508A & B    | MB     |        |        |        |        |         |
| 4    | 11-13-95 | VS  | DMS   | CHANGED PI 118 AND PI 119 TO PI 8472 AND PI 8473 | DMS    |        |        |        |        |         |
| 5    | 12-2-96  | DVR | DMS   | REBRWN IN ACAD3                                  | DMS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTE ELECTRIC GENERATING PLANT  
UNIT 2

PUMP INSERVICE TESTING LOOP  
FOR CENTRIFUGAL CHARGING PUMP  
2-1208-P6-003

|          |         |                    |            |
|----------|---------|--------------------|------------|
| DESIGNED | FT      | DRAWN              | DKC        |
| TYPED    |         | CHECKED            | VS         |
| SCALE    | NONE    | CONTINUED ON SHEET |            |
|          | PROJ.B. | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A     | ISI-D-271          | 1 OF 15    |

BORIC ACID TRANSFER PUMPS  
(2-1208-P6-006 & 007)

|                         |  |
|-------------------------|--|
| System Function         | Provides boric acid to the CVCS for use in RCS inventory control and makeup to systems requiring reactor grade borated water. The boric acid transfer system also provides boric acid for emergency boration of the RCS. |
| Quantity                | 2  |
| Type                    | Canned motor   |
| Manufacturer/Model      | Chempump Model GVH-1K  |
| Design Flowrate         | 75 gpm   |
| Design Head             | 235 ft.  |
| Driver                  |  |
| Type                    | Electric motor   |
| kW                      | 15.5   |
| Speed                   | 3450 rpm   |
| Power Supply            | 4160V, 60 Hz, 3 phase  |
| Code Class              | 3  |
| Project Class           | 313  |
| Outline Drawing         | 2X6AH02-45 & 2X6aH02-92  |
| Instruction Book        | 2X6AA07-10   |
| Physical Location       | Aux Bldg, Level D, Rooms R-D106 & R-D123   |
| P&ID                    | 2X4DB118   |
| Surveillance Procedure  | 14811-2  |
| Pump Test Loop Diagrams | ISI-D-277 & ISI-D-278  |
| Test Parameter Sheets   | Page 21-2 & 21-3   |

**Test Parameter Table - Pump 2-1208-P6-006**  
(Figure ISI-D-277)

| Parameter             | Test Freq. | Instrumentation Utilized |                 |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-----------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range           | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA              | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-10115                 | -15 to +15 psig | ± 2%      | NA         | NA               | NA                             | NA                   | Relief Request RR-P-1              |
| Outlet Pressure (Po)  | Qtr        | PI-0113                  | 0-160 psig      | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA              | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-40001                 | 0-100 gpm       | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA              | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

- Differential pressure is calculated as,  $\Delta P = P_o - P_i$
- Portable vibration instruments are utilized.
- At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
- Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.


**Test Parameter Table - Pump 2-1208-P6-007**  
**(Figure ISI-D-278)**

| Parameter             | Test Freq. | Instrumentation Utilized |                 |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-----------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range           | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA              | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-10116                 | -15 to +15 psig | ± 2%      | NA         | NA               | NA                             | NA                   | Relief Request RR-P-1              |
| Outlet Pressure (Po)  | Qtr        | PI-0114                  | 0-160 psig      | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA              | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-40001                 | 0-100 gpm       | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA              | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.

NOTE THIS IS A SIMPLIFIED DIAGRAM USED TO DEPICT A TEST CIRCUIT. REFER TO THE P&I.D. FOR DETAILS.



| REV. | DATE    | BY  | CHK'D | DESCRIPTION            | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 1-26-88 | CL  | RLB   | ISSUED FOR PST / IST   | JJC    |        |        |        |        |         |
| 1    | 5-16-89 | TEV | JJA   | REVISED TEST FLOW PATH | JJC    |        |        |        |        |         |
| 2    | 12-2-96 | DVR | QMS   | REBRAIN IN ACADIS      | QMS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company


VDGTE ELECTRIC GENERATING PLANT  
UNIT 2

PUMP INSERVICE TESTING LOOP FOR  
BORIC ACID TRANSFER PUMP  
2-1208-P6-007

|          |      |                    |           |
|----------|------|--------------------|-----------|
| DESIGNED | JJC  | DRAWN              | CL        |
| TYPE     |      | CHECKED            | FLB       |
| SCALE    | NONE | CONTINUED ON SHEET |           |
| PROJ. B. | N/A  | DRAWING NUMBER     | ISI-D-278 |
|          |      | SHEET              | 1 OF 1    |
|          |      | REV.               | 2         |



NOTE THIS IS A SIMPLIFIED DIAGRAM USED TO DEPICT A TEST CIRCUIT. REFER TO THE P&I.D. FOR DETAILS.



| REV. | DATE    | BY  | CHK'D | DESCRIPTION            | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 1-26-88 | CL  | RLB   | ISSUED FOR PST / IST   | JJC    |        |        |        |        |         |
| 1    | 5-16-89 | TEV | JMA   | REVISED TEST FLOW PATH | JJC    |        |        |        |        |         |
| 2    | 12-2-96 | DVR | DMS   | REDRAWN IN ACADIS      | DMS    |        |        |        |        |         |
|      |         |     |       |                        |        |        |        |        |        |         |
|      |         |     |       |                        |        |        |        |        |        |         |
|      |         |     |       |                        |        |        |        |        |        |         |
|      |         |     |       |                        |        |        |        |        |        |         |
|      |         |     |       |                        |        |        |        |        |        |         |
|      |         |     |       |                        |        |        |        |        |        |         |
|      |         |     |       |                        |        |        |        |        |        |         |
|      |         |     |       |                        |        |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT UNIT 2

PUMP INSERVICE TESTING LOOP FOR BORIC ACID TRANSFER PUMP 2-1208-P6-006

|          |           |                    |            |
|----------|-----------|--------------------|------------|
| DESIGNED | JTC       | DRAWN              | CL         |
| TYPED    |           | CHECKED            | RLB        |
| SCALE    | NONE      | CONTINUED ON SHEET |            |
|          | PROJ.L.D. | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A       | ISI-D-277          | 1 OF 1 2   |

AFW Pumps  
(2-1302-P4-001, 002 & 003)

System Function

Supply water to the steam generators whenever the reactor coolant temperature is above 350°F and the main feedwater system is not in operation, i.e., during startup, cooldown, or emergency conditions resulting in a loss of main feedwater.

Automatically provides feedwater for the removal of reactor core decay heat following a loss of main feedwater. This prevents damage to the reactor core until the reactor coolant temperature is brought from a Hot Standby condition to the point at which RHR may be placed into operation.

AFW supplies feedwater to the steam generators at a flowrate sufficient to support normal low-power transients such as startup, cooldown, and hot standby.

Turbine Driven AFW Pump (2-1302-P4-001)

|                    |  |
|--------------------|--|
| Quantity           | 1  |
| Type               | Horizontal, centrifugal, 5 stage, split-case                               |
| Manufacturer/Model | Ingersoll-Rand, Model 6HMTA  |
| Capacity           | 1175 gpm   |
| Total Dynamic Head | 3500 ft.   |
| Driver             |  |
| Type               | Terry Turbine, Model GS-2N, non-condensing, single-stage, mechanical drive |
| Horsepower         | 1603   |
| Speed              | 4250 rpm   |
| Power Supply       | Steam  |
| Code Class         | 3  |
| Project Class      | 313  |
| Outline Drawing    | 2X4AF03-88   |
| Instruction Book   | 2X4AF03-20031  |

Turbine Driven AFW Pump (2-1302-P4-001) (cont)

|                         |                |
|-------------------------|----------------|
| Physical Location       | AFW pump house |
| P&ID                    | 2X4DB161-2     |
| Surveillance Procedure  | 14810-2        |
| Pump Test Loop Diagrams | ISI-D-272      |
| Test Parameter Sheets   | Page 22-4      |

Motor-Driven AFW Pumps (2-1302-P4-002 & 003)

|                         |  |
|-------------------------|--|
| Quantity                | 2  |
| Type                    | Horizontal, centrifugal, 6 stage, split-case |
| Manufacturer/Model      | Ingersoll-Rand, Model 4HMTB                  |
| Design Flowrate         | 630 gpm                                      |
| Total Dynamic Head      | 3500 ft.                                     |
| Driver                  |  |
| Type                    | Westinghouse electric motor, LLD 5810 H      |
| Horsepower              | 900  |
| Speed                   | 3600 rpm                                     |
| Power Supply            | 4160V, 60 Hz, 3 phase                        |
| Code Class              | 3  |
| Project Class           | 313  |
| Outline Drawing         | 2X4AF03-87                                   |
| Instruction Book        | 2X4AF03-20030                                |
| Physical Location       | AFW pump house                               |
| P&ID                    | 2X4DB161-2                                   |
| Surveillance Procedure  | 14807-2                                      |
| Pump Test Loop Diagrams | ISI-D-273 & ISI-D-274                        |
| Test Parameter Sheets   | Page 22-5 & 22-6                             |

**Test Parameter Table - Pump 2-1302-P4-001**  
(Figure ISI-D-272)

| Parameter             | Test Freq. | Instrumentation Utilized |                |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|----------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range          | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | Qtr        | SI-15109A                | 0-6000         | ±2%       | Nr         | NA               | NA                             | NA                   | Speed is set to reference value    |
| Inlet Pressure (Pi)   | Qtr        | PI-5110A                 | 0-30<br>psig   | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-5107A                 | 0-2000<br>psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA             | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-15100                 | 0-200<br>gpm   | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA             | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.

**Test Parameter Table - Pamp 2-1302-P4-002**  
**(Figure ISI-D-273)**

| Parameter             | Test Freq. | Instrumentation Utilized |             |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range       | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA          | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-5128A                 | 0-30 psig   | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-5140A                 | 0-2000 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA          | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-15101                 | 0-200 gpm   | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA          | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**


1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.

**Test Parameter Table - Pump 2-1302-P4-003**  
(Figure ISI-D-274)

| Parameter             | Test Freq. | Instrumentation Utilized |             |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|-------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range       | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA          | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-5129A                 | 0-2000 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-5141A                 | 0-2000 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA          | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-15102                 | 0-200 gpm   | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA          | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

- Differential pressure is calculated as,  $\Delta P = P_o - P_i$
- Portable vibration instruments are utilized.
- At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
- Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.



NOTE: THIS IS A SIMPLIFIED DIAGRAM USED TO DEPICT A TEST CIRCUIT. REFER TO THE P&ID FOR DETAILS.


| REV. | DATE    | BY  | CHK'D | DESCRIPTION                      | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|----------------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 9-5-84  | BOS | VS    | ISSUED FOR PST                   | FT     |        |        |        |        |         |
| 1    | 1-26-88 | CL  | RLB   | UPDATED TO REV. 18 OF 24488161-2 | JJC    |        |        |        |        |         |
| 2    | 12-2-96 | DVR |       | REDRAWN IN ACADIS                | DMS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
UNIT 2  
PUMP INSERVICE TESTING LOOP  
FOR AUXILLARY FEEDWATER PUMP  
2-1302-P4-001

| DESIGNED   | FT   | DRAWN              | BRG        |
|------------|------|--------------------|------------|
| TYPED      |      | CHECKED            | VS         |
| SCALE      | NONE | CONTINUED ON SHEET |            |
| PROJ. I.D. | N/A  | DRAWING NUMBER     | SHEET REV. |
|            | N/A  | ISI-D-272          | 1 OF 2     |





NOTE: THIS IS A SIMPLIFIED DIAGRAM USED TO DEPICT A TEST CIRCUIT. REFER TO THE P&I.D. FOR DETAILS.


| REV | DATE    | BY  | CHK'D | DESCRIPTION                     | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|-----|---------|-----|-------|---------------------------------|--------|--------|--------|--------|--------|---------|
| 0   | 9-5-84  | BGS | VS    | ISSUED FOR PST                  | FT     |        |        |        |        |         |
| 1   | 1-26-88 | CL  | RLB   | UPDATED TO REV.18 OF 2X4DB161-2 | JJC    |        |        |        |        |         |
| 2   | 12-2-96 | DVR |       | REDRAWN IN ACAD13               | DW3    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VGTLE ELECTRIC GENERATING PLANT  
UNIT 2

PUMP INSERVICE TESTING LOOP  
FOR AUXILLARY FEEDWATER PUMP  
2-1302-P4-002

|             |                    |           |          |
|-------------|--------------------|-----------|----------|
| DESIGNED FT | DRAWN DRC          |           |          |
| TYPED       | CHECKED VS         |           |          |
| SCALE NONE  | CONTINUED ON SHEET |           |          |
| PROJ.I.D.   | DRAWING NUMBER     | SHEET     | REV.     |
| N/A         | N/A                | ISI-D-273 | 1 OF 1 2 |



NOTE: THIS IS A SIMPLIFIED DIAGRAM USED TO DEPICT A TEST CIRCUIT. REFER TO THE P&I.D. FOR DETAILS.

| REV. | DATE    | BY  | CHK'D | DESCRIPTION   | APPROX. 1 | APPROX. 2 | APPROX. 3 | APPROX. 4 | APPROX. 5 | REMARKS |
|------|---------|-----|-------|---|-----------|-----------|-----------|-----------|-----------|---------|
| 0    | 9-5-84  | RGS | VS    | ISSUED FOR P&I                                      |           |           |           |           |           |         |
| 1    | 1-25-88 | CL  | RLB   | UPDATED TO REV/B OF 24408161-E<br>RE-DRAWN IN A-CAD | JJC       |           |           |           |           |         |
| 2    | 12-2-96 | DWR |       |   | DW2       |           |           |           |           |         |

|             |  |  |  |            |  |  |  |           |  |  |  |
|-------------|--|--|--|------------|--|--|--|-----------|--|--|--|
| DESIGNED BY |  |  |  | CHECKED BY |  |  |  | DRAWN BY  |  |  |  |
| SCALE       |  |  |  | SCALE      |  |  |  | SCALE     |  |  |  |
| N/A         |  |  |  | N/A        |  |  |  | N/A       |  |  |  |
| PROJECT     |  |  |  | PROJECT    |  |  |  | PROJECT   |  |  |  |
| N/A         |  |  |  | N/A        |  |  |  | N/A       |  |  |  |
| SHEET NO.   |  |  |  | SHEET NO.  |  |  |  | SHEET NO. |  |  |  |
| 1 OF 2      |  |  |  | 1 OF 2     |  |  |  | 1 OF 2    |  |  |  |

Southern Company Services, Inc. for Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
UNIT 2  
PUMP INSERVICE TESTING LOOP  
FOR AUXILIARY FEEDWATER PUMP  
2-1302-P4-003

ESF Pumps  
(2-1592-P7-001, & 002)

|                         |   |
|-------------------------|---|
| System Function         | During normal operation, the ESF chilled-water system is in standby mode; it is activated during emergency conditions upon receipt of a safety injection signal, containment ventilation isolation, or control room isolation signal. The ESF chilled-water system serves air handling units located in the safety-related areas of the plant to ensure the integrity of the cooling system during plant emergency situation. |
| Quantity                | 2   |
| Type                    | Centrifugal   |
| Manufacturer            | Goulds  |
| Capacity                | 600 gpm   |
| Total Dynamic Head      | 125 ft.   |
| Driver                  |   |
| Type                    | Westinghouse electric motor   |
| Horsepower              | 30  |
| Speed                   | 1800 rpm  |
| Power Supply            | 480V, 60 Hz, 3 phase  |
| Code Class              | 3   |
| Project Class           | 313   |
| Outline Drawing         | 2X4AJ05-28  |
| Instruction Book        | AX4AJ05-86  |
| Physical Location       | Control Bldg, EL 260 ft., Rooms R-310 & R-308   |
| P&ID                    | 2X4DB221  |
| Surveillance Procedure  | 14809-2   |
| Pump Test Loop Diagrams | ISI-D-275 & ISI-D-276   |
| Test Parameter Sheets   | Page 23-2 & 23-3  |

**Test Parameter Table - Pump 2-1592-P7-001  
(Figure ISI-D-275)**

| Parameter             | Test Freq. | Instrumentation Utilized |            |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range      | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA         | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-22410                 | 0-30 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-22414                 | 0-200 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA         | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-22425                 | 0-750 gpm  | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA         | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**


1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.

**Test Parameter Table - Pump 2-1592-P7-002**  
(Figure ISI-D-276)

| Parameter             | Test Freq. | Instrumentation Utilized |            |           | Ref. Value | Acceptable Range | Alert Range                    | Action Range         | Comments                           |
|-----------------------|------------|--------------------------|------------|-----------|------------|------------------|--------------------------------|----------------------|------------------------------------|
|                       |            | I.D. No.(3)              | Range      | Req. Acc. |            |                  |                                |                      |                                    |
| Speed (N)             | NA         | NA                       | NA         | NA        | NA         | NA               | NA                             | NA                   | Constant speed driver              |
| Inlet Pressure (Pi)   | Qtr        | PI-22411                 | 0-30 psig  | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Outlet Pressure (Po)  | Qtr        | PI-22415                 | 0-200 psig | ± 2%      | NA         | NA               | NA                             | NA                   | NA                                 |
| Differ. Pressure (ΔP) | Qtr        | NA(1)                    | NA         | ± 2%      | ΔPr        | .90 - 1.10ΔPr    | NA                             | <.90 or >1.10ΔPr     | NA                                 |
| Flowrate (Q)          | Qtr        | FI-22426                 | 0-750 gpm  | ± 2%      | Qr         | NA               | NA                             | NA                   | Flowrate is set at reference value |
| Vib. Amp. (V)(4)      | Qtr        | (2)                      | NA         | ± 5%      | Vr         | ≤ 2.5Vr          | > 2.5Vr - 6Vr<br>or >.325 in/s | >6Vr or<br>>.70 in/s | NA                                 |

**Notes:**

1. Differential pressure is calculated as,  $\Delta P = P_o - P_i$
2. Portable vibration instruments are utilized.
3. At the discretion of SNC, instrumentation other than that listed, which meets the requirements of the OM Code, may be utilized for measuring test parameters.
4. Measurements are taken in a plane approximately perpendicular to the rotating shaft in two orthogonal directions on each accessible pump-bearing housing and in the axial direction on each accessible thrust bearing housing.



NOTE: 1. THIS IS A SIMPLIFIED DIAGRAM USED TO DEPICT A TEST CIRCUIT. REFER TO THE P&ID FOR DETAILS.  
 2. VALVE INTERNALS REMOVED PER DCP 90-V2N0068-0-1

CB ESF CHILLED WATER PUMP  
 2-1592-P7-001-000  
 PROJ. CLASS 313

CB ESF CHILLER  
 2-1592-C7-001-000

TRAIN "A"  
 COOLING COILS


| REV. | DATE    | BY  | CHK'D | DESCRIPTION                     | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|---------------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 9-5-84  | BGS | VS    | ISSUED FOR PST                  |        |        |        |        |        |         |
| 1    | 1-06-88 | CL  | RLB   | UPDATED TO REV. II OF EXHIBIT 2 | JJC    |        |        |        |        |         |
| 2    | 1-21-91 | VS  | VLV   | REMOVED VALVE I06 INTERNALS     | MB     |        |        |        |        |         |
| 3    | 12-2-96 | BVR | AMS   | REDRAWN IN ACADIS               | AMS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTLE ELECTRIC GENERATING PLANT  
 UNIT 2

PUMP INSERVICE TESTING LOOP  
 FOR CB ESF CHILLED WATER PUMP  
 TRAIN "A" 2-1592-P7-001-000

|          |            |                    |            |
|----------|------------|--------------------|------------|
| DESIGNED | FT         | DRAWN              | BGS        |
| TYPE     |            | CHECKED            | VS         |
| SCALE    | NONE       | CONTINUED ON SHEET |            |
|          | PROJ. I.D. | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A        | ISI-D-275          | 1 OF 1 3   |



NOTE: 1. THIS IS A SIMPLIFIED DIAGRAM USED TO DEPICT A TEST CIRCUIT. REFER TO THE P&ID FOR DETAILS.  
 2. VALVE INTERNALS REMOVED PER DCP 90-V2N0068-0-1

| REV. | DATE    | BY  | CHK'D | DESCRIPTION                   | APPR.1 | APPR.2 | APPR.3 | APPR.4 | APPR.5 | REMARKS |
|------|---------|-----|-------|-------------------------------|--------|--------|--------|--------|--------|---------|
| 0    | 9-5-84  | BGS | VS    | ISSUED FOR PST                | FT     |        |        |        |        |         |
| 1    | 1-26-88 | CL  | RLB   | UPDATED TO REV.11 OF EX108021 | JJC    |        |        |        |        |         |
| 2    | 1-21-91 | VS  | VLV   | REMOVED VALVE 187 INTERNALS   | MB     |        |        |        |        |         |
| 3    | 12-2-96 | DVR | AKZ   | REBRAIN IN ACAD13             | DAS    |        |        |        |        |         |

Southern Company Services, Inc. FOR Southern Nuclear Operating Company

VOGTE ELECTRIC GENERATING PLANT  
 UNIT 2

PUMP INSERVICE TESTING LOOP  
 FOR CB ESF CHILLED WATER PUMP  
 TRAIN "B" 2-1592-P7-002-000

|          |           |                    |            |
|----------|-----------|--------------------|------------|
| DESIGNED | FT        | DRAWN              | BGS        |
| TYPE     |           | CHECKED            | VS         |
| SCALE    | NONE      | CONTINUED ON SHEET |            |
|          | PROJ. NO. | DRAWING NUMBER     | SHEET REV. |
| N/A      | N/A       | ISI-D-276          | 1 OF 1 3   |

PUMP RELIEF REQUEST LOG

Relief Request Number

Status

RR-P-1

Submitted for NRC Review.

RR-P-2

Submitted for NRC Review.

RR-G-1

Submitted for NRC Review.

RR-G-2

Submitted for NRC Review.



PUMP RELIEF REQUEST  
RR-P-1

SYSTEM: Chemical Volume and Control System (CVCS)

PUMPS: Boric Acid Transfer  
1-1208-P6-006 and -007 and 2-1208-P6-006 and -007

CLASS: 3

TEST REQUIREMENT: ISTB 4.7.1(b)(1) requires the full scale range of analog instruments to be not greater than three times the reference value.

BASIS FOR RELIEF: Suction pressure gages PI-10115 and PI-10116 have a full scale range of 30 inches of mercury to 15 psig, or -15 psig to 15 psig with an accuracy of  $\pm 0.15$  psig. Since pressure readings when the pump is running will always be positive, the range of interest for IST is 0 - 15 psig. The actual suction pressure experienced during surveillance testing is approximately 2 psig which results in a maximum allowable range of 0 - 6 psig to satisfy the Code requirements. The Code allowable tolerance would be  $\pm 0.12$  psig ( $0.02 \times 6$ ). Since the only purpose for measuring suction pressure is to use in determining differential pressure, for comparison to the test reference value, a total difference of 0.03 (0.15 - 0.12) psig in the measurement of differential pressure will have no impact on the repeatability or adequacy of the pump test. Therefore, the existing suction pressure gages provide adequate means for measuring the pump suction pressure and do not jeopardize the adequacy of the testing being performed.

ALTERNATE TESTING: None. The existing suction pressure gages will be utilized for IST of the referenced pumps.

PUMP RELIEF REQUEST  
RR-P-2

SYSTEM: All included in scope of IST Program

PUMPS: All included in scope of IST Program

CLASS: 2 and 3

TEST REQUIREMENT: ISTB 6.1 - If deviations fall within the required action range of Table ISTB 5.2-1, the pump shall be declared inoperable until the cause of the deviation has been determined and the condition corrected

BASIS FOR RELIEF: The ASME Section XI Code, 1989 Edition, subsection IWP-3230(c) states that;

“Corrective action shall be either replacement or repair per IWP-3111, or shall be an analysis to demonstrate that the condition does not impair pump operability and that the pump will still fulfill its function. A new set of reference values shall be established after such analysis.”

The OMc-1994 Addenda (ISTB 6.2.2) and the OM 1995 edition (ISTB 6.2.2) both state that;

“If the measured test parameter values fall within the required action range of Table 5.2.1-1, Table 5.2.1-2, Table 5.2.2-1, or Table 5.2.3-1, as applicable, the pump shall be declared inoperable until either the cause of the deviation has been determined and the condition corrected, or an analysis of the pump is performed and new reference values are established in accordance with ISTB 4.6.”

The Code applicable for the first interval IST Program (1983 ASME XI), and the latest issued Code both provide for analysis of pump test data in lieu of repair or replacement of the pump if the test parameters fall within the required action range. The OM Code-1990 Edition did not include such provisions. Communications with members of the OM Code Committee indicate that this was an oversight and that it was never intended to delete the ability to analyze the test data and determine if the pump is still capable of performing its intended safety function.

ALTERNATE TESTING: Should pump test parameters fall within the required action range of Table ISTB 5.2-2 (OM Code 1990 Edition), then the OM Code 1995 Edition, subsection ISTB 6.2.2 will be utilized. Since subsection ISTB 4.6 in the 1995 Code Edition references ISTB 6.2.2, subsection ISTB 4.6 from the OM Code 1995 Edition will also be applied.

## GENERAL RELIEF REQUEST

RR-G-1

SYSTEMS: All in Scope of IST Program

VALVES: All in Scope of IST Program

PUMPS: All in Scope of IST Program

CLASS: 1, 2 and 3

### TEST

REQUIREMENT: The version of 10CFR50 in effect on May 31, 1996, paragraph 50.55a(b)(2) specifies the applicable Code to be the ASME XI, 1988 Addenda through 1989 Edition. The 1989 Edition of ASME XI references OM part 6 and 10 for inservice pump and valve testing respectfully. Paragraph 50.55a(b)(2)(viii) of the CFR specifies the Code applicable to inservice pump and valve testing to be the ASME/ANSI part 6 and ASME/ANSI part 10 of the OMa-1988 Addenda to the OM-1987 Edition.

### BASIS FOR RELIEF:

The ASME/ANSI OM document was issued as a Code with the ASME OM Code-1990 Edition. This edition was amended with the OMa Code-1991 Addenda, the OMb Code-1992 Addenda, and the OMc Code-1994 Addenda. The ASME OM Code-1995 Edition was issued in early 1995. With each addenda and edition of the ASME OM Code, the ASME OM Code Committee has included updated inservice testing requirements based on improved knowledge, operating history and experience and changes in testing technology. Beginning with the ASME OM Code-1990 Edition, the format of the document was also changed to read like a Code instead of a standard as it was initially drafted. Therefore, application of later versions of the ASME OM Code, than specified in 10CFR50, should enhance the quality of the IST Program.

### ALTERNATE TESTING:

The ASME OM Codes utilized for update of the Vogtle Inservice Testing Program shall be:

IST of Valves (except safety/relief valves) - ASME OM Code-1990 Edition

IST of Pumps - ASME OM Code-1990 Edition

IST of Safety/Relief Valves - ASME OM Code 1995 Edition (ASME OM Code-1995 Edition, Appendix I, augments the rules of Subsection ISTC 4.4.)

**The NRC previously approved use of the above referenced Codes in a letter dated November 27, 1996. This relief request is identical to RR-G-1 included in the IST Valve Program.**

## GENERAL RELIEF REQUEST

RR-G-2

SYSTEMS: All in Scope of Unit 2 IST Program

VALVES: All in Scope of Unit 2 IST Program

PUMPS: All in Scope of Unit 2 IST Program

CLASS: 1, 2 and 3

### TEST

REQUIREMENT: The version of 10CFR50 in effect on May 31, 1996, paragraph 50.55a(f)(4)(ii), specifies that inservice testing to verify operational readiness of pumps and valves required for safety, conducted during successive 120-month intervals must comply with the requirements of the latest edition and addenda of the Code incorporated by reference in paragraph 10CFR50.55a(b) 12 months prior to the start of the 120-month interval.

### BASIS FOR RELIEF:

The commercial operation date for Vogtle Unit 1 was May 31, 1987. The commercial operation date for Vogtle Unit 2 was May 20, 1989. Maintaining both units on the same interval schedule allows both IST programs to be developed utilizing the same edition of the applicable Codes, will make it easier for involved personnel to become familiar with the Code requirements, will ensure a greater degree of consistency for IST between the units, and will reduce the cost associated with surveillance procedure revisions for the program update and for maintenance of the program documents.

### ALTERNATE TESTING:

Update the Vogtle Nuclear Plant Unit 2 IST Program concurrent with the Unit 1 second 10-year interval IST Program update due on May 31, 1997. The Unit 2 IST Program will be updated concurrent with the Unit 1 IST Program in accordance with the applicable regulations for the remainder of the plant life.

**The NRC previously approved use of the above referenced Codes in a letter dated November 27, 1996. This relief request is identical to RR-G-1 included in the IST Valve Program.**