

EFFLUENT AND WASTE DISPOSAL  
SEMIANNUAL REPORT  
FOR  
FIRST AND SECOND QUARTERS, 1986

Vermont Yankee Nuclear Power Station

8801260087 860829  
PDR ADOCK 05000271  
R PDR

IE48  
1/1

TABLE 1A

## Vermont Yankee

## Effluent and Waste Disposal Semiannual Report

First and Second Quarters, 1986

## Gaseous Effluents - Summation of All Releases

|  | Unit    | Quarter<br>1 | Quarter<br>2 | Est. Total<br>Error, % |
|--|---------|--------------|--------------|------------------------|
| A. Fission and Activation Gases        |         |              |              |                        |
| 1. Total release                       | Ci      | <7.78E+02    | <7.86E+02    | ±1.00E+02              |
| 2. Average release rate for period     | uCi/sec | <9.89E+01    | <1.00E+02    |                        |
| 3. Percent of Tech. Spec. limit (1)(4) | %       | <2.80E+00    | <2.90E+00    |                        |
| B. Iodines                             |         |              |              |                        |
| 1. Total Iodine-131                    | Ci      | <2.18E-04    | 2.54E-05     | ±5.00E+01              |
| 2. Average release rate for period     | uCi/sec | <2.78E-05    | 3.23E-06     |                        |
| 3. Percent of Tech. Spec. limit (2)(4) | %       | 9.71E-03     | 1.12E-02     |                        |
| C. Particulates                        |         |              |              |                        |
| 1. Particulates with T-1/2 > 8 days    | Ci      | 1.11E-03     | 9.54E-04     | ±5.00E+01              |
| 2. Average release rate for period     | uCi/sec | 1.41E-04     | 1.21E-04     |                        |
| 3. Percent of Tech. Spec. limit        | %       | (3)          | (3)          |                        |
| 4. Gross alpha radioactivity           | Ci      | <7.64E-07    | <1.75E-06    |                        |
| D. Tritium                             |         |              |              |                        |
| 1. Total release                       | Ci      | 4.28E-01     | 3.20E-01     | ±5.00E+01              |
| 2. Average release rate for period     | uCi/sec | 5.45E-02     | 4.07E-02     |                        |
| 3. Percent of Tech. Spec. limit        | %       | (3)          | (3)          |                        |

- (1) Technical Specification 3.8.F.1.a for gamma air dose. Percent values for Technical Specification 3.8.F.1.a for beta air dose are approximately the same.
- (2) Technical Specification 3.8.G.1 for dose from I-131, I-133, Tritium, and radionuclides in particulate form.
- (3) Per Technical Specification 3.8.G.1, dose contribution from Tritium and particulates are included with I-131 above in Part B.
- (4) The first and second quarter percent of Technical Specification limits are based on conservative plant quarterly dose determinations.

TABLE 1B  
Vermont Yankee  
Effluent and Waste Disposal Semiannual Report  
First and Second Quarters, 1986  
Gaseous Effluents - Elevated Release

| Nuclides Released    | Unit | Continuous Mode |           | Batch Mode <sup>(1)</sup> |         |
|----------------------|------|-----------------|-----------|---------------------------|---------|
|                      |      | Quarter         | Quarter   | Quarter                   | Quarter |
|                      |      | 1               | 2         | 1                         | 2       |
| 1. Fission Gases     |      |                 |           |                           |         |
| Krypton-85           | Ci   | (2)             | (2)       |                           |         |
| Krypton-85m          | Ci   | (10)            | (10)      |                           |         |
| Krypton-87           | Ci   | (11)            | (11)      |                           |         |
| Krypton-88           | Ci   | (12)            | (12)      |                           |         |
| Xenon-133            | Ci   | <7.78E+02       | <7.86E+02 |                           |         |
| Xenon-135            | Ci   | (13)            | (13)      |                           |         |
| Xenon-135m           | Ci   | (3)             | (3)       |                           |         |
| Xenon-138            | Ci   | (14)            | (14)      |                           |         |
|                      | Ci   |                 |           |                           |         |
| Unidentified         | Ci   |                 |           |                           |         |
| Total for period     | Ci   | <7.78E+02       | <7.86E+02 |                           |         |
| 2. Iodines           |      |                 |           |                           |         |
| Iodine-131           | Ci   | (4)             | 2.54E-05  |                           |         |
| Iodine-133           | Ci   | (15)            | (15)      |                           |         |
| Iodine-135           | Ci   | (16)            | (16)      |                           |         |
| Total for period     | Ci   | (4)             | 2.54E-05  |                           |         |
| 3. Particulates      |      |                 |           |                           |         |
| Strontium-89         | Ci   | (5)             | (5)       |                           |         |
| Strontium-90         | Ci   | (6)             | (6)       |                           |         |
| Cesium-134           | Ci   | (7)             | (7)       |                           |         |
| Cesium-137           | Ci   | (8)             | 5.66E-05  |                           |         |
| Barium-Lanthanum-140 | Ci   | (9)             | (9)       |                           |         |
| Manganese-54         | Ci   | 1.18E-05        | 3.75E-05  |                           |         |
| Cobalt-60            | Ci   | 6.56E-04        | 6.95E-04  |                           |         |
| Zinc-65              | Ci   | 4.41E-04        | 1.65E-04  |                           |         |
| Unidentified         | Ci   |                 |           |                           |         |

- (1) There were no batch mode gaseous releases for this reporting period.
- (2) Not detected in the off-gas mix. Limit of detectability  $\leq 6.97\text{E-}07$  uCi/cc.
- (3) Not detected in the off-gas mix. Limit of detectability  $\leq 2.54\text{E-}07$  uCi/cc.
- (4) Not detected in the off-gas mix. Limit of detectability  $\leq 1.15\text{E-}15$  uCi/cc.
- (5) Not detected in the off-gas mix. Limit of detectability  $\leq 4.39\text{E-}15$  uCi/cc.
- (6) Not detected in the off-gas mix. Limit of detectability  $\leq 5.35\text{E-}16$  uCi/cc.
- (7) Not detected in the off-gas mix. Limit of detectability  $\leq 1.42\text{E-}13$  uCi/cc.
- (8) Not detected in the off-gas mix. Limit of detectability  $\leq 1.80\text{E-}13$  uCi/cc.
- (9) Not detected in the off-gas mix. Limit of detectability  $\leq 5.19\text{E-}13$  uCi/cc.
- (10) Not detected in the off-gas mix. Limit of detectability  $\leq 1.63\text{E-}07$  uCi/cc.
- (11) Not detected in the off-gas mix. Limit of detectability  $\leq 6.07\text{E-}07$  uCi/cc.
- (12) Not detected in the off-gas mix. Limit of detectability  $\leq 5.09\text{E-}07$  uCi/cc.
- (13) Not detected in the off-gas mix. Limit of detectability  $\leq 2.81\text{E-}07$  uCi/cc.
- (14) Not detected in the off-gas mix. Limit of detectability  $\leq 2.47\text{E-}06$  uCi/cc.
- (15) Not detected in the off-gas mix. Limit of detectability  $\leq 2.48\text{E-}12$  uCi/cc.
- (16) Not detected in the off-gas mix. Limit of detectability  $\leq 2.03\text{E-}11$  uCi/cc.

TABLE 1C

Vermont Yankee

Effluent and Waste Disposal Semiannual Report

First and Second Quarters, 1986

Gaseous Effluents - Ground Level Releases

There were no routine measured ground level continuous or batch mode gaseous releases during the first or second quarters of 1986.

TABLE 1D

Vermont Yankee

Effluent and Waste Disposal Semiannual Report

First and Second Quarters, 1986

Gaseous Effluents - Nonroutine Releases

There were no nonroutine or accidental gaseous releases during the first or second quarters of 1986.

TABLE 2A

Vermont Yankee

Effluent and Waste Disposal Semiannual Report

First and Second Quarters, 1986

Liquid Effluents - Nonroutine Releases

There were no liquid releases during the first or second quarters of 1986.

TABLE 2B

Vermont Yankee

Effluent and Waste Disposal Semiannual Report

First and Second Quarters, 1986

Liquid Effluents - Nonroutine Releases

There were no nonroutine or accidental releases during the first or second quarters of 1986.

TABLE 3

## Vermont Yankee

## Effluent and Waste Disposal Semiannual Report

First and Second Quarters, 1986

## Solid Waste and Irradiated Fuel Shipments

## A. Solid Waste Shipped Off-Site for Burial or Disposal (Not Irradiated Fuel)

|  | Unit                 | 6-Month<br>Period    | Est. Total<br>Error, % |
|--|----------------------|----------------------|------------------------|
| 1. Type of Waste   |                      |                      |                        |
| a. Spent resins, filter sludges, evaporator<br>bottoms, etc. | m <sup>3</sup><br>Ci | 2.93E+01<br>1.78E+02 | ±7.50E+01              |
| b. Dry compressible waste, contaminated<br>equipment, etc.   | m <sup>3</sup><br>Ci | 2.26E+02<br>1.06E+01 | ±7.50E+01              |
| c. Irradiated components, control rods,<br>etc.              | m <sup>3</sup><br>Ci |                      |                        |

## 2. Estimate of Major Nuclide Composition (By Type of Waste)

|              |            |               |            |
|--------------|------------|---------------|------------|
| a. Zinc-65   | % 4.75E+01 | b. Cesium-137 | % 3.79E+01 |
| Cobalt-60    | % 2.55E+01 | Cobalt-60     | % 3.48E+01 |
| Cesium-137   | % 1.56E+01 | Zinc-65       | % 1.29E+01 |
| Manganese-54 | % 8.93E+00 | Manganese-54  | % 4.67E+00 |
| Cobalt-58    | % 7.10E-01 | Cesium-134    | % 2.87E+00 |
| Nickel-63    | % 4.20E-01 | Plutonium-241 | % 2.61E+00 |
| Cesium-134   | % 3.90E-01 | Cobalt-58     | % 1.64E+00 |
| %            |            | Hydrogen-3    | % 9.70E-01 |
| %            |            | Zirconium-95  | % 7.30E-01 |
| %            |            | %             | %          |
| %            |            | %             | %          |
| %            |            | %             | %          |
| %            |            | %             | %          |
| %            |            | %             | %          |

## 3. Solid Waste Disposition

| Number of Shipments | Mode of Transportation | Destination  |
|---------------------|------------------------|--------------|
| 15                  | Truck                  | Barnwell, SC |

## B. Irradiated Fuel Shipments (Disposition): None

## C. Supplemental information

- 1) Class of solid waste containers shipped: 8A (unstable), 7B
- 2) Types of containers used: 6 Type A, 1 Type B, and 8 LSA
- 3) Solidification agent or absorbent: None



# APPENDIX A

## EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

Supplemental Information  
First and Second Quarters, 1986

Facility: Vermont Yankee Nuclear Power Station

Licensee: Vermont Yankee Nuclear Power Corporation

### 1A. Technical Specification Limits - Dose and Dose Rate

|    | <u>Technical Specification and Category</u>  | <u>Limit</u>          |
|----|--|-----------------------|
| a. | <u>Noble Gases</u>   |                       |
|    | 3.8.E.1 Total body dose rate   | 500 mrem/yr           |
|    | 3.8.E.1 Skin dose rate   | 3000 mrem/yr          |
|    | 3.8.F.1 Gamma air dose   | 5 mrad in a quarter   |
|    | 3.8.F.1 Gamma air dose   | 20 mrad in a year     |
|    | 3.8.F.1 Beta air dose  | 10 mrad in a quarter  |
|    | 3.8.F.1 Beta air dose  | 20 mrad in a year     |
| b. | <u>Iodine-131, Iodine-133, Tritium and Radionuclides</u><br><u>in Particulate Form With Half-Lives</u><br><u>Greater Than 8 Days</u> |                       |
|    | 3.8.E.1 Organ dose rate  | 1500 mrem/yr          |
|    | 3.8.G.1 Organ dose   | 7.5 mrem in a quarter |
|    | 3.8.G.1 Organ dose   | 15 mrem in a year     |
| c. | <u>Liquids</u>   |                       |
|    | 3.8.B.1 Total body dose  | 1.5 mrem in a quarter |
|    | 3.8.B.1 Total body dose  | 3 mrem in a year      |
|    | 3.8.B.1 Organ dose   | 5 mrem in a quarter   |
|    | 3.8.B.1 Organ dose   | 10 mrem in a year     |

2A. Technical Specification Limits - Concentration

|    | <u>Technical Specification and Category</u>   | <u>Limit</u>  |
|----|---|---------------|
| a. | <u>Noble Gases</u>  | No MPC limits |
| b. | <u>Iodine-131, Iodine-133, Tritium and Radionuclides in Particulate Form With Half-Lives Greater Than 8 Days:</u> | No MPC limits |
| c. | <u>Liquids</u>  |               |

3.8.A.1 Total fraction of MPC  
excluding noble gases  
(10CFR20, Appendix B,  
Table II, Column 2):  $\leq 1.0$

3.8.A.1 Total noble gas concentration:  $\leq 2E-04$  uCi/cc

3. Average Energy

Provided below are the average energy ( $\bar{E}$ ) of the radionuclide mixture in releases of fission and activation gases, if applicable.

|    |                       |                |                  |
|----|-----------------------|----------------|------------------|
| a. | Average gamma energy: | 3rd Quarter    | 3.00E-03 MeV/dis |
|    |                       | 4th Quarter    | 3.00E-03 MeV/dis |
| b. | Average beta energy:  | Not Applicable |                  |

4. Measurements and Approximations of Total Radioactivity

Provided below are the methods used to measure or approximate the total radioactivity in effluents and the methods used to determine radionuclide composition.

a. Fission and Activation Gases

Daily samples are drawn at the discharge of the air ejector. Isotopic breakdown of the releases are determined from these samples. A logarithmic chart of the stack gas monitor is read daily to determine the gross release rate. At the very low release rates normally encountered during operation with the augmented off-gas system the error of release rates may be approximately  $\pm 100$  percent.

b. Iodines

Continuous isokinetic samples are drawn from the plant stack through a particulate filter and charcoal cartridge. The filters and cartridge are removed weekly (if releases are less than 4 percent of the Tech Spec limit), or daily (if they are greater than 4 percent of the limit), and are analyzed for radioiodine 131, 132, 133, 134, and 135. The iodines found on the filter are added to those on the charcoal cartridge. The error involved in these steps may be approximately  $\pm 50$  percent.

c. Particulates

The particulate filters described in b. above are also counted for particulate radioactivity. The error involved in this sample is also approximately  $\pm 50$  percent.

d. Liquid Effluents

Radioactive liquid effluents released from the facility are continuously monitored. Measurements are also made on a representative sample of each batch of radioactive liquid effluents released. For each batch, station records are retained of the total activity (mCi) released, concentration (uCi/ml) of gross

radioactivity, volume (liters), and approximate total quantity of water (liters) used to dilute the liquid effluent prior to release to the Connecticut River.

Each batch of radioactive liquid effluent released is analyzed for gross gamma and gamma isotopic radioactivity. A monthly proportional composite sample, comprising an aliquot of each batch released during a month, is also analyzed for tritium, SR-89, SR-90, gross beta and gross alpha radioactivity, in addition to gamma spectroscopy.

There were no liquid releases during the reporting period.

5. Batch Releases

a. Liquid

There were no routine liquid batch releases during the reporting period.

b. Gaseous

There were no routine gaseous batch releases during the reporting period.

6. Abnormal Releases

a. Liquid

There were no nonroutine liquid releases during the reporting period.

b. Gaseous

There were no nonroutine gaseous releases during the reporting period.

## APPENDIX B

### LIQUID HOLDUP TANKS

Requirement: Technical Specification 3.8.D.1 limits the quantity of radioactive material contained in any outside tank. With the quantity of radioactive material in any outside tank exceeding the limits of Technical Specification 3.8.D.1, a description of the events leading to this condition is required in the next Semiannual Effluent Release Report per Technical Specification 6.7.C.1.

Response: The limits of Technical Specification 3.8.D.1 were not exceeded during this reporting period.

## APPENDIX C

### RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION

Requirement: Radioactive liquid effluent monitoring instrumentation channels are required to be operable in accordance with Technical Specification Table 3.9.1. If an inoperable radioactive liquid effluent monitoring instrument is not returned to operable status prior to a release pursuant to Note 4 of Table 3.9.1, an explanation in the next Semiannual Effluent Release Report of the reason(s) for delay in correcting the inoperability are required per Technical Specification 6.7.C.1.

Response: Since the requirements of Technical Specification Table 3.9.1 governing the operability of radioactive liquid effluent monitoring instrumentation were met for this reporting period, no response is required.

## APPENDIX D

### RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION

Requirement: Radioactive gaseous effluent monitoring instrumentation channels are required to be operable in accordance with Technical Specification Table 3.9.2. If inoperable gaseous effluent monitoring instrumentation is not returned to operable status within 30 days pursuant to Note 5 of Table 3.9.2, an explanation in the next Semiannual Effluent Release Report of the reason(s) for the delay in correcting the inoperability is required per Technical Specification 6.7.C.1.

Response: Since the requirements of Technical Specification Table 3.9.2 governing the operability of radioactive gaseous effluent monitoring instrumentation were met for this reporting period, no response is required.

## APPENDIX E

### RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

Requirement: The radiological environmental monitoring program is conducted in accordance with Technical Specification 3.9.C. With milk samples no longer available from one or more of the sample locations required by Technical Specification Table 3.9.3, Technical Specification 6.7.C.1 requires the following to be included in the next Semiannual Effluent Release Report:

- (1) identify the cause(s) of the sample(s) no longer being available,
- (2) identify the new location(s) for obtaining available replacement samples and
- (3) include revised ODCM figure(s) and table(s) reflecting the new location(s).

Response: As part of the Environmental Monitoring Program, milk sampling locations TM-11 (Miller Farm, 0.8 km, WNW) and TM-13 (Newton Farm, 5.1 km, SSE) were replaced with TM-14 (Brown Farm, 2.1 km, SSW) and TM-15 (Coombs Farm, 4.7 km, NW), based on a dosimetric analysis done pursuant to Technical Specification 3.9.D.2 (Land Use Census). Milk sampling location TM-12 (Whitaker Farm, 2.6 km, S) was also replaced during the reporting period with location TM-13 (Newton Farm, 5.1 km, SSE) when TM-12 went out of business. The choice of TM-13 as a replacement was based on the dosimetric ranking of available locations done as part of the Land Use Census.

None of the above changes will reduce the accuracy or reliability of dose calculations or setpoint determinations. Proposed ODCM tables and maps reflecting the above radiological environmental monitoring program changes are included in Appendix H.



Milk sampling location TM-11 (Miller Farm, 0.8 km, WNW) and air sampling location AP/CF-15 (Tyler Hill Rd., 3.2 km, WNW) were also added to the ODCM as non-Technical Specification stations. Samples are collected there routinely in order to provide additional information to the program.

## APPENDIX F

### LAND USE CENSUS

Requirement: A land use census is conducted in accordance with Technical Specification 3.9.D. With a land use census identifying a location(s) which yields at least a 20 percent greater dose or dose commitment than the values currently being calculated in Technical Specification 4.8.G.1, Technical Specification 6.7.C.1 requires the identification of the new location(s) in the next Semiannual Effluent Release Report.

Response: No locations were identified by the 1985 land use census that would yield at least a 20 percent greater dose or dose commitment than the values currently being calculated pursuant to Technical Specification 4.8.G.1.

## APPENDIX G

### PROCESS CONTROL PROGRAM

Requirement: Technical Specification 6.12.A.1 requires that licensee initiated changes to the Process Control Program (PCP) be submitted to the Commission in the Semiannual Radioactive Effluent Release Report for the period in which the change(s) was made.

Response: There was no licensee initiated change(s) to the Process Control Program during this reporting period.

## APPENDIX II

### OFF-SITE DOSE CALCULATION MANUAL

Requirement: Technical Specification 6.13.A.1 requires that licensee initiated changes to the Off-Site Dose Calculation Manual (ODCM) be submitted to the Commission in the Semiannual Radioactive Effluent Release Report for the period in which the change(s) was made effective.

Response: Changes were made to the radiological environmental monitoring program as described in Appendix E. Proposed revisions to the tables and maps of Section 4 of the ODCM are included in this appendix. None of the changes will reduce the accuracy or reliability of dose calculations or setpoint determinations.

Table 4.1

Radiological Environmental Monitoring Stations\*

| <u>Exposure Pathway<br/>and/or Sample</u> | <u>Sample Location<br/>and Designated Code**</u> | <u>Distance From<br/>the Plant<br/>Stack (km)</u> | <u>Direction From<br/>the Plant</u> |
|---|--|---|-------------------------------------|
| 1. AIRBORNE (Radioiodine and Particulate) |  |   |                                     |
|   | AP/CF-11 River Station<br>No. 3.3                | 1.9   | SSE                                 |
|   | AP/CF-12 N. Hinsdale, NH                         | 3.6   | NNW                                 |
|   | AP/CF-13 Hinsdale Substation                     | 3.1   | E                                   |
|   | AP/CF-14 Northfield, MA                          | 11.3  | SSE                                 |
|   | *1AP/CF-15 Tyler Hill Rd.                        | 3.2   | WNW                                 |
|   | AP/CF-21 Spofford Lake                           | 16.1  | NNE                                 |
| 2. WATERBORNE                             |  |   |                                     |
| a. Surface                                | WR-11 River Station<br>No. 3.3                   | 1.9   | Downriver                           |
|   | WR-21 Rt. 9 Bridge                               | 12.8  | Upriver                             |
| b. Ground                                 | WG-11 Plant Well                                 | --  | On-site                             |
|   | WG-12 Vernon Nursing Well                        | 2.0   | SSE                                 |
|   | WG-21 Brattleboro CC                             | 12.1  | NNW                                 |
| c. Sediment                               | SE-11 Shoreline Downriver                        | 0.8   | On-site                             |
| From                                      | SE-12 North Storm***<br>Shorline Drain Outfall   | 0.15  | On-site                             |
| 3. INGESTION                              |  |   |                                     |
| a. Milk                                   | *1 TM-11 Miller Farm                             | 0.8   | WNW                                 |
|   | TM-14 Brown Farm                                 | 2.6   | S                                   |
|   | TM-13 Newton Farm                                | 5.1   | SSE                                 |
|   | TM-15 Coombs Farm                                | 4.5   | NW                                  |
|   | TM-21 Moore Farm                                 | 15.9  | N                                   |
| b. Mixed<br>Grasses                       | TG-11 River Station<br>No. 3.3                   | 1.9   | SSE                                 |
|   | TG-12 N. Hinsdale, NH                            | 3.6   | NNE                                 |
|   | TG-13 Hinsdale Substation                        | 3.1   | E                                   |
|   | TG-14 Northfield, MA                             | 11.3  | SSE                                 |
|   | *1 TG-15 Tyler Hill Rd.                          | 3.2   | WNW                                 |
|   | TG-21 Spofford Lake                              | 16.1  | NNE                                 |
| c. Silage                                 | *1 TC-11 Miller Farm                             | 0.8   | WNW                                 |
|   | TC-14 Brown Farm                                 | 2.6   | S                                   |
|   | TC-13 Newton Farm                                | 5.1   | SSE                                 |
|   | TC-15 Coombs Farm                                | 4.5   | NW                                  |
|   | TC-21 Moore Farm                                 | 15.9  | N                                   |
| d. Fish                                   | FH-11 Vernon Pond                                | --  | On-site                             |
|   | FH-21 Rt. 9 Bridge                               | 12.8  | Upriver                             |
|   | *1 Non-Tech Spec Station                         |   |                                     |

Proposed




Figure 4-2 Environmental Sampling Locations Within 5km of Plant


## APPENDIX I

### RADIOACTIVE LIQUID, GASEOUS, AND SOLID WASTE TREATMENT SYSTEMS

Requirement: Technical Specification 6.14.A requires that licensee initiated major changes to the radioactive waste systems (liquid, gaseous, and solid) be reported to the Commission in the Semiannual Radioactive Effluent Release Report for the period in which the evaluation was reviewed by the Plant Operation Review Committee.

Response: There were no licensee initiated major changes to the radioactive waste systems (liquid, gaseous, and solid) during this reporting period.

# VERMONT YANKEE NUCLEAR POWER CORPORATION



RD 5, Box 169, Ferry Road, Brattleboro, VT 05301

August 29, 1986  
FVY 86-79

REPLY TO:  
ENGINEERING OFFICE  
1671 WORCESTER ROAD  
FRAMINGHAM, MASSACHUSETTS 01701  
TELEPHONE 617-872-8100

United States Nuclear Regulatory Commission  
Region I  
631 Park Avenue  
King of Prussia, PA 19406

Attention: Dr. Thomas E. Murley  
Regional Administrator

References: (a) License No. DPR-28 (Docket No. 50-271)

Subject: Vermont Yankee Semiannual Effluent Release Report

Dear Sir:

Enclosed herewith please find two copies of the Vermont Yankee Nuclear Power Corporation Semiannual Effluent Release Report. This report covers the period beginning January 1, 1986 and ending June 30, 1986, and is submitted in accordance with our Technical Specifications 6.7.c.1.

We trust that the enclosed information is satisfactory; however, should you have any questions, please contact us.

Very truly yours,

VERMONT YANKEE NUCLEAR POWER CORPORATION

*R. W. Capstick*  
R. W. Capstick  
Licensing Engineer

RWC/b11

Enclosures

cc: United States Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Washington, DC 20555  
Attention: Document Control Desk

IE48  
11