

GPU NUCLEAR

B/A No. 128108

W/O No. 95-552A-52108

SEISMIC QUALIFICATION
03-24-97
No. SQ - ^{TI} CO-T-0001A
REVISION 0

COMPONENT: CO-T-0001A

SUBCOMPONENT(S):

Sheet 1 of 27

FOR RICK AUGUSTINE TELECON 2/8/94
EVALUATED BY: *Roy L. Cox* DATE *2/8/94*
EVALUATED BY: *Erigo* DATE *2-8-94*

SQUG DATA FILE INDEX

COMPONENT TAG NUMBER CD-T-0001A

DESCRIPTION CONDENSATE STORAGE TANK A

► DOCUMENTS

NUMBERS/STATUS

SEWS	_____	✓
GMS-2 (TECHNICAL FUNCTIONS DATA SURVEY)	_____	✓
PHYSICAL DRAWING/ASSEMBLY DRAWING	<u>1, 69-4476U (00485)</u>	✓
VENDOR CATALOG/DATA/INSTRUCTION MANUAL	_____	_____
INSTALLATION SPECIFICATION	_____	_____
SEISMIC ANALYSIS/TEST REPORTS/CALCS	<u>C 1101X-322C-A26</u>	✓
CONCRETE OR PAD DRAWINGS, SPECS, BLOCK WALLS	<u>435-201</u>	✓
EMBEDDED STEEL DRAWINGS	_____	_____
ANCHORAGE DRAWING/DETAILS/AIDS	<u>423-039</u>	✓
FIELD CHANGE DOCS/MNCR'S	_____	_____

OTHER 10, 694476U (00485) SHE 1,2,3,4,6,7,8,9,10
015-012

RL 5/11/93
signature

► GENERIC ISSUES

- _____ POTENTIAL OUTLIER
- _____ BASE PLATE PLUG WELDS
- _____ OTHERS

► DISPOSITION

- _____ NEED MORE DATA
- _____ KNOWN OUTLIER
- _____ SEISMIC DATA ACCEPTABLE. CONFIRMATION WALKDOWN ONLY

ANCHORAGE CALCULATIONS: _____ EXIST _____ PERFORM IN FIELD

COMMENTS ALL INFO. AVAILABLE FOR TANK EVALUATION.

READY FOR SQUG WALKDOWN

RL
Seismic Capacity Engineer (SCE)

SCREENING EVALUATION WORK SHEET (SEWS)

Equip. ID No. CO-T-0001A Equip. Class 21 - Tanks and Heat Exchangers

Equipment Description CONDENSATE STORAGE TANK 1A

Location: Bldg. YD Floor El. 305 Room, Row/Col S.E. OF TURB BLDG

Manufacturer, Model, Etc. (optional) CHICAGO BRIDGE AND IRON CO.

SHELL CAPACITY VS DEMAND

Buckling capacity of shell of large, flat-bottom, vertical tank is equal to or greater than demand:

Y N U N/A

SEE ATTACHMENT A

ANCHOR BOLTS AND EMBEDMENT

Capacity of anchor bolts and their embedments is equal to or greater than demand:

Y N U N/A

SEE ATTACHMENT A & OUTLIER

CONNECTION BETWEEN ANCHOR BOLTS AND SHELL

Capacity of connections between the anchor bolts and the tank shell is equal to or greater than the demand:

Y N U N/A

SEE ATTACHMENT A

FLEXIBILITY OF ATTACHED PIPING

Attached piping has adequate flexibility to accommodate motion of large, flat-bottom, vertical tank:

Y N U N/A

TANK FOUNDATION

Ring-type foundation is not used to support large, flat-bottom, vertical tank:

Y N U N/A

IS EQUIPMENT SEISMICALLY ADEQUATE?

Y N U

SEE OUTLIER

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 2 of 2

Equip. ID No. CO-T-0001A Equip. Class 21 - Tanks and Heat Exchangers

Equipment Description CONDENSATE STORAGE TANK 1A

COMMENTS

Evaluated by:

B. D. Augustino
[Signature]

Date:

1-24-94
1-28-94

Exhibit 5-1

OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

1. OUTLIER IDENTIFICATION, DESCRIPTION, AND LOCATION

Equipment ID Number CO-T-0001A Equipment Class 21
 Equipment Location: Building YD Floor Elevation 305
 Room or Row/Column Base Elevation 305
 Equipment Description CONDENSATE STORAGE TANK 1A

2. OUTLIER ISSUE DEFINITION

a. Identify all the screening guidelines which are not met.
 (Check more than one if several guidelines could not be satisfied.)

<u>Mechanical and Electrical Equipment</u>		<u>Tanks and Heat Exchangers</u>	
Capacity vs. Demand	<input type="checkbox"/>	Shell Buckling ¹	<input type="checkbox"/>
Caveats	<input type="checkbox"/>	Anchor Bolts and Embedment	<input checked="" type="checkbox"/>
Anchorage	<input type="checkbox"/>	Anchorage Connections	<input type="checkbox"/>
Seismic Interaction	<input type="checkbox"/>	Flexibility of Attached Piping ¹	<input type="checkbox"/>
Other	<input type="checkbox"/>	Other	<input type="checkbox"/>
		<u>Cable and Conduit Raceways</u>	
<u>Essential Relays</u>		Inclusion Rules	<input type="checkbox"/>
Capacity vs. Demand	<input type="checkbox"/>	Other Seismic Performance Concerns	<input type="checkbox"/>
Mounting, Type, Location	<input type="checkbox"/>	Limited Analytical Review	<input type="checkbox"/>
Other	<input type="checkbox"/>	Other	<input type="checkbox"/>

¹ Shell buckling and flexibility of attached piping only apply to large, flat-bottom, vertical tanks.

b. Describe all the reasons for the outlier (i.e., if all the listed outlier issues were resolved, then the signatories would consider this item of equipment to be verified for seismic adequacy):

The tank does not meet the GIP guidelines.

Exhibit 5-1 (Cont'd)

OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

Equipment ID Number CO-T-0001A

3. PROPOSED METHOD OF OUTLIER RESOLUTION (OPTIONAL)

a. Define proposed method(s) for resolving outlier.

* CALCULATION SHOWS TANK IS SEISMICALLY
ADEQUATE. (Attached)

b. Provide information needed to implement proposed method(s) for resolving outlier (e.g., estimate of fundamental frequency).

4. CERTIFICATION:

The information on this OSVS is, to the best of our knowledge and belief, correct and accurate, and resolution of the outlier issues listed on the previous page will satisfy the requirements for this item of equipment to be verified for seismic adequacy:

Approved by: (For Equipment Classes #0 - #22, all the Seismic Capability Engineers on the Seismic Review Team (SRT) should sign; there should be at least two on the SRT. One signatory should be a licensed professional engineer. For Relays, the Lead Relay Reviewer should sign.)

R.D. AUGUSTINE
Print or Type Name

R.D. Augustine
Signature

1-24-94
Date

ENRIQUE TANG
Print or Type Name

Enrique Tang
Signature

1-28-94
Date

Print or Type Name

Signature

Date

GPU Nuclear**Calculation Sheet**

Subject CO-T-0001A & IB		Calc No. CO-T-0001A & IB	Rev. No. 0	Sheet No. 1 of 19
Originator R.D. Augustus	Date 1-24-94	Reviewed by Ernst	Date 1-28-94	

Purpose The purpose of this calculation is to seismically verify the tank and its anchorage.

Methodology The methodology to be used in this calculation is that detailed in the Generic Implementation Procedure (GIP).

References

1. ES-022, Seismic Design Criteria
2. Gilbert Associates Drawing No. E-435-201 Rev.6
3. Gilbert Associates Drawing No. E-423-039 Rev. 2
4. Not Used
5. Chicago Bridge and Iron Company Drawing for Dome Roof for 48'-0" diameter tank (4692-17-058-0)
6. Chicago Bridge and Iron Company Drawing for Dome Roof for Anchor Bolt Chairs for tank 48'-0" x 20'-0" tall. (4692-17-055-0)
7. Generic Implementation Procedure (GIP) for the Seismic Verification of Nuclear Plant Equipment, Rev.2
8. EQE Report No. 42105-R-001
9. EPRI Report NP-6041, "A Methodology for Assessment of Nuclear Plant Seismic Margin: Final Report dated October 1988."
10. EPRI Report NP-5228-SL, "Seismic Verification of Nuclear Plant Equipment Anchorage", Volume 4
11. EPRI Report NP-5228-SL, "Seismic Verification of Nuclear Plant Equipment Anchorage", Volume 1
12. NUREG-CR-1161, "Recommended Revisions to Nuclear Regulatory Commission Seismic Design Criteria". Published May 1980
13. AISC Manual of Steel Construction 9th Edition
14. EQE Calculation 50097-C-010, Rev. 0, "TMI DBS Time Histories".
15. Haroun, M.A., and G.W. Housner, "Seismic Design of Liquid Storage Tanks," Journal of the Technical Councils, ASCE, April 1981.

GPI Nuclear**Calculation Sheet**

Subject <i>CO-T-0001A & 1B</i>		Calc. No. <i>CO-T-0001A & 1B</i>	Rev. No. <i>0</i>	Sheet No. <i>2 of 19</i>
Originator <i>G.D. Augustine</i>	Date <i>1-24-94</i>	Reviewed by <i>[Signature]</i>		Date <i>1-28-94</i>

Determine allowable shear and tension loads for a 1-1/2" diameter cast-in-place anchor bolt in accordance with the guidelines of Reference 10. Note that this is the reference material for the derivation of the allowable loads for cast-in-place anchor bolts in the GIP. The values just were not derived for 1-1/2" diameter bolts.

The allowable tension and shear loads are based on the nominal bolt area times allowable shear and tension stresses. These allowable stresses (17,000 psi shear and 34,000 psi tension for A307 bolt material) are equal to 1.767 times the working stress design allowable given in Part 1 of the AISC specification for Design, Fabrication, and Erection of Structural Steel for Buildings, Reference 11.

Per Reference 13, the nominal bolt area for a 1-1/2" diameter bolt = 1.767 in².

$$P_t = 1.767 \cdot 34000 = 60078 \quad \text{psi}$$

$$P_v = 1.767 \cdot 17000 = 30039 \quad \text{psi}$$

Determine Minimum Embedment, Spacing, and Edge Distance

The recommended minimum embedment lengths are developed by applying the concrete shear-cone theory put forth in Appendix B of the ACI Standard 349 (Reference 13), and assuring ductile failure mode in bolt material rather than brittle failure associated with pulling of concrete cone. The ACI concrete shear-cone theory gives the pullout strength of concrete P, as:

a capacity reduction factor	ϕ :=	0.65
concrete compressive strength in psi	f_c :=	3500
diameter of bolt or stud in inches	D :=	1.5
embedment = 10D	L :=	15

where:


$$P = 4 \cdot \phi \cdot \sqrt{f_c} \cdot \pi \cdot (L + D) \cdot L$$

To determine the embedment lengths required by the GIP, the above equation was solved by setting P equal to twice the pullout capacity value given as P_t . Solving the equation for L in terms of bolt diameter for $f_c' = 3,500$ psi yields a required embedment of 10D. Thus for a 1-1/2" diameter bolt, the embedment length must be a minimum of 15". Page 2-77 states that the minimum spacing and edge distance requirements are 12.5D and 8.75D respectively. This equates to 18-3/4" spacing and 13-1/8" edge distance requirements.

Subject CO-T-0001A & 1B	Calc. No. CO-T-0001A & 1B	Rev. No. 0	Sheet No. 3 of 19
Originator P.D. Augustini	Date 1-24-94	Reviewed by [Signature]	Date 1-28-94

CALCULATIONS

- Determine height of freeboard above fluid surface =



- For tanks with a domed roof, measure the freeboard from the fluid surface to the point where the roof surface is at a distance of 0.9R from the tank &.

From Ref 5, the dome roof arc length from pt. ① to ② is 25'-1 5/16" =

$$A^\circ = 57.29578 \frac{\text{arc length}}{\text{radius}}$$

$$= 57.29578 \left(\frac{301.3125''}{48(12)} \right)$$

$$= 29.97^\circ$$

$$x = (576 \sin 60.3) - 240$$

$$= 258.97'$$

$$\text{Freeboard} = (576^2 - 259.2^2)^{1/2} - 240 - 258.97$$


$$= 15.41''$$

Freeboard above max. water level =

$$15.41 + (20'-0'' - 19'-7'') = 15.82''$$

Subject CO-T-0001A & 1B	Calc No. CO-T-0001A & 1B	Rev. No. 0	Sheet No. 4 of 19
Originator S.D. Augustus	Date 10-7-93	Reviewed by E. J. [Signature]	Date 1-28-94

- ANCHOR BOLTS - From Ref 2 find the anchor bolts are (16) Type TB2 bolts. From Ref 3 find the following:



The walkdown found the anchor bolts to have an edge distance = 9"

$$\text{Spacing} \Rightarrow \frac{2\pi r}{360} = \frac{x}{22.5^\circ} \Rightarrow x = \frac{2\pi(291.5)(22.5)}{360} = 114.5"$$



Calculation Sheet

Subject CO-T-0001A & 1B		Calc. No. CO-T-0001A & 1B	Rev. No. 0	Sheet No. 5 of 19
Originator H.D. Augustin	Date 1-9-94	Reviewed by [Signature]	Date 1-28-94	

**CAPACITY REDUCTION FACTORS FOR CAST-IN-PLACE BOLTS
WITH NUTS OR HEADED STUDS**

CONDENSATE WATER STORAGE TANK

Bolt Dia. (D) inches:	<u>1.5</u>	Concrete Strength f'_c (psi) =	<u>3,000</u>
Required Edge Dist. (E _{min}) inches:	<u>13.125</u>	Actual Edge Dist. (E) inches:	<u>9.00</u>
Required Embedment (L _{min}) inches:	<u>15</u>	Actual Embedment (L) inches:	<u>18.00</u>
Required Spacing (S _{min}) inches:	<u>18.75</u>	Actual Spacing (S) inches:	<u>114.50</u>

Note: If actual embedment, spacing, or edge distance exceeds minimum required, use minimum values for calculation of reduction factors.

$$L = \underline{15} \text{ inches} \quad S = \underline{18.75} \text{ inches} \quad E = \underline{9} \text{ inches}$$

$$\begin{aligned} \text{THETA (edge Dist.)} &= 2 \cos^{-1} (2E/(2L+D)) \\ &= \underline{1.93} \text{ radians} \end{aligned}$$

$$\begin{aligned} r &= (2L+D)/2 \\ &= \underline{15.75} \end{aligned}$$

$$\begin{aligned} \text{THETA (spacing)} &= 2 \cos^{-1} (S/(2L+D)) \\ &= \underline{1.87} \text{ radians} \end{aligned}$$

Edge Distance Check

$$E = 9.0 > = 4D, \text{ but not } > E_{min}, \text{ pullout reduction factor must be applied}$$

$$\begin{aligned} RE_p &= \text{Pullout Capacity Reduction Factor} \\ &= A(\text{reduced})/A(\text{nominal}) \end{aligned}$$

$$\begin{aligned} A(\text{reduced}) &= (PI)(r^2) - .5((r^2)(\text{THETA edge}) - 2rE \sin(\text{THETA edge}/2)) \\ &= \underline{657} \text{ in}^2 \end{aligned}$$

$$\begin{aligned} A(\text{nominal}) &= .96(PI/4)((2L+D)^2) \\ &= \underline{748} \text{ in}^2 \end{aligned}$$

$$RE_p = \underline{0.88}$$

$$E = 9.0 > = 4D, \text{ but not } > 8.75D, \text{ shear reduction factor must be applied}$$

$$\begin{aligned} RE_s &= \text{Shear Capacity Reduction Factor} = 0.0131*(E/D)^2 \\ &= \underline{0.47} \end{aligned}$$

GPU Nuclear

Calculation Sheet

Subject CO-T-0001A & 1B	Calc No. CO-T-0001A & 1B	Rev. No. 0	Sheet No. 6 of 19
Originator H.D. Augustin	Date 1-9-94	Reviewed by [Signature]	Date 1-28-94

- Concrete Strength Check

GIP Table C.3-1 allowables are based on a concrete strength = $f'_c = 3500$ psi.Concrete strength < 3,500 psi but $\geq 1,500$ psi. Strength reduction factor required.

$$\text{Reduction factor (RFp)} = (\text{RFs}) = \text{SQRT}(f'_c / 3500)$$

$$= \underline{0.93}$$

- Embedment Check:

$10 * D = \underline{15.00}$

$4 * D = \underline{6.00}$

 $L \geq 10D$, no reduction factor required.

- Spacing Check

$2 * D = \underline{3.00}$

Actual spacing equals or exceeds required spacing, no pullout reduction factor required.

Shear capacity reduction factor for closely spaced cast-in-place anchor bolts = RS_s :

$RS_s = \underline{1.00}$ for actual spacing (S) $\geq 2 * D$

- Revised Allowable Loads

From Table C.3-1 of the GIP, the subject bolt has the following full allowable loads:

For $D = 1.500$ inches, the allowable pullout capacity (P_u') = 60,078 lbs. and
the allowable shear capacity (V_u') = 30,039 lbs.

$$\text{The revised pullout load} = P_u = P_u' * RE_p * RF_p * RL_p * RSp$$

$$= \underline{49,168} \text{ lbs.}$$

$$\text{The revised shear load} = V_u = V_u' * RE_s * RF_s * RL_s * RS_s$$

$$= \underline{13,130} \text{ lbs.}$$

VERTICAL TANKS -- CONDENSATE WATER STORAGE TANK

STEP 1: Determine the following input data :

TANK MATERIAL	
diameter of tank (ft):	<u>48</u>
R (nominal tank radius) (inches):	<u>288</u>
height of tank shell (ft):	<u>20</u>
H' (height of tank shell) (inches):	<u>240</u>
t min (minimum shell thickness along height of tank) (inches):	<u>0.25</u>
t s (minimum thickness of tank in the lowest 10% of height) (inches):	<u>0.25</u>
F y (yield strength of tank shell mat'l) (psi):	<u>36,000</u>
h c (height of shell compression zone at base of tank, usually height of chair) (inches):	<u>12</u>
E s (elastic modulus of tank shell mat'l) (psi):	<u>29,000,000</u>
V s (average shear wave velocity of soil for tanks located at grade) (ft/sec):	<u>N/A</u>


FLUID	
GAMMA (weight density of fluid) (lb/in ³):	<u>0.036</u>
H (height of fluid at maximum fill level) (inches):	<u>235</u>
h f (height of freeboard above fluid surface) (inches):	<u>15.82</u>

ANCHOR BOLTS	
N (number of bolts):	<u>16</u>
d (diameter of bolt) (inches):	<u>1.60</u>
h b (eff. length of anchor bolt being stretched, usually from top of chair to embedded plate) (in.):	<u>36</u>
E b (elastic modulus of bolt material) (psi):	<u>29,000,000</u>
Anchor Bolt Allowable Tension Load (Pu) (lbs):	<u>49,168</u>
Anchor Bolt Allowable Shear Load (Vu) (lbs):	<u>13,130</u>
(Note: Allowables are with reduction factors applied)	
Yield stress of anchor bolt material (f y) (psi):	<u>36,000</u>

From Figure 7-5 of the GIP, find the following dimensions (inches):

d =	<u>1.75</u>	j =	<u>0.5</u>	t b =	<u>0.25</u>
f =	<u>0.875</u>	g =	<u>2.5</u>	k =	<u>3.72</u>
b =	<u>5</u>	c =	<u>0.75</u>	e =	<u>3.25</u>
s =	<u>4.5</u>	h =	<u>12</u>	t s =	<u>0.25</u>

Weld size between anchor chair and tank shell (t w) (inches): 0.25



Ground or floor response spectrum at 4% damping for overturning moment and shear loadings on tanks and at 1/2% damping for fluid slosh height.

Ground response spectrum ZPA = 0.12 g

Subject	CO-T-0001A \$1B	Calc No	CO-T-0001A \$1B
Original	A. D. Augustin	Rev'd by	Eng JF
Date	1-9-94	Date	1-28-94
Rev No	0	Sheet No	7 of 19

EPRI Nuclear

Calculation Sheet

Subject:	CD-T-0001A & 1B		
Original By:	R.D. Augustino		
Revised By:	G. J. [Signature]		
Date:	1-28-94	Rev. No.:	0
Sheet No.:	19	Calc No.:	CD-T-0001A & 1B

STEP 2: Calculate the following ratios and values:

H/R = 0.816 t_e/R = 0.001

t_{avg.} = thickness of tank shell averaged over the linear height of the tank shell
 = (SUM t_i * h_i) / H'

= 0.250 inches

i	t	h	t x h
1	0.25	80	20
2	0.25	80	20
3	0.25	80	20
4			
5			
			80 = SUM t x h

t_{eff} = (t_{avg.} + t_{min}) / 2
 = 0.25 in

(t_{eff}/R) = 0.001

Ab = Cross-sectional area of embedded anchor bolt
 = (PI * d²) / 4
 = 1.767 in²

t' = equivalent shell thickness having the same cross-sectional area as the anchor bolts
 = ((N * Ab) / (2 * PI * R)) * (Eb / Es)
 = 0.0158

c' = coefficient of tank wall thickness and length under stress
 = (t' / t_e) * (h_c / h_b)
 = 0.02

W = weight of fluid in tank
 = PI * R² * H * GAMMA
 = 2,204,475 lbs

CHECK TABLE 7-1 REQUIREMENTS

Tank Material = Carbon, Stainless Steel, Aluminum (circle one)	
Tank Fluid Content = Water or similar YES or NO (circle yes or no), if no tank is an OUTLIER	
Nominal Radius of Tank R = <u>288</u> inches	OK, Table 7-1 requirements met, 60 in > R < 420 in
Height of Tank Shell (H') = <u>240</u> inches	OK, Table 7-1 requirements met, 120 in > H < 980 in
Height of Fluid at the maximum Level to which the tank will be filled (H) = <u>235</u> inches	OK, Table 7-1 requirements met, 120 in > H < 980 in
Minimum Thickness (t) of the Tank Shell in the lowest 10% of the Shell Height = <u>0.25</u> inches	OK, Table 7-1 requirements met, 3/16 in > t < 1 in
Effective Thickness (t _{eff}) of Tank Shell Based on the mean of the Average Thickness (t _{avg}) = <u>0.250</u> inches	OK, Table 7-1 requirements met, 3/16 in > t _{eff} < 1 in
Diameter of Anchor Bolt (d) = <u>1.500</u> inches	OK, Table 7-1 requirements met, 1/2 in > d < 2 in
Number of Anchor Bolts (N) = <u>18</u>	OK, Table 7-1 requirements met, N > 8
Tank Wall Thickness (t _{Base})-to-Tank radius Ratio = (t _{Base} /R) = <u>0.001</u>	OK, Table 7-1 requirements are met, .001 <= t _{Base} / R <= .01
Effective Tank Wall Thickness-to-Tank Radius ratio = (t _{eff} /R) = <u>0.001</u>	OK, Table 7-1 requirements met, .001 <= t _{eff} / R <= .01 inches.
H/R = <u>0.818</u>	Table 7-1 requirements not met. Classify as an OUTLIER and proceed w/ H / R not 1.0 to 5.0

STEP 3: Determine the fluid-structure modal frequency for vertical carbon steel tanks containing water:

R = 288 t_{eff} / R = 0.001 , and H / R 0.818

From Table 7-3, find (F_f) = 2.78 Hz.

NOTE: If the tank material is not carbon steel (E_s not equal to 29,000 ksi) or fluid is not water (GAMMA not equal to 62.4 lbs/ft³) the frequency must be adjusted in accordance with the GIP STEP 3.

STEP 4: Determine the spectral acceleration (S_{af}) for the fluid-structure modal frequency.

Enter the 4% damped horizontal ground or floor response spectrum for the surface on which the tank is mounted, with the fluid-structure modal frequency determined in STEP 3, and determine the maximum spectral acceleration (S_{af}) over the following frequency range:

.8 * F_f < F < 1.2 * F_f = 2.22 Hz < F < 3.34 Hz

Appropriate Spectral Acceleration (S_{af}) = 0.48 g 5% damping

g 4% damping = g 5% [SQRT(5/4)] = 0.51 g

Subject CO-T-0001A 5 11B	Calc No CO-T-0001A 5 11B	Rev No 0	Sheet No 9 of 14
Original R.D. Wigginton	Date 1-9-94	Reviewed By Exg JLP	Date 1-28-94

STEP 5: Determine the base shear load (Q).

Enter Figure 7-3 with (H/R) and (t eff/R) from above:

H/R = 0.818 and t eff/R = 0.001

And find base shear load coefficient (Q') = 0.64

Shear Load at Bottom of Tank = (Q) = Q' * W * S_{af} = 719,541 lbs

STEP 6: Determine the base overturning moment (M)

Enter Figure 7-4 with H/R = 0.818 and t eff/R = 0.001

And find M' = 0.305

Compute overturning moment = M = M' * W * H * S_{af}
= 80,582,830 lb-in

STEP 7: From the anchor bolt tensile load capacity, P_u, compute the allowable bolt stress (F_b):

F_b = P_u / A_b
= 27,826

Note: If the Section 4 and Appendix C criteria are not met for the anchorage, then the concrete is considered the weak link in the load path and the postulated failure mode is brittle. Determine an appropriate reduced allowable anchor bolt stress (F_r) per applicable code requirements.

STEP 8: Check the bending stress in the top plate of the chair. If each of the anchorage connection components meets the acceptance criteria defined below, then the bolt tensile capacity determined in STEP 7 is limiting. If, however, any of the components does not meet these guidelines, the reduced anchor bolt tension capacity represented by the equivalent value of anchor bolt allowable stress (F_r), as calculated here should be used. Note that if the top plate projects radially beyond the vertical plates, no more than 1/2 inch of this projecting plate can be included in the dimension f used in the following equation.

The maximum bending stress in the top plate is:

SIGMA = [(0.375 * g) - (0.22 * d)] * P_u / (f * c * 2)
= 96,588 > f_y. Capacity reduction factor must be used.

Reduction Factor = f_y / SIGMA = 0.37

Reduced Anchor Bolt Stress = F_r = F_b * (f_y/SIGMA) = 10,286 psi

Subject	CO-T-0001A & 1B	Calc No.	CO-T-0001A & 1B
Original	R.D. Augustus	Date	1-9-94
Revised by	<i>[Signature]</i>	Date	1-28-94
Rev No.	0	Sheet No.	19 of 19

Subject:	CO-T-00014 & 1B	Car. No.	CO-T-00014 & 1B
Original:	S.D. Augustine	Reviewed by:	[Signature]
Date:	1-9-94	Date:	1-28-94
Rev. No.	0	Sheet No.	11 of 19

STEP 9: Check Tank Shell Stress

Shell Stress = 133,435 psi > F_y. Reduction factor must be applied

$$Z = \frac{1}{\left(\frac{10.177 \cdot a \cdot t_b \cdot (t_b/t_c)^2}{\text{SORT}(R \cdot t_c)} + 1 \right)}$$

Reduction Factor = F_y / SHELL STRESS = 0.27

Reduced Anchor Bolt Allowable Stress = F_r = 7,513 psi

STEP 10: The vertical stiffener plates are considered adequate if they satisfy the following guidelines:

- $(k/j) < (95 / ((f_y / 1000)^{0.5}))$
 $k/j = \frac{7.44}{15.83}$ Guideline No. 1 Satisfied
- $(j > 0.04 \cdot (h - c) \text{ and } j > 0.5 \text{ in.})$
 $j = \frac{0.50}{0.46}$ Guideline No. 2 Satisfied
- $(P_u / (2 \cdot k \cdot j)) < 21,000 \text{ psi}$
 $P_u / (2 \cdot k \cdot j) = \frac{13,217}{}$ Guideline No. 3 is Satisfied

STEP 11: Check weld between the tank chair and the tank.

Load per linear inch of weld = W_w

$$= P_u \cdot \left(\frac{1}{(1 + 2 \cdot h)^2} + \frac{1}{(1 + 0.867 \cdot h^2)^2} \right)^{0.5}$$

= 2,027 lbs/inch

Allowable load per inch = $(30,600 \cdot t_w) / \text{SORT}(2)$ Weld is adequate

= 5,409 lbs/inch

STEP 12: Check tank wall for elephant's foot buckling:

Enter Figure 7-7 with the following parameters: S_{ef} = 0.51 and H/R = 0.816

and find the fluid pressure coefficient (P_e) = 1.4

The fluid pressure at the base of the vertical tank from elephant-foot buckling type loading = (P_e) = P_e * GAMMA * R (psi)

= 14,5152 psi

STEP 13: Determine the elephant-foot buckling stress capacity factor:

Enter Figure 7-8 with the following parameters:

$P_e = \underline{14,5152} \text{ psi}$ and $t_e / R = \underline{0.001}$

And find the Capacity Factor = 12,000 psi

Note: The above Capacity Factor is for carbon steel. If the tank being evaluated is of some other material, see STEP 13 in the GIP for the conversion factor.

STEP 14: Determine the fluid pressure for diamond-shape buckling (Pd):

Enter Figure 7-9 with the following parameters:

$S_{ef} = \underline{0.51} g$ and $H/R = \underline{0.816}$

and find the pressure coefficient for diamond-shape buckling (Pd') = 1.25

The fluid pressure at the base of the vertical tank from diamond-shape buckling type loading = (Pd) = $P_d' \cdot \text{GAMMA} \cdot R$
 = 12.86 psi

STEP 15: Determine the diamond-shape buckling stress capacity factor

Enter Figure 7-10 with the following parameters:

$P_d = \underline{12.86} \text{ psi}$ and $t_e / R = \underline{0.001}$

And find the capacity factor = 12,000 psi

Note: The above Capacity Factor is for carbon steel. If the tank being evaluated is of some other material, see STEP 15 in the GIP for the conversion factor.

STEP 16: Select the allowable buckling stress, SIGMA_{ac}, as 72% of the lower value of the elephant-foot or diamond-shape buckling Capacity Factor:

Elephant-Foot Buckling Capacity Factor =	<u>12,000</u> psi	CONTROLS
Diamond-Shape Buckling Capacity Factor =	<u>12,000</u> psi	CONTROLS
Allowable buckling stress =	<u>8,640</u> psi	

Subject	CO-T-00014 & 1B	Calc No.	CO-T-00014 & 1B
Original By	G.O. Augustator	Reviewed By	E. J. [Signature]
Date	1-9-94	Date	1-28-94
Sheet No.	19	Rev No.	

Subject	CD-T-00014 E1B		Calc No	CD-T-00014 E1B
Original By	P.D. Vasquez		Rev No	0
Date	1-9-94	Reviewed By	E. J. [Signature]	
Date	1-28-94	Sheet No	13 of 22	

STEP 17: Determine the overturning moment capacity (M_{ocp}).

The overturning moment capacity of the tank, (M_{ocp}), is dependent upon whether the postulated weak link failure mode is ductile or brittle. A ductile failure mode is defined as one in which the weak link is one of the following:

- Anchor bolt stretching (Step 7)
- Chair top plate bending (Step 8)
- Tank shell bending (Step 9)

A brittle mode of failure is defined as one in which the weak link is one of the following:

- Concrete cone failure (Step 7)
- Chair stiffener plate shear or buckling failure (Step 10)
- Chair-to-tank wall weld shear failure (Step 11)

For DUCTILE failure, enter Figure 7-12 with the following parameters and find the base overturning moment coefficient (M_{ocp'}) = 0.06

F (b or r) = 7,513 psi h b = 36.00 h c = 12.00 inches

Allowable Buckling Stress = 8,940 psi

σ' = 0.02 ((Allowable Buckling Stress)/(Fb)) * (h c / h b) = 0.383

For BRITTLE failure, enter Table 7-4 with the following parameter and find the base overturning moment coefficient (M_{ocp'}) = N/A

σ' = 0.02 and ((Allowable Buckling Stress)/(Fb)) * (h c / h b) = 0.383

Per Steps 7 to 10, the expected failure mode is DUCTILE

Use (M_{ocp}) value = 0.06 for DUCTILE failure.

Note: Fb is the smallest of Fb from Step 7, Fr from Step 8, or Fr from Step 9 = 7,513

Compute (M_{ocp}) based on the following formula:

$$M_{ocp} = (M_{ocp}') * (2 * F_b) * (R^2 * t_s) * (h_b / h_c)$$

$$= \underline{56,084,244} \text{ lb-inches}$$

STEP 18: Compare the overturning moment capacity of the tank (M_{ocp}) from Step 17 with the overturning moment (M) from Step 6.

M_{ocp} = 56,084,244 lb-in < M = 80,582,930 lb-in

The tank is not seismically adequate for this loading and must be classified as an OUTLIER. proceed to Section 6 OUTLIER RESOLUTION after completing the remainder of the evaluations.



Calculation Sheet

Subject	CO-T-0001A 4/13	Calc No	CO-T-0001A 4/13	Rev No	0	Sheet No	4 of 4
Originator	R.D. Augustin	Date	1-28-94	Reviewed by	[Signature]		

STEP 19: Compute the base shear load capacity (Cap) of the tank

$$Cap = .65 * (1 - 0.21 * Sef) * W$$

$$= \underline{1,082,607} \text{ lbs}$$

STEP 20: Compare the base shear load capacity of the tank (Cap) from Step 19 with the shear load (Q) from Step 5.

$$Cap = \underline{1,082,607} \text{ lbs} > Q = \underline{719,541} \text{ lbs}$$

Shear capacity exceeds demand. The tank is adequate for this loading.

STEP 21: Compare the freeboard clearance to the slosh height to ensure that the roof is not subjected to significant forces from the sloshing liquid.

In calculating the slosh height, (h_s), the spectral acceleration, (S_{ef}), must be obtained from the input demand spectrum at the sloshing mode frequency, (F_s), and a damping value of 1/2%. Care should be exercised in assuring that the spectrum values are accurately defined in the sloshing mode frequency range, typically for 0.5 Hz to 0.2 Hz.

$$F_s = \left(\frac{1}{2} * \pi \right) * \left\{ \text{SQRT} \left[\left(1.84 * g \right) / R \right] * \tanh \left[\left(1.84 * H \right) / R \right] \right\}$$

$$= \underline{0.24} \text{ Hz}$$

Spectral acceleration, (S_{ef}), from 1/2% damped input response spectrum at the sloshing mode frequency (F_s): NOT CLEARLY DEFINED

$$\text{Slosh height} = h_s = 0.837 * R * S_{ef}$$

$$= \underline{N/A} \text{ inches}$$

Alternatively, if the spectrum values (S_{ef}) are not well defined in the range of the sloshing mode frequency (F_s) determine the slosh height by entering Table 7-5 with the following parameters to find the slosh height, (h_s), of the fluid in the tank for a ZPA of 1g at the base of the tank:

$$H / R = \underline{0.82} \quad \text{and} \quad R = \underline{288} \text{ inches}$$

$$\text{to find } (h_s) = \underline{108}$$

$$\text{Compute the slosh height } (h_s) : h_s = h_s * ZPA = \underline{12.86} \text{ inches}$$

$$\text{where ZPA is from horizontal response spectrum} = \underline{0.12}$$



Calculation Sheet

Subject	C0-T-0001A & 1B		Calc. No.	C0-T-0001A & 1B	
Original By	R.D. Carpenter		Rev. No.	0	
Date	1-9-94		Sheet No.	5 of 19	
Reviewed By	[Signature]		Date	1-28-94	

STEP 22: Determine the available freeboard above the fluid surface at the maximum level to which the tank will be filled:

For conical roofs, measure the freeboard from the fluid surface to the intersection of the wall and the roof (a distance R from the tank centerline).


For tanks with a domed roof, measure the freeboard from the fluid surface to the point where the roof surface is at a distance of 0.8R from the tank centerline.

$h_f = \underline{15.82}$ inches

Compare the available freeboard (h_f) to the slosh height of the fluid (h_s), from Step 21.

$h_f = \underline{15.82}$ inches > $h_s = \underline{12.93}$ inches

Available freeboard exceeds expected slosh height. This tank is adequate for this condition.



Calculation Sheet

Subject <i>CO-T-0001A E 1B</i>		Calc No. <i>CO-T-0001A E 1B</i>	Rev. No. <i>0</i>	Sheet No. <i>16 of 19</i>
Originator <i>H.D. Augustino</i>	Date <i>1-24-94</i>	Reviewed by <i>E. J. L.</i>		Date <i>1-28-94</i>

STEP 2 OUTLIER RESOLUTION

Per Step 2 of the GIP evaluation the tank is classified as an OUTLIER as the Height / Radius does not meet the class inclusion guidelines. The Height / Radius of this tank = $20' / 24' = 0.816$. The minimum ratio per the guidelines is 1.0. Page 2-3 (Reference 10) states that the range of parameters for the database tank are Diameter from 10' to 70' and a Height from 10' to 80'. The Condensate Water Storage does not meet the ratio guidelines but does meet the parameter range (diameter = 48' and the fluid height = 20'). As such, an explicit tank evaluation is required.

The input parameters used in the GIP evaluation were taken from a H/R value equal to 1.0. This is conservative as the overturning moment calculations with a H/R value equal to 1.0 will be larger than a H/R value equal to 0.816.

To verify this assumption, each step in the GIP evaluation will be checked to ensure values of H/R = 1.0 are conservative.

STEP 3: For constant values of t_{ef} / R , as H/R decreases the corresponding impulsive mode frequency increases. Therefore, using the frequency for H/R = 1.0 will yield a lower impulsive mode frequency than the value of H/R = 0.816 would.

STEP 5: The curves shown in GIP Figure 7-3 show a decreasing Base Shear Load Coefficient as the value of H/R decreases. As this value decreases the corresponding actual base shear load also decreases. Therefore, using the Base Shear Load Coefficient for H/R = 1.0 will yield a higher actual base shear load than the value of H/R = 0.816 would.

STEP 6: The curves shown in GIP Figure 7-4 show a decreasing Base Overturning Moment Load Coefficient as the value of H/R decreases. As this value decreases the corresponding actual base overturning moment also decreases. Therefore, using the Base Overturning Moment Load Coefficient for H/R = 1.0 will yield a higher actual base overturning moment than the value of H/R = 0.816 would.

STEP 12: The curves shown in GIP Figure 7-7 show a decreasing Pressure Coefficient for Elephant-Foot Buckling as the value of H/R decreases. As this value decreases the corresponding actual fluid pressure at the base of the tank from elephant-foot buckling type loading also decreases. Therefore, using the Pressure Coefficient for Elephant-Foot Buckling for H/R = 1.0 will yield a higher actual fluid pressure than the value of H/R = 0.816 would.

GRU Nuclear**Calculation Sheet**

Subject CO-T-0001A & 1B		Calc. No. CO-T-0001A & 1B	Rev. No. 0	Sheet No. 17 of 19
Originator G.D. Augustini	Date 1-24-94	Reviewed by <i>[Signature]</i>		Date 1-28-94

STEP 14: The curves shown in GIP Figure 7-9 show a decreasing Pressure Coefficient for Diamond-Shape Buckling as the value of H/R decreases. As this value decreases the corresponding actual fluid pressure at the base of the tank from diamond-shape buckling type loading also decreases. Therefore, using the Pressure Coefficient for Diamond-Shape Buckling for $H/R = 1.0$ will yield a higher actual fluid pressure than the value of $H/R = 0.816$ would.

STEP 21: The values shown in GIP Table 7-5 show a Slosh Height of Water as the value of H/R decreases. As this value decreases the corresponding slosh height also decreases. Therefore, using the Slosh Height of Water value for $H/R = 1.0$ will yield a higher actual slosh height than the value of $H/R = 0.816$ would.

The use of H/R values equal to 1.0 are judged to be acceptable and the OUTLIER is considered to be resolved.

STEP 18 OUTLIER RESOLUTION


Per Step 18 this tank is classified as an OUTLIER as the computed overturning moment is greater than the computed overturning capacity. Per page 2-5 (Reference 10), Reference 9 was used to determine the overturning demand of vertical steel tanks. Page H-3 (Reference 9) states that the overturning moment demand is only summarized and that Reference 12 can be used for a more detailed overturning moment demand calculation.

Per page 115 (Reference 12) the minimum acceptable analysis must incorporate at least two contributors to the horizontal mode. These are the IMPULSIVE mode where the response of the tank roof and shell are coupled together with the portion of the fluid contents which moves in unison with the shell and the SLOSHING mode where a portion of the tank contents moves independent of the tank shell.

HORIZONTAL IMPULSIVE MODE

It is necessary to estimate the fundamental frequency of the vibration of the tank including the impulsive contained fluid weight. From Steps 2 and 3 of the GIP analysis it is found that the SSE free field acceleration at 4% damping for the fluid-structure modal frequency is 0.51g.

GIP Nuclear**Calculation Sheet**

Subject CO-T-000A & IB		Calc No. CO-T-000A & IB	Rev. No. 0	Sheet No. 18 of 19
Originator G.D. Augustin	Date 1-24-94	Reviewed by 		Date 1-28-94

SLOSHING MODE

The fundamental convective (sloshing) mode frequency can be estimated by from the following equation from page H-11, Reference 9:

$$H_{ft} := 19.58 \text{ feet} \quad R := 24 \text{ feet}$$

$$f_s := \sqrt{\frac{1.5}{R} \cdot \tanh\left(1.835 \cdot \frac{H_{ft}}{R}\right)} \quad f_s = 0.24 \text{ Hz}$$

From Reference 14 for a frequency of 0.24 Hz, find a OBE acceleration with 5% damping =

$$\text{acc_OBE_5\%} := -.123 \cdot f_s^3 + 0.207 \cdot f_s^2 \quad \text{acc_OBE_5\%} = 0.010 \text{ g}$$

$$\text{acc_SSE_5\%} := 2 \cdot \text{acc_OBE_5\%} \quad \text{acc_SSE_5\%} = 0.020 \text{ g}$$

Using the guidelines of Section 4.4.3 of the GIP and assuming the free-field response spectrum is the input spectrum, convert the 5% damped acceleration to 1/2% damped:

$$\text{acc_SSE_0.5\%} := \text{acc_SSE_5\%} \cdot \sqrt{\frac{5}{.5}} \quad \text{acc_SSE_0.5\%} = 0.064 \text{ g}$$

Reference 10 states that the overturning moment demand (M) of vertical storage tanks is a combination of the mass of the contents (m), the sloshing mode mass of the contents (m_s), the impulsive flexible mass (m_f), and the rigid motion mass of the contents (m_r) being applied at the the respective heights, (H) height of the fluid level, (h_s) height of sloshing mode, (h_f) height of the impulsive flexible mass, and (h_r) height of the rigid mass.

From Figures 3 to 9 of Reference 15, find the following ratios:

$$\text{SLOSHING:} \quad m_s / m = M_s := 0.50 \quad h_s / H = H_s := 0.57$$

$$\text{IMPULSIVE FLEXIBLE:} \quad m_f / m = M_f := 0.48 \quad h_f / H = H_f := 0.41$$

$$\text{IMPULSIVE RIGID:} \quad m_r / m = M_r := 0.48 \quad h_r / H = H_r := 0.40$$

GPI Nuclear**Calculation Sheet**

Subject CO-T-0001A & 1B		Calc No. CO-T-0001A & 1B	Rev. No. 0	Sheet No. 19 of 19
Originator G.D. Augustine	Date 1-28-94	Reviewed by <i>[Signature]</i>		Date 1-28-94

The following values have already been defined in the GIP part of the analysis:

Weight = W := 2204475 lbs H_{in} := 240

4% damped acceleration = acc4% := 0.51g ZPA := 0.1g

From page 2-7 of Reference 10 the overturning moment is defined as follows:

$$M := \sqrt{(M_s \cdot H_s \cdot \text{acc_SSE_05})^2 + (M_f \cdot H_f \cdot \text{acc4\%})^2 + (M_r \cdot H_r - M_f \cdot H_f)^2 \cdot \text{ZPA}^2 \cdot W \cdot H}$$

$$M = 53960924 \text{ lb-in}$$

Per Step 17 of the GIP evaluation, the tank has an overturning moment capacity of 56,084,244 lb-in. As the capacity exceeds the demand, the tank is seismically adequate and the OUTLIER is adequately resolved.



CONCLUSION: The Condensate Water Storage Tank is seismically verified.

January 21, 1994

To: Rick Augustine

From: Phil Hashimoto

I have reviewed your A-46 evaluation of the Three Mile Island condensate storage tank. I concur with the technical approach adopted, including that used for outlier resolution, and have verified that the results obtained are correct.



CO-T-0001A