

GPU NUCLEAR

B/A No. 128108

W/O No. 95-552A-52108

SEISMIC QUALIFICATION

No. SQ - T1 - EG-T-0001B-1

REVISION 0

COMPONENT: EG-T-0001B-1

SUBCOMPONENT(S): \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_


Sheet 1 of 5  
*S.M. 2/12/95* ADDED SHEET AT OFS *RAD 7/14/95*

EVALUATED BY: PA Lott

DATE 17 Sept 93

EVALUATED BY: JCW

DATE 9-17-93



DOCUMENT NO.

SQ-T1-EG-T-000B-1

TITLE

EDG 1B AIR START 1 RESERVOIR

REV	SUMMARY OF CHANGE	APPROVAL	DATE
0	<p>9/17/93 COMPLETION DATE OF ORIGINAL SQ-PACKAGE</p> <p>7/14/95 REVISED SQ-PACKAGE TO REFLECT NEW DIESEL GENERATOR RESPONSE SPECTRA (SEE EQE CALC# 42105-C-004, FIG 2) ADDED ATTACHMENT A (2 SHEETS)</p>	<p>RASVOTEUS</p> <p>S.M. Lazorchak</p> <p>S.M. Lazorchak</p> <p><i>[Signature]</i></p>	<p>14 JULY 95</p> <p>12/12/95</p> <p>4/2/96</p>



N0036 (03-90)

### SOUG DATA FILE INDEX

COMPONENT TAG NUMBER EG-T-0001B1

DESCRIPTION EDG 1B AIR START 1 RESERVOIR

► DOCUMENTS

NUMBERS/STATUS

- SEWS \_\_\_\_\_ ✓
- GMS-2 (TECHNICAL FUNCTIONS DATA SURVEY) \_\_\_\_\_ ✓
- PHYSICAL DRAWING/ASSEMBLY DRAWING PT-8027X (A0266) ✓
- VENDOR CATALOG/DATA/INSTRUCTION MANUAL \_\_\_\_\_
- INSTALLATION SPECIFICATION \_\_\_\_\_
- SEISMIC ANALYSIS/TEST REPORTS/CALCS \_\_\_\_\_
- CONCRETE OR PAD DRAWINGS, SPECS, BLOCK WALLS \_\_\_\_\_
- EMBEDDED STEEL DRAWINGS \_\_\_\_\_
- ANCHORAGE DRAWING/DETAILS/AIDS 421-401 ✓
- FIELD CHANGE DOCS/MNCR'S \_\_\_\_\_

OTHER 1E-157-02-001

RL 4/22/93  
signature

► GENERIC ISSUES

- \_\_\_ POTENTIAL OUTLIER
- \_\_\_ BASE PLATE PLUG WELDS
- \_\_\_ OTHERS

► DISPOSITION

- \_\_\_ NEED MORE DATA
- \_\_\_ KNOWN OUTLIER
- \_\_\_ SEISMIC DATA ACCEPTABLE, CONFIRMATION WALKDOWN ONLY

ANCHORAGE CALCULATIONS: \_\_\_ EXIST \_\_\_ PERFORM IN FIELD

COMMENTS VERIFY ANCHORAGE - PAD DETAILS HAVE NOT BEEN FOUND.  
PAD MAY NOT BE REINFORCED OR ATTACHED TO CONCRETE.

READY FOR SOUG WALKDOWN

RL  
Seismic Capacity Engineer (SCE)

SCREENING EVALUATION WORK SHEET (SEWS)

Equip. ID No. EG-T-0001B-1 Equip. Class 21 - Tanks and Heat Exchangers

Equipment Description EDG 1B AIR START 1 RESERVOIR

Location: Bldg. DG Floor El. 305 Room, Row/Col "B" DG BLDG NR DIESEL

Manufacturer, Model, Etc. (optional) MORRISON BROS. CO.

SHELL CAPACITY VS DEMAND

Buckling capacity of shell of large, flat-bottom, vertical tank is equal to or greater than demand:

Y N U (N/A)

ANCHOR BOLTS AND EMBEDMENT

Capacity of anchor bolts and their embedments is equal to or greater than demand:

~~Y~~ (N) U <sup>2/3/95</sup> N/A COMMENT 1

CONNECTION BETWEEN ANCHOR BOLTS AND SHELL

Capacity of connections between the anchor bolts and the tank shell is equal to or greater than the demand:

(Y) N U N/A

FLEXIBILITY OF ATTACHED PIPING

Attached piping has adequate flexibility to accommodate motion of large, flat-bottom, vertical tank:

\* (Y) N U N/A COMMENT 2

TANK FOUNDATION

Ring-type foundation is not used to support large, flat-bottom, vertical tank:

Y N U (N/A)

IS EQUIPMENT SEISMICALLY ADEQUATE?

<sup>2/3/95</sup>  
~~Y~~ (N) U

Equip. ID No. EG-T-0001B-1 Equip. Class 21 - Tanks and Heat Exchangers

Equipment Description EDG 1B AIR START 1 RESERVOIR

COMMENTS


1. TANK & ITS SUPPORTING SKIRT FORM A RIGID ASSEMBLY WHICH IS STABLE UNDER THE LOW ACC. LOADS THAT IT SEES. THE LOW ACCELERATIONS ALSO FORM THE BASIS FOR CONCRETE PAD ACCEPTABILITY & THE LOW FORCES ON THE TANK SUPPORTING COLS. SEE CALC: EG-T-0001A-1-SEW1 TANK UNSTABLE UNDER WIND LOADS SEE EDGE CALC #22105-C-001. OUTLIER RAJ 2/4/95 STG 10/9/95
2. TANK IS NOT FLAT-BOTTOMED & ATTACHED PIPING IS JUDGED TO BE FLEXIBLE ENOUGH TO ACCOMMODATE TANK MOVEMENTS.
3. ALL <sup>FOUR</sup> BOLTS MET GIP TORQUE TEST REQD

PHOTO: 15 SEPT 93 'B' FRAMES: 9, 10, 11



Evaluated by: RAJ  
JWS

Date: 17 SEPT 93  
9-17-93

05-15-97 09:02:54



EG-T-1B1  
EG-T-1B2



EG-T-1B  
WREST ANCHOR  
(MOST SHIMS)

←  
EG-T-1B3  
SHIMMED ANGLE  
BRACKET



Exhibit 5-1

OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

1. OUTLIER IDENTIFICATION, DESCRIPTION, AND LOCATION

Equipment ID Number EG-F-0001B-4 Equipment Class 21  
 Equipment Location: Building DG Floor Elevation 305'  
 Room or Row/Column - Base Elevation 305'  
 Equipment Description EDGE 15 A&E START 1 RETARDER

2. OUTLIER ISSUE DEFINITION

a. Identify all the screening guidelines which are not met.  
 (Check more than one if several guidelines could not be satisfied.)

<u>Mechanical and Electrical Equipment</u>		<u>Tanks and Heat Exchangers</u>	
Capacity vs. Demand	---	Shell Buckling <sup>1</sup>	---
Caveats	---	Anchor Bolts and Embedment	---
Anchorage	X	Anchorage Connections	---
Seismic Interaction	---	Flexibility of Attached Piping <sup>1</sup>	---
Other	---	Other	---
<u>Essential Relays</u>		<u>Cable and Conduit Raceways</u>	
Capacity vs. Demand	---	Inclusion Rules	---
Mounting, Type, Location	---	Other Seismic Performance Concerns	---
Other	---	Limited Analytical Review	---
		Other	---

<sup>1</sup> Shell buckling and flexibility of attached piping only apply to large, flat-bottom, vertical tanks.

b. Describe all the reasons for the outlier (i.e., if all the listed outlier issues were resolved, then the signatories would consider this item of equipment to be verified for seismic adequacy):

TANK HAS INSUFFICIENT FB AGAINST OVERTURNING OR SLIDING  
SINCE CONCRETE FOUNDATION PAD IS NOT INTEGRAL WITH FLOOR.

Exhibit 5-1 (Cont'd)

OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

Equipment ID Number EG-T-0001B-1

3. PROPOSED METHOD OF OUTLIER RESOLUTION (OPTIONAL)

a. Define proposed method(s) for resolving outlier.

1. PROVIDE UPPER SUPPORT AT HORIZONTAL BAND AROUND TANK

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

b. Provide information needed to implement proposed method(s) for resolving outlier (e.g., estimate of fundamental frequency).

No 1 - Outlier resolved per Attachment B & C  
of SQ-T1-EG-0001A-1 S.M. Lazorchak 12/12/95

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

4. CERTIFICATION:

The information on this OSVS is, to the best of our knowledge and belief, correct and accurate, and resolution of the outlier issues listed on the previous page will satisfy the requirements for this item of equipment to be verified for seismic adequacy:

Approved by: (For Equipment Classes #0 - #22, all the Seismic Capability Engineers on the Seismic Review Team (SRT) should sign; there should be at least two on the SRT. One signatory should be a licensed professional engineer. For Relays, the Lead Relay Reviewer should sign.)

<u>RA SVOTELIS</u>	<u>RA Litz</u>	<u>7/14/95</u>
Print or Type Name	Signature	Date
<u>Stephen M. Lazorchak</u>	<u>S.M. Lazorchak</u>	<u>12/12/95</u>
Print or Type Name	Signature	Date
_____ Print or Type Name	_____ Signature	_____ Date