

GPU NUCLEAR

B/A No. 128108

W/O No. 95-552A-52108

SEISMIC QUALIFICATION

No. SQ - T1 - IA - T - 0019

REVISION 0

COMPONENT: IA-T-19

SUBCOMPONENT(S): \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Sheet 1 of 4

EVALUATED BY: [Signature]

DATE 10-28-93

EVALUATED BY: [Signature]

DATE 10-28-93

Status Y N U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 2

Equip. ID No. IA-T-0019 Equip. Class 21 - Tanks and Heat Exchangers

Equipment Description AIR ACCUMULATOR FOR FW-V-16B

Location: Bldg. IB Floor El. 322 Room, Row/Col ON WALL EAST OF VALVE

Manufacturer, Model, Etc. (optional) DAYTON ELECTRIC MFG CO.

SHELL CAPACITY VS DEMAND

Buckling capacity of shell of large, flat-bottom, vertical tank is equal to or greater than demand:

Y N U N/A

ANCHOR BOLTS AND EMBEDMENT

Capacity of anchor bolts and their embedments is equal to or greater than demand:

Y N U N/A  
COMMENT 1

CONNECTION BETWEEN ANCHOR BOLTS AND SHELL

Capacity of connections between the anchor bolts and the tank shell is equal to or greater than the demand:

Y N U N/A  
COMMENT 1

FLEXIBILITY OF ATTACHED PIPING

Attached piping has adequate flexibility to accommodate motion of large, flat-bottom, vertical tank:

Y N U N/A

TANK FOUNDATION

Ring-type foundation is not used to support large, flat-bottom, vertical tank:

Y N U N/A

IS EQUIPMENT SEISMICALLY ADEQUATE?

Y N U

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 2 of 2

Equip. ID No. IA-T-0019 Equip. Class 21 - Tanks and Heat ExchangersEquipment Description AIR ACCUMULATOR FOR FW-V-16BCOMMENTS

1. TANK IS ANCHORED TO CONCRETE WALL VIA 2 - P1000 UNISTRUTS, (2) 1/2" HILTI KWIK BOLTS EACH. BOLTED TO UNISTRUT WITH (4) 1/2"  $\phi$  CAP SCREWS & CHANNEL NUTS. REF. DRAWING ID-422-44-1005, P.O. ANCHORAGE IS JUDGED ADEQUATE DUE TO SMALL APPLIED LOADS

Evaluated by:

D. H. Apple  
G. J. P.

Date:

10-28-9310-28-93



05-15-97 08:24:09

4 of 4

SC-71-023

SC-71-023

