

CALCULATION TITLE PAGE

35

CLIENT & PROJECT TEXAS UTILITIES GENERATING CO. / CPS&S UNITS 1 AND 2				PAGE 1 OF 498 Including 10 ATTACHMENTS			
CALCULATION TITLE (INDICATIVE OF THE OBJECTIVE): FATIGUE CYCLE DETERMINATION FOR PIPE SUPPORTS				<input checked="" type="checkbox"/> NUCLEAR SAFETY RELATED <input type="checkbox"/> NON-NUCLEAR SAFETY RELATED			
CALCULATION IDENTIFICATION NUMBER				OPTIONAL WORK PACKAGE NO.			
J.O. OR W.O. NO.	DIVISION & GROUP	CURRENT CALC. NO.	OPTIMAL TASK CODE				
15454	MP(C)	GEN X 103					
PREPARER(S)/DATE(S)	REVIEWER(S)/DATE(S)	INDEPENDENT REVIEWER(S)/DATE(S)	REV. NO. OR NEW CALC. NO.	SUPERSEDES CALC. NO. OR REV. NO.	CONFIRMATION REQUIRED (X)		
Shil Lee 9/12/86 J. Liaw 9/13/86 M. H. Yu 9/13/86	J. Liaw 9/13/86 Shil Lee 9/13/86 J. Liaw 9/13/86	Chengjai Lin 9/15/86	REV. 0		YES	NO	✓ SEE PAGES 11, 15 ATT # 6, 8
Yan-jing Wu 9-16-86							
DISTRIBUTION -							
GROUP	NAME & LOCATION	COPY SENT (X)		GROUP	NAME & LOCATION	COPY SENT (X)	
RECORDS MGT. FILES (OR FIRE FILE IF NONE)		0 1 2				0 2 2	
ORIGINAL TO PROJECT FILE	SR. CLERK - CHOC 4Y						

CALCULATION SHEET

CALCULATION IDENTIFICATION NUMBER				PAGE <u>2</u>
JO. OR WO. NO. 15454	DIVISION & GROUP NP(C)	CALCULATION NO. GENX-103	OPTIONAL TASK CODE	

REF.

REV. 0

REVISION STATUS TABLE

REV NO.	PAGE NO.	DESCRIPTION / REASON

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>3</u>
J.O. OR W.O. NO. 15454	DIVISION & GROUP NP(C)	CALCULATION NO. GENX-103 REV. 0	OPTIONAL TASK CODE	

TABLE OF CONTENTS

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

<u>ITEM</u>	<u>PAGE</u>
TITLE PAGE	1
REVISION STATUS TABLE	2
TABLE OF CONTENTS	3
OBJECTIVE	5
ASSUMPTIONS	6
ANALYSIS	7
REFERENCES	11
CONCLUSIONS	16
SUMMARY	16A
ATTACHMENT # 1 - FLUID TRANSIENT CYCLE DETERMINATION	2 1/2 pages
ATTACHMENT # 2 - SUMMARY OF THERMAL CYCLES FOR CHEMICAL & VOLUME CONTROL FROM CALCULATION 15616 - NP(C) - GENX-025 REV. 1	2 pages
ATTACHMENT # 3 - NC-3611.2	1 page
ATTACHMENT # 4 - COMPUTER OUTPUT	234 pages
ATTACHMENT # 5 - ASME PAPER "SPECTRUM METHOD FOR EQUIPMENT FATIGUE EVALUATION".	6 pages
ATTACHMENT # 6 - VERIFICATION OF FFT PROGRAM	1 page
ATTACHMENT # 7 - VERIFICATION OF PRE FFT PROGRAM	5 pages

STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATION SHEET

A 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>4</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
15454	NP(C)	GENX-103		

REV. 0

TABLE OF CONTENTS (CONTINUE)

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

<u>ITEM</u>	<u>PAGE</u>
ATT# 8 - VERIFICATION OF FLUID TRANSIENT CYCLES CALCULATION PROGRAM	1 page
ATT# 9 - I.O.C. FOR REVISED FLUID TRANSIENT OCCURRENCES	8 pages
ATT# 10 - DETAIL CALCULATION FOR TOTAL EQUIVALENT STRESS CYCLES DUE TO FLUID TRANSIENT AND SEISMIC EVENTS FOR STRESS PROBLEMS MS-2-023A & MS-1-023D	9 pages

Section	Preparer	Checker
Page 3-16 A	J. Liaw	M.H. Yu
Attachment #1 Page 13, 171 thru 201	M.H. Yu	J. Liaw
Attachment #10	M.H. Yu	J. Liaw

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010.85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>5</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
15454	NP(C)	GENX-103 REV. D		

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

OBJECTIVE: TO DETERMINE FATIGUE CYCLES FOR CPSES PIPE SUPPORTS TO COMPLY WITH THE ASME SECTION III NF-3130 CODE REQUIREMENTS (DESIGN RULES FOR LINEAR TYPE SUPPORTS). THE RULES FOR DESIGNING LINEAR TYPE SUPPORTS GIVEN IN NF-3132.3 ARE ESSENTIALLY THE SAME AS THOSE GIVEN IN NF-3230 FOR LINEAR ELASTIC ANALYSIS, EXCEPT THAT THE MAXIMUM RANGE OF STRESS, NAMELY THE DIFFERENCE BETWEEN THE MINIMUM AND MAXIMUM VALUE OF THE STRESS THROUGHOUT EACH CYCLE AND THE FREQUENCY WITH WHICH THE SUPPORT WILL BE SUBJECTED TO THIS RANGE OF STRESS, SHALL BE TAKEN INTO CONSIDERATION WHEN SO STIPULATED BY THE DESIGN SPECIFICATION (NA-3250). THE THEORY OF FAILURE USED IN THE RULES FOR THE DESIGN OF LINEAR TYPE SUPPORTS IS THE MAXIMUM STRESS THEORY. IN THE MAXIMUM STRESS THEORY, THE CONTROLLING STRESS IS THE MAXIMUM PRINCIPAL STRESS. SUPPORT MEMBERS AND THEIR CONNECTIONS SUBJECT TO A NUMBER OF CYCLES ($> 20,000$) OF FATIGUE LOADING RESULTING IN DAMAGE AS DEFINED IN NF-3331.2, SHALL BE PROPORTIONED TO SATISFY THE STRESS RANGE LIMITATIONS.

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

A 5010 88

CALCULATION IDENTIFICATION NUMBER				PAGE <u>6</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
15424	NP(C)	GENX-103		

REV. 0

ASSUMPTIONS

- 1.) THE MAX. 30 CYCLES PER OCCURRENCE ARE USED FOR FLUID TRANSIENT CALCULATIONS OTHER THAN CHEMICAL AND VOLUME CONTROL AND MAIN STEAM SYSTEMS. THE 30 CYCLES PER OCCURRENCE WERE OBTAINED BY SWEEPING THE SINGLE DEGREE OF FREEDOM SYSTEM AT THE MAJOR FLUID TRANSIENT FREQUENCIES FOUND IN THE FORCING FUNCTIONS.
- 2.) THE 720 CYCLES FOR SEISMIC EVENT ARE ASSUMED. THIS IS BASED ON FSAR 3.7B.3.2 6 EARTHQUAKES AND 120 CYCLES PER EARTHQUAKE.
- 3.) SINGLE DEGREE OF FREEDOM MODEL IS USED TO PREDICT THE POSSIBLE HIGHEST FLUID TRANSIENT RESPONSE CYCLES (REF 5)
- 4.) UNIT 2 ASSESSMENT ON THERMAL CYCLES (REF. 4) IS APPLICABLE FOR UNIT 1 PROBLEMS.
- 5.) DYNAMIC STRESS CYCLES OBTAINED FROM FLUID TRANSIENT CALCULATIONS FOR UNIT 1 PROBLEMS IS APPLICABLE TO UNIT 2 PROBLEMS OF SAME SYSTEM.

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 86

CALCULATION IDENTIFICATION NUMBER				PAGE <u>7</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
15454	NP(C)	GENX-03		

REV. 0

ANALYSIS : THE TOTAL SERVICE CYCLES OF A PIPE SUPPORT OVER 40 YEARS OF PLANT LIFE IS OBTAINED BY COMBINING THE TOTAL EQUIVALENT CYCLES RESULTING FROM THE FLUID TRANSIENT EVENT AND THE EQUIVALENT SEISMIC TO THE THERMAL CYCLES. TO OBTAIN THE FLUID TRANSIENT EQUIVALENT STRESS CYCLES FROM ANY GIVEN TIME HISTORY MOTION. THE TIME HISTORY IS APPLIED TO SEVERAL SINGLE DEGREE OF FREEDOM SYSTEMS (SDOF), AS BASIC EXCITATION. THE RELATIVE-DISPLACEMENT RESPONSE OF EACH SDOF IS ANALYZED TO YIELD EQUIVALENT STRESS CYCLES. THE COUNTING IS BASED ON CALCULATING HALF OF EACH ALTERNATING PEAK TO PEAK RESPONSE I.E. $U_{1/2}$, $U_{2/2}$, $U_{3/2}$... ETC; AND THEN NORMALIZING EACH OF THESE VALUES TO THE MAXIMUM SUCH RESPONSE USING AN EXPONENT FORMULA. THE EXPONENT FORMULA TO CALCULATE THE EQUIVALENT CYCLES N_{EQ} IS AS FOLLOWS

$$N_{EQ} = \sum_{a=1}^n \left(\frac{U_{a/2}}{U_{max/2}} \right)^P \quad (1)$$

WHERE n REPRESENTS THE TOTAL ALTERNATING CYCLES IN THE RESPONSE, U_{max} IS THE MAXIMUM OF ANY PEAK TO PEAK RESPONSE AND P IS THE EXPONENT

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>8</u>
J.O. OR W.O. NO. 15454	DIVISION & GROUP NP(C)	CALCULATION NO. GENX-103	OPTIONAL TASK CODE	

REV. 0

ANALYSIS (CONTINUED) :




FIGURE 1

ONE OF THE IMPORTANT PARAMETER IN EQUATION (1) IS P . THIS VALUE DEPENDS ON THE PORTION OF THE S-N FATIGUE CURVE WHERE S_i , $i = 1 \dots n$ LOCATE. A SIMPLE AND CONSERVATIVE METHOD IS TO USE THE SLOPE OF S-N CURVE AT THE HIGHEST STRESS LEVEL RATHER THAN USING THAT OF THE CORD BECAUSE OF THE CONCAVITY OF THE CURVE. THE RESULTS OF A STUDY OF THREE TYPES OF MATERIALS (1) CARBON, LOW ALLOY, AND HIGH TENSILE STEELS, (2) AUSTENITIC STEELS, NICKEL-CHROMIUM-IRON ALLOY, NICKEL-IRON-CHROMIUM ALLOY, AND NICKEL-COPPER ALLOY. AND (3) HIGH STRENGTH STEEL BOLTING, INDICATE A CONSERVATIVE VALUE OF $P=2$ CAN BE USED. THE VALUE OF $P=2$ CORRESPONDS TO A STRESS LEVEL OF ABOUT 550 KSI AND SHOULD ENVELOP THE MAXIMUM STRESS IN AN ENGINEERED COMPONENT. THE EQUIVALENT THERMAL CYCLES IS DETERMINED FROM THE ASME NC-3611 PROCEDURE. IF THE RANGE OF TEMPERATURE CHANGE VARIES, EQUIVALENT FULL TEMPERATURE CYCLES MAY BE COMPUTED AS FOLLOWS:

STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATION SHEET

A 5010 65

CALCULATION IDENTIFICATION NUMBER				PAGE <u>9</u>
J.O. OR W.O. NO. 15454	DIVISION & GROUP NP(C)	CALCULATION NO. GENX403 REV. D	OPTIONAL TASK CODE	

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

ANALYSIS (CONTINUED) :

$$N = N_E + Y_1^5 N_1 + Y_2^5 N_2 + \dots + Y_n^5 N_n$$

WHERE N_E = NUMBER OF CYCLES AT FULL TEMPERATURE CHANGE ΔT_E , FOR WHICH EXPANSION STRESS, S_E HAS BEEN CALCULATED

N_1, N_2, \dots, N_n = NUMBER OF CYCLE AT LESSER TEMPERATURE CHANGES, $\Delta T_1, \Delta T_2, \dots, \Delta T_n$

$Y_1, Y_2, \dots, Y_n = (\Delta T_1)/(\Delta T_E), (\Delta T_2)/(\Delta T_E), \dots, (\Delta T_n)/(\Delta T_E)$ = THE RATIO OF ANY LESSER TEMPERATURE CYCLES FOR WHICH THE EXPANSION STRESS S_E HAS BEEN CALCULATED.

THE OPERATING CONDITIONS AND THE ASSOCIATED NUMBER OF OCCURRENCES ARE OBTAINED FROM PRDP & SID DOCUMENTS.

THE PLANT HAS 200 START UP / SHOT DOWN CYCLES.

STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>10</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
15454	NP(CC)	GENX-103, REV 0		

ANALYSIS (CONTINUED)

THE DETAIL METHOD OF CALCULATING EQUIVALENT
 FROM ATT #5
 DYNAMIC CYCLES, ILLUSTRATED BELOW :

$$N = N_s + \frac{P}{C} \left(\frac{RT_c}{R} \right)^2 (NT_c - N_s)$$

WHERE

N = COMBINED DYNAMIC CYCLES

N_s = SEISMIC CYCLES

P = 2.0 , RT_c = CTH FLUID TRANSIENT LOAD

R = MAX. COMBINED FLUID TRANSIENT & SEISMIC LOAD

NT_c = CTH FLUID TRANSIENT CYCLES,

USED TO COMBINE DYNAMIC CYCLES (FLUID
 TRANSIENT AND SEISMIC CYCLES)

SINCE THERMAL AND DYNAMIC LOADS ARE ADDED DIRECTLY
 TO BE CONSIDERED AS A TOTAL LOAD FOR SUPPORT
 DESIGN, THE ABOVE MENTIONED DYNAMIC CYCLE
 COMBINATION AND ANALYSIS IS CONSIDERED
 VERY CONSERVATIVE.

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>11</u>
J.O. OR W.O. NO. 15454	DIVISION & GROUP NP(C)	CALCULATION NO. GENX-103	OPTIONAL TASK CODE	

REV. 0

REFERENCES

1. ASME BOILER AND PRESSURE VESSEL CODE, SECTION III, DIVISION I, NUCLEAR POWER PLANT COMPONENTS, 1974 EDITION, SUBSECTION C AND D, F INCLUDING WINTER 1974 ADDENDA
2. PROJECT PROCEDURE CPPP-10, REV. 1 DATED 4-1-86, PROCEDURE FOR REVIEW OF PLANT OPERATING MODE CONDITIONS.
3. FSAR - FINAL SAFETY ANALYSIS REPORT FOR CPSES, REV. 2-27-78, INCLUDING UPDATE AND ALL AMENDMENTS AS OF 8-7-86.
4. S&W CALCULATION 15616 - NP(C) - GENX-025 REV. 1 TITLE "EQUIVALENT NUMBER OF THERMAL STRESS CYCLES AND STRESS RANGE REDUCTION FACTOR FOR PIPING REGIONS, PER PROBLEM, OF THE CHEMICAL AND VOLUME CONTROL SYSTEM (CS) OF CPSES UNIT 2 AND COMMON PIPING" DATED 9-15-86
- *5. 15454 - NP(C) - GENX-109 REV. 0 "VERIFICATION OF FLUID TRANSIENT CYCLES CALCULATION PROGRAM".
6. SYSTEM IDENTIFICATION DOCUMENTS - CPSES UNIT 1

SYSTEM	REV.	DATED
6.1 SID - AF	2	6-16-86
6.2 SID - BR	2	6-9-86
6.3 SID - CA	2	6-10-86
6.4 SID - CC	2	6-13-86
6.5 SID - CH	2	6-11-86
6.6 SID - CI	2	6-12-86

* SEE ATT# 8 (CONFIRMATION REQUIRED)

CALCULATION SHEET

▲ 5010 86

CALCULATION IDENTIFICATION NUMBER				PAGE <u>12</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
15454	NP(C)	GENX-103 REV. 0		

REFERENCE (CONTINUED)

6. SYSTEM IDENTIFICATION DOCUMENTS - CPSES UNIT 1

SYSTEM	REV.	DATED
6.7 SID - CO	NOT REVIEWED	
6.8 SID - CS	3	8-4-86
6.9 SID - CT	2	6-5-86
6.10 SID - DD	2	6-12-86
6.11 SID - DO	2	6-11-86
6.12 SID - EW	2	6-11-86
6.13 SID - GH	NOT REVIEWED	
6.14 SID - HA	NOT REVIEWED	
6.15 SID - MS	3	7-23-86
6.16 SID - PS *	0	7-10-86
6.17 SID - RC	2	6-12-86
6.18 SID - RH	4	6-11-86
6.19 SID - RM *	0	8-29-86
6.20 SID - SB	NOT REVIEWED	
6.21 SID - SF	2	6-6-86
6.22 SID - SI	3	6-12-86
6.23 SID - SW	2	6-12-86
6.24 SID - VA	2	6-12-86
SID - VAGH)	2	6-6-86
6.25 SID - VD	2	6-9-86
6.26 SID - WP	2	6-9-86

* FOR UNIT 2 ONLY

STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATION SHEET

A 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>13</u>
P.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
15454	NP(C)	GENX403 REV. 0		

REFERENCE (CONTINUED)

6. SYSTEM IDENTIFICATION DOCUMENTS - CPSES UNIT 1

SYSTEM	REV.	DATED
--------	------	-------

6.27 SID-FP	1	6/10/86
-------------	---	---------

7. S & W FLUID TRANSIENT CALCULATIONS.

7.1 15454 - NP(B) - F01 REV. 1 DATED 6/14/86

PUMP START (WATER SLUG IMPACT) (TRAIN A & B)

7.2 15454 - NP(B) - F03 REV. 0 DATED 2/5/86

PUMP START (WATER SLUG IMPACT) (TRAIN A & B)

7.3 15454 - NP(B) - F02 REV. 1 DATED 6/24/86

PUMP TRIP (CHECK VALVE SLAM)

7.4 15454 - NP(B) - F04 REV. 0 DATED 10/29/85

RELIEF VALVE DISCHARGE B708A, B

7.5 15454 - NP(B) - F06 REV. 1 DATED 1-10-86

PUMP TRIP AND PUMP START (TRAIN A & B)

7.6 15454 - NP(B) - F19 REV. 0 DATED 2-3-86

PUMP TRIP AND PUMP START (TRAIN A & B)

7.7 15454 - NP(B) - F23 REV. 0 DATED 7-22-86

PUMP START WITH AIR COLUMN

7.8 15454 - NP(B) - F05 REV. 0 DATED 12-19-85

RELIEF VALVE DISCHARGE B117

7.9 15454 - NP(B) - F07 REV. 0 DATED 12-10-85

RELIEF VALVE DISCHARGE B118

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

4 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>14</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
15454	NP(C)	GENX103 REV. 0		

REFERENCE (CONTINUED)

7. S & W FLUID TRANSIENT CALCULATIONS (CONTINUED)

- 7.10 15454 - NP(B) - F08 REV. 1 DATED 1-25-86
RELIEF VALVE DISCHARGE B120
- 7.11 15454 - NP(B) - F09 REV. 0 DATED 12-10-85
RELIEF VALVE DISCHARGE B119
- 7.12 15454 - NP(B) - F15 REV. 0 DATED 1-10-86
RELIEF VALVE DISCHARGE B121
- 7.13 15454 - NP(B) - F16 REV. 0 DATED 1-10-86
RELIEF VALVE DISCHARGE B123
- 7.14 15454 - NP(B) - F17 REV. 0 DATED 12-10-85
RELIEF VALVE DISCHARGE B510A, B
- 7.15 15454 - NP(B) - F10 REV. 1 DATED 6-23-86
MAIN STEAM TURBINE TRIP
- 7.16 15454 - NP(B) - F18 REV. 0 DATED 2-12-86
FEEDPUMP TURBINE TRIP
- 7.17 15454 - NP(B) - F11 REV. 0 DATED 1-23-86
AUX FEEDPUMP TURBINE TRIP
- 7.18 15454 - NP(B) - F12 REV. 1 DATED 8-6-86
S/RV DISCHARGE
- 7.19 15454 - NP(B) - F20 REV. - DATED 6-13-86 **
PIPE BREAK (VALVE SLAM)

** PRELIMINARY RESULTS BASED ON IOM (CONFIRMATION REQUIRED)

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>15</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
15454	NP(C)	GENX 103 REV. 0		

REFERENCE (CONTINUED)

7. S & W FLUID TRANSIENT CALCULATIONS (CONTINUED)

7.20 15454 - NP(B) - F24 REV. 0 DATED 7-7-86

3/4" x 1" THERMAL AND AIR RELIEF VALVE OPENING

7.21 15454 - NP(B) - F13 REV. 0 DATED 3-14-86

PUMP TRIP (CHECK VALVE SLAM)

7.22 15454 - NP(B) - F21 REV. - DATED 6-23-86**

PUMP TRIP (CHECK VALVE SLAM)

7.23 15454 - NP(B) - F14 REV. 0 DATED 5-1-86

PRESSURIZER S/RV DISCHARGE

7.24 15454 - NP(B) - F22 REV. 0 DATED 7-10-86

RELIEF VALVE DISCHARGE 8634

7.25⁺ 15454 - NP(B) - F25 REV. 0 DATED 7-22-86

OPENING AND CLOSING OF ISOLATION AND CONTROL VALVES

7.26⁺ 15454 - NP(B) - F26 REV. 0 DATED 7-23-86

CLOSURE OF THE SCREEN WASH PUMP SUCTION CHECK VALVES.

7.27⁺ 15454 - NP(B) - F27 REV. 0 DATED 7-29-86

CLOSING OF ISOLATION VALVE IN CC SYSTEM

* B. 15454-NP(C)-GENX-108 REV. 0 "VERIFICATION OF FFT PROGRAM".

** PRELIMINARY RESULTS BASED ON IOM (CONFIRMATION REQUIRED)

+ FLUID TRANSIENT LOADS ARE INSIGNIFICANT.

* SEE ATT # 6 (CONFIRMATION REQUIRED)

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

A 5010 05

CALCULATION IDENTIFICATION NUMBER				PAGE 16
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
15454	NP(C)	GENX-103		
REV. 0				
<u>CONCLUSION</u>				
<p>THE SUPPORT ENGINEERING APPLYS THE THERMAL AND DYNAMIC LOADS TO SUPPORTS SIMULTANEOUSLY FOR CAPACITY CHECK IN LOAD CONDITION 3, THEREFORE THE FATIGUE CYCLES DETERMINATION ^{CAN BE CONSERVATIVELY} BASED ON ENVELOPED CYCLES OF THE THERMAL, FLUID TRANSIENT AND SEISMIC CYCLES AS SHOWN ON SUMMARY SECTION. THE THERMAL CYCLES FOR ALL SYSTEMS EXCEPT CHEMICAL & VOLUME CONTROL ARE UNDER 7000. THE DETAIL THERMAL CYCLE ANALYSIS FOR CHEMICAL & VOLUME CONTROL IS SHOWN IN CALCULATION 15454-NP(C)-GENX-025 REV. 1 (REF. 4) AND THE CYCLES WERE PROVED TO BE UNDER 20000. THE FLUID TRANSIENT CYCLES FOR ALL SYSTEMS EXCEPT STRESS PROBLEMS NO 23A, B, C & D IN MAIN STEAM SYSTEM ARE UNDER 16000. THE DETAIL FLUID TRANSIENT CYCLES ANALYSIS FOR STRESS PROBLEMS 23A, 23B, 23C & 23D IS SHOWN IN ATTACHMENT # 10 AND THE CYCLES WERE PROVED TO BE UNDER 20,000. OVERALL ALL THE SYSTEMS OF SUPPORT FATIGUE CYCLES ARE UNDER 20,000. AND THEREFORE, NO HIGH CYCLE FATIGUE EVALUATION AS SPECIFIED IN NF 3132.3 IS REQUIRED FOR BOTH UNIT 1 & UNIT 2 SUPPORTS.</p>				

CALCULATION SHEET

▲ 5010.85

		CALCULATION IDENTIFICATION NUMBER				PAGE 16A	
J.O. OR W.O. NO.		DIVISION & GROUP		CALCULATION NO.		OPTIONAL TASK CODE	
15454		NPCO		GENX103 REV. D			
SYSTEM DESIGNATION	SYSTEM DESCRIPTION	ESTIMATED THERMAL CYCLE	ESTIMATED FLUID TRANSIENT CYCLE	ESTIMATED SEISMIC CYCLE	ENVELOPED MAXIMUM ESTIMATED FATIGUE CYCLE	ASME NF-3000 ALLOWABLE CYCLE	REMARK
DO	DIESEL GENERATOR FUEL OIL	7000	N/A	720	7000	20000	CYCLES SHOWN ON SID ARE NOT THER. CYCLES
FW	STEAM GENERATOR FEED WATER	7000	6000	720	7000		
GH	WASTE PROCESSING - GAS	7000	N/A	720	7000		
HA	HYDROGEN ANALYZING	7000	N/A	720	7000		
MS	MAIN STEAM	7000	equiv. dyn. cycles < 20000		20000		FOR F.T. DETAIL, SEE ATTACHMENT
PS	PROCESS SAMPLING	7000	N/A	720	7000		
RC	REACTOR COOLANT	7000	1200	720	7000		

SUMMARY OF FATIGUE CYCLE DETERMINATION (CONTINUED)

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

CALCULATION SHEET

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER								PAGE <u>17</u>
J.O. OR W.O. NO.	DIVISION & GROUP		CALCULATION NO.		OPTIONAL TASK CODE			
15454	NP(S)		GENX 103 REV 0					
SYSTEM DESIGNATION	SYSTEM DESCRIPTION	ESTIMATED THERMAL CYCLE	ESTIMATED FLUID TRANSGIENT CYCLE	ESTIMATED SEISMIC CYCLE	ENVELOPED MAXIMUM ESTIMATED FATIGUE CYCLE	A.S.M.E NF-9000 ALLOWABLE CYCLE	REMARK	
AF	AUXILIARY FEEDWATER	7000	3000	720	7000	20000		
BR	BORON RECYCLE	7000	1200	720	7000			
CA	SERVICE AIR	7000	N/A	720	7000			
CC	COMPONENT COOLING WATER	7000	N/A	720	7000			
CH	CHILLED WATER	7000	N/A	720	7000			
CI	INSTRUMENT AIR	7000	N/A	720	7000			
CO	CONDENSATE	7000	N/A	720	7000			
CS	CHEMICAL AND VOLUME CONTROL	12962	1200	720	12962		FOR DET. ON THER. SEE ATT # 2	
CT	CONTAINMENT SPRAY	7000	30	720	7000			
DD	DEMINGERIALIZED AND REACTOR MAKE UP WATER	7000	N/A	720	7000			

SUMMARY OF FATIGUE CYCLE DETERMINATION

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

STONE & WEBSTER ENGINEERING CORPORATION
 CALCULATION SHEET

▲ 5010 85

		CALCULATION IDENTIFICATION NUMBER				PAGE 18	
J.O. OR W.O. NO. 15454		DIVISION & GROUP NP(C)		CALCULATION NO. GENX103 REV. 0		OPTIONAL TASK CODE	
SYSTEM DESIGNATION	SYSTEM DESCRIPTION	ESTIMATED THERMAL CYCLE	ESTIMATED FLUID TRANSIENT CYCLE	ESTIMATED SEISMIC CYCLE	ENVELOPED MAXIMUM ESTIMATED FATIGUE CYCLE	ASME NF-3000 ALLOWABLE CYCLE	REMARK
RH	RESIDUAL HEAT REMOVAL	7000	6000	720	7000	20000	
RM	RADIATION MONITORING	7000	N/A	720	7000		
SB	STEAM GENERATOR BLOWDOWN & CLEAN UP	7000	N/A	720	7000		
SF	SPENT FUEL POOL COOLING & CLEAN UP	7000	N/A	720	7000		
SI	SAFETY INJECTION	7000	30	720	7000		
SW	SERVICE WATER	7000	6000	720	7000		
VA	HYDROGEN PURGE	7000	N/A	720	7000		
VD	VENT AND DRAIN	7000	N/A	720	7000		
WP	WASTE PROCESS LIQUID	7000	N/A	720	7000		
FP	FIRE PROTECTION	7000	N/A	720	7000		
	NOTE N/A = NOT APPLICABLE (NO FLUID TRANSIENT)						

SUMMARY OF FATIGUE CYCLE DETERMINATION (CONTINUED)

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

STONE & WEBSTER ENGINEERING CORPORATION
CALCULATION SHEET

▲ 5010 66

CALCULATION IDENTIFICATION NUMBER			
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE
15454	NP (C)	GENX-103	

PAGE 1 OF 2

Rev. 0

Attachment #1

FLUID TRANSIENT CYCLES DETERMINATION

- AL-1) Introduction of Computer Program PREFFT
and FTRANS I Page 2
- AL-2) Major Forcing Function Frequency (MS and CV)
Page 3 ~ 12
- AL-3) System and Curve No. Table Page 13
- AL-4) Plots of Hydraulic Force and FFT in order
of Table Page 14 ~ 163
- AL-5) Summary of Fluid Transient Cycles Determin
-ation Page 164 ~ 201
- AL-6) Computer Log Page 202 ~ 208
- AL-7) Microfiche Page 209 ~ 212

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

CALCULATION SHEET

▲ 5010 88

CALCULATION IDENTIFICATION NUMBER				PAGE <u>2</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
<u>15454</u>	<u>NP (C)</u>	<u>GENX-103</u>		

Rev. 0

Attachment #1

Introduction of Computer Program PREFFT and FTRANS1

Water Hammer or Steam Hammer computer code generates force-time histories and these data are stored in magnetic tapes. PREFFT (The program name is HAMMER) computer code reads these data from the magnetic tape and rewrite on disk in a format which FTRANS1 computer code is able to read, i.e., PREFFT is a preprocessor for FTRANS1. FTRANS1 converts source hydraulic forces into piping vibrations, i.e., from the time domain to frequency domain using a fast fourier transform method.

CALCULATION SHEET

Attachment #1

A 9010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>3</u>
J.O. OR W.O. NO. 15454	DIVISION & GROUP NP (C)	CALCULATION NO. GENX-103	OPTIONAL TASK CODE	

Rev. 0

system: Main Steam

Calculation No.: F10

Fluid Transient Data Set Name: MS.F1010.CUR32

FFT Job No.: 3286

Job Date: 8/29/86

Major Forcing Function Frequency

0.73, 1.22, 2.2, 3.4, 4.6, 5.6, 6.6, 7.1, 8.5
10.5, 11.0, 15.1, 19.0, 19.5, 22.9

system: Main Steam

Calculation No.: F18

Fluid Transient Data Set Name: MS.F1813.CUR17

FFT Job No.: 3291

Job Date: 8/29/86

Major Forcing Function Frequency

0.488, 1.22, 2.2, 2.93, 4.2, 6.1, 7.6, 8.8, 9.8
10.3, 11.2, 12.9, 20.0, 23.7, 45.9, 56.4

CALCULATION SHEET

Attachment #1

A 9010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>4</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
15454	NP (C)	GENX-103		

Rev.0

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

system: Main Steam

Calculation No.: F11

Fluid Transient Data Set Name: MS.F117.CUR54

FFT Job No.: 3977 Job Date: 09/08/86

Major Forcing Function Frequency

0.977, 3.42, 5.37, 7.32, 7.81, 9.77, 11.7, 13.7
16.6, 18.1, 20.0, 22.0, 24.4, 25.4, 26.4, 29.3
31.7, 32.7, 34.7, 36.1, 37.1, 39.1, 41.5, 43.0, 43.9
44.9, 47.9, 49.3, 51.8, 55.2, 56.6, 58.1

system: Main Steam

Calculation No.: F11

Fluid Transient Data Set Name: MS.F117.CUR10

FFT Job No.: 6408 Job Date: 09/09/86

Major Forcing Function Frequency

0.977, 2.93, 5.37, 7.32, 9.28, 10.7, 11.7, 13.7
15.6, 18.1, 19.5, 21.0, 22.9, 24.4, 25.9, 27.8
29.8

CALCULATION SHEET

Attachment #1

A 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>5</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
15454	NP (C)	GENX-103		
Rev. 0				
1	system: Main Steam			
2	Calculation No.: F11			
3	Fluid Transient Data Set Name: MS.F118.CUR27			
4	FFT Job No.: 3346 Job Date: 8/29/86			
5	Major Forcing Function Frequency			
6	0.977, 2.93, 5.4, 6.8, 7.8, 9.8, 12.2, 14.1,			
7	16.6, 18.6, 27.3, 40.5, 42.0, 44.4, 45.9, 47.9			
8	54.2, 67.9, 86.9			
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				
26	system: Main Steam			
27	Calculation No.: F11			
28	Fluid Transient Data Set Name: MS.F118.CUR39			
29	FFT Job No.: 3357 Job Date: 8/29/86			
30	Major Forcing Function Frequency			
31	0.977, 3.4, 5.9, 7.8, 10.3, 15.1, 21.0, 22.5			
32	25.9, 27.8, 29.8, 31.7, 33.2, 35.2			
33				
34				
35				
36				
37				
38				
39				
40				
41				
42				
43				
44				
45				
46				

CALCULATION SHEET

Attachment #1

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>6</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
15454	NP (C)	GENX-103		

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

Rev.0

System: Main Steam

Calculation No.: F11

Fluid Transient Data Set Name: MS.F119.CUR14

FFT Job No.: 3361 Job Date: 8/29/86

Major Forcing Function Frequency

0.977, 3.4, 4.4, 5.9, 7.8, 10.3, 11.2, 12.7
17.6, 22.9, 24.4, 26.4, 28.3, 29.8

System: Main Steam

Calculation No.: F11

Fluid Transient Data Set Name: MS.F119.CUR25

FFT Job No.: 3366 Job Date: 8/29/86

Major Forcing Function Frequency

1.95, 3.42, 4.4, 5.9, 6.8, 8.8, 11.2, 13.2
15.6, 17.6, 20.0, 22.5, 37.6, 45.6, 47.9

CALCULATION SHEET

Attachment #1

▲ 9010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>7</u>
J.O. OR W.O. NO. 15454.05	DIVISION & GROUP NP (C)	CALCULATION NO. GENX-103	OPTIONAL TASK CODE	

Rev. D

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

System: Main Steam

Calculation No.: F12

Fluid Transient Data Set Name: MS.F121.CUR02

FFT Job No.: 708 Job Date: 9/12/86

Major Forcing Function Frequency

4.88, 9.77, 29.3, 53.7, 83, 122.1

system: Main Steam

Calculation No.: F12

Fluid Transient Data Set Name: MS.F121.CUR04

FFT Job No.: 740 Job Date: 9/12/86

Major Forcing Function Frequency

4.88, 9.77, 29.3, 48.8, 68.4, 190.

CALCULATION SHEET

Attachment #1

A 9010 85

CALCULATION IDENTIFICATION NUMBER

J.O. OR W.O. NO. 15454	DIVISION & GROUP NF (C)	CALCULATION NO. GENX-103	OPTIONAL TASK CODE	PAGE <u>8</u>
---------------------------	----------------------------	-----------------------------	--------------------	---------------

Rev. 0

1
2
3 system: Chemical and Volume Control

4
5 Calculation No.: PX-F05

6
7 1 Transient Data Set Name: CS.F0510.CUR05

8
9 FFT Job No.: 2648

Job Date: 8/29/86

10
11 Major Forcing Function Frequency

12
13 11.9 33.6 47, 84.8

14
15
16
17
18
19
20
21
22
23
24
25
26 system: Chemical and Volume Control

27
28 Calculation No.: PX-F07

29
30 Fluid Transient Data Set Name: CS.F075.CUR03

31
32 FFT Job No.: 2651

Job Date: 8/29/86

33
34 Major Forcing Function Frequency

35
36 19.5, 45.9, 53.7, 58.6, 77.1

37
38
39
40
41
42
43
44
45
46

CALCULATION SHEET

Attachment # 1

A 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>9</u>
J.O. OR W.O. NO. 1545A	DIVISION & GROUP NP (C)	CALCULATION NO. GENX-103	OPTIONAL TASK CODE	
Rev. 0				
1	system: Chemical and Volume Control			
2	Calculation No.: F07			
3	Fluid Transient Data Set Name: CS.F075.CUR43			
4	FFT Job No.: 2652 Job Date: 8/29/86			
5	Major Forcing Function Frequency			
6	7.81, 13.7, 26.4, 35.2, 43.0, 54.7, 64.5			
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				
26	system: Chemical and Volume Control			
27	Calculation No.: F08			
28	Fluid Transient Data Set Name: CS.F0816.CUR04			
29	FFT Job No.: 2659 Job Date: 8/29/86			
30	Major Forcing Function Frequency			
31	4.88, 8.54, 12.9, 14.4, 19.0, 20.3, 24.7			
32	27.3, 38.6, 53.6, 59.6,			
33				
34				
35				
36				
37				
38				
39				
40				
41				
42				
43				
44				
45				
46				

CALCULATION SHEET

Attachment #1

5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE 10
J.O. OR IV.C. NO. 15454	DIVISION & GROUP NP (C)	CALCULATION NO. GENX-103	OPTIONAL TASK CODE	

Rev. 0

system: Chemical and Volume Control

Calculation No.: F09

Fluid Transient Data Set Name: CS.F093.CUR22

FFT Job No.: 2660

Job Date: 8/29/86

Major Forcing Function Frequency

17.4, 28.2, 36.9, 45.6, 56.4, 65.1

system: Chemical and Volume Control

Calculation No.: PX-F09

Fluid Transient Data Set Name: CS.F093.CUR64

FFT Job No.: 2662

Job Date: 8/29/86

Major Forcing Function Frequency

2.17, 6.51, 15.2, 23.9, 36.9, 43.4, 56.4,
69.4

CALCULATION SHEET

Attachment #1

▲ 10/86

CALCULATION IDENTIFICATION NUMBER

J.O. OR W.O. NO. 15454	DIVISION & GROUP NP (C)	CALCULATION NO.	OPTIONAL TASK CODE	PAGE 11
		GENX-103		

Rev. 0

System: Chemical and Volume Control

Calculation No.: FIS

Fluid Transient Data Set Name: CS.FIS13.CUR99

FFT Job No.: 2666

Job Date: 8/29/86

Major Forcing Function Frequency

6.51, 13.0, 18.4, 28.2, 40.1, 43.4, 56.4
81.4

System: Chemical and Volume Control

Calculation No.: F16

Fluid Transient Data Set Name: CS.F1614 CUR118

FFT Job No.: 2669

Job Date: 8/29/86

Major Forcing Function Frequency

0.488, 3.91, 8.79, 10.3, 14.6, 17.1, 19.5, 21.5
24.9, 27.3, 30.3, 32.2, 36.1, 40.0, 42.5,
43.9, 44.9, 47.4, 48.3,

CALCULATION SHEET

Attachment #1

▲ 5010 85

CALCULATION IDENTIFICATION NUMBER				PAGE <u>12</u>
J.O. OR W.O. NO.	DIVISION & GROUP	CALCULATION NO.	OPTIONAL TASK CODE	
15454	NP (C)	GENX-103		

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46

Rev. 0

system: Chemical and Volume Control

Calculation No.: F17

Fluid Transient Data Set Name: CS.F178.CUR19

FFT Job No.: 2670 Job Date: 8/29/86

Major Forcing Function Frequency

0.543, 5.43, 6.57, 13.0, 14.6, 19.5, 26.6
32.6, 36.3, 39.1, 46.1, 52.6, 58.6, 65.1

system: N/A

Calculation No.:

Fluid Transient Data Set Name:

FFT Job No.: Job Date:

Major Forcing Function Frequency

CALCULATION SHEET

15454 - NPCC - GENX-103 REV. 0 ATT # 2

A 8010 85

CALCULATION IDENTIFICATION NUMBER

J.O. OR W.O. NO. 15616	DIVISION & GROUP NP(C)	CALCULATION NO. GENX-025 Rev. 1	OPTIONAL TASK CODE	PAGE 13
---------------------------	---------------------------	------------------------------------	--------------------	---------

CHEMICAL & VOLUME CONTROL THERMAL CYCLES
SUMMARY OF RESULTS

PROBLEM NO.	SID	PRDP		STRESS RANGE RED. FACTOR f	CALCULATED ON PAGES	EQUIVALENT CYCLES
		REV.	DATE			
1-N085	CS	2	7-1-86	1	16	≤7000
1-N086		0	5-14-86	1	16	≤7000
1-N087		1	7-8-86	1	17	≤7000
1-N088		2	7-3-86	1	17-18	≤7000
1-N095		0	5-19-86	0.9	19-20	9289
1-N098		0	6-2-86	1	21-24	≤7000
1-N112		0	5-12-86	0.9	25	7585
1-N117		0	6-10-86	1	25-27	≤7000
1-N118	CS,WP	0	6-10-86	1	27	≤7000
1-N123	CS	0	6-5-86	1	28	≤7000
(2-039)		-	-	-	-	-
2-040		1	7-10-86	1	29	≤7000
(2-041A)		-	-	-	-	-
(2-041L)	CS,RC	-	-	-	-	-
2-042A	CS	0	6-9-86	1	31-35	≤7000
2-042B	CS,RH,RC	0	7-21-86	1	36-37	≤7000
(2-043B)	CS	-	-	-	-	-
(2-043D)	RC,CS	-	-	-	-	-
(2-043Y)	CS	-	-	-	-	-
(2-044)	CS,RC	-	-	-	-	-
(2-045C)	CS	-	-	-	-	-
(2-045D)		-	-	-	-	-
(2-045E)		-	-	-	-	-
2-045G		1	7-15-86	1	29-30	≤7000
2-045R		1	7-11-86	1	29-30	≤7000
2-045S		1	7-15-86	1	29-30	≤7000
2-045T		0	5-19-86	1	38	≤7000
(2-045V)		-	-	-	-	-
(2-045W)		-	-	-	-	-
(2-045X)		-	-	-	-	-
(2-045Y)		-	-	-	-	-
2-046A	CS,RH	0	6-18-86	1	39-43	≤7000
2-046B	CS	1	7-18-86	0.9	44-45	12439
2-047A			(2)	0.9	49-54	10815
2-047B	CS,SI	1	5-1-86	1	55	≤7000



CALCULATION SHEET

15454-NP(C)-GENX 103 REV. 0 ATT # 2

A 5010 86

CALCULATION IDENTIFICATION NUMBER

J.O. OR W.O. NO. 15616	DIVISION & GROUP NP(C)	CALCULATION NO. GENX-025 Rev. 1	OPTIONAL TASK CODE	PAGE 14
---------------------------	---------------------------	------------------------------------	--------------------	---------

SUMMARY OF RESULTS, CONT'D

PROBLEM NO.	SID	PRDP		STRESS RANGE RED. FACTOR f	CALCULATED ON PAGES	EQUIVALENT CYCLES
		REV.	DATE			
2-051 A	CS,SI	0	5-22-86	1	56-58	≤7000
2-051 B	CS	0	7-18-86	1	59-60	≤7000
2-051 C		1	7-10-86	1	45-46	≤7000
2-051 D		0	5-30-86	1	61	≤7000
2-052 B		0	6-2-86	1	62	≤7000
2-052 C		0	6-6-86	0.9	63-64	≤7000
2-052 U		0	6-2-86	1	65	≤7000
2-052 V		1	7-14-86	1	46	≤7000
2-052 W		1	7-14-86	1	46	≤7000
2-052 Z		1	7-24-86	1	46-47	≤7000
2-071 A	RM,CS,SI	0	5-9-86	1	55	≤7000
2-092 A	BR,CS	0	7-11-86	1	66	≤7000
2-150 F	CS	0	4-18-86	0.9	47	7585
2-150 G		0	4-18-86	0.9	47	7585
2-150 H		0	4-24-86	0.9	48	7585
2-150 I		0	4-23-86	0.9	48	7585
2-150 J		0	4-23-86	0.9	48	7585
2-N 001		1	7-18-86	1	47-48	≤7000
2-N 002	CS,DD	0	6-26-86	0.9	67-72	8461
2-N 007	BR,CS	0	8-6-86	1	73-74	≤7000
2-N 010	CS,WP	1	7-22-86	0.9	75	7585
2-N 030	CS	0	6-4-86	1	76-77	≤7000

FOOTNOTES :

(1) PROBLEM NUMBERS IN PARENTHESES ARE WITHIN WESTINGHOUSE SCOPE. NO PRDP EXISTS.

NC-3600 PIPING DESIGN

NC-3610 GENERAL REQUIREMENTS

NC-3611 Acceptability

The requirements for acceptability of a piping system are given in the following subparagraphs.

NC-3611.1 Allowable Stress Values. Allowable stress values to be used for the design of piping systems are given in Tables I-7.0 for acceptable materials at various temperatures.

NC-3611.2 Limits of Calculated Stresses Due to Sustained Loads and Thermal Expansion

(a) Internal Pressure Stress. The calculated stress due to internal pressure shall not exceed the allowable stress values except as permitted in NC-3612.3.

(b) External Pressure Stress. Piping subject to external pressure shall be considered safe when the wall thickness and means of stiffening meet the requirements of NC-3641.2.

(c) Allowable Stress Range for Expansion Stresses. The expansion stress, S_E (NC-3672.9) shall not exceed the allowable stress range, S_A , given by the following formula:

$$S_A = f (1.25 S_c + 0.25 S_h)$$

where

S_c = basic material allowable stress at minimum (cold) temperature, psi

S_h = basic material allowable stress at maximum (hot) temperature, psi

f = stress range reduction factor for cyclic conditions for total number, N , of full temperature cycles over total number of years during which system is expected to be in operation, from Table NC-3611.2(c)-1

(1) In determining the basic material allowable stresses, S_c and S_h , joint efficiencies need not be applied.

TABLE NC-3611.2(c)-1
 STRESS RANGE REDUCTION FACTORS

Number of Equivalent Full Temperature Cycles N	f
7,000 and less	1.0
7,000 to 14,000	0.9
14,000 to 22,000	0.8
22,000 to 45,000	0.7
45,000 to 100,000	0.6
100,000 and over	0.5

(2) Stress reduction factors apply essentially to noncorrosive service and to corrosion resistant materials, where employed to minimize the reduction in cyclic life caused by corrosive action.

(3) If the range of temperature change varies, equivalent full temperature cycles may be computed as follows:

$$N_f = N_E + r_1^2 N_1 + r_2^2 N_2 + \dots + r_n^2 N_n$$

where

N_E = number of cycles at full temperature change, ΔT_E , for which expansion stress, S_E , has been calculated

N_1, N_2, \dots, N_n = number of cycles at lesser temperature changes, $\Delta T_1, \Delta T_2, \dots, \Delta T_n$

$r_1, r_2, \dots, r_n = (\Delta T_1 / \Delta T_E), (\Delta T_2 / \Delta T_E), \dots, (\Delta T_n / \Delta T_E)$ = the ratio of any lesser temperature cycles for which the expansion stress, S_E , has been calculated.

875

(d) Additive Stresses. The sum of the longitudinal stresses due to pressure, weight and other sustained loads shall not exceed the allowable stress in the hot condition, S_h . Where the sum of these stresses is less than S_h , the difference between S_h and this sum may be added to the term $0.25S_A$ in Formula (1) for determining the allowable stress range, S_A .

NC-3611.3 Limits of Calculated Stresses

(a) Normal Operating Conditions. The sum of stresses due to design pressure, weight, and other sustained loads shall not exceed S_h and the requirements of Equation 8, NC-3652.1 shall be met. In addition, either the stress range due to thermal expansion as calculated by Equation 10, NC-3652.3 shall not exceed S_A , or the sum of stresses due to design pressure, weight, other sustained loads and the stress range due to thermal expansion shall not exceed the sum of S_A and S_h as required by Equation 11, NC-3652.3.

(b) During Upset Conditions. The sum of the stresses produced by maximum pressure, live and dead loads and those produced by occasional loads such as wind or earthquake defined in the Design Specifications as normal or upset, may be as much as 1.2 times the allowable stress values given in Tables I-7.0. Under upset conditions, the requirements of all equations of NC-3651 shall be met.

(c) During Emergency Conditions. The sum of the stresses produced by internal pressure, live and dead loads and those produced by occasional loads defined in the Design Specifications or emergency conditions