



Log # TXX-88335
File # 10110
903.9
Ref. # 10CFR50.55(e)

March 22, 1988

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NO. 50-446
SMALL BORE PIPING AND SUPPORTS
SDAR: CP-86-72 (FINAL REPORT FOR UNIT 2)

Gentlemen:

On June 9, 1986, we notified you via TXX-4844 of a reportable item involving the scope of plant modifications resulting from the project's pipe support validation program. This is a final report submitted to provide the schedule for completion of corrective action on Unit 2. Our Final Report on Unit 1 was logged TXX-88100, submitted on January 29, 1988.

As we stated in our last report, this issue was initially deemed reportable after identification of a single overstressed pipe support in the Chemical and Volume Control System (TXX-4844, dated June 9, 1986). Subsequently, we have not performed a detailed failure analysis of individual pipe supports requiring modification on Unit 2. However, we have conservatively assumed that detailed analyses of individual supports would have identified other overstressed hangers, some of which could have adversely affected the safety of operations over the life of the plant.

We will complete required support modifications on Unit 2 prior to the Unit 2 hot functional test. The support modifications implemented for Unit 2 will be similar to those implemented for Unit 1.

Very truly yours,

W. G. Council

By: John W. Beck
John W. Beck
Vice President,
Nuclear Engineering

BSD/qr

c-Mr. R. D. Martin, Region IV
Resident Inspectors CPSES (3)

8803280196 880322
PDR ADOCK 05000446
S DCD

400 N. Olive Dallas, Texas 75201

IF27
10