

DEC 28 1976

Dockets Nos.: 50-29  
50-309  
and 50-271

Yankee Atomic Electric Company  
ATTN: Mr. L. H. Heider  
Assistant Vice President  
20 Turnpike Road  
Westboro, Massachusetts 05181

Dear Mr. Heider:

RE: EVALUATION OF AMENDMENT TO QA TOPICAL REPORT

We have evaluated Amendment No. 1 to Yankee Atomic Electric Company's Topical Report YOQAP-1, "Operational Quality Assurance Program" submitted with your December 9, 1976, letter to determine its conformance with Appendix B to 10 CFR 50.

The NRC staff's positions, which were discussed with members of your staff on December 17, 1976, relative to this topical report are enclosed. Your responses to the enclosure should be submitted as an amendment (50 copies to the attention of C. J. Heltemes, Jr.) to the original report by January 14, 1977.

If you have any additional questions regarding this request, please contact John Gilray or James Conway on (301) 492-7741.

Sincerely,

*K. R. Goller*

Karl R. Goller, Assistant Director  
for Operating Reactors  
Division of Operating Reactors

Enclosure:  
Staff Positions

cc w/enclosure: See next page

THIS DOCUMENT CONTAINS  
POOR QUALITY PAGES

OFFICE	JConway	JWGilray	CHeltemes	C-ORB#1: DOR ASchwencer	C-ORB#4: DOR RReid:rm	AD-OR: DOR
SURNAME	JConway	JWGilray	CHeltemes	ASchwencer	RReid:rm	KRGoller
DATE	12/23/76	12/23/76	12/23/76	12/23/76	12/23/76	12/28/76

8011060708

Yankee Atomic Electric  
Company

cc: Mr. James E. Griffin, President  
Vermont Yankee Nuclear Power Corporation  
77 Grove Street  
Rutland, Veront 05701

Mr. Donald E. Vandenburg, Vice President  
Vermont Yankee Nuclear Power Corporation  
Turnpike Road, Route 9  
Westboro, Massachusetts 01581

John A. Ritsher, Esquire  
Ropes & Gray  
225 Franklin Street  
Boston, Massachusetts 02110

Gregor I. McGregor, Esquire  
Assistant Attorney General  
Department of the Attorney General  
State House, Room 370  
Boston, Massachusetts 02133

Richard E. Ayres, Esquire  
Natural Resources Defense Council  
917 - 15th Street, N. W.  
Washington, D. C. 20005

Honorable M. Jerome Diamond  
Attorney General  
State of Vermont  
109 State Street  
Pavilion Office Building  
Montpelier, Vermont 05602

John A. Calhoun  
Assistant Attorney General  
State of Vermont  
109 State Street  
Pavilion Office Building  
Montpelier, Vermont 05602

Anthony Z. Roisman, Esquire  
Berlin, Roisman and Kessler  
1025 15th Street, N.W., 5th Floor  
Washington, D. C. 20005

Brooks Memorial Library  
224 Main Street  
Brattleboro, Vermont 05301

John R. Stanton, Director  
Radiation Control Agency  
Hazen Drive  
Concord, New Hampshire 03301

John W. Stevens  
Conservation Society of  
Southern Vermont  
P. O. Box 256  
Townshend, Vermont 05353

Mr. David M. Scott  
Radiation Health Engineer  
Agency of Human Services  
Division of Occupational Health  
P. O. Box 607  
Barre, Vermont 05641

New England Coalition on  
Nuclear Pollution  
Hill and Dale Farm  
West Hill - Faraway Road  
Putney, Vermont 05346

Public Service Board  
State of Vermont  
120 State Street  
Montpelier, Vermont 05602

Yankee Atomic Electric Company

cc: E. W. Thurlow, President  
Maine Yankee Atomic Power Company  
9 Green Street  
Augusta, Maine 04330

Mr. Donald E. Vandenburg  
Vice President - Engineering  
Yankee Atomic Electric Company  
20 Turnpike Road  
Westboro, Massachusetts 01581

John A. Ritsher, Esquire  
Ropes & Gray  
225 Franklin Street  
Boston, Massachusetts 02110

Mr. John M. R. Paterson  
Assistant Attorney General  
State of Maine  
Augusta, Maine 04330

Harold P. Green, Esquire  
Suite 1000  
The Watergate  
600 New Hampshire Avenue, N. W.  
Washington, D. C. 20037

Mr. Nicholas Barth  
Executive Director  
Sheepscot Valley Conservation  
Association, Inc.  
P. O. Box 125  
Alna, Maine 04535

Wiscasset Public Library Association  
High Street  
Wiscasset, Maine 04578



Yankee Atomic Electric Company

cc: Mr. Donald G. Allen, President  
Yankee Atomic Electric Company  
20 Turnpike Road  
Westboro, Massachusetts 01581

Greenfield Public Library  
402 Main Street  
Greenfield, Massachusetts 01581

YANKEE ATOMIC ELECTRIC COMPANY  
QA TOPICAL REPORT (YOQAP-1)

421.0      QUALITY ASSURANCE

- 421.9 (RSP)      Appendices C, D, E which list the safety-related structures, systems, and components controlled by the QA program should be modified to include "fuel assemblies" and identified expendable consumable items such as boric acid, welding rod, and diesel fuel. In addition, on page 1 of Section II delete "The safety class designations of" in the last sentence under "scope."
- 421.10 (RSP)      In Section II, note "No. 5" on page 5 should be modified (II) to read as follows: "Programmatic changes (except those that are editorial in nature) in the QA program as described herein shall require written NRC notification prior to implementation. Organizational changes which affect the QA program will be reported to the NRC within 30 days after announcement."
- 421.11 (RSP)      In Appendix B (Exceptions), item "C" on page 8 should be (App. B) modified to read as follows: "The Yankee Nuclear Services Division Radiation Protection Group shall at least include an individual that possesses a bachelor's degree or the equivalent in a science or engineering subject, including formal training in radiation protection and at least five years of professional experience in applied radiation protection. At least three years of this professional experience should be in applied radiation protection work at an operating nuclear power plant."