



Carolina Power & Light Company

Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461-0429

January 19, 1988

FILE: B09-13510C
SERIAL: BSEP/88-0037

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555

BRUNSWICK STEAM ELECTRIC PLANT UNIT 2
DOCKET NO. 50-324
LICENSE NO. DPR-62
SPECIAL REPORT PER TECHNICAL SPECIFICATION 3.7.8 AND
PURSUANT TO TECHNICAL SPECIFICATION 6.9.2 (2-SR-88-001)

Gentlemen:

During the Unit 2 1988 refueling/maintenance outage, a Unit 2 fire barrier LCO was initiated on January 3, 1988, for fire door No. 203 in the unit Reactor Building. Door No. 203 is located at fire barrier penetration seal No. R2-2-020 on the 20-foot elevation of the building and provides personnel access to the building from the unit Turbine Building hallway. The subject LCO was initiated to permit opening the door to help prevent wear and possible damage to its locking seals and interlocks resulting from outage-related traffic. On January 10, 1988, the specified seven-day time frame of the LCO was exceeded. Until return of the door to service and cancellation of the involved LCO, appropriately stationed fire watches will be maintained.


It is expected that during the remainder of the Unit 2 refueling/maintenance outage, the following Reactor Building fire doors, in addition to door No. 203, will be appropriately placed under LCO at various times to provide for additional outage-related traffic: fire door Nos. 301 and 303 (located on the 50-foot elevation) and fire door No. 209 (located on the 20-foot elevation).

8801260322 880119
PDR ADOCK 050003:24
S PDR

TK22
1/0

This report is intended to meet the reporting requirements for fire door No. 203 as well as any of the above-listed Unit 2 Reactor Building fire doors, which may require 30-day reporting in accordance with Technical Specification 3.7.8.

Very truly yours,



C. R. Dietz, General Manager
Brunswick Steam Electric Plant

MJP/mcg

Enclosure

cc: Dr. J. N. Grace
Mr. E. D. Sylvester
BSEP NRC Resident Office