



Public Service™

Public Service
Company of Colorado

16805 WCR 19 1/2, Platteville, Colorado 80651

March 21, 1988
Fort St. Vrain
Unit No. 1
P-88106

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Attention: Mr. Jose A. Calvo
Director, Project Directorate IV

Docket No. 50-267

SUBJECT: Control Rod Drive Partial Scram
Test Results and Maximum Daily
Temperature Report

Dear Mr. Calvo:

The Fort St. Vrain Interim Technical Specifications (Surveillance Requirements, Section 4.1.1.A.1.a) require that a report be provided to the NRC at least once every 31 days when one or more Control Rod Drive (CRD) motor temperature(s) exceeds 215 degrees Fahrenheit. A report on the partial scram test results and the maximum daily temperature of those CRD's with motor temperatures above 215 degrees Fahrenheit for the month of February, 1988, is included as Attachment 1 for your review. The report for the month of March and succeeding months, as applicable, will be included in the Fort St. Vrain Monthly Operations Report.

We hope you will find this submittal responsive to your concerns. If you have any questions or comments, please contact Mr. M. H. Holmes at (303) 480-6960.

Sincerely,

R. O. Williams, Jr.

R. O. Williams, Jr.
Vice President, Nuclear Operations

ROW:DLS/skd

Attachments

8803290282 880321
PDR ADOCK 05000267
P DCD

A001
~~A047~~
//

P-88106

-2-

March 21, 1988

cc: Regional Administrator, Region IV
ATTN: Mr. T. F. Westerman, Chief
Projects Section B

Mr. Robert Farrell
Senior Resident Inspector
Fort St. Vrain