



BOSTON EDISON
 Executive Offices
 800 Boylston Street
 Boston, Massachusetts 02199

10CFR50
 Appendix R

January 19, 1988

BECO 88-010

Ralph G. Bird
 Senior Vice President — Nuclear

U. S. Nuclear Regulatory Commission
 Document Control Desk
 Washington, DC 20555

License DPR-35
 Docket 50-293

10CFR50 APPENDIX R EXEMPTION REQUESTS
SUPPLEMENTAL INFORMATION

- References:
1. BECo letter to NRC (dated November 16, 1983) Subject: 10CFR50 Appendix R Exemption Requests (BECO Letter No. 83-281).
 2. BECo letter to NRC (dated December 27, 1984) Subject: 10CFR50 Appendix R Exemption Requests, Calculations used in Evaluation of Structural Steel Supports (BECO Letter No. 84-214).
 3. NRC letter to BECo (dated December 10, 1987) Subject: Meeting Between Boston Edison Company and NRC on November 24, 1987.

This letter provides additional information for consideration by the staff in its evaluation of BECo Exemption Requests 11, 12, 13 and 14. The need to supplement our previous submittals (References 1 and 2) resulted from discussions in our November 24, 1987 meeting (Reference 3). The information is presented in four attachments.

Attachment 1, entitled Combustible Loading, contains maximum permitted fire loadings which we propose for various fire zones discussed in Exemption Requests 11 and 12. These loading limits were conservatively selected to be well below those that may constitute a challenge to the fire area barriers and their ability to prevent fire propagation. These limits supplement our exemption request. We anticipate no circumstances where transient combustibles combined with fixed combustibles would exceed them.

*A006
11*


8801270139 880119
 PDR ADOCK 05000293
 F PDR-DEB

Page 2

Attachments 2 and 3 are BECo calculations M-197, Revision 2, Fire Resistance of Structural Steel in the Torus Area (EL -17'-6"), and M-198, Revision 1, Fire Resistance of Structural Steel in the Steam Tunnel. These documents provide the basis for Exemption Requests 13 and 14 and are updated versions of those used for our earlier submittals (References 1 and 2). These versions incorporate a more rigorous analytical methodology to compute temperature rise in the structural steel supporting the fire barrier. These new calculations show that postulated fires in the Torus Area or Steam Tunnel will produce temperature rises in the unprotected steel that are well below the failure temperature. This means the conclusions of the previous calculations (the steel and fire barrier are safe from collapse) remain unchanged. Please note that some of the numerical results and statements presented in References 1 and 2, which were based on the old methodology, are superseded by these revised calculations.

Attachment 4 is furnished for the convenience of the NRC staff reviewers. It shows how the new M197/M198 calculation methodology was applied to determine the proposed Torus Area and Steam Tunnel combustible loading limits were safe.

We request that the NRC incorporate this information into its review of the affected exemption requests.


R. G. Bird

GD/amm/1619

cc: Mr. D. McDonald, Project Manager
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
7920 Norfolk Avenue
Bethesda, MD 20814

U. S. Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA 19406

Senior NRC Resident Inspector
Pilgrim Nuclear Power Station

Attachments: 1. Table: Combustible Loading
2. BECo Calculation M197, Rev. 2
3. BECo Calculation M198, Rev. 1
4. Application of M197/M198 Calculation Methodology

ATTACHMENT 1 TO BECO LETTER 88-010

COMBUSTIBLE LOADING

<u>Fire Zone</u>	<u>Proposed Maximum Permitted Loading (BTU/SF)</u>
SE Quad FZ 1.1	40,000 (1)
NW Quad FZ 1.2	40,000 (1)
NE Quad FZ 1.6/1.8	40,000 (1)
Torus Area FZ 1.30A	14,000 (2)
Steam Tunnel FZ 1.32	8,200 (2)

NOTES

1. The proposed maximum permitted loading for the Quad zones is equivalent to a "30 minute" fire hazard. This loading was administratively selected to represent a limit which provides assurance against spread of a fire beyond the affected zone, and is based on the realistic analysis described in Exemption Requests 11 and 12.
2. The proposed maximum permitted loadings for the Torus Area and Steam Tunnel are essentially equivalent to those calculated to produce a maximum average steel temperature of 255°F using the methodology of calculation M197, Rev. 2 and M198, Rev. 1, and are well below those needed to produce the theoretical steel failure temperature of 1000°F used by the fire protection industry.

ATTACHMENT 2 TO BECO LETTER 88-010

BECo Calculation M197, Revision 2
TORUS AREA



CALCULATION COVER SHEET

CAPITAL AUTHORIZATION NO _____

PILGRIM UNIT 1

Sheet 1 of 25

Calc No. M-197 REV. 2 File No. _____

Subject FIRE RESISTANCE OF STRUCTURAL STEEL
IN THE TORUS AREA - (BL-17'6")
Discipline Group Leader TJ TRACY / WS CLANCY
Approval TJ Tracy by WS Clancy Date 10/4/86

SR
NSR
Preliminary Calc. Finalization due date
Final Calc.

Independent Verifier John J. Jey Statement Attached
CIVIL/STRUCTURAL 9/26/86

Page(s)	By	Date	Chk'd	Date	Agree
<u>ALL</u>	<u>J.F. BIENKIEWICZ</u>	<u>8/23/86</u>	<u>John T. PRAWLOCKI</u>	<u>9/23/86</u>	<input checked="" type="checkbox"/>
	<u>J.F. Biunk</u>	<u>9/23/86</u>	<u>John T. PRAWLOCKI</u>	<u>9/23/86</u>	

THIS CALCULATION VERIFIES THE ADEQUACY OF FIRE BARRIERS, FOR THE ABOVE AREAS, BY EVALUATING THE UNPROTECTED STRUCTURAL STEEL WHICH IS PART OF OR SUPPORTS THE FIRE BARRIER.

THIS CALCULATION SUPERSEDES M-197 R 1 TO PRESENT THE CALCULATION IN AN EASY TO FOLLOW FORMAT AND CLARIFY AREAS OF THE CALCULATION TO ELIMINATE CONFUSION.

THIS CALCULATION REVISION SUPPORTS THE ORIGINAL CALCULATION CONCLUSION, THAT THE STEEL WILL NOT ATTAIN A MAXIMUM AVERAGE TEMPERATURE OF 1000 OF, AND THERE BY CONFIRMS THE ADEQUACY OF THE UNPROTECTED STRUCTURAL STEEL TO SUPPORT THE FIRE BARRIER.

DURING A FIRE. See ATTACHMENT II FOR INDEPENDENT VERIFICATION STATEMENT FOR CIVIL/STRUCTURAL; AND ATTACHMENT III FOR FS&MC INDEPENDENT VERIFICATION.

THIS CALCULATION SUPPORTS ENGINEERING EVALUATION NO. 859.

Minor revision(s) made on page(s) _____ of this calculation. See next revision.

Replaces calc # _____ Voided by calc # _____ or attache

FOR INFORMATION ONLY

PRIMARY
 REV _____ DATE _____
 FINAL M197
 REV 2 DATE _____

CALCULATION SHEET



CAPITAL AUTHORIZATION NO. _____
 PREPARED BY JFB/JPB DATE 9/23/86
 CHECKED BY MP DATE 9/23/86
 APPVD BY ML DATE 10/14/86
 SHEET 2 OF 25

SUBJECT: TORUS AREA STEEL

TABLE OF CONTENTS

<u>SECTION:</u>	<u>PAGE</u>
1.0 PURPOSE	3
2.0 SUMMARY OF RESULTS	2
3.0 METHODOLOGY	4
4.0 REFERENCES	6
5.0 ASSUMPTIONS	7
6.0 DETAILED CALCULATIONS	9
6.1 CALCULATION DATA	9
6.2 CALCULATION TABLE & LEGEND	11
6.3 CALCULATION OF STEEL AREA & CONCRETE AREA	12
6.4 THEORETICAL FIRE LOADING	20
6.5 CALCULATION TABLE B	21
6.6 DISCUSSION	23
7.0 CALCULATION CONCLUSION	25
ATTACHMENT I	<u>29</u> PAGES
ATTACHMENT II	<u>1</u> PAGES
ATTACHMENT III	<u>4</u> PAGES

SR
 NSR

FOR INFORMATION ONLY

PRELIMINARY
REV _____ DATE _____
 FINAL M-197
REV 2 DATE _____

CALCULATION SHEET



CAPITAL AUTHORIZATION NO. _____
PREPARED BY JTB JTP DATE 9/23/86
CHECKED BY mpg DATE 9/23/86
APPVD BY llw DATE 10/14/86
SHEET 3 OF 25

SUBJECT: TORUS AREA STEEL

SR
NSR

1.0 PURPOSE

THE PURPOSE OF THIS CALCULATION IS TO ESTIMATE THE MAXIMUM AVERAGE UNIFORM TEMPERATURE THAT STEEL IN THE TORUS AREA (-17'6").

MAY ATTAIN DUE TO A POSTULATED FIRE. THE FAILURE POINT FOR STEEL WILL BE DEFINED AS A MAXIMUM AVERAGE TEMPERATURE OF GREATER THAN 1,000 °F.

2.0 SUMMARY OF RESULTS

THE NUMERICAL ANALYSIS PRESENTED IN TABLE B. AUGMENTED BY THE DISCUSSION OF CONSERVATIVE ESTIMATES AND ASSUMPTIONS CONCLUDES THAT THE MAXIMUM AVERAGE UNIFORM TEMPERATURE OF STEEL IN THE TORUS AREA -EL-17'6", SHALL NOT EXCEED 137°F, BASED UPON 40% OF THE CONSERVATIVE THEORETICAL FIRE LOAD (Ref 30+40). SINCE THE FINAL TEMPERATURE IS LESS THAN THE 1,000°F, IT IS DETERMINED THAT THE STRUCTURAL STEEL WILL NOT DEGRADE THE FIRE BARRIER

FOR INFORMATION ONLY

REV _____ DATE _____

FINAL M-197

REV 2 DATE _____



AUTHORIZATION NO. _____

PREPARED BY JFB 9/23/80 DATE 8/23/80

CHECKED BY mpe DATE 9/23/80

APPVD BY MLL DATE 10/4/80

SHEET 4 OF 25

SUBJECT: TORUS AREA STEEL

SR

NSR

3.0 METHODOLOGY

3.1 THE TEMPERATURE WITHIN THE TORUS AREA - EC (117'6" SHALL BE MODELED TO FOLLOW THE TEMPERATURE PROFILE PRESENTED BY THE STANDARD TIME-TEMPERATURE CURVE IN ASTM-E-119. THE MODEL SHALL ASSUME AMBIENT TEMPERATURE OF 68°F.


3.2 AS THE TEMPERATURE OF THE MODELED SPACE RISES (PER ASTM-E-119) THE TEMPERATURE DIFFERENCE, BETWEEN THE SPACE (T_s) AND THE SPACE BOUNDARY (T_w) IS CALCULATED (ΔT). THIS INITIAL TEMPERATURE DIFFERENCE IS UTILIZED TO DETERMINE THE COMBINED CONVECTIONS AND RADIATION COEFFICIENTS ($h_c + h_r$) = h REQUIRED TO CALCULATE THE HEAT FLUX (F_o) PER UNIT AREA.

$$F_o = \Delta T h$$

3.3 THE HEAT FLUX, PER UNIT AREA (F_o) IS THEN UTILIZED TO TO INDEPENDENTLY

FOR INFORMATION ONLY

PRELIMINARY
REV _____ DATE _____
 FINAL M-497
REV 2 DATE _____



CAPITAL AUTHORIZATION NO. _____
PREPARED BY JFB/jpd DATE 9/23/86
CHECKED BY mjr DATE 7/23/86
APPVD BY WU DATE 10/1/86
SHEET 5 OF 25

SUBJECT: TORUS AREA: STEEL

CALCULATE THE NEW SPACE BOUNDARY:
SURFACE TEMPERATURE OF STEEL (T_w)
AND CONCRETE (T_w_c).

SR
NSR

$$T_w = T_0 + 2 \left(\frac{F_0}{K} \right) \left(\frac{2b}{3.14} \right)^{1/2}$$

3.4 THE TOTAL HEAT ABSORBED BY THE
SPACE BOUNDARY IS CALCULATED ($Q_s : Q_c$),

$$Q_s = F_0 A_s ; Q_c = F_0 A_c$$

3.5 THE THEORETICAL FIRE LOADING OF
THE SPACE SHALL BE CALCULATED.

$$\text{FIRE LOADING} = \text{COMBUSTIBLES} \times \text{HEAT OF COMBUSTION}$$
$$\text{BTU} = (\text{LB.} \times \text{BTU/LB.})$$

3.6 THE THEORETICAL FIRE LOADING SHALL BE
REDUCED TO A NET FIRE LOADING BASED
UPON PUBLISHED INDUSTRY DATA AND
CALCULATION SUPPORTED ASSUMPTIONS,
THE NET FIRE LOAD SHALL BE UTILIZED
TO IDENTIFY THE MAXIMUM AVERAGE
STEEL TEMPERATURE

FOR INFORMATION
ONLY

REV _____ DATE _____

FINAL M-197

REV 2 DATE _____



SUBJECT: TORUS AREA STEEL

AUTHORIZATION NO _____

PREPARED BY JTB JTB DATE 9/23/82

CHECKED BY MLD DATE 9/22/86

APPROVED BY LM DATE 10/14/86

SHEET 6 OF 25

4.0 REFERENCES:

SR
NSR

1. FIRE TEST STANDARDS, FIRST EDITION, 1982
ASTM-E-119, TABLE X 1, PAGE 53.
2. STANDARD HANDBOOK FOR MECHANICAL ENGINEERS,
SEVENTH EDITION, TABLE 11, PAGE 4-106,
AND FORMULA (15), (ATTACHED)
3. THERMAL CONDUCTIVITY:
STEEL - ASME VIII - DIVISION 2 - TABLE 1 (ATTACHED)

CONCRETE - STANDARD HANDBOOK FOR
MECHANICAL ENGINEERS, SEVENTH EDITION,
TABLE 3, PAGE 4-95. (ATTACHED)
4. FOR STEEL - THERMAL DIFFUSIVITY - ASME VIII -
DIVISION 2 - TABLE 1 (ATTACHED).
5. CONDUCTION OF HEAT IN SOLIDS, Pg 75,
PARA 2.9 - CARSLAW & JAEGER (ATTACHED)
6. NATIONAL RESEARCH COUNCIL OF CANADA,
FIRE RESISTANCE OF UNPROTECTED STEEL
COLUMNS, RESEARCH PAPER N677, MAY 23, 1973 -
(ATTACHED).
7. FIRE TECHNOLOGY, NFPA, ASSESSMENT OF
FIRE RESISTANCE REQUIREMENTS, VOL 17,
NOVEMBER 1981. (ATTACHED)
8. 1978 STRUCTURAL STEEL SHAPES, BETHLEHEM
CATALOG 3277, 1978 EDITION.
9. DRAWING REFERENCES ARE CALLED OUT IN SECT. 6.3
3-CONT. CONCRETE THERMAL DIFFUSIVITY;
"HEAT, MASS, AND MOMENTUM TRANSFER",
W.M. ROHSENOW & H.Y. CHOI - PRENTICE HALL INC.
(ATTACHED)

FOR INFORMATION
ONLY

PRELIMINARY
REV _____ DATE _____
 FINAL M-197
REV 2 DATE _____

CALCULATION SHEET



AUTHORIZATION NO _____
PREPARED BY JPB JPB DATE 9/23/86
CHECKED BY MJD DATE 9/23/86
APPVD BY LM DATE 10/14/86
SHEET 17 OF 25

SUBJECT: TOEUS AREA STEEL

5.0 ASSUMPTIONS

SR
NSR

1. AREA TEMPERATURE ASSUMED TO BE 68°F @ T_o .
2. THE COMBINED CONVECTION AND RADIATION COEFFICIENT VALUES ASSUME LINEAR APPROXIMATION BETWEEN TABLE TEMPERATURE VALUES.
3. THE THERMAL CONDUCTIVITY - ASSUME - LINEAR APPROXIMATION BETWEEN TABLE TEMPERATURE VALUES FOR STEEL. THE CONCRETE THERMAL CONDUCTIVITY IS ASSUMED CONSTANT OVER TEMPERATURE RANGE.
4. THE STEEL THERMAL DIFFUSIVITY - ASSUME LINEAR APPROXIMATION BETWEEN TABLE TEMPERATURE VALUES FOR STEEL. THE CONCRETE THERMAL DIFFUSIVITY IS ASSUMED CONSTANT OVER TEMPERATURE RANGE.
5. STEEL IS ASSUMED TO FAIL WHEN IT REACHES AN ESTIMATED MAXIMUM UNIFORM AVERAGE TEMPERATURE OF $1,000^{\circ}\text{F}$.
6. THE STEEL IS ASSUMED TO HEAT UNIFORMLY.
7. COMBUSTIBLE MATERIAL IS ASSUMED TO RELEASE AN AMOUNT OF HEAT EQUIVALENT TO THE THEORETICAL HEAT OF COMBUSTION.
8. [BLANK]
- ~~9. EMISSIVITY OF STEEL EQUALS ABSORPTIVITY OF CONCRETE.~~

JPB
FOR INFORMATION ONLY

REV. _____ DATE _____

FINAL M-197

REV. 2 DATE _____



AUTHORIZATION NO. _____

PREPARED BY JFB JFB DATE 9/23/80
8/23/80

CHECKED BY MD DATE 9/27/80

APPVD BY WLL DATE 10/14/80

SHEET 8 OF 25

SUBJECT: TORUS AREA STEEL

ASSUMPTIONS - CONT

SR	<input checked="" type="checkbox"/>
NSR	<input type="checkbox"/>

- 10. STEEL AND CONCRETE ACT AS SEMI-INFINITE SOLIDS.
- 11. INSULATION - HEAT OF COMBUSTION ASSUMED TO BE 26000 BTU/LB WHICH IS MAXIMUM FOR CABLES IN THIS AREA.
- 12. [BLANK]
- 13. ALTHOUGH THE NOTE ON TABLE II (REF 2) INDICATES THE VALUES OF h ARE BASED ON AN 80°F ROOM TEMPERATURE, FOR THIS CALCULATION THE VALUES ARE ACCEPTABLE FOR DETERMINING AN ORDER OF VALUE FOR THE COMBINED COEFFICIENT.

FOR INFORMATION ONLY

PRELIMINARY
 REV _____ DATE _____
 FINAL **M-197**
 REV **2** DATE _____

CALCULATION SHEET



CAPITAL AUTHORIZATION NO _____
 PREPARED BY JFB JFB DATE 9/23/56
 CHECKED BY MJP DATE 9/23/56
 APPVD BY JFB DATE 10/4/56
 SHEET 9 OF 25

SUBJECT: TORUS AREA STEEL

SR
 NSR

6.0 DETAILED CALCULATION

6.1 CALCULATION DATA IS PRESENTED IN TABULAR FORM ON TABLE A.

COLUMN NUMBER 1 IS THE TIME - IN MINUTES - RELATIVE TO THE TIME TEMPERATURE CURVE IN ASTM E-119.

COLUMN NUMBER 2 IS THE TEMPERATURE OF THE FIRE RELATIVE TO THE TIME TEMPERATURE CURVE IN ASTM-E 119.

COLUMN NUMBER 3 IS THE TEMPERATURE OF THE SURFACE BOUNDARY WHICH INCREASES OVER TIME AND TEMPERATURE.

COLUMN NUMBER 4 IS THE DIFFERENCE IN TEMPERATURE BETWEEN COLUMN NUMBER 2 AND 3

COLUMN NUMBER 5 IS THE COMBINED CONVECTION AND RADIATION COEFFICIENT BASED ON THE TEMPERATURE DIFFERENCE IN COLUMN NUMBER 4.

COLUMN NUMBER 6 IS THE FLUX PER UNIT AREA WHICH IS EQUAL TO COLUMN NUMBER 4 MULTIPLIED BY COLUMN NUMBER 5.

COLUMN NUMBER 7 IS THE THERMAL CONDUCTIVITY OF THE MATERIAL.

COLUMN NUMBER 8 IS THE THERMAL DIFFUSIVITY OF THE MATERIAL.

COLUMN NUMBER 9 IS THE TEMPERATURE DIFFERENCE (INCREASE) IN THE SURFACE BOUNDARY, WHICH IS CALCULATED AS FOLLOWS:

$$\Delta T_w = \frac{2F_o}{K} \left(\frac{\Delta b}{3.14} \right)^{1/2} \text{ WHICH IS } \Delta T_w = 2 \left(\frac{CN6}{CN7} \right) \left(\frac{CN8 \times (T_w - T_{w-1})}{3.14} \right)^{1/2}$$

WHERE CN = COLUMN NUMBER

FOR INFORMATION ONLY



SUBJECT: TORUS AXIAL STEEL

SR	<input checked="" type="checkbox"/>
NSR	<input type="checkbox"/>

COLUMN NUMBER 10 IS THE NEW SURFACE TEMPERATURE AFTER TIME τ .

$$T_{w2} = T_{w1} + \Delta T_w$$

$$CN10 = CN3 + CN9$$

WHERE CN = COLUMN NUMBER

COLUMN NUMBER 11 IS THE TOTAL NUMBER OF BTU'S APPLIED TO THE STEEL OR CONCRETE.

$$Q_s = F_{o_s} \times A_s \times (T_n - T_{n-1})$$

WHERE: s = STEEL

A_s = AREA STEEL FROM TABLE B
 $(T_n - T_{n-1})$ = TIME IN MINUTES

$$CN11 = \sum_{c=1}^{CN1} C_{Uc} \times A_s \times (T_n - T_{n-1})$$

WHERE CU = COLUMN NUMBER
 SUBSCRIPT C IS SUBSTITUTED FOR S TO IDENTIFY. Q_c FOR CONCRETE.

COLUMN NUMBER 12 IS THE CUMULATIVE SUM OF $Q_{s/c}$ FROM CN11.

REFER TO TABLE A FOR A SAMPLE OF THE CALCULATION TABLE AND LEGEND - WHICH ITEMIZES REFERENCES AND ASSUMPTIONS.

REV DATE

FINAL M-A7

REV 2 DATE

PREPARED BY JAB 9/23/86 DATE 2/23/86

CHECKED BY RYD DATE 2/23/86

APPVD BY LW DATE 10/1/86

SHEET 11 OF 35



OBJECT: TORUS AREA STEEL

6.2 CALCULATION TABLE & LEGEND

TABLE A

SR	NSR	1	2	3	4	5	6	7	8	9	10	11	12
		τ MIN	T_f °F	T_{w1} °F	ΔT ($T_f - T_w$)	h_{COMB} AT	F_0 BTU /HR-FT ²	K	α	ΔT_w OF	T_{w2} °F	$Q_{c/s}$ BTU	$\Sigma Q_{c/s}$ BTU

FOR INFORMATION ONLY

LEGEND:

- τ - MIN. [REF 1]
- T_f = TEMP(°F) @ τ [REF 1]
- T_{w1} = TEMP(°F) OF SPACE SURFACE AT τ
- ΔT = TEMP DIFFERENCE - °F = ($T_f - T_w$)
- h_{COMB} = COMBINED CONVECTION AND RADIATION COEFFICIENT = (BTU/HR-FT²-°F) = ($h_c + h_r$).
[REF 2; ASSUMPTION 2 & 13]
- $F_0 = \Delta T h$ = HEAT FLUX PER UNIT AREA - BTU/HR-FT² - [REF 2]
- K = THERMAL CONDUCTIVITY - BTU/°F-HR-FT - [REF 3; ASSUMPTION 3]
- α = THERMAL DIFFUSIVITY - [REF 4; ASSUMPTION 4]; REF. 3
- ΔT_w = INCREASE IN SURFACE TEMP OF FROM $\Delta T_w = 2 \left(\frac{F_0}{K} \right) \left(\frac{\alpha b^*}{3.14} \right)^{1/2}$ [b = TIME IN HOURS]
- T_{w2} = TEMP. OF SPACE SURFACE AFTER TIME τ
 $T_{w2} = T_{w1} + \Delta T_w$
- $Q_{c/s}$ = TOTAL HEAT IN BTU Q_s (STEEL) / Q_c (CONCRETE) $\times 10^6$
- $\Sigma Q_{c/s}$ = THE TOTAL CUMULATIVE HEAT IN BTU'S $\times 10^6$.
- b = TIME IN HOURS

PRELIMINARY
 REV _____ DATE _____
 FINAL M-97
 REV 2 DATE _____
 SUBJECT: TORUS AREA
STEEL & CONC.

CALCULATION SHEET OF
 STRUCT STEEL & CONC
 AREAS FOR TORUS AREA
 (CEL.-17LG" TO 23')



CAPITAL AUTHORIZATION NO. _____
 PREPARED BY JFB JFB DATE 9/23/86
 CHECKED BY JFB DATE 9/23/86 9/24/86
 APPVD BY [Signature] DATE 10/14/86
 SHEET 12 OF 25

6.3 CALCULATION OF STEEL & CONCRETE AREA

SR
 NSR

- SHEET NO. 12. SUMMARY
- 13. STEEL TABLE
- 14. 5,758.88 S.F.
- 15. 4,033.69
- 16. 3,826.88

TORUS SHELL & SUPPORT

17. 32,532.91

METAL DECKING 18. 10,658.00

TORUS 56,810.36 S.F. AREA STEEL

TORUS CONCRETE

SHEET 19. 36,026.54 S.F. AREA CONC.

FOR INFORMATION ONLY


PRELIMINARY
 REV ___ DATE _____
 FINAL **M-197**
 REV **2** DATE _____

CALCULATION SHEET



CAPITAL AUTHORIZATION NO. _____
 PREPARED BY JL DATE 9/23/86
 CHECKED BY JL DATE 9/23/86 7/21/86
 APPVD BY JL DATE 10/1/86
 SHEET **13** OF **25**

SUBJECT:



$$2xd + 3 \times b1 - 2 \times tw =$$

SR
 NSR

	d	b1	tw	PERIMETER	
				INCHES	FT.
14 WF 43	13 5/8"	8"	5/16"	50.62	4.22
30 WF 99	29 5/8	10 1/2	1/2	89.75	7.48
30 WF 108	29 7/8	10 1/2	9/16	90.13	7.51
30 WF 124	30 1/8	10 1/2	9/16	90.63	7.55
30 WF 172	29 7/8	15	5/8	103.5	8.62
30 WF 190	30 1/8	15	11/16	103.87	8.65
30 WF 210	30 3/8	15 1/8	3/4	104.62	8.72
36 WF 170	36 1/8	12	11/16	106.87	8.9
36 WF 230	35 7/8	16 1/2	3/4	119.75	9.98
36 WF 300	36 3/4	16 5/8	15/16	121.5	10.125

FOR INFORMATION ONLY

PRELIMINARY
 REV ___ DATE ___
 FINAL **M-197**
 REV **2** DATE ___
 (TORUS) EC. 23'0"
 SUBJECT: STEEL DWG. C.132 BY BUCHTE

CALCULATION SHEET



CAPITAL AUTHORIZATION NO. _____
 PREPARED BY JFB JFB DATE 9/23/86
 CHECKED BY JFB DATE 9/23/86 9/23/86
 APPVD BY JFB DATE 10/4/86
 SHEET **14** OF **25**

PCC	SIZE	LENGTH EXPOSED	EXPOSED SQ. FT.	
EW 4	30 WF 99	11'	329.12	
EW 1	30 WF 124	19'	143.45	
EW 1	30 99	19'	142.12	
2	30 108	19'	285.38	
1	30 190	27'	233.55	
1	30 172	27'	197.8	<i>19'-7" FOR 14'</i>
1	30 172	27'	232.74	
1	30 108	27'	202.77	
1	30 190	34'	294.1	
1	30 172	34'	221.	<i>I-19'-7"</i>
1	30 190 PL. 1"x12" (.17)	34'	299.88	<i>I-(.17)</i>
GIR ② 1		34'	334.33	<i>4" x 30" CONC. I-1'-10" 26x2 1/2"</i>
1	30 172	42'	362.04	
1	30 172	42'	318.96	<i>I-19'-7" FOR 23'</i>
1	30 210	42'	369.64	<i>I-12'1" x 20'</i>
GIR ① 1		42'	415.	<i>(52'1" x 30" I-1'-10" 28x2 1/2"</i>
1	30 210	38'	331.36	
1	30 210	38'	378.96	<i>I 38' G.S. (1.25) ✓</i>
2	30 WF 172	38'	655.2	
			<u>5,758.88</u>	

SR
 NSR

FOR INFORMATION ONLY

CALCULATION SHEET

PRELIMINARY
REV _____ DATE _____

FINAL **M-197**
REV **2** DATE _____

TORUS - STEEL
SUBJECT: REF. DWG. C.132



CAPITAL AUTHORIZATION NO. _____

PREPARED BY JTB DATE 9/23/80

CHECKED BY [Signature] DATE 9/23/80 9/23/80

APPVD BY [Signature] DATE 10/1/80

TORUS
SHEET **15** OF **25**

PCS	SIZE	LENGTH EXPOSED	EXPOSED SQ. FT	
4	30WF172	34'	1172.32	
6	30WF172	30	1551.6	
7	14 43	8.5'	~251.1	} approximate values
FW 2	14 43	6'	~50.64	
NS				
2	36WF230	34'	546.83	I # 6 3/4"
1	36WF230	30'	241.2	I # 6 3/4"
2	36WF170	30'	220.	I # 6 3/4"
			4033.69 sq'	

SR
NSR

FOR INFORMATION ONLY

PRELIMINARY
REV _____ DATE _____

CALCULATION SHEET

CAPITAL AUTHORIZATION NO. _____
 PREPARED BY JFB DATE 9/23/86
 CHECKED BY PMP DATE 9/23/86 9/27/86
 APPVD BY [Signature] DATE 11/4/86
 TORUS SHEET 16 OF 25

FINAL M-197
 REV 2 DATE _____
 SUBJECT: REF DWG. C-132



SR
 NSR

PCS	SIZE	LENGTH EXPOSED	EXPOSED SQ. FT.	
NS 8	14 WF 43	8.6'	290.336	
GRD ② 2	@ J-15	8'	147.	
NS 2	36 WF 300 + R 14x18" + C. 2.	37'	638.75	JFB I
1	30 WF 190 (K. 25)	35'	302	JFB
GRD ⑥ 1	+ STIFF 12S 1 END 3/4"	33'	297.0 15.	S. E. S
GRD ⑤ 1	+ STIFF 12S 1 END 3/4"	33'	312.5	
3	30 WF 108	30'	675.9	
1	30 WF 210	35'	305.2	
GRD ④ 1		37'	396	JFB
M-P GRD ⑦ 1		37'	360	JFB
14-G GRD ③ 1		13	116.	
			<u>3826.88</u>	

FOR INFORMATION ONLY

PRELIMINARY
 REV. DATE _____
 FINAL **M-197**
 REV. **2** DATE _____

CALCULATION SHEET




CAPITAL AUTHORIZATION NO. _____
 PREPARED BY **JP** DATE **9/23/80**
 CHECKED BY **AMP** DATE **9/23/80**
 APPVD BY **llc** DATE **10/4/80**
 SHEET **17** OF **25**

SUBJECT:


REF. DWG. M-15 REV. E3
 TORUS CIRCUM. = 92.68'

SR
 NSR

$92.68' \times 20' \times 16 = 29,657.6$
 CIRCUM. L SEGMENTS



TORUS SHELL
 AREA STEEL 29,657.6 sq'



$10.75' \times \frac{.21 (2 \text{ WEB T})}{6.04'} = 64.9$ EA. COL
 $64.9 \times 32 = 2077$ COLS

COL. BASE PLATES $2.5833' \times 2.5833' \times 32 = 213.55$ sq'

$4 \times 3 \times 3/16 \text{ L} + 2 \text{ PLS}$
 $1.16' \times 7.5' = 8.7$ sq'
 2. PLS

EA. BRACE $10.7' \times 32 = 12 \# \text{ BRACES} \approx 342.4$ sq'

TORUS SHELL + SUPPORTS = TOTAL $\approx 32,532.91$ sq'

FOR INFORMATION ONLY

PRELIMINARY
 REV _____ DATE _____
 FINAL **M-197**
 REV **2** DATE _____


CALCULATION SHEET

CAPITAL AUTHORIZATION NO. _____
 PREPARED BY **gpp** **gpp** DATE **9/23/56**
 CHECKED BY **gpp** DATE **9/23/56** **9/23/56**
 APPVD BY **luc** DATE **10/4/56**
 TORUS SHEET **18** OF **25**




SUBJECT:

METAL DECK 4 1/2" DP.
 (EL. 20' 4") (DWG. C-124)
 FIN. FL.



SR
 NSR



TOP OF STEEL
 EL. 20' 4"

		AREA
①	$39' \times 39' \div 2 = 760.5 \times 4$	$= 3,042 \text{ sq}'$
②	$56 \times 34 = 1904 \times 4$	$= 7616 \text{ sq}'$
	METAL DECK TOTAL	<u><u>10,658 sq'</u></u>

FOR INFORMATION ONLY

PRELIMINARY

CALCULATION SHEET

CAPITAL AUTHORIZATION NO. _____


FINAL 11-197

PREPARED BY JFB DATE 9/23/86

CHECKED BY J.P.M.P. DATE 9/23/86

APPVD BY [Signature] DATE 10/1/86

SUBJECT: CONCRETE




TORUS SHEET 19 OF 25

CONCRETE REF. DWGS. C-20, C-21, C-62
VALLS

SR	<input checked="" type="checkbox"/>
NSR	<input type="checkbox"/>

T.W. EL. 20'-2"
B.W. EL. -17'-6"
37'-10"

37.83' x 56'-6 1/2"



OUTBOARD WALLS

$$\begin{matrix} 10 & 102 \\ 37.93' & \times 56-54 & \times 8 & = & \underline{17,111.26} \end{matrix} \square'$$

HT LGTH

INBOARD WALLS


$$\begin{matrix} 28.83 & \times & 13.5 & \times & 16 & = & \underline{6,227.28} \end{matrix} \square'$$

HT L

DIAG AT EL. -17'-6"

$$15' \times 13' \times 16 = \underline{3,120} \square'$$

{ OUTBOARD & INBOARD
TOTAL WALL AREA 26,458.54 \square'



SLAB AT EL. -17'-6"

$$26 \times 46 \times 8 = \underline{9,568} \square'$$

36,026.54 S.F.

FOR INFORMATION ONLY

PRELIMINARY
REV ___ DATE _____

CALCULATION SHEET

CAPITAL AUTHORIZATION NO. _____
PREPARED BY JFO JPD DATE 9/23/80

FINAL M-197
REV 2 DATE _____



CHECKED BY m.j. DATE 7/23/80
APPVD BY lm DATE 10/4/80
SHEET 20 OF 25

SUBJECT: TORUS AREA (-17'6')

SR
NSR

1.4 THEORETICAL FIRE LOADING

A. FUEL LOADING:

- 1. CABLE INSULATION 24LB.
- 2. WOOD 8200LB

B. HEAT OF COMBUSTION:

- 1. INSULATION 21,000 BTU/LB
- 2. WOOD 8,000 BTU/LB

C. TOTAL THEORETICAL LOAD:

1. INSULATION

$$24LB \times 21,000 \frac{BTU}{LB} = 504,000 BTU$$

2. WOOD

$$8200LB \times 8,000 \frac{BTU}{LB} = 65,600,000 BTU$$

SAY 66,000,000 BTU

THEORETICAL FIRE LOAD APPLIED TO
SPACE BOUNDARY:

$$66 \times 10^6 BTU \times 40\% = 26.4 \times 10^6 BTU$$

[REF. 7]

FOR INFORMATION ONLY

PRELIMINARY
REV _____ DATE _____
 FINAL **M-197**
REV **2** DATE _____

CALCULATION SHEET



CAPITAL AUTHORIZATION NO. _____
PREPARED BY JFB JFD 9/23/86 DATE 9/23/86
CHECKED BY WGP DATE 2/25/86
APPVD BY W DATE 10/4/86
SHEET **22** OF **25**

SUBJECT: TORUS AREA (-17'6")

SR
NSR

ENTERING TABLE "B" @ 26.4×10^6 BTU

$$ie @ \Sigma Q_s + \Sigma Q_c = (42.35 + 105) \times 10^6 \text{ BTU}$$

WE ENVELOPE THE 26.4×10^6 BTU LOADING
AND DETERMINE THE MAXIMUM AVERAGE
STEEL TEMPERATURE SHALL BE 137°F.

FOR INFORMATION
ONLY

PRELIMINARY
REV ___ DATE _____
 FINAL M-197
REV 2 DATE _____

CALCULATION SHEET



CAPITAL AUTHORIZATION NO. _____
PREPARED BY JB JP DATE 9/23/86
CHECKED BY WJD DATE 9/23/86
APPVD BY LM DATE 10/14/86
SHEET 23 OF 25

SUBJECT: TORUS AREA (66-176)

SR
NSR

6.6 Discussion

AN EVALUATION OF THE CALCULATIONS INPUT VARIABLES AND CONSERVATIVE ESTIMATES AND ASSUMPTIONS WILL CONCLUDE THAT THE ACTUAL AVERAGE ESTIMATED STEEL TEMPERATURE WILL MOST PROBABLY BE SUBSTANTIALLY LESS THAN THE CALCULATED TEMPERATURE OF 137°F.

THE FOLLOWING IS A REVIEW OF ESTIMATES AND ASSUMPTIONS:

1. THE AMOUNT OF COMBUSTIBLES IS CONSERVATIVELY ESTIMATED.
2. THE HEAT OF COMBUSTION IS THE AMOUNT OF HEAT RELEASED DURING A SUBSTANCE'S COMPLETE OXIDATION (COMBUSTION). THE HEAT OF COMBUSTION IS DETERMINED IN A LABORATORY UTILIZING A "BOMB CALORIMETER", IN WHICH A KNOWN MASS OF FUEL IS BURNT COMPLETELY IN ATMOSPHERE OF PURE OXYGEN

FOR INFORMATION ONLY

PRELIMINARY
REV ___ DATE _____

CALCULATION SHEET

CAPITAL AUTHORIZATION NO. _____

FINAL M-197
REV 2 DATE _____



PREPARED BY JR YD DATE 9/23/86
8/23/86

CHECKED BY MD DATE 7/23/86

APPROVED BY W DATE 10/4/86

SHEET 24 OF 25

SUBJECT: TORUS AREA (EL-176')

SR	<input checked="" type="checkbox"/>
NSR	<input type="checkbox"/>

THE ACTUAL HEAT LOAD WILL BE SUBSTANTIALLY LESS DUE TO ACTUAL FIELD CONDITIONS IN LIEU OF LABORATORY CONDITIONS.

3 REFERENCE NO 7 INDICATES THAT THE NORMALIZED HEAT LOAD ON THE COMPARTMENT BOUNDARIES IS ONLY 10-40% OF "H_m", WHERE H_m IS THE CONCEIVABLE ABSOLUTE MAXIMUM HEAT LOAD. APPLYING THE MAXIMUM 40% FACTOR, THE CALCULATED TEMPERATURE OF STEEL IS 137 °F.

THIS CALCULATION ASSUMES THE INTERNAL TEMPERATURE OF THE STEEL IS IDENTICAL TO THE SURFACE TEMPERATURE, THIS IS A CONSERVATIVE ASSUMPTION SINCE THE SURFACE HEATS UP FASTER AND IS 100-200 DEGREES HOTTER AFTER EXPOSURE TO THE STANDARD FIRE, I.E. ASTM-E-119 FOR UP TO 60 MIN (R/6)

FOR INFORMATION ONLY

PRELIMINARY
REV _____ DATE _____
 FINAL M-197
REV 2 DATE _____

CALCULATION SHEET



CAPITAL AUTHORIZATION NO. _____
PREPARED BY JFB JFB DATE 9/23/86
CHECKED BY mqd DATE 9/23/86
APPVD BY luc DATE 10/4/86
SHEET 25 OF 25

SUBJECT: TORUS AREA (-17'6")

SR
NSR

7.0 CALCULATION CONCLUSION

BASED UPON TABLE "B" AND REASONABLE ENGINEERING JUDGEMENT, AS SUPPORTED BY THE DISCUSSION OF THIS CALCULATION'S CONSERVATIVE ESTIMATES AND ASSUMPTIONS, IT IS REASONABLE TO DEDUCE THAT THE STRUCTURAL STEEL IN THE TORUS COMPARTMENT (-17'6") WILL NOT REACH AN AVERAGE MAXIMUM ESTIMATED TEMPERATURE OF 1,000°F AND THEREFORE IS ASSUMED NOT TO FAIL.

FOR INFORMATION ONLY

PRELIMINARY
REV _____ DATE _____
 FINAL M-197
REV 2 DATE _____

CALCULATION SHEET



CAPITAL AUTHORIZATION NO. _____
PREPARED BY JFB DATE 8/23/86
CHECKED BY MD DATE 9/23/86
APPVD BY lu DATE 10/14/86
SHEET 1 OF 29

SUBJECT:

ATTACHMENT NUMBER I

SR
NSR

<u>REFERENCE</u>	<u>NO OF PAGES</u>
2	1
3 & 4	1
5	1
6	20
7	2

TOTAL NUMBER OF
PAGES IN ATT.1 ~~28~~ + COVER PAGE
28

FOR INFORMATION
ONLY

4-106 TRANSMISSION OF HEAT BY CONDUCTION AND CONVECTION

Table 10. Maximum Flux and Corresponding Over-all Temperature Difference for Liquids Boiled at 1 Atm with a Submerged Horizontal Steam-heated Tube

Liquid	Aluminum		Copper		Chromium-plated copper		Steel	
	q/A 1000	$(\Delta t)_s$	q/A 1000	$(\Delta t)_s$	q/A 1000	$(\Delta t)_s$	q/A 1000	$(\Delta t)_s$
Ethyl acetate.....	41	70	61	55	77	55		
Benzene.....	51	80	58	70	73	100	82	100
Ethyl alcohol.....	55	80	85	65	124	65		
Methyl alcohol.....	100	95	110	110	155	110
Distilled water.....	230	85	350	75	410	150

For forced-circulation evaporators, vapor binding is also encountered. Thus with liquid benzene entering a 4-pass steam-jacketed pipe at 0.9 fps, up to the point where 60 percent by weight was vaporized, the maximum flux of 60,000 Btu per hr per sq ft was obtained at an over-all temperature difference of 60 F; beyond this point, the coefficient and flux decreased rapidly, approaching the values obtained in superheating vapor, see Eq. (6b). For comparison, in a natural convection evaporator, a maximum flux of 73,000 Btu per hr per sq ft was obtained at $(\Delta t)_s$ of 100 F.

Combined Convection and Radiation Coefficients. In some cases of heat loss, such as that from bare and insulated pipes, where loss is by convection to the air and radiation to the walls of the enclosing space it is convenient to use a combined convection and radiation coefficient $(h_c + h_r)$. The rate of heat loss thus becomes

$$q = (h_c + h_r)A(\Delta t)_s \quad (15)$$

where $(\Delta t)_s$ is the temperature difference, deg F, between the surface of the hot body and the walls of the space. In evaluating $(h_c + h_r)$, h_c should be calculated by the appropriate convection formula [see Eqs. (11c) to (11g)] and h_r from the equation

$$h_r = 0.00685\epsilon(T_{av}/100)^2$$

where ϵ is the black body coefficient of the radiating surface, p. 4-111, T_{av} is the average temperature of the surface and the enclosing walls, deg R. For oxidized bare steel pipe, the sum $h_c + h_r$ may be taken directly from Table 11.

Table 11. Values of $(h_c + h_r)$

(For horizontal bare or insulated standard steel pipe of various sizes and for flat plates in a room at 80 F)

Nominal pipe diam. in.	$(\Delta t)_s$, temperature difference, deg F, from surface to room															
	50	100	150	200	250	300	400	500	600	700	800	900	1000	1100	1200	
1/4	2.12	2.48	2.76	3.10	3.41	3.75	4.47	5.30	6.21	7.25	8.40	9.73	11.20	12.81	14.65	
1	2.03	2.38	2.65	2.98	3.29	3.62	4.33	5.16	6.07	7.11	8.25	9.57	11.04	12.65	14.48	
2	1.93	2.27	2.52	2.85	3.14	3.47	4.18	4.99	5.89	6.92	8.07	9.38	10.85	12.46	14.28	
4	1.84	2.16	2.41	2.72	3.01	3.33	4.02	4.83	5.72	6.75	7.89	9.21	10.66	12.27	14.09	
8	1.76	2.06	2.29	2.60	2.89	3.20	3.88	4.68	5.57	6.60	7.73	9.05	10.50	12.10	13.93	
12	1.71	2.01	2.24	2.54	2.82	3.13	3.83	4.61	5.50	6.52	7.65	8.96	10.42	12.03	13.84	
24	1.64	1.93	2.15	2.45	2.72	3.03	3.70	4.48	5.37	6.39	7.52	8.83	10.28	11.90	13.70	
FLAT PLATES																
Vertical.....	1.82	2.13	2.40	2.70	2.99	3.30	4.00	4.79	5.70	6.72	7.86	9.18	10.64	12.25	14.06	
HFU.....	2.00	2.35	2.65	2.97	3.26	3.59	4.31	5.12	6.04	7.07	8.21	9.54	11.01	12.63	14.45	
HFD.....	1.58	1.85	2.09	2.36	2.63	2.93	3.61	4.38	5.27	6.27	7.40	8.71	10.16	11.76	13.57	

HFU, horizontal, facing upward; HFD, horizontal, facing downward.

Heat Transmission through Pipe Insulation. (McMillan, Trans. ASME, 1915.)
 For any number of layers of insulation on any size of pipe, Eqs. (2), (4), and (15)

combine to give

where q_s/A_s is the Btu all temperature differ

Heat loss per sq ft per deg
 Fahr difference per hr

FIG. 6. Variation with for $k = 0.042$.

outer surface; r_1 is the layer of insulation, for etc., are the conducti $h_c + h_r$ is often taken will have but little eff U_s with pipe size and tures of 375 and 75 F

FOR INFORMATION ONLY

FOR INFORMATION ONLY

TABLE 1
NOMINAL COEFFICIENTS OF THERMAL CONDUCTIVITY (TC) AND THERMAL DIFFUSIVITY (TD)*

Table 1

Carbon and Low Alloy Steels

Temp., °F	Plain Carbon		Carbon-Silicon		C-Mn		C-Mn-Si		Mat'l. Group A ¹		Mat'l. Group B ²		Mat'l. Group C ³	
	TC	TD	TC	TD	TC	TD	TC	TD	TC	TD	TC	TD	TC	TD
	70	35.1	0.495	30.0	0.582	27.5	0.529	23.6	0.454	24.8	0.482	21.3	0.414	24.2
100	34.7	0.474	29.9	0.567	27.6	0.512	23.9	0.443	25.0	0.477	21.5	0.409	24.3	0.464
150	34.3	0.445	29.6	0.544	27.6	0.496	24.2	0.433	25.1	0.466	21.8	0.400	24.4	0.452
200	33.6	0.417	29.2	0.521	27.6	0.486	24.4	0.422	25.2	0.454	21.9	0.391	24.4	0.439
250	32.9	0.395	28.9	0.502	27.4	0.467	24.4	0.414	25.2	0.442	22.0	0.382	24.3	0.426
300	32.3	0.361	28.4	0.481	27.2	0.453	24.4	0.406	25.1	0.430	22.0	0.373	24.2	0.414
350	31.6	0.334	28.0	0.464	27.0	0.440	24.3	0.396	25.0	0.418	22.0	0.365	24.0	0.402
400	30.9	0.312	27.6	0.447	26.7	0.428	24.2	0.386	24.8	0.405	21.9	0.356	23.9	0.390
450	30.3	0.285	27.1	0.430	26.3	0.413	23.9	0.375	24.6	0.394	21.8	0.347	23.6	0.378
500	29.5	0.272	26.6	0.414	25.9	0.398	23.7	0.364	24.3	0.381	21.7	0.337	23.4	0.367
550	28.8	0.257	26.1	0.398	25.5	0.387	23.4	0.355	24.0	0.370	21.5	0.327	23.1	0.355
600	28.0	0.242	25.6	0.385	25.0	0.374	23.1	0.346	23.7	0.359	21.3	0.320	22.7	0.344
650	27.3	0.214	25.1	0.370	24.5	0.360	22.7	0.333	23.4	0.348	21.0	0.310	22.3	0.333
700	26.6	0.194	24.6	0.355	24.0	0.346	22.4	0.320	23.0	0.335	20.8	0.299	22.0	0.320
750	25.9	0.174	24.0	0.337	23.5	0.332	22.0	0.308	22.6	0.322	20.5	0.288	21.6	0.307
800	25.2	0.155	23.5	0.323	23.0	0.318	21.7	0.298	22.2	0.308	20.2	0.278	21.2	0.295
850	24.5	0.135	23.0	0.309	22.6	0.305	21.2	0.286	21.9	0.297	20.0	0.268	20.9	0.283
900	23.8	0.117	22.5	0.296	22.1	0.291	20.9	0.274	21.4	0.283	19.7	0.258	20.5	0.271
950	23.1	0.101	21.9	0.281	21.5	0.277	20.5	0.262	20.9	0.269	19.4	0.248	20.1	0.259
1000	22.4	0.082	21.4	0.267	21.0	0.263	20.0	0.248	20.4	0.256	19.1	0.238	19.8	0.248
1050	21.6	0.065	20.8	0.252	20.5	0.249	19.6	0.237	19.9	0.242	18.8	0.227	19.4	0.236
1100	20.9	0.050	20.2	0.236	19.9	0.237	19.2	0.228	19.5	0.230	18.5	0.216	19.1	0.225
1150	20.2	0.034	19.6	0.221	19.3	0.219	18.7	0.213	18.9	0.215	18.2	0.204	18.7	0.213
1200	19.5	0.018	19.0	0.206	18.7	0.202	18.2	0.197	18.4	0.202	17.7	0.192	18.2	0.199
1250	18.7	0.017	18.3	0.189	18.0	0.184	17.5	0.179	17.7	0.185	17.2	0.178	17.6	0.184
1300	18.0	0.010	17.6	0.172	17.1	0.159	16.7	0.155	16.7	0.164	16.5	0.161	16.9	0.166
1350	17.2	0.014	16.8	0.151	16.2	0.122	15.8	0.119	15.9	0.142	15.3	0.138	15.6	0.139
1400	16.4	0.007	16.2	0.082	15.6	0.078	15.3	0.077	15.3	0.077	15.0	0.076	15.3	0.077
1450	15.9	0.017	15.7	0.137	15.2	0.155	15.1	0.154	15.0	0.128	14.9	0.130	15.1	0.128
1500	15.7	0.162	15.6	0.180	15.1	0.169	15.1	0.169	15.0	0.199	14.8	0.171	15.0	0.199

ASME SECTION VIII - DIVISION 2 Table 1

REFERENCE
CALC BR M197 REV-1
ATTCH. I
384

Pg 3/29

FOR INFORMATION ONLY

REF NO 5
SRM197 REV-2
ATTACH. I

CARSLAW & JAEGGER

[Chap. II

2.9] THE INFINITE AND SEMI-INFINITE SOLID 75

2.9. The semi-infinite solid. The flux of heat at $x = 0$ a prescribed function of the time. Zero initial temperature

(i) Constant flux, F_0 per unit time per unit area. BTU/FT².HR

The flux $f = -K \frac{\partial v}{\partial x}$ (1)

satisfies the same differential equation as v , namely

$\frac{\partial^2 f}{\partial x^2} = \frac{\partial f}{\partial t}$, $x > 0, t > 0$. (2)

The solution of (2) with

$f = F_0$, constant, $x = 0, t > 0$, (3)

is, by 2.4 (10), $f = F_0 \operatorname{erfc} \frac{x}{2\sqrt{\kappa t}}$. (4)

Thus, from (1), using Appendix II, (9) and (11),

$v = \frac{F_0}{K} \int_0^x \operatorname{erfc} \frac{x}{2\sqrt{\kappa t}} dx$ (5)

$= \frac{2F_0\sqrt{\kappa t}}{K} \operatorname{ierfc} \frac{x}{2\sqrt{\kappa t}}$ (6)

$= \frac{2F_0}{K} \left\{ \left(\frac{\kappa t}{\pi} \right)^{\frac{1}{2}} e^{-x^2/4\kappa t} - \frac{x}{2} \operatorname{erfc} \frac{x}{2\sqrt{\kappa t}} \right\}$. (7)

A table of values of the function $\operatorname{ierfc} x$ is given in Appendix II.

The temperature at $x = 0$ is given by

$\frac{2F_0}{K} \left(\frac{\kappa t}{\pi} \right)^{\frac{1}{2}}$. (8)

The boundary condition of constant flux is of considerable practical importance. It appears if heat is generated by a flat heating element carrying electric current, if heat is generated by friction, and as an approximation in the early stages of heating a furnace or a room. It has also important applications to problems on diffusion. The cooling of the Earth's surface after sunset on a clear windless night† is very nearly that due to removal of heat at a constant rate per unit area per unit time, thus (8) gives the way in which the surface temperature falls after sunset.

The results above apply also to the case of the region $-\infty < x < \infty$ with heat supply $2F_0$ in the plane $x = 0$. The corresponding results for

† Cf. Brunt, Quart. J. R. Met. Soc. 58 (1932) 389.



National Research
Council Canada

Conseil national
de recherches Canada

REF NO 6
CALC ~~SR~~ M-197 REV-2
ATTACH. I

Pg 5/29

FIRE RESISTANCE OF UNPROTECTED STEEL COLUMNS

BY

W. W. STANZAK AND T. T. LIE

REPRINTED FROM
JOURNAL OF THE STRUCTURAL DIVISION, ASCE
VOL 99, NO. 575, PROC. PAPER 9719, MAY 1973
P. 837 - 852

RESEARCH PAPER NO. 877
OF THE
DIVISION OF BUILDING RESEARCH

OTTAWA

PRICE 25 CENTS

NRC 12888

FOR INFORMATION
ONLY

FOR INFORMATION
ONLY

Pg 6/29
M 197 REV-2
ATTACH. I

LA RESISTANCE AU FEU DES POUTRES D'ACIER
NON PROTEGEES

SOMMAIRE

Les auteurs étudient la résistance au feu des poutres d'acier non protégées au moyen d'essais d'incendie standards et de l'analyse numérique. On a découvert que la durée de la résistance au feu varie selon le facteur forme du poids de la poutre divisé par le périmètre chauffé. Les auteurs ont établi deux équations simples pour calculer les durées de résistance au feu des poutres d'acier non protégées et ils recommandent de les utiliser dans les normes du bâtiment.

FOR INFORMATION
ONLY

FOR INFORMATION
ONLY

JOURNAL OF THE
STRUCTURAL DIVISIONM 197 REV-2
ATTACH. I

FIRE RESISTANCE OF UNPROTECTED STEEL COLUMNS

By W. W. Stanzak¹ and T. T. Lie²

In the past the fire resistance of unprotected steel columns has been considered so small a quantity that it could be ignored. Fire experience and controlled fire tests on structural steel columns of small cross-sectional area showed that unprotected steel columns could not survive the effects of fire exposure for more than 10 min to 20 min. However, it will now be shown that the heavier columns required to carry the vertical loads in modern high-rise buildings are capable of much better fire performance than had previously been realized, and that some can attain fire resistance classifications of 1 hr or better.

Fire fatality statistics (1) show that the number of deaths attributable to structural collapse during a building fire is negligible. The main causes of life loss have been shown to be asphyxiation and burns (1,3,7). Therefore, to provide life safety to occupants, enough fire resistance to allow people time to escape must be provided. Except where escape routes are extremely long or the number of occupants is very large, 10 min to 20 min is usually assumed to be sufficient. However, with very tall buildings it has become evident that evacuation by stairs can be so time consuming that complete evacuation is impractical (4). In such buildings sufficient fire resistance to withstand a burnout of the contents must be provided.

Provision of fire resistance beyond that required to prevent life loss is determined largely by economic considerations. A recent study on the optimum fire resistance of structures (11) has shown that for buildings with a small-loss poten-

Note.—Discussion open until October 1, 1973. To extend the closing date one month, a written request must be filed with the Editor of Technical Publications, ASCE. This paper is part of the copyrighted Journal of the Structural Division, Proceedings of the American Society of Civil Engineers, Vol. 99, No. ST5, May, 1973. Manuscript was submitted for review for possible publication on June 9, 1972.

¹Steel Industries Fellow, Fire Research Sect., Div. of Building Research, National Research Council of Canada, Ottawa, Canada.

²Research Officer, Fire Research Sect., Div. of Building Research, National Research Council of Canada, Ottawa, Canada.

that it would be uneconomical to provide any fire protection beyond that inherent in the structure, provided such fire resistance is sufficient to allow evacuation by the occupants. Buildings representing a small-loss expectation are those that are small in size and not valuable; those with no valuable contents; those for which the probability of a serious fire is low (e.g., completely sprinklered buildings); or those having a low fire load. The use of unprotected steel columns in such buildings is generally justified if these elements have the minimal fire resistance required to prevent loss of life.

Accordingly, the writers have investigated the fire resistance of unprotected steel columns by methods of numerical calculation and by full-scale fire tests in their laboratory, with a view to developing simple expressions for calculating the fire resistance of these building elements.

TEST METHODS AND CRITICAL TEMPERATURE

On this continent, two test methods are acceptable. The most recent ASTM Standard prescribing these is E119-71 (16).

The older load test requires a sample at least 9 ft in length to be tested under an applied load calculated to develop theoretical working stresses contemplated by the design. The column is required to sustain the applied load for a period of fire exposure equal to that for which classification is desired.

The newer alternate test of protection for structural steel columns requires that a sample at least 8 ft in length be tested in a vertical position without applied load. This test is applicable when the protection is not required by design to carry any part of the column load. The applied protection must be restrained against longitudinal thermal expansion greater than that of the steel column. Temperatures are measured by at least three thermocouples located at each of four levels (cross sections). The upper and lower levels are 2 ft from the ends of the steel column, and the two intermediate levels are equally spaced. The test is considered successful if the transmission of heat through the protection, during the period of fire exposure for which classification is desired, does not raise the average (arithmetical) temperature of the steel to any level above 1,000° F (538° C), or above 1,200° F (649° C) at any one of the measured points.

The 1,000° F average allowable temperature that usually determines the fire endurance time in a test may be regarded as a critical temperature for structural failure established for protected columns as a result of many fire tests on axially loaded column sections. Thus, for the analysis in this paper, it has been assumed that structural failure is imminent when the steel cross section attains an average temperature of 1,000° F as all calculations and fire tests were made on the basis of heat conduction alone.

While complete theoretical justification for the use of temperature criteria is beyond the scope of this paper, it can readily be shown that 1,000° F is a reasonable value. For long columns, assuming that the member is uniformly heated, the buckling stress is given by Euler's formula:

$$\sigma_{cr} = \frac{\pi^2 E I}{\lambda^2} \dots \dots \dots (1)$$

and the allowable design stress for long columns is given by CSA S16-1969 (17) as:

$$\sigma_c = \frac{\pi^2 E_c}{1.92 \lambda^2} \dots \dots \dots (2)$$

in which 1.92 is a safety factor prescribed by the Code and $\lambda = \frac{286,000}{\sigma_c}$ ($\sigma_c = 13) < \lambda \leq 200$).




FIG. 1.—Average Compressive Properties of ASTM A36 Structural Steel

At elevated temperatures failure is due to occur when the left-hand sides of the equations are equal, i.e.:

$$E_c = \frac{E_c}{1.92} \dots \dots \dots (3)$$

Accepting the commonly assumed value for carbon steels of $E_c = 29 \times 10^6$ ksi, then

$$E_c = 15.1 \times 10^6 \text{ ksi } (104 \times 10^9 \text{ N/m}^2) \dots \dots \dots (4)$$

Using Fig. 1, based on data reported by Ingberg and Sale (10), it is found that the temperature at buckling is approximately 880° F (471° C). Fire tests of loaded columns (9) have shown that the point of maximum expansion (approximately the point at which the column buckles) is followed by a further 100° F-150°

F (58° C-83° C) rise in temperature before complete failure of the column occurs. Thus failure of columns can be expected at cross-sectional temperatures of from 920° - 1,050° F, (510° C-565° C), depending on the design method and slenderness ratio. A value of 1,000° F has been assumed as a reasonable average for any column, as has been indicated by the ASTM fire test standard.

TEMPERATURE RISE IN UNPROTECTED STEEL COLUMNS

The column is exposed on four sides to the heat of a fire that follows approximately the temperature-time course prescribed in ASTM E119 for the standard fire of "controlled extent and severity." Heat is transferred from the flames in the furnace and from the furnace walls to the specimen by convection and radiation, with radiation as the primary mechanism when the flames have sufficient thickness (18). The coefficient of heat transfer (the quantity of heat received per unit area of the column, per unit time, and temperature difference between the column surface and fire) depends on many factors. The most significant are: emissivity of the flames; thickness of the flames between furnace walls and column; size of specimen; and thermal properties of the furnace walls. Experimental data (5) have indicated that the heat transfer to the specimen in test furnaces approximates the radiative heat transfer from a black body at the so-called "furnace temperature." Similar heat transfer may also be expected in most building fires because the flames are luminous and usually have considerable thickness, giving them a correspondingly high emissivity.

The coefficient of heat transfer can vary significantly, however, for different individual conditions, and the effect of varying this quantity will be examined later herein.

CALCULATION OF TEMPERATURE RISE

Two-Dimensional Numerical Procedure.—To determine the temperature distribution in massive square steel columns, a number of calculations based on a two-dimensional procedure (12) were carried out. In these tests black body radiation at the prescribed furnace temperature was assumed as the only mechanism of heat transfer. The two equations used for the calculation are:

$$T_{1,s}^{t+\Delta t} = T_{1,s}^t + \frac{\Delta t}{(\rho c)_{1,s}^t (\Delta \xi)^2} \{ [k_{2,1s}^{t+\Delta t} + k_{1,s}^t] [T_{2,1s}^{t+\Delta t} - T_{1,s}^t] + [k_{2,1s}^{t+\Delta t} + k_{1,s}^t] [T_{2,1s}^{t+\Delta t} - T_{1,s}^t] + 2\sqrt{2} \Delta \xi \sigma \epsilon_s [(T_f)^4 - (T_{1,s}^t)^4] \} \dots (5)$$

for the temperature of an elementary surface element of the column, and

$$T_{m,s}^{t+\Delta t} = T_{m,s}^t + \frac{1}{2} \frac{\Delta t}{(\rho c)_{m,s}^t (\Delta \xi)^2} \{ [k_{m-1,1s}^{t+\Delta t} + k_{m,s}^t] [T_{m-1,1s}^{t+\Delta t} - T_{m,s}^t] + [k_{m-1,1s}^{t+\Delta t} + k_{m,s}^t] [T_{m-1,1s}^{t+\Delta t} - T_{m,s}^t] + [k_{m-1,1s}^{t+\Delta t} + k_{m,s}^t] [T_{m-1,1s}^{t+\Delta t} - T_{m,s}^t] + [k_{m-1,1s}^{t+\Delta t} + k_{m,s}^t] [T_{m-1,1s}^{t+\Delta t} - T_{m,s}^t] \} \dots (6)$$

for the temperature at any point inside the steel cross section, in which T is expressed in degrees Rankine and t in hours. It should be noted that the

term, ϵ , in Eq. 5 is, strictly speaking, a material and temperature dependent quantity, but it is sufficiently accurate, for the purpose of this study, to be regarded as a constant. Also, since most building materials have emissivities in the range of 0.85 to 0.95 (13) a value of 0.9 was used, although the results indicated that a value of 0.95 would have been more appropriate.


The dependence of the thermal properties of steel on temperature was taken into account in the calculations. The material properties used were derived

TABLE 1.—Thermal Properties of Steel


Temperature, in degrees Fahrenheit (1)	Volumetric heat capacity, in British thermal units per cubic foot-degrees Fahrenheit (2)	Thermal conductivity, in British thermal units per foot-hour-degrees Fahrenheit (3)
70	54.30	26.60
100	54.86	26.60
200	56.36	26.82
300	58.27	26.43
400	60.35	25.87
500	62.44	25.34
600	64.90	24.71
700	67.52	23.72
800	70.56	22.80
900	74.59	21.86
1,000	80.32	21.06
1,100	85.72	20.07
1,200	90.52	18.98
1,250	94.29	18.55
1,300	127.85	18.16
1,350	164.15	17.87
1,400	117.75	17.60
1,450	84.58	17.34
1,500	66.16	16.78
1,550	62.23	15.69
1,600	60.74	15.26
1,650	62.01	15.45
1,700	66.09	15.48
1,800	67.96	16.03
2,100	69.65	16.85
2,350	70.97	17.56

from available data (15) and are reproduced in Table 1. As is apparent, the involved nature of the calculation makes utilization of a high speed digital computer almost mandatory.

Calculated temperature profiles for a 6-in. (0.152-m) square unprotected steel column are shown in Fig. 2 at 10-min intervals. Similar profiles for a 12-in. (0.304-m) square column are shown in Fig. 3 after 50-min and 60 min of fire exposure. Fig. 3(b) shows that at 60 min the maximum temperature difference between the surface and the core was 225° F (125° C) and the temperature at



(a) 10 MIN



(b) 20 MIN


FIG. 2.—Temperature Rise in Unprotected Steel Square Column (6 in.)

M197 REV-2
ATTACH. I


ST5

FIRE RESISTANCE

Py 13/29⁸⁴³



(c) 30 MIN



(d) 40 MIN


FIG. 2—Continued

FOR INFORMATION
ONLY

FOR INFORMATION
ONLY

The point midway between the surface and core was about 1,000° F. From Figs. 2(c) and 2(d) it is seen that the maximum temperature difference between the surface of the 6-in. column and the core is about 100° F. This can be regarded as a reasonable maximum for most steel columns likely to be encountered in building practice. For the purpose of determining fire endurance time by temperature rise, the temperature at the point halfway between the surface and core of the cross section (or flange in the case of a wide flange section) may be regarded as representing the average temperature of the cross section. For all but very thick sections this temperature will be almost equal to the temperature at the column surface.

Fig. 4 shows temperature rise curves for a 6-in. square column (calculated or measured as was just described). As is seen, the assumption of radiative heat transfer only does not adequately represent the conditions prevailing in



(a) 50 MIN

FIG. 3.—Temperature Rise in Unprotected Steel Square Column (12 in.)

FOR INFORMATION
ONLY

FOR INFORMATION
ONLY

the DBR/NCR furnace when short fire endurance times are involved. The curve labeled (2) in Fig. 4 was calculated by assuming that 20% of the heat transfer is due to convection and produces good agreement with the experimental result. Unfortunately, this finding is of no general value because the convective heat transfer varies with each individual situation. With most fires of short duration the convection component of heat transfer can be in the order of 10% to 20%. In the calculation the effect of convective heat transfer was simulated by raising ϵ_c from 0.9 to the fictitious value of 1.1.

The heat transfer coefficients to columns of square cross section were calculated based on an emissivity (ϵ_c) of 0.5 using results obtained by Eqs. 5 and 6. The results are shown in Fig. 5, where the coefficient of heat transfer has been plotted as a function of the duration of standard fire exposure. As is seen, the heat transfer coefficient rises almost linearly with time, and the smaller

6

1327	1276	1237	1207	1188	1179	1179	1164	1207	1237	1276	1327
1276	1264	1217	1181	1156	1142	1137	1142	1156	1181	1217	1264
1264	1207	1164	1133	1112	1103	1103	1112	1133	1164	1207	1264
1276	1207	1155	1117	1091	1075	1070	1075	1091	1117	1155	1207
1217	1155	1109	1076	1055	1041	1041	1055	1076	1109	1155	1217
1237	1164	1109	1069	1042	1026	1021	1026	1042	1069	1109	1164
1181	1117	1069	1035	1013	1003	1003	1013	1035	1069	1117	1181
1207	1133	1076	1035	1007	991	985	991	1007	1035	1076	1133
1156	1091	1042	1007	985	974	974	985	1007	1042	1091	1156
1188	1112	1055	1013	985	968	963	968	985	1013	1055	1112
1142	1075	1026	991	968	957	957	968	991	1026	1075	1142
1179	1103	1041	1003	974	957	952	957	974	1003	1041	1103
1137	1070	1021	985	963	952	952	963	985	1021	1070	1137
1179	1103	1041	1003	974	957	952	957	974	1003	1041	1103
1142	1075	1026	991	968	957	957	968	991	1026	1075	1142
1188	1112	1055	1013	985	968	963	968	985	1013	1055	1112
1156	1091	1042	1007	985	974	974	985	1007	1042	1091	1156
1207	1133	1076	1035	1007	991	985	991	1007	1035	1076	1133
1181	1117	1069	1035	1013	1003	1003	1013	1035	1069	1117	1181
1237	1164	1109	1069	1042	1026	1021	1026	1042	1069	1109	1164
1217	1155	1109	1076	1055	1041	1041	1055	1076	1109	1155	1217
1276	1207	1155	1117	1091	1075	1070	1075	1091	1117	1155	1207
1264	1207	1164	1133	1112	1103	1103	1112	1133	1164	1207	1264
1327	1264	1217	1181	1156	1142	1137	1142	1156	1217	1264	1327

(b) 60 MIN

FIG 3—Continued

M197 REV-2
ATTACH. I

B3E

MAY 1973

Py 16/29 STS

the column the higher the coefficient of heat transfer.

(One-Dimensional Numerical Procedure.)—The temperature distributions, determined by the two-dimensional calculation method described previously, show




FIG. 4.—Temperature Rise Curves, 6 x 6 Solid Column




FIG. 5.—Coefficients of Heat Transfer for Unprotected Columns During Exposure to Standard Fire

that the temperature differences in the steel are relatively small, except for very thick sections. Most columns used in buildings have sections less than 10 in. (0.25 m) thick. In such cases detailed calculation of temperature distribution in the steel cross section is unnecessary, and a one-dimensional model of the

FOR INFORMATION
ONLY

FOR INFORMATION
ONLY

M197 REV-2
ATTACH. I

heated column can be usefully employed. The model consists of a steel plate having the same cross-sectional and surface areas per unit height as the four sides of the heated column, with the edges and unexposed side perfectly insulated. This model permits use of a one-dimensional numerical procedure by which

TABLE 2—Sample Calculation for 10-in. Square Column

t (1)	T _s (2)	T _c (3)	(T _s - T _c) (4)	ΔT _s (5)	T _c (6)
0	70	535	465	58	70
5	1,000	1,150	1,022	128	128
10	1,300	1,350	1,094	137	266
15	1,396	1,431	1,038	130	393
20	1,462	1,486	963	120	523
25	1,510	1,530	887	111	643
30	1,550	1,567	813	102	754
35	1,584	1,599	743	93	856
40	1,613	1,626	677	85	949
45	1,638				1,034

Note: $\alpha = 18.45$; $c = 0.12$; $D = 3.33$; $W = 340$; $\Delta T_s = 0.125 (T_s - T_c)$ for $\Delta t = 1/12$ hr.




FIG. 6—Temperature Rise of Square Solid Steel Columns (Calculated, $\alpha = 18.45$)

the temperature of the steel cross section can be calculated with only a desk calculator or slide rule. In the calculation, with each interval of time, Δt , the rise in steel temperature, ΔT_s , is given by:

$$\Delta T_s = \frac{\alpha}{c} \frac{D}{W} (T_s - T_c) \Delta t \dots \dots \dots (7)$$




FIG. 8.—Fire Endurance of Square Columns (Experimental)




FIG. 7.—Temperature Rise of Square Solid Steel Columns (Experimental data)

FOR INFORMATION ONLY

FOR INFORMATION ONLY

in which Δt is expressed in hours. The results of sample calculation for a 10-in. square column with $\alpha = 18.45$ (104.8) and $c = 0.12$ (502) are shown in Table 2. A family of temperature rise curves obtained by similar calculations is shown by the solid lines in Fig. 6.

Experimental Results.—To obtain information on the temperature rise of unprotected steel columns in the DBR/NRC floor furnace, five fire tests were carried out on square columns of various cross sections. The temperatures measured at the point halfway between the surface and the core at mid-height of the columns are plotted in Fig. 7. Fig. 8 shows a plot of fire endurance time versus the dimensional parameter, W/D , on logarithmic scales. As is seen, the relationship is linear and, from the graph, it is possible to obtain the following relation directly:

$$t = 10.3 \left(\frac{W}{D} \right)^{2.95} \dots \dots \dots (8)$$

in which $W/D < 10$. To obtain a relation for columns whose $W/D \geq 10$,




FIG. 9.—Built-up Column—3 Plates

a straight line temperature rise for the 16-in. square column is assumed, as shown by the dashed line in Fig. 7. From this it is possible to obtain the relation:

$$T_c = 120 \left(\frac{D}{W} \right)^{0.8} \dots \dots \dots (9)$$

and by setting T_c equal to the critical temperature of 1,000° F:

$$t = 8.3 \left(\frac{W}{D} \right)^{0.8} \dots \dots \dots (10)$$

The lines resulting from Eq. 9 are plotted in Figs. 6 and 7 (dashed lines). The line resulting from Eq. 10 is plotted in Fig. 8 and that equation should be used for columns having $W/D \geq 10$. However, as is seen from Fig. 7,

it can be conservatively applied to any column section, and provides a relation that could readily be incorporated into a building by-law. ~~Although the experimental data are confined to solid square columns, numerical analyses show that Eqs. 9 and 10 can apply to any shape of cross section.~~

As an example of the fire resistance typical in columns of very tall buildings, a calculation for the section shown in Fig. 9, one of several massive sections used in Toronto's 56-story Toronto Dominion Centre, is worked out:

$$D = 2(30 + 16) + 2(30 - 7) + 2(10) = 174 \text{ in.} \quad (11)$$

$$W = 1,870 \text{ lb per ft.} \frac{W}{D} = 10.75 \quad (12)$$

Eq. 10 yields a fire endurance time of:

$$t = 8.3(10.75)^{0.7} = 56 \text{ min} \quad (13)$$

As is seen, these massive sections can have fire endurance times approaching 1 hr. even when unprotected.

Recent North American practice has seen increased installation of sprinkler systems in large (especially tall) buildings, including some that are not considered to have a very high fire load (2,6). ~~Once complete sprinklering of high buildings becomes more common, the use of unprotected massive column sections with a fire resistance capability of about 1 hr should prove adequate for fire safety, provided that the fire load is no more than 5 lb/sq ft to 10 lb/sq ft, which should not result in a fire of severity greater than a 1-hr standard fire (8).~~ (Fire load is the heat of combustion of the combustible contents expressed in equivalent pounds of wood per unit floor area.) It can be reasonably deduced from Refs. 4 and 14 that no safety factor need be applied to the actual fire load if the building is fully sprinklered, although such a safety factor is implied by all current North American building regulations now in force.

ACKNOWLEDGMENTS

This paper is a contribution from the Division of Building Research, National Research Council of Canada, and is published with the approval of the Director of the Division.

APPENDIX I.—REFERENCES

1. Chandler, S. E., "Deaths in Fires Attended by Fire Brigades in 1969," *Fire Research Technical Paper No. 26*, H. M. Stationery Office, London, England, 1970.
2. "Fire Protection for High-Rise Buildings," *Building Systems Design*, Sept., 1971.
3. Galbreath, M., "Fire in High Buildings," *Fire Study No. 21*, Division of Building Research, National Research Council of Canada, Ottawa, Canada, 1968.
4. Galbreath, M., "Time of Evacuation by Stairs in High Buildings," *Fire Fighting in Canada*, Feb., 1969.
5. Harwathy, T. Z., "Thermal Performance of Concrete Masonry Walls in Fire," *Special Technical Publication No. 464*, American Society for Testing and Materials, 1970, pp. 209-243.
6. "High Rise, Tall Dilemma," *News Bulletin*, Canadian Automatic Sprinkler Association, May-Aug., 1971.
7. Huicheon, N. B., and Shorter, G. W., "Smoke Problems in Highrise Buildings."

ASHRAE *Journal*, American Society of Heating Refrigerating and Air Conditioning Engineers, Vol. 10, No. 9, 1968, pp. 57-61.

8. Ingberg, S. H., "Tests of Severity of Building Fires," *Quarterly*, National Fire Protection Association, Vol. 22, No. 43, 1928.
9. Ingberg, S. H., et al., "Fire Tests of Building Columns," *Technologic Papers of the Bureau of Standards*, No. 184, 1921.
10. Ingberg, S. H., and Sale, P. D., "Compressive Strength and Deformation of Structural Steel and Cast-Iron Shapes at Temperatures up to 950° C (1742° F)," *Proceedings of the American Society for Testing and Materials*, Vol. 26, No. 11, 1926.
11. Lie, T. T., "Optimum Fire Resistance of Structures," *Journal of the Structural Division*, ASCE, Vol. 98, No. ST1, Proc. Paper 8638, Jun., 1972, pp. 215-232.
12. Lie, T. T., and Harmathy, T. Z., "A Numerical Procedure to Calculate the Temperature of Protected Steel Columns Exposed to Fire," NRCC 12535, National Research Council of Canada, Division of Building Research, Mar., 1972.
13. Liley, P. E., Touloukian, Y. S., and Lambill, W. R., "Physical and Chemical Data," Sect. 3, *Chemical Engineers Handbook*, J. H. Perry, ed., McGraw-Hill Book Co., Inc., New York, N.Y., 1963.
14. "Norme di sicurezza per la protezione contro il fuoco dei fabbricati a struttura in acciaio destinati ad uso civile" ("Safety Standards for the Fire Protection of Structural Steel Buildings Intended for Civilian Use"), *Circolare N. 91*, Ministero dell'Interno, Direzione Generale dei Servizi Antincendi, Rome, Italy, 1961, (Available as NRC Technical Translation TT-1347, Ottawa, Canada, 1968).
15. *Physical Constants of Some Commercial Steels at Elevated Temperatures*, British Iron and Steel Research Association, Butterworths Scientific Publications, London, England, 1953.
16. "Standard Methods of Fire Tests of Building Construction and Materials," *ASTM Designation E119-71*, Pt. 14, 1971 *Book of ASTM Standards*, American Society for Testing and Materials, 1971.
17. *Steel Structures for Building*, CSA S16-1969, Canadian Standards Association, Ottawa, Canada, 1969.
18. Trinks, W., and Mawhinney, M. W., *Industrial Furnaces*, Carnegie Institute of Technology, John Wiley and Sons, Inc., New York, N.Y., 1961.

APPENDIX II.—NOTATION

The following symbols are used in this paper:

- c = specific heat of steel, in British thermal units per pound—degrees Fahrenheit (or degrees Rankine) (joules per kilogram—degrees Kelvin);
- D = heated perimeter, in inches (meters);
- E = modulus of elasticity of steel, in kips per square inch (newtons per square meter);
- FE = fire endurance time, in minutes;
- k = thermal conductivity, in British thermal units per foot-hour-degrees Fahrenheit (watts per meter-degrees Kelvin);
- T = temperature, in degrees Fahrenheit (degrees Celsius);
- t = time, in minutes (unless specified otherwise);
- W = mass of steel section, in pounds per foot (kilograms per meter);
- α = coefficient of heat transfer, in British thermal units per foot-hour-degrees Fahrenheit (watts per meter-degrees Kelvin);
- Δ = increment;
- $\Delta \xi$ = mesh width, in feet (meters);
- ϵ = emissivity;
- λ = slenderness ratio;

M 197 REV-2
ATTACH. I

852

MAY 1973

Pg 22/24
ST5

μ = density of steel, in pounds per cubic foot (kilograms per cubic meter);
and
 σ = stress, ksi (N/m^2); Stefan-Boltzmann constant, 0.1713×10^{-8} , in British
thermal units per hour-square foot-degrees Rankine to the fourth power
(watts per square meter—degrees Kelvin to the fourth power);

Subscripts

a = allowable, average;
 cr = critical;
 f = of furnace;
 m = at or around mesh point in m th row;
 n = at or around mesh point in n th column;
 o = at room temperature;
 s = of steel cross section;
 T = at temperature T ; and
 y = at yield stress.

Superscripts

j = at $t = j\Delta t$.

FOR INFORMATION
ONLY

FOR INFORMATION
ONLY

Pg 23/29

M197 REV-2
ATTACH. I

9719 FIRE RESISTANCE OF UNPROTECTED STEEL COLUMNS

KEY WORDS: Buildings (codes); Columns; Fire protection; Fire resistance; Heat transfer; Steel; Structural engineering; Temperature

ABSTRACT: Fire resistance of unprotected steel columns is examined by standard fire test and numerical analyses based on a 1,000 D F (538 D-C) critical temperature for failure. It is shown that fire resistance time varies with the shape factor of column weight divided by the heated perimeter, and two simple equations for calculating the fire resistance times of unprotected steel columns are established. A practical example shows that large columns used in high-rise buildings can have fire resistance times of up to one hr. The more conservative of the two equations is recommended for use in building standards.

REFERENCE: "Fire Resistance of Unprotected Steel Columns," *Journal of the Structural Division, ASCE*, Vol. 99, No. ST5, Proc. Paper 9719, May, 1973, pp. 837-852

FOR INFORMATION
ONLY

FOR INFORMATION
ONLY

Pg 24/29
M197 REV-2
ATTACH. I

This publication is being distributed by the Division of Building Research of the National Research Council of Canada. It should not be reproduced in whole or in part without permission of the original publisher. The Division would be glad to be of assistance in obtaining such permission.

Publications of the Division may be obtained by mailing the appropriate remittance (a Bank Express, or Post Office Money Order, or a cheque, made payable to the Receiver General of Canada, credit NRC) to the National Research Council of Canada, Ottawa, K1A 0R6. Stamps are not acceptable.

A list of all publications of the Division is available and may be obtained from the Publications Section, Division of Building Research, National Research Council of Canada, Ottawa, K1A 0R6.

FOR INFORMATION
ONLY

FOR INFORMATION
ONLY

R - NO. 7

CALC P-2M197 REV-2

ATTACH. I

PP 25-29

Fire Technology
Nov

Assessment of Fire Resistance Requirements

J. R. MEHAFFEY and T. Z. HARMATHY
National Research Council of Canada
Division of Building Research

The calculation of normalized heat load, a succinct quantifier of the potential of compartment fires to spread by destruction, is greatly simplified by the introduction of two semi-empirical equations. These afford direct insight into the relation between the destructive potential of fire and the principal characteristics of the fire compartment and its contents of combustibles.

ALTHOUGH the bases on which code writers bring down their decisions on fire resistance requirements have changed over the years, the influence of Ingberg's fire load concept¹ is still recognizable. That concept, developed some 40 years ago, claims that the destructive potential of compartment fires is proportional to the specific fire load (mass of combustibles per unit floor area), and that the fire resistance requirement for compartment boundaries should also be allocated in proportion to the specific fire load.

Although still widely used, the concept was soundly disproved by the results of subsequent experimental research. The outlines of a rational way of assigning fire resistance requirements has recently emerged, following the identification of a parameter as a unique quantifier of the potential of enclosure fires for destructive spread.² With this new understanding, decisions regarding fire resistance requirements are a matter of matching the of the parameter calculated for real-world conditions with those used for test conditions.

FOR INFORMATION ONLY
calculation of the parameter quantifying the destructive spread of fires under real-world conditions is quite straightforward; but involves an iterative technique, it may prove somewhat time consuming for those who attempt to perform it without a programmable calculator. To eliminate the need for iteration, the feasibility of expressing the parameter by an approximate empirical equation has been examined. Results of the examination are reported in this paper.

theorem of uniformity of normalized heat load.

SEMI-EMPIRICAL EXPRESSION FOR THE NORMALIZED HEAT LOAD

According to statistical data, the fire load in modern buildings, despite the increasing use of plastics, consists predominantly of cellulose. Since, in addition, fires of cellulose excel in their destructive potential, it appears to be a safe practice to assume that the fire load consists fully of cellulose.

By reflecting on the meaning of Ingberg's fire load concept, one recognizes that it has been built on the implicit assumption that in a fire the bulk of the fuel energy is eventually absorbed by the compartment boundaries. The normalized heat load pertaining to the assumption that all heat release by the fuel is absorbed within the compartment is

$$H_m = \frac{1}{\sqrt{k_{qc}}} \frac{G \Delta H}{A} \quad (6)$$

where the subscript m has been affixed to H to indicate that it represents the conceivable absolute maximum, G is the total fire load (total fuel mass), and ΔH is the heat of combustion of the fuel.

Fortunately it has been found that the normalized heat load on the compartment boundaries is only 10 to 40 percent of H_m . Some of the fuel energy is released outside the compartment, but even of the portion released inside some energy will leave the compartment with the fire gases as sensible heat and some will be lost by radiation through the ventilation opening. A multitude of calculations performed by the detailed iterative technique mentioned earlier indicates that the normalized heat load, in other words the potential of fire for destructive spread,

- increases less than in proportion to the fire load,
- decreases as the ventilation of the compartment increases, and
- decreases as the thermal inertia of the boundaries increases.

The numerical results of these calculations formed the basis for an investigation that resulted in the following semi-empirical equation:

$$H = 10^4 \frac{(11.0 \delta + 1.6) G}{A \sqrt{k_{qc}} + 935 \sqrt{\phi G}} \quad (7)$$

FOR INFORMATION
ONLY

located inside the compartment. It is to be estimated from the following equation:

$$\delta = \begin{cases} 0.79 \sqrt{h_c^3} / \phi \\ 1 \end{cases} \quad \text{whichever is less} \quad (8)$$

where h_c is the height of the compartment.

ϕ is a variable that characterizes the ventilation of the compartment. It is defined as

$$\phi = \rho_e A_v \sqrt{gh} \quad (9)$$

where ρ_e is the density of environmental atmosphere, A_v is the area of ventilation opening (window or door), h is the height of the ventilation opening, and g is the acceleration due to gravity. The considerations that have led to the development of Equation 7 are discussed in the Appendix.

As the specific fire load G/A , (where A is the floor area of the compartment) may vary rather markedly from compartment to compartment, the selection of the value of G for the fire safety design must be based on an analysis of statistical data. If the compartment boundaries are simple "dividing elements" without essential structural functions, the design value for G/A , is usually taken as the 80th percentile in the cumulative plot for the applicable occupancy. If, on the other hand, the compartment boundaries are "key elements" that play an important part in the structural performance of the building as a whole, some extra degree of safety is justified. The selection of G may be based on considerations propounded by Lie³ and outlined later by Harmathy.⁴

The ventilation parameter, ϕ , is a measure of the minimum ventilation of the compartment. This occurs under "classic" draft-free conditions. As discussed by Harmathy,⁴ the presence of drafts causes the value of ϕ to increase over that calculated from Equation 9 and thus (by virtue of Equation 7) to reduce the value of the normalized heat load, a value for ϕ obtained from Equation 9 may be used in assessing the potential of fires for destructive spread.

It is of interest to examine the normalized heat load in relation to its limiting value, as expressed by Equation 6. Combining Equations 6 and 7 and using $\Delta H = 18.8 \times 10^4 \text{ J kg}^{-1}$ in the former (because the fire load is assumed to be cellulose), the following equation is obtained:

$$\frac{H}{H_m} = \frac{0.585 \delta + 0.085}{1 + 935 \frac{\sqrt{G \phi}}{A \sqrt{k_{qc}}}}$$

FOR INFORMATION
ONLY
M 197 REV-2
Pg 26/29
ATTACH. I

RET-3

M-197 REV-2

ATTACH. I

PP 27/29

~~XXXXXXXXXX~~

**HEAT, MASS,
AND
MOMENTUM TRANSFER**

Warren M. Rohsenow

PROFESSOR OF MECHANICAL ENGINEERING
MASSACHUSETTS INSTITUTE OF TECHNOLOGY

Harry Y. Choi

ASSOCIATE PROFESSOR OF MECHANICAL ENGINEERING
TUFTS UNIVERSITY

Prentice-Hall, Inc.

ENGLEWOOD CLIFFS, NEW JERSEY

**FOR INFORMATION
ONLY**

REV #3
 M-197 REV-2
 ATTACH. I

~~CONFIDENTIAL~~
 PP 28/29
 APPENDIX E 517

TABLE E.1—Continued

(2) Nonmetals	T (°F)	ρ (lb _m /ft ³)	c_p (Btu/lb _m F)	k (Btu/hr ft F)	α (ft ² /hr)
Aerogel, silica	100	5.3	0.205	0.013	0.012
Asbestos	32	36	0.25	0.08	0.010
	800	36		0	
	68	100	0.20	0.20-0.10	0.01-0.02
Brick, common	68	100	0.20	0.20-0.10	0.01-0.02
fire clay	1472	145	0.23	0.79	0.024
Bakelite	68	79.5	0.38	0.134	0.0044
Concrete	68	119-144	0.21	0.47-0.81	0.019-0.027
Corkboard	100	10	0.4	0.025	0.006
Diatomaceous earth, powdered	100	14	0.21	0.030	0.01
Fiber insulating board	100	14.3		0.024	
Glass, window	68	162	0.16	0.51	0.020
Glass wool, fine	100	1.5		0.031	
	100	6.0		0.022	
Ice	32	57	0.46	1.28	0.048
Magnesia, 85%	100	17		0.039	
Marble	68	156-169	0.193	1.6	0.064
Paper				0.075	
Rock wool	100	12		0.023	
Rubber, hard	32	74.8	0.48	0.067	0.0024
Wood, oak, \perp to grain	70	51	0.57	0.12	0.004
Wood, oak, to grain	70	51	0.57	0.23	0.0069

SOME SOLIDS

k (Btu/hr ft F)	α (ft ² /hr)
(212 F) (1.12 F)	(68 F)
119	3.665
74	1.322
13	0.237
219	4.353
39	0.785
	0.666
33	0.634
19.3	0.924
97	3.762
68	2.074
48	0.882
37	0.677
240	6.011
25	0.452
10	0.172
34	1.505
87	2.490
63	1.591

FOR INFORMATION
 ONLY

ND CONVECTION

am*

600	800	1000
0.0266	0.0303	0.0337
0.0238	0.0292	0.0345

Table 3. Thermal Conductivities of Miscellaneous Solid Substances*
 (Values of k are to be regarded as rough average values for the temperature range indicated)

Material	Bulk density, lb per cu ft	Temp, deg F	k	Material	Bulk density, lb per cu ft	Temp, deg F	k
Asbestos board, compressed asbestos and cement	123.	86.	0.225	Quartz, crystal, parallel to C-axis	...	-300.	25.0
Asbestos millboard	60.5	86.	0.070			0.	8.3
Asbestos wool	25.	212.	0.058	Rubber, hard	74.3	100.	0.092
Ashes, soft wood	12.5	65.	0.018	Rubber, soft, vulcanized	68.6	86.	0.08
Ashes, volcanic	51.	300.	0.123	Sand, dry	94.8	68.	0.188
Carbon black	12.	133.	0.012	Sawdust, dry	13.4	68.	0.042
Cardboard, corrugated	87.3	86.	0.12	Silica, fused	200.	200.	0.83
Celluloid	87.3	86.	0.12	Silica gel, powder	32.5	131.	0.049
Cellulose sponge, du Pont	3.4	82.	0.033	Soil, dry	...	68.	0.075
Concrete, sand and gravel	142.	75.	1.05	Soil, dry, including stones	127.	68.	0.30
Concrete, cinder	97.	75.	0.41	Snow	7-31	32.	0.34-1.3
Charcoal, powder	11.5	63.	0.029	Titanium oxide, finely ground	52.	1000.	0.041
Cork, granulated	5.4	23.	0.028	Wool, pure	5.6	86.	0.021
Cotton wool	5.0	100.	0.035	Zirconia grain	113.	600.	0.11
Diamond	151.	70.	320.	Woods, oven dry, across grain†:			
Earth plus 42% water	108.	0.	0.62	Aspen	26.	85.	0.069
Fiber, red	80.5	68.	0.27	Bald cypress	24.	85.	0.063
"Flotofoam" (U.S. Rubber Co.)	1.6	92.	0.017	Balsa	10.	85.	0.034
Glass, pyrex	139	200.	0.59	Basswood	24.	85.	0.058
Glass, soda lime	...	200.	0.59	Douglas Fir	29.	85.	0.063
Graphite, solid	93.5	122.	87.	Elm, rock	48.	85.	0.097
Gravel	116.	68.	0.22	Fir, white	26.	85.	0.069
Gypsum board	51.	99.	0.062	Hemlock	29.	85.	0.066
Ice	57.5	...	1.26	Larch, western	36.	85.	0.078
Kaolin wool	10.6	800.	0.059	Maple, sugar	43.	85.	0.094
Leather, sole	62.4	...	0.092	Oak, red	42.	85.	0.099
Mica	122.	...	0.25	Pine, southern yellow	35.	85.	0.078
Pearlite, Arizona, spherical shell of siliceous material	9.1	112.	0.035	Pine, white	25.	85.	0.060
Polystyrene, expanded "Styrofoam"	1.7	...	0.021	Red cedar, western	21.	85.	0.053
Pumice, powdered	49.	300.	0.11	Redwood	25.	85.	0.062
Quartz, crystal, perpendicular to C-axis	...	-300.	12.5	Spruce	21.	85.	0.052
		0.	4.3				
		300.	2.3				

ial is
 (1)

is $q_x = -k(\partial t/\partial x)$, and if q_x is constant. This states that the cross-sectional $A(x)$ normal to $\partial t/\partial x$ along the conductor thermal conductivity

with temperature, and the

is the value of k at the thickness l

(2)

* $(A_0 - A_i)/\ln(A_0/A_i)$; A_0 and A_i must be determined by the procedure (Awbrey and 10) or by the relaxation

* The thermal conductivity of different materials varies greatly. For metals and alloys k is high, while for certain insulating materials, such as glass wool, cork, and kapok, it is very low. In general, k varies with the temperature, but in the case of metals, the variation is relatively small. With most other substances, k increases with rising temperatures, but in the case of many crystalline materials, the reverse is true.
 † With heat flow parallel to the grain, k may be 2 to 3 times that with heat flow perpendicular to the grain; the values for wood are taken chiefly from J. D. MacLean, Trans. ASHRAE, 47, 1941, p. 823.

M-197 REV. 2

Attachment II: Independent Verification Statement (CIVIL/STRUCTURAL)
Calculation # M197, Revision # 2 *(SEE NOTES BELOW) has been independently verified by the following method(s), as noted below:

- Design Review including verification that:
- * Design inputs were correctly selected and included in the calculation.
 - * Assumptions are adequately described and are reasonable.
 - * Input or assumptions requiring confirmation are identified, and if any exist, the calculation has been identified as "Preliminary" and a "Finalization Due Date" has been specified.
 - * Design requirements from applicable codes, standards and regulatory documents are identified and reflected in the design.
 - * Applicable construction and operating experience was considered in the design.
 - * The calculation number has been properly obtained and entered.
 - * An appropriate design method or computer code was used.
 - o A mathematical check has been performed.
 - o The output is reasonable compared to the input.

Alternate Calculation including verification of asterisked items noted above. The alternate calculation (___ pages) is attached.

- Qualification Testing for design feature _____ including verification of asterisked items noted above and the following:
- o The test was performed in accordance with written test procedures.
 - o Most adverse design conditions were used in the test.
 - o Scaling laws were established and verified and error analyses were performed, if applicable.
 - o Test acceptance criteria were clearly related to the design calculation.
 - o Test results (documented in _____) were reviewed by the calculation Preparer or other cognizant engineer.

* **NOTES:**
 Independent Verifier Comments: THE SCOPE OF THIS INDEPENDENT VERIFICATION IS LIMITED TO THE REVIEW OF THE CONCRETE AND STEEL SURFACE AREA CALCULATIONS ON PAGES 12 THROUGH 19 AND ITEM # 2 BELOW.
 See NED Procedure 3.05, Sec. 7.1.1 14/ Joseph Z. Jany 9/26/86
 Independent Verifier Date

Preparer concurrence with findings and comment resolution 14/ John P. Prawlucki 9/23/86
 Preparer or other cognizant engineer Date

Exhibit 3.05-Q Rev. 5
 2. REFER TO INDEPENDENT REVIEW STATEMENT ATTACHMENT II TO CALCULATION NO. FP 26 REV. 1 DATED 9-23-86 FOR INFORMATION ONLY
 "DOCUMENTATION OF STRUCTURAL PERFORMANCE OF STEEL ELEVATED TEMPERATURES" BY J. PRAWLUCKI DATED 9/23/86
 THIS PROVIDES FURTHER JUSTIFICATION OF THE USE OF 1000 F AS A TEMPERATURE LIMIT FOR UNPROTECTED STRUCTURAL STEEL.

III

Attachment - Independent Verification Statement (FS&MC)

M197

Calculation # M197 Revision # 2 has been independently verified by the following method(s), as noted below:

Design Review including verification that:

- * Design inputs were correctly selected and included in the calculation.
- * Assumptions are adequately described and are reasonable.
- * Input or assumptions requiring confirmation are identified, and if any exist, the calculation has been identified as "Preliminary" and a "Finalization Due Date" has been specified.
- * Design requirements from applicable codes, standards and regulatory documents are identified and reflected in the design.
- * Applicable construction and operating experience was considered in the design.
- * The calculation number has been properly obtained and entered.
- * An appropriate design method or computer code was used.
- o A mathematical check has been performed.
- o The output is reasonable compared to the input.

Alternate Calculation including verification of asterisked items noted above. The alternate calculation (___ pages) is attached.

Qualification Testing for design feature _____ including verification of asterisked items noted above and the following:

- o The test was performed in accordance with written test procedures.
- o Most adverse design conditions were used in the test.
- o Scaling laws were established and verified and error analyses were performed, if applicable.
- o Test acceptance criteria were clearly related to the design calculation.
- o Test results (documented in _____) were reviewed by the calculation Preparer or other cognizant engineer.

Independent Verifier Comments:

see attached sheet cannot resolve

See NED Procedure 3.05, Sec. 7.1.1

/s/ J. Stobach
Independent Verifier

10/2/86
Date

Preparer concurrence with findings and comment resolution

/s/ J. Bienkiewicz
Preparer or other cognizant engineer

10/3/86
Date

ATTACHMENT III - INDEPENDENT VERIFICATION
ESEM

QUESTIONS/COMMENTS

CALC W197
PAGE 2 OF 4

- Q1 SHOULD THE STANDARD TIME TEMPERATURE CURVE (ASTM-E-119) BE INCLUDED AS AN ATTACHMENT TO THE CALCULATION?
- Q2 HOW WERE THE TEMPERATURES DETERMINED FOR TIME INCREMENTS FOR THE CALCULATION?
- Q3 CLARIFY TABLE 6.5. WHY IS TABLE DEVELOPED FOR COMBUSTIBLE LOADINGS GREATER THAN FOUND IN AREAS ANALYSED?
- Q4 WHAT IS THE RELATIONSHIP BETWEEN FIRE LOADING AND HEAT FLUX? DOES FIRE LOADING EQUAL HEAT FLUX AT EQUILIBRIUM?
- Q5 WHAT IS THICKNESS OF THE CONCRETE FIRE BARRIERS?
- Q6 SHOULD THE TEMPERATURE COMPUTATION BE IN UNITS OF °R?
- Q7 CLEARLY IDENTIFY THE NEW SURFACE TEMPERATURE IN CALCULATION.
- Q8 DOES ASSUMPTION 9 APPLY TO THIS CALCULATION?

FOR INFORMATION
ONLY

ATTACHMENT III - INDEPENDENT VERIFICATION
F&MC

ANSWERS/COMMENTS

CALC M197
PAGE 3 OF 4

A1. THE STANDARD-TIME-TEMPERATURE CURVE IS FROM A NATIONAL STANDARD (ASTM) AND WAS NOT INCLUDED IN THE CALCULATION TEXT. THE "STT" CURVE DOES, HOWEVER, APPEAR IN ATTACHMENT II, pg 8 OF 22.

A2. THE TEMPERATURES FOR THIS CALCULATION WERE TAKEN FROM APPENDIX "B" OF THE NATIONAL FIRE CODES; VOLUME 10; 1981; SECTION 251. APPENDIX "B" IS ACTUALLY THE ASTM-E-119 CURVE IN TABULAR FORM.

A3. TABLE 6.5 HAS BEEN MARKED-UP TO CLEARLY IDENTIFY STEEL TEMPERATURES. PORTIONS OF THE TABLE, WHICH EXCEED THE COMBUSTIBLE HEAT LOAD WHICH IS APPLIED TO THE AREA BOUNDARY, HAVE BEEN ELIMINATED.

A4. THE HEAT FLUX IS DETERMINED BY COLUMNS 1 THRU 6 (TABLE A). IT IS A FUNCTION OF ΔT AND THE COMBINED CONVECTION AND RADIATION COEFFICIENTS. THE HEAT FLUX IS USED TO DETERMINE THE GROSS HEAT APPLIED TO THE

FOR INFORMATION
ONLY

A4.(CONT) BOUNDARIES. WHEN THE TOTAL GROSS HEAT APPLIED ($\sum Q_s + \sum Q_c$) IS EQUAL TO 40% OF THE THEORITICAL FIRE LOAD, THE TEMPERATURE OF THE STEEL IS IDENTIFIED.

A5. THE THICKNESS OF THE CONCRETE FIRE BARRIERS IS NOT REQUIRED FOR THIS CALCULATION. THE CONCRETE THICKNESS MEETS OR EXCEEDS THE THICKNESS REQUIRED FOR THE FIRE BARRIER RATING.

A6. THE TEMPERATURE COMPUTATION, IN DEGREES FAHRENHEIT, IS ACCEPTABLE;

a) $F_o = \Delta T h$

b) $T_w = T_{w_i} + 2 \left(\frac{F_o}{k} \right) \left(\frac{\partial b}{3.14} \right)^{\frac{1}{2}}$

ABOVE FORMULA UTILIZES A ΔT FOR
Q $\therefore \Delta T_{OF 10F} = \Delta T_{OF 10R}$

A7. DONE

A8. ASSUMPTION 9 HAS BEEN DELETED FROM THE CALCULATION ASSUMPTIONS. THIS ASSUMPTION IS NOT REQUIRED.

FOR INFORMATION ONLY

ATTACHMENT 3 TO BECO LETTER 88-010

BECo Calculation M198, Revision 1
STEAM TUNNEL



CALCULATION COVER SHEET

AUTHORIZATION NO _____

PILGRIM UNIT 1

Sheet 1 of 21

M198

REV. 1 File No. _____

Subject FIRE RESISTANCE OF STRUCTURAL STEEL IN THE STEEL TUNNEL

SR NSR

Discipline Group Leader TJ TRACY WS CLANCY

Preliminary Calc.
Finalization due date _____

Approval /s/ TJ Tracy 9-24-86 /s/ William 10/4/86 Date _____

Final Calc. Independent Verifier John J. Day
CIVIL/STRUCTURAL 9/24/86Statement Attached

Page(s)	By	Date	Chk'd	Date	Agree
All	J.F. Breakiewicz	8/29/86	John T. Pawluczyk	9/23/86	X
	/s/ J.F. Breakiewicz	9/23/86	Michael J. DiMou		
			/s/ John J. Day	9/23/86	

THIS CALCULATION VERIFIES THE ADEQUACY OF FIRE BARRIERS, FOR THE ABOVE AREAS, BY EVALUATING THE UNPROTECTED STRUCTURAL STEEL WHICH IS PART OF THE SUPPORTS THE FIRE BARRIER.

THIS CALCULATION SUPERSEDES M-198 R 0 TO PRESENT THE CALCULATION IN AN EASY TO FOLLOW FORMAT AND CLARIFY AREAS OF THE CALCULATION TO ELIMINATE CONFUSION.

THIS CALCULATION REVISION SUPPORTS THE ORIGINAL CALCULATION CONCLUSION, THAT THE STEEL WILL NOT ATTAIN A MAXIMUM AVERAGE TEMPERATURE OF 1000°F, AND THEREBY CONFIRMS THE ADEQUACY OF THE UNPROTECTED STRUCTURAL STEEL TO SUPPORT THE FIRE BARRIER DURING A FIRE. REFER TO ATTACHMENT II FOR INDEPENDENT VERIFICATION STATEMENT (CIVIL/STRUCTURAL) AND ATTACHMENT III FOR FS & MC - INDEPENDENT VERIFICATION STATEMENT.

Minor revision(s) made on page(s) _____ of this calculation. See next revision.

Replaces calc # _____
Voided by calc # _____ or attached memo

FOR INFORMATION ONLY

PRELIMINARY
 REV _____ DATE _____
 FINAL M198
 REV 1 DATE _____

CALCULATION SHEET



CAPITAL AUTHORIZATION NO. _____
 PREPARED BY JPD JPD DATE 8/27/86 9/23/86
 CHECKED BY MP DATE 9/23/86
 APPVD BY LM DATE 10/1/86
 SHEET 2 OF 21

SUBJECT:

TABLE OF CONTENTS

<u>SECTION:</u>	<u>PAGE</u>
1.0 PURPOSE	3
2.0 SUMMARY OF RESULTS	3
3.0 METHODOLOGY	4
4.0 REFERENCES	6
5.0 ASSUMPTIONS	7
6.0 DETAILED CALCULATIONS	9
6.1 CALCULATION DATA	9
6.2 CALCULATION TABLE & LEGEND	11
6.3 CALCULATION OF STEEL AREA & CONCRETE AREA	12
6.4 THEORETICAL FIRE LOADING	16
6.5 CALCULATION TABLE B	17
6.6 DISCUSSION	19
7.0 CALCULATION CONCLUSION	20
ATTACHMENT I	<u>29</u> PAGE
ATTACHMENT II	<u>2</u> PAGE
ATTACHMENT III	<u>4</u> PAGE

SR
 NSR

FOR INFORMATION ONLY

PRELIMINARY
REV _____ DATE _____
 FINAL M198
REV J DATE 11/1/06

CALCULATION SHEET



CAPITAL AUTHORIZATION NO. _____
PREPARED BY JTB DATE 8/24/06
CHECKED BY MJP DATE 9/27/06
APPVD BY LM DATE 10/4/06
SHEET 3 OF 21

SUBJECT:

SR
NSR

1.0 PURPOSE

THE PURPOSE OF THIS CALCULATION IS TO ESTIMATE THE MAXIMUM AVERAGE UNIFORM TEMPERATURE THAT STEEL IN THE STEAM TUNNEL MAY ATTAIN DUE TO A POSTULATED FIRE. THE FAILURE POINT FOR STEEL WILL BE DEFINED AS A MAXIMUM AVERAGE TEMPERATURE OF GREATER THAN 1,000 °F.

2.0 SUMMARY OF RESULTS

THE NUMERICAL ANALYSIS PRESENTED IN TABLE B, AUGMENTED BY THE DISCUSSION OF CONSERVATIVE ESTIMATES AND ASSUMPTIONS CONCLUDES THAT THE MAXIMUM AVERAGE UNIFORM TEMPERATURE OF STEEL IN THE STEAM TUNNEL WILL NOT EXCEED 255°F. SINCE THE FINAL TEMPERATURE IS LESS THAN 1000°F, IT IS ASSUMED THAT THE STRUCTURAL STEEL WILL NOT DEGRADE THE FIRE BARRIER.

FOR INFORMATION ONLY

REV _____ DATE _____

FINAL M-198

REV 1 DATE _____



SUBJECT:

SR	<input checked="" type="checkbox"/>
NSR	<input type="checkbox"/>

3.0 METHODOLOGY

3.1 THE TEMPERATURE WITHIN THE STEAM TUNNEL

SHALL BE MODELED TO FOLLOW THE TEMPERATURE PROFILE PRESENTED BY THE STANDARD TIME-TEMPERATURE CURVE IN ASTM-E-119. THE MODEL SHALL ASSUME AMBIENT TEMPERATURE OF 68°F.

3.2 AS THE TEMPERATURE OF THE MODELED SPACE RISES (PER ASTM-E-119) THE TEMPERATURE DIFFERENCE, BETWEEN THE SPACE (T_s) AND THE SPACE BOUNDARY (T_w) IS CALCULATED (ΔT). THIS INITIAL TEMPERATURE DIFFERENCE IS UTILIZED TO DETERMINE THE COMBINED CONVECTION AND RADIATION COEFFICIENTS ($h_c + h_r$) = h REQUIRED TO CALCULATE THE HEAT FLUX (F_o) PER UNIT AREA.

$$F_o = \Delta T h$$

3.3 THE HEAT FLUX PER UNIT AREA (F_o) IS THEN UTILIZED TO TO INDEPENDENTLY

FOR INFORMATION ONLY

PRELIMINARY
REV _____ DATE _____
 FINAL **M-198**
REV 1 DATE _____

CALCULATION SHEET



CAPITAL AUTHORIZATION NO. _____
PREPARED BY JAB/PPD DATE 9/27/86
CHECKED BY MJD DATE 9/23/86
APPVD BY JK DATE 10/4/86
SHEET 5 OF 21

SUBJECT:

CALCULATE THE NEW SPACE BOUNDARY SURFACE TEMPERATURE OF STEEL (T_{ws}) AND CONCRETE (T_{wc}).

SR
NSR

$$T_w = T_o + 2 \left(\frac{F_o}{K} \right) \left(\frac{\Delta b}{3.14} \right)^{1/2}$$

3.4 THE TOTAL HEAT ABSORBED BY THE SPACE BOUNDARY IS CALCULATED (Q_s ; Q_c),

$$Q_s = F_o A_s ; Q_c = F_o A_c$$

3.5 THE THEORETICAL FIRE LOADING OF THE SPACE SHALL BE CALCULATED.

$$\text{FIRE LOADING} = \text{COMBUSTIBLES} \times \text{HEAT OF COMBUSTION}$$
$$\text{BTU} = (\text{LB} \times \text{BTU/LB})$$

3.6 THE THEORETICAL FIRE LOADING SHALL BE REDUCED TO A NET FIRE LOADING BASED UPON PUBLISHED INDUSTRY DATA AND CALCULATION SUPPORTED ASSUMPTIONS. THE NET FIRE LOAD SHALL BE UTILIZED TO IDENTIFY THE MAXIMUM AVERAGE STEEL TEMPERATURE


FOR INFORMATION ONLY

REV _____ DATE _____

FINAL **M198**

REV 1 DATE _____

SUBJECT: _____



AUTHORIZATION NO _____ DATE 9/23/88
PREPARED BY JTB DATE 8/29/88
CHECKED BY MJP DATE 9/23/88
APPVD BY W DATE 10/4/88
SHEET 6 OF 21

4. REFERENCES:

SR	<input checked="" type="checkbox"/>
NSR	<input type="checkbox"/>

1. FIRE TEST STANDARDS, FIRST EDITION, 1982
ASTM-E-119, TABLE X 1, PAGE 53.
2. STANDARD HANDBOOK FOR MECHANICAL ENGINEERS,
SEVENTH EDITION, TABLE 11, PAGE 4-106,
AND FORMULA (15), (ATTACHED)
3. THERMAL CONDUCTIVITY:
STEEL - ASME VIII - DIVISION 2 - TABLE 1 (ATTACHED)

CONCRETE - STANDARD HANDBOOK FOR
MECHANICAL ENGINEERS, SEVENTH EDITION,
TABLE 3, PAGE 4-95. (ATTACHED)
4. FOR STEEL - THERMAL DIFFUSIVITY - ASME VIII -
DIVISION 2 - TABLE 1 (ATTACHED).
5. CONDUCTION OF HEAT IN SOLIDS, Pg 75,
PARA 2.9 - CARSLAW & JAEGER (ATTACHED)
6. NATIONAL RESEARCH COUNCIL OF CANADA,
FIRE RESISTANCE OF UNPROTECTED STEEL
COLUMNS, RESEARCH PAPER NG77, MAY 23, 1973 -
(ATTACHED).
7. FIRE TECHNOLOGY, NFPA, ASSESSMENT OF
FIRE RESISTANCE REQUIREMENTS, VOL 17,
NOVEMBER 1981. (ATTACHED)
8. 1978 STRUCTURAL STEEL SHAPES, BETHLEHEM
CATALOG 3277, 1978 EDITION.
9. DRAWING REFERENCES ARE IDENTIFIED IN
SECTION 6.3
- 3 CON'T. - CONCRETE THERMAL DIFFUSIVITY; "HEAT,
MASS, AND MOMENTUM TRANSFER", WM. ROSSMAN &
H.Y. CHOI - PRENTICE HALL INC (ATTACHED)

FOR INFORMATION ONLY



50 ASSUMPTIONS

SR
 NSR

1. AREA TEMPERATURE ASSUMED TO BE 68°F @ T_o.
2. THE COMBINED CONVECTION AND RADIATION COEFFICIENT VALUES ASSUME LINEAR APPROXIMATION BETWEEN TABLE TEMPERATURE VALUES.
3. THE THERMAL CONDUCTIVITY - ASSUME - LINEAR APPROXIMATION BETWEEN TABLE TEMPERATURE VALUES FOR STEEL. THE CONCRETE THERMAL CONDUCTIVITY IS ASSUMED CONSTANT OVER TEMPERATURE RANGE.
4. THE STEEL THERMAL DIFFUSIVITY - ASSUME LINEAR APPROXIMATION BETWEEN TABLE TEMPERATURE VALUES FOR STEEL. THE CONCRETE THERMAL DIFFUSIVITY IS ASSUMED CONSTANT OVER TEMPERATURE RANGE.
- b. STEEL IS ASSUMED TO FAIL WHEN IT REACHES AN ESTIMATED MAXIMUM UNIFORM AVERAGE TEMPERATURE OF 1,000 °F.
6. THE STEEL IS ASSUMED TO HEAT UNIFORMLY.
7. COMBUSTIBLE MATERIAL IS ASSUMED TO RELEASE AN AMOUNT OF HEAT EQUIVALENT TO THE THEORETICAL HEAT OF COMBUSTION.
8. [BLANK]
9. ~~EMISSIVITY OF STEEL EQUALS ABSORPTIVITY OF CONCRETE.~~

FOR INFORMATION ONLY

REV _____ DATE _____

FINAL **M-198**

REV. 1 DATE _____



SUBJECT:

AUTHORIZATION NO. _____
PREPARED BY JFD gfd DATE 8/29/80 90380
CHECKED BY smf DATE 7/23/80
APPVD BY llk DATE 10/4/80
SHEET 8 OF 21

ASSUMPTIONS - CONT

SR

NSR

- 10. STEEL AND CONCRETE ACT AS SEMI-INFINITE SOLIDS.
- 11. INSULATION - HEAT OF COMBUSTION ASSUMED TO BE 26000 BTU/LB WHICH IS MAXIMUM FOR CABLES IN THIS AREA.
- 12. [BLANK]
- 13. ALTHOUGH THE NOTE ON TABLE II (REF 2) INDICATES THE VALUES OF h ARE BASED ON AN 80°F ROOM TEMPERATURE, FOR THIS CALCULATION THE VALUES ARE ACCEPTABLE FOR DETERMINING AN ORDER OF VALUE FOR THE COMBINED COEFFICIENT.

FOR INFORMATION ONLY

PRELIMINARY
REV _____ DATE _____
 FINAL
REV M 98 DATE _____

CALCULATION SHEET



CAPITAL AUTHORIZATION NO. _____ 9/23/86
PREPARED BY JFD JFD DATE 8/29/86
CHECKED BY MDP DATE 9/23/86
APPVD BY ML DATE 10/4/86
SHEET 9 OF 21

SUBJECT:

6.0 DETAILED CALCULATION

SR

NSR

6.1 CALCULATION DATA IS PRESENTED IN TABULAR FORM ON TABLE A.

COLUMN NUMBER 1 IS THE TIME - IN MINUTES - RELATIVE TO THE TIME TEMPERATURE CURVE IN ASTM E-119.

COLUMN NUMBER 2 IS THE TEMPERATURE OF THE FIRE RELATIVE TO THE TIME TEMPERATURE CURVE IN ASTM-E 119.

COLUMN NUMBER 3 IS THE TEMPERATURE OF THE SURFACE BOUNDARY WHICH INCREASES OVER TIME AND TEMPERATURE.

COLUMN NUMBER 4 IS THE DIFFERENCE IN TEMPERATURE BETWEEN COLUMN NUMBER 2 AND 3

COLUMN NUMBER 5 IS THE COMBINED CONVECTION AND RADIATION COEFFICIENT BASED ON THE TEMPERATURE DIFFERENCE IN COLUMN NUMBER 4.

COLUMN NUMBER 6 IS THE FLUX PER UNIT AREA WHICH IS EQUAL TO COLUMN NUMBER 4 MULTIPLIED BY COLUMN NUMBER 5.

COLUMN NUMBER 7 IS THE THERMAL CONDUCTIVITY OF THE MATERIAL.

COLUMN NUMBER 8 IS THE THERMAL DIFFUSIVITY OF THE MATERIAL.

COLUMN NUMBER 9 IS THE TEMPERATURE DIFFERENCE (INCREASE) IN THE SURFACE BOUNDARY, WHICH IS CALCULATED AS FOLLOWS:

$$\Delta T_w = \frac{2F_0}{K} \left(\frac{\Delta t}{3.14} \right)^{1/2} \text{ WHICH IS } \Delta T_w = 2 \frac{(CN6)}{(CN7)} \frac{(CN8)(T_u - T_{L-1})^{1/2}}{3.14}$$

WHERE CN = COLUMN NUMBER

FOR INFORMATION ONLY



SUBJECT:

SR	<input checked="" type="checkbox"/>
NSR	<input type="checkbox"/>

COLUMN NUMBER 10 IS THE NEW SURFACE TEMPERATURE AFTER TIME T.

$$TW_2 = TW_1 + \Delta TW$$

$$CN10 = CN3 + CN9$$

WHERE CN = COLUMN NUMBER

COLUMN NUMBER 11 IS THE TOTAL NUMBER OF BTUS APPLIED TO THE STEEL OR CONCRETE.

$$Q_s = F_{0s} \times A_s \times (T_n - T_{n-1})$$

WHERE: s = STEEL

A_s = AREA STEEL FROM TABLE B

(T_n - T_{n-1}) = TIME IN MINUTES

$$CN11 = C_{U6} \times A_s \times (T_n - T_{n-1})$$

WHERE C_U = COLUMN NUMBER

SUBSCRIPT C IS SUBSTITUTED FOR S TO IDENTIFY Q_c FOR CONCRETE.

COLUMN NUMBER 12 IS THE CUMULATIVE SUM OF Q_{s/c} FROM CN11.

REFER TO TABLE A FOR A SAMPLE OF THE CALCULATION TABLE AND LEGEND - WHICH ITEMIZES REFERENCES AND ASSUMPTIONS.

6.2 CALCULATION TABLE & LEGEND

TABLE A

<input checked="" type="checkbox"/> SR <input type="checkbox"/> NSR	1	2	3	4	5	6	7	8	9	10	11	12
	τ MIN	T_f °F	T_{w1} °F	ΔT ($T_f - T_{w1}$)	h_{OAT}	F_0 BTU/HR-FT ²	K	α	ΔT_w °F	T_{w2} °F	$Q_{c/s}$ BTU	$\Sigma Q_{c/s}$ BTU

FOR INFORMATION ONLY


LEGEND:

- τ - MIN. REF 1
- T_f = TEMP (°F) @ τ REF 1
- T_{w1} = TEMP (°F) OF SPACE SURFACE AT τ
- ΔT = TEMP DIFFERENCE - °F = ($T_f - T_{w1}$)
- h_{OAT} = COMBINED CONVECTION AND RADIATION COEFFICIENT = (BTU/HR-FT²-°F) = ($h_c + h_r$).
REF 2; ASSUMPTION 2 & 13
- $F_0 = \Delta T h$ = HEAT FLUX PER UNIT AREA - BTU/HR-FT² - REF 2
- K = THERMAL CONDUCTIVITY - BTU/°F-HR-FT - REF 3; ASSUMPTION 3
- α = THERMAL DIFFUSIVITY - REF 4; ASSUMPTION 4
 $\frac{ft^2}{hr} = (K)(e)(S_f)$
- ΔT_w = INCREASE IN SURFACE TEMP OF FROM $\Delta T_w = 2 \left(\frac{F_0}{K} \right) \left(\frac{\alpha \tau}{316} \right)^{1/2}$ [WHERE b EQUALS TIME IN HOURS]
- T_{w2} = TEMP. OF SPACE SURFACE AFTER TIME τ .
 $T_{w2} = T_{w1} + \Delta T_w$
- $Q_{c/s}$ = TOTAL HEAT IN BTU Q_s (STEEL) / Q_c (CONCRETE) $\times 10^6$
- $\Sigma Q_{c/s}$ = THE TOTAL CUMULATIVE HEAT IN BTU'S $\times 10^6$.

$of = \frac{Q_{c/s}}{h_{\text{OAT}} \times A} = \frac{BTU}{HR-FT^2} \left(\frac{hr \cdot ft^2}{hr} \right)^{1/2}$

CAPITAL AUTHORIZATION NO. _____ DATE 8/28/76
 PREPARED BY JPP DATE 8/28/76
 CHECKED BY MGR DATE 7/13/76
 APPVD BY [Signature] DATE 8/11/76
 SHEET 11 OF 21

CALCULATION SHEET



PRELIMINARY REV _____ DATE _____
 FINAL M-198
 REV 1 DATE _____
 SUBJECT: _____

PRELIMINARY
REV _____ DATE _____
 FINAL M198
REV L DATE _____

CALCULATION SHEET OF
STEEL & CONC. EXPOSED
AREAS FOR THE STEAM
TUNNEL (FROM 56.22 T 46
COLS. HTS J & COL. 9.9 T
12.15)



CAPITAL AUTHORIZATION NO. _____
PREPARED BY J.P. J.P. DATE 8/29/86 9/23/86
CHECKED BY J.P.M.P. DATE 9/23/86 9/23/86
APPVD BY [Signature] DATE 10/4/86
SHEET 12 OF 21

SUBJECT: STEEL & CONC.

6.3 CALCULATION OF CONCRETE & STEEL AREA
STEAM TUNNEL CONCRETE

SR
NSR

SUMMARY
3,664 S.F. AREA CONC.

STEEL
STEEL TABLE
1,640.09 S.F. AREA STEEL

FOR INFORMATION ONLY

PRELIMINARY
 REV. DATE _____
 FINAL M 198
 REV. 1 DATE _____

CALCULATION SHEET

CAPITAL AUTHORIZATION NO. _____
 PREPARED BY JD 999 DATE 8/25/12 9/23/12
 CHECKED BY [Signature] DATE 9/23/12 9/21/12
 APPVD BY [Signature] DATE 10/4/12
 SHEET 13 OF 21



SUBJECT: CONCRETE-STEAM TUNNEL 24' W X 32.67' L X 24' H

REF. DWGS. C-63, C367, C134

SR
 NSR

AREAS

CONC. FL. 24'-0" x 32.67' = 784'

CHEEK WALLS:

① $7'H \times 2'W \times 24'L$
 $7' \times 24' \times 2 = 336' + 2 \times 24' = 48' \text{ TOTAL } \underline{384}'$

② H-LINE
 $13' \times 24' + 3 \times 24' = \underline{384}'$


WALLS

J LINE 24' x 24' = 576'

9.9 LINE 32.67' x 24' = 784'

12.1 LINE SAME AS 9.9 LINE - OPNGS.
 1- 2'-6" x 3'-0" , 1- 3'-5" x 7' (7.5 + 24.5 = 32)' = 752'

TOTAL CONCRETE AREA 3,664 S.F.
 STEAM TUNNEL



FOR INFORMATION ONLY

PRELIMINARY
 REV _____ DATE _____
 FINAL M198
 REV 1 DATE _____

CALCULATION SHEET

CAPITAL AUTHORIZATION NO. _____
 PREPARED BY J.B. GFD DATE 8/24/86 9/23/86
 CHECKED BY WMP DATE 9/23/86 9/23/86
 APPVD BY WMP DATE 10/4/86
 SHEET 14 OF 21



SUBJECT: STEEL STEAM TUNNEL

REF. DWG. C-127

PERIM.

W10 x 49 $\frac{5}{16}$ I ^{10"} 10" = 5'

W12 x 65 $\frac{3}{8}$ I ^{12"} 12.125" = 5.96'

TUBE (HORIZ.) \square 12" = 4'

TUBE (VERT.) \square 12" = 5.66'
 STRUTS $\frac{1}{2}$ 1.10" .83

SR
 NSR

STRUCTURAL STEEL FOR PIPE RESTRAINTS SHOWN ON DRAWING C-367 AND COLUMN ALONG "H" ARE NOT INCLUDED IN THIS CALCULATION (CONSERVATIVE ASSUMPTION).

FOR INFORMATION ONLY

PRELIMINARY
 REV _____ DATE _____
 FINAL M198
 REV 1 DATE _____

CALCULATION SHEET



CAPITAL AUTHORIZATION NO. _____
 PREPARED BY JAB 9/27/86 DATE 9/27/86
 CHECKED BY JAB 9/27/86 DATE 9/27/86
 APPVD BY [Signature] DATE 10/3/86
 SHEET 15 OF 21


SUBJECT: STEAM TUNNEL

METAL SIDING REF. DWG. C-79

S.F.
 264

SR
 NSR

H LINE 11' x 24' =



$53 \frac{1}{2} \div 12 = 4.42' \times 32.67' \times 3 = 433.2$

EL. 23'-2"

REF. DWG. C-127

(12x12) 24' x 4' = 96.
 10 WF 49 DIAG. 2 x 5' x 10' = 100
 " 2 x 5' x 9' = 90

EL. 29'-6 1/4"

(12x12) 24' x 4' = 96.
 12 WF 65 2 x 5.96' x 7.5' = 89.4
 12 WF 65 5.96' x 6.5' = 38.74

EL. 34'-0"

(12x12) 24' x 4' = 96
 12 WF 65 2 x 5.96' x 7.5' = 89.4
 12 WF 65 5.96' x 6.5' = 38.74

VERT. STRUTS, ELEVATION DET. $\frac{12}{C-127}$

EL. 23'-2" UP

QNT.
 (12x1'-10") 2 x 5.66' x 2.5' = 28.3
 2 x 5.66' x 6' = 67.92
 2 x 5.66' x 2' = 22.64

EL. 29'-6 1/4" UP

4 x 5.66' x 4' = 90.56

STEAM TUNNEL TOTAL STEEL. 1,640.09 S.F

FOR INFORMATION ONLY

PRELIMINARY
REV _____ DATE _____
 FINAL **M-198**
REV **L** DATE _____

CALCULATION SHEET



CAPITAL AUTHORIZATION NO. _____
PREPARED BY **JTB JPP** DATE **9/23/86**
CHECKED BY **MP** DATE **9/27/86**
APPVD BY **W** DATE **10/4/86**
SHEET **16** OF **31**

SUBJECT:

6.4 THEORETICAL FIRE LOADING

SR
NSR

A. FUEL LOAD:

1. CABLE INSULATION 200 LB

B. HEAT OF COMBUSTION:

1. INSULATION 21,000 BTU/LB

C. TOTAL THEORETICAL LOAD:

$$200 \text{ LB} \times 21,000 \text{ BTU/LB} = 4.2 \times 10^6 \text{ BTU}$$

THEORETICAL FIRE LOAD APPLIED TO
SPACE BOUNDARY:

$$4.2 \times 10^6 \text{ BTU} \times 40\% = 1.7 \times 10^6 \text{ BTU}$$

[40% ; REF 7]

FOR INFORMATION
ONLY

PRELIMINARY
 REV ___ DATE ___
 FINAL **M-198**
 REV 1 DATE ___

CALCULATION SHEET



CAPITAL AUTHORIZATION NO. _____
 PREPARED BY gjp DATE 8/24/80
 CHECKED BY mgp DATE 2/23/86
 APPVD BY llw DATE 10/14/86
 SHEET **17** OF **21**

SUBJECT:

TABLE 6.5 STEAM TUNNEL

T	STEEL SAY 1200 FT ²										CONCRETE SAY 3700 FT ²									
	2	3	4	5	6	7	8	9	10	11	12	3	4	5	6	9	10	11	12	
0.00	TF	TW	AT	H	FO	K	Q	AT	TN	Q3	SQ3	TW	AT	H	FO	AT	TN	QC	SQ3	
0.01	600	68										68	532	51	270	53	121	1	1	
0.02	700											121	579	5.5	349	63	184	2	3	
0.03	800											184	616	5.8	357	68	252	2	5	
0.04	900											252	648	6.2	401	77	329	2	7	
0.05	1000											329	678	6.4	424	81	410	2	9	
0.10	1300											410	890	9.1	899	85	764	2.4	3.3	
0.15	1344	255	932	1144	1300	1447	1510	1550	1584	1603	1638	7.4	635	6.0	3810	166	930			
0.20	1462	305	1097	1230	1349	1447	1510	1550	1584	1603	1638	930	532	5.1	2713	118	1048			
0.25	1510	464	1096	1144	1192	1230	1268	1306	1344	1382	1420	1048	442	4.5	2079	91	1139			
0.30	1550	554	996	1044	1092	1140	1188	1236	1284	1332	1380	1129	411	4.1	1665	73	1212			
0.35	1584	710	874	922	970	1018	1066	1114	1162	1210	1258	1212	372	3.8	1413	62	1274			
0.40	1603	767	846	894	942	990	1038	1086	1134	1182	1230	1274	339	3.6	1220	54	1328			
0.45	1638	822	816	864	912	960	1008	1056	1104	1152	1200	1128	310	3.4	1054	46	1374			
0.50	1661	873	788	836	884	932	980	1028	1076	1124	1172	1128	287	3.1	890	39	1413			
0.55	1681	919	762	810	858	906	954	1002	1050	1098	1146	1413	268	3.0	804	35	1448			

7 1.7
 3.1
 3.3

 6.4

SR
 NSR

TABLE "B"

Intermittent
 Tunnel
 from

FOR INFORMATION ONLY

PRELIMINARY
REV ___ DATE ___
 FINAL M 198
REV 1 DATE ___

CALCULATION SHEET



CAPITAL AUTHORIZATION NO. _____
PREPARED BY JFB 9/2/86 DATE 2/2/86
CHECKED BY mg DATE 2/2/86
APPVD BY LM DATE 10/1/86
SHEET 18 OF 21

SUBJECT:

6.5 CONTINUED

ENTERING TABLE 'B' AT x

TOTAL THEORETICAL HEAT LOAD

OF 1.7×10^6 BTU WE SEE THAT

AT 0 HRS & 10 MIN THE TOTAL

HEAT LOAD IS $\Sigma Q_s + \Sigma Q_c$

OR $3.1 + 3.3 = 6.4 \times 10^6$ BTU

@ TEMP OF STEEL = 255° F.

THIS HEAT LOAD ENVELOPES

THE ACTUAL LOAD OF 1.7×10^6 BTU

WHICH INDICATES THE EXPOSED STEEL

AVERAGE UNIFORM TEMPERATURE WILL

NOT EXCEED 255° F.

SR
NSR

FOR INFORMATION ONLY

PRELIMINARY
REV _____ DATE _____
 FINAL M 198
REV 1 DATE _____

CALCULATION SHEET



CAPITAL AUTHORIZATION NO. _____
PREPARED BY JFB 9/23/86 DATE 8/27/86
CHECKED BY MD DATE 7/23/86
APPVD BY W DATE 10/4/86
SHEET 19 OF 21

SUBJECT:

1.6 DISCUSSION

SR
NSR

AN EVALUATION OF THE CALCULATIONS INPUT VARIABLES AND CONSERVATIVE ESTIMATES AND ASSUMPTIONS WILL CONCLUDE THAT THE ACTUAL AVERAGE ESTIMATED STEEL TEMPERATURE WILL MOST PROBABLY BE SUBSTANTIALLY LESS THAN THE CALCULATED TEMPERATURE OF 255 OF

1. TRANSIENT COMBUSTIBLES ARE ADMINISTRATIVELY CONTROLLED TO MINIMIZE QUANTITIES IN PLANT AREAS
2. THE HEAT OF COMBUSTION IS THE AMOUNT OF HEAT RELEASED DURING A SUBSTANCE'S COMPLETE OXIDATION (COMBUSTION). THE HEAT OF COMBUSTION IS DETERMINED IN A LABORATORY UTILIZING A "BOMB" CALORIMETER, IN WHICH A KNOWN MASS OF FUEL IS BURNT COMPLETELY IN AN ATMOSPHERE OF PURE OXYGEN. THE ACTUAL HEAT LOAD WILL BE SUBSTANTIALLY LESS DUE TO ACTUAL FIELD CONDITIONS IN

FOR INFORMATION ONLY

PRELIMINARY
REV _____ DATE _____
 FINAL **M-198**
REV **L** DATE _____

CALCULATION SHEET



CAPITAL AUTHORIZATION NO. _____
PREPARED BY **JAS JPD** DATE **9/23/86**
CHECKED BY **Am GP** DATE **7/25/86**
APPVD BY **LM** DATE **10/14/86**
SHEET **20** OF **21**

SUBJECT:

LIEU OF LABORATORY CONDITIONS.

SR

NSR

3. REFERENCE NOT INDICATES THAT THE NORMALIZED HEAT LOAD ON THE COMPARTMENT BOUNDARIES IS ONLY 10-40% OF H_m , "WHERE H_m IS THE CONCEIVABLE ABSOLUTE MAXIMUM HEAT LOAD." APPLYING THE MAXIMUM 40% FACTOR, THE CALCULATED TEMPERATURE OF STEEL IS 255°F.

THIS CALCULATION ASSUMES THAT THE INTERNAL TEMPERATURE OF THE STEEL IS IDENTICAL TO THE SURFACE TEMPERATURE. THIS IS A CONSERVATIVE ASSUMPTION SINCE THE SURFACE HEATS UP FASTER AND IS 100-200 °F HOTTER AFTER EXPOSURE TO THE STANDARD FIRE, I.E. ASTM-E-119, FOR UP TO 60 MIN (Ref 6).

7.0 CALCULATION CONCLUSION

BASED UPON TABLE "B" AND REASONABLE ENGINEERING JUDGEMENT, AS SUPPORTED BY THE DISCUSSION OF THIS CALCULATION'S

FOR INFORMATION ONLY

PRELIMINARY
REV _____ DATE _____
 FINAL M198
REV 1 DATE _____

CALCULATION SHEET



CAPITAL AUTHORIZATION NO. _____
PREPARED BY J.B. J.P.P. DATE 8/24/86
CHECKED BY mg DATE 2/21/86
APPVD BY llc DATE 10/4/86
SHEET 21 OF 21

SUBJECT:

CONSERVATIVE ESTIMATES AND
ASSUMPTIONS, IT IS REASONABLE TO
DEDUCE THAT THE MAXIMUM AVERAGE
ESTIMATED TEMPERATURE WILL BE
LESS THAN 1,000°F.

SR
NSR

FOR INFORMATION ONLY

PRELIMINARY
REV _____ DATE _____
 FINAL **M-198**
REV **L** DATE _____

CALCULATION SHEET



CAPITAL AUTHORIZATION NO. _____
PREPARED BY **JFB** DATE **8/29/86**
CHECKED BY **mgp** DATE **9/13/86**
APPVD BY **W** DATE **10/1/86**
SHEET **1** OF **29**

SUBJECT:

ATTACHMENT NUMBER 1

SR
NSR

REFERENCE

NO OF PAGES

2	1
3 & 4	4
5	1
6	20
7	<u>2</u>

TOTAL NUMBER OF PAGES IN ATT.1 **28 + COVER PAGE**

FOR INFORMATION ONLY

4-106 TRANSMISSION OF HEAT BY CONDUCTION AND CONVECTION

Table 10. Maximum Flux and Corresponding Over-all Temperature Difference for Liquids Boiled at 1 Atm with a Submerged Horizontal Steam-heated Tube

Liquid	Aluminum		Copper		Chromium-plated copper		Steel	
	q/A 1000	(Δt) _s	q/A 1000	(Δt) _s	q/A 1000	(Δt) _s	q/A 1000	(Δt) _s
Ethyl acetate.....	41	70	61	55	77	55		
Benzene.....	51	80	58	70	73	100	82	100
Ethyl alcohol.....	55	80	85	65	124	65		
Methyl alcohol.....	100	95	110	110	155	110
Distilled water.....	230	85	350	75	410	150

For forced-circulation evaporators, vapor binding is also encountered. Thus with liquid benzene entering a 4-pass steam-jacketed pipe at 0.9 fps, up to the point where 60 percent by weight was vaporized, the maximum flux of 60,000 Btu per hr per sq ft was obtained at an over-all temperature difference of 60 F; beyond this point, the coefficient and flux decreased rapidly, approaching the values obtained in superheating vapor, see Eq. (6b). For comparison, in a natural convection evaporator, a maximum flux of 73,000 Btu per hr per sq ft was obtained at (Δt)_s of 100 F.

Combined Convection and Radiation Coefficients. In some cases of heat loss, such as that from bare and insulated pipes, where loss is by convection to the air and radiation to the walls of the enclosing space it is convenient to use a combined convection and radiation coefficient (h_c + h_r). The rate of heat loss thus becomes

$$q = (h_c + h_r)A(\Delta t_s) \quad (15)$$

where (Δt)_s is the temperature difference, deg F, between the surface of the hot body and the walls of the space. In evaluating (h_c + h_r), h_c should be calculated by the appropriate convection formula [see Eqs. (11c) to (11g)] and h_r from the equation

$$h_r = 0.00685\epsilon(T_{av}/100)^3$$

where ε is the black body coefficient of the radiating surface, p. 4-111, T_{av} is the average temperature of the surface and the enclosing walls, deg R. For oxidized bare steel pipe, the sum h_c + h_r may be taken directly from Table 11.

Table 11. Values of (h_c + h_r)

(For horizontal bare or insulated standard steel pipe of various sizes and for flat plates in a room at 80 F)

Nominal pipe diam. in.	(Δt) _s temperature difference, deg F, from surface to room														
	50	100	150	200	250	300	400	500	600	700	800	900	1000	1100	1200
1/8	2.12	2.48	2.76	3.10	3.41	3.75	4.47	5.30	6.21	7.25	8.40	9.73	11.20	12.81	14.65
1	2.03	2.38	2.65	2.98	3.29	3.62	4.33	5.16	6.07	7.11	8.25	9.57	11.04	12.65	14.48
2	1.93	2.27	2.52	2.85	3.14	3.47	4.18	4.99	5.89	6.92	8.07	9.38	10.85	12.46	14.28
4	1.84	2.16	2.41	2.72	3.01	3.33	4.02	4.83	5.72	6.75	7.89	9.21	10.66	12.27	14.09
8	1.76	2.06	2.29	2.60	2.89	3.20	3.88	4.68	5.57	6.60	7.73	9.05	10.50	12.10	13.93
12	1.71	2.01	2.24	2.54	2.82	3.13	3.83	4.61	5.50	6.52	7.65	8.96	10.42	12.03	13.84
24	1.64	1.93	2.15	2.45	2.72	3.03	3.70	4.48	5.37	6.39	7.52	8.83	10.28	11.90	13.70
FLAT PLATES															
Vertical.....	1.82	2.13	2.40	2.70	2.99	3.30	4.00	4.79	5.70	6.72	7.86	9.18	10.64	12.25	14.06
HFU.....	2.00	2.35	2.65	2.97	3.26	3.59	4.31	5.12	6.04	7.07	8.21	9.54	11.01	12.63	14.45
HFD.....	1.58	1.85	2.09	2.36	2.63	2.93	3.61	4.38	5.27	6.27	7.40	8.71	10.16	11.76	13.57

HFU, horizontal, facing upward; HFD, horizontal, facing downward.

Heat Transmission through Pipe Insulation. (McMillan, Trans. ASME, 1915.)
 For any number of layers of insulation on any size of pipe, Eqs. (8), (4), and (16)

combine to give

$$\frac{q}{A}$$

where q/A is the Btu per sq ft per deg F, all temperature difference




FIG. 6. Variation with k = 0.042.

outer surface; r_i is the layer of insulation, fcc etc., are the conductivities, h_c + h_r is often taken will have but little effect U, with pipe size and temperatures of 375 and 75 F,

FOR INFORMATION ONLY

51c 1

ASME SECTION VIII - DIVISION 2 Table 1

TABLE 1
 NOMINAL COEFFICIENTS OF THERMAL CONDUCTIVITY (TC) AND THERMAL DIFFUSIVITY (TD)*
 Carbon and Low Alloy Steels

Temp., F	Plain Carbon		Carbon-Silicon		C-Mn		C-Mn-Si		Mat'l. Group A'		Mat'l. Group B'		Mat'l. Group C'	
	TC	TD	TC	TD	TC	TD	TC	TD	TC	TD	TC	TD	TC	TD
70	35.1	0.475	30.0	0.582	27.5	0.529	23.6	0.454	24.8	0.482	21.3	0.414	24.2	0.471
100	34.7	0.474	29.9	0.567	27.6	0.512	23.9	0.443	25.0	0.477	21.5	0.409	24.3	0.464
150	34.1	0.465	29.6	0.544	27.6	0.496	24.2	0.433	25.1	0.466	21.8	0.400	24.4	0.452
200	33.6	0.457	29.2	0.521	27.6	0.486	24.4	0.422	25.2	0.454	21.9	0.391	24.4	0.439
250	32.9	0.449	28.9	0.502	27.4	0.467	24.4	0.414	25.2	0.442	22.0	0.382	24.3	0.426
300	32.3	0.441	28.4	0.481	27.2	0.453	24.4	0.406	25.1	0.430	22.0	0.373	24.2	0.414
350	31.6	0.434	28.0	0.464	27.0	0.440	24.3	0.396	25.0	0.418	22.0	0.365	24.0	0.402
400	30.9	0.427	27.6	0.447	26.7	0.428	24.2	0.386	24.8	0.405	21.9	0.356	23.9	0.390
450	30.3	0.420	27.1	0.430	26.3	0.413	23.9	0.375	24.6	0.394	21.8	0.347	23.6	0.378
500	29.5	0.412	26.6	0.414	25.9	0.398	23.7	0.364	24.3	0.381	21.7	0.337	23.4	0.367
550	28.8	0.405	26.1	0.398	25.5	0.387	23.4	0.355	24.0	0.370	21.5	0.327	23.1	0.355
600	28.0	0.397	25.6	0.385	25.0	0.374	23.1	0.346	23.7	0.359	21.3	0.320	22.7	0.344
650	27.3	0.390	25.1	0.370	24.5	0.360	22.7	0.333	23.4	0.348	21.0	0.310	22.3	0.333
700	26.6	0.383	24.6	0.355	24.0	0.346	22.4	0.320	23.0	0.335	20.8	0.299	22.0	0.320
750	25.9	0.376	24.0	0.337	23.5	0.332	22.0	0.308	22.6	0.322	20.5	0.288	21.6	0.307
800	25.2	0.369	23.5	0.323	23.0	0.318	21.7	0.298	22.2	0.308	20.2	0.278	21.2	0.295
850	24.5	0.362	23.0	0.309	22.6	0.305	21.2	0.286	21.9	0.297	20.0	0.268	20.9	0.283
900	23.8	0.355	22.5	0.296	22.1	0.291	20.9	0.274	21.4	0.283	19.7	0.258	20.5	0.271
950	23.1	0.348	21.9	0.281	21.5	0.277	20.5	0.262	20.9	0.269	19.4	0.248	20.1	0.259
1000	22.4	0.341	21.4	0.267	21.0	0.263	20.0	0.248	20.4	0.256	19.1	0.238	19.8	0.248
1050	21.6	0.334	20.8	0.252	20.5	0.249	19.6	0.237	19.9	0.242	18.8	0.227	19.4	0.236
1100	20.9	0.327	20.2	0.236	19.9	0.237	19.2	0.228	19.5	0.230	18.5	0.216	19.1	0.225
1150	20.2	0.320	19.6	0.221	19.3	0.219	18.7	0.213	18.9	0.215	18.2	0.204	18.7	0.213
1200	19.5	0.313	19.0	0.206	18.7	0.202	18.2	0.197	18.4	0.202	17.7	0.192	18.2	0.199
1250	18.7	0.306	18.3	0.189	18.0	0.184	17.5	0.179	17.7	0.185	17.2	0.178	17.6	0.184
1300	18.0	0.299	17.6	0.172	17.1	0.159	16.7	0.155	16.7	0.164	16.5	0.161	16.9	0.166
1350	17.2	0.292	16.8	0.151	16.2	0.122	15.8	0.119	15.9	0.142	15.3	0.138	15.6	0.135
1400	16.4	0.285	16.2	0.062	15.6	0.078	15.3	0.077	15.3	0.077	15.0	0.076	15.3	0.077
1450	15.9	0.278	15.7	0.137	15.2	0.155	15.1	0.154	15.0	0.128	14.9	0.130	15.1	0.128
1500	15.7	0.271	15.6	0.180	15.1	0.169	15.1	0.169	15.0	0.199	14.8	0.171	15.0	0.199

FOR INFORMATION ONLY

FOR INFORMATION ONLY

2.9. The semi-infinite solid. The flux of heat at $x = 0$ prescribed function of the time. Zero initial temperature

(i) Constant flux, F_0 per unit time per unit area. BTU/FT².HR

The flux
$$f = -K \frac{\partial v}{\partial x}, \quad (1)$$

satisfies the same differential equation as v , namely

$$K \frac{\partial^2 f}{\partial x^2} = \frac{\partial f}{\partial t}, \quad x > 0, t > 0. \quad (2)$$

The solution of (2) with

$$f = F_0, \quad \text{constant}, \quad x = 0, t > 0, \quad (3)$$

is, by 2.4 (10),
$$f = F_0 \operatorname{erfc} \frac{x}{2\sqrt{\kappa t}}. \quad (4)$$

Thus, from (1), using Appendix II, (9) and (11),

$$v = \frac{F_0}{K} \int_0^x \operatorname{erfc} \frac{x}{2\sqrt{\kappa t}} dx \quad (5)$$

$$= \frac{2F_0\sqrt{\kappa t}}{K} \operatorname{ierfc} \frac{x}{2\sqrt{\kappa t}} \quad (6)$$

$$= \frac{2F_0}{K} \left(\frac{\kappa t}{\pi} \right)^{\frac{1}{2}} e^{-x^2/4\kappa t} - \frac{x}{2} \operatorname{erfc} \frac{x}{2\sqrt{\kappa t}}. \quad (7)$$

A table of values of the function $\operatorname{ierfc} x$ is given in Appendix II.

The temperature at $x = 0$ is given by

$$\frac{2F_0}{K} \left(\frac{\kappa t}{\pi} \right)^{\frac{1}{2}}. \quad (8)$$

The boundary condition of constant flux is of considerable practical importance. It appears if heat is generated by a flat heating element carrying electric current, if heat is generated by friction, and as an approximation in the early stages of heating a furnace or a room. It has also important applications to problems on diffusion. The cooling of the Earth's surface after sunset on a clear windless night† is very nearly that due to removal of heat at a constant rate per unit area per unit time, thus (8) gives the way in which the surface temperature falls after sunset.

The results above apply also to the case of the region $-\infty < x < \infty$ with heat supply $2F_0$ in the plane $x = 0$. The corresponding results for

† Cf. Brunt, *Quart. J. R. Met. Soc.* 58 (1932) 289.



National Research
Council Canada

Conseil national
de recherches Canada

REF NO 6
CALC ~~SR~~ M-198 REV-1
ATTACH. I

pg 5/~~29~~
29

FIRE RESISTANCE OF UNPROTECTED STEEL COLUMNS

BY

W. W. STANZAK AND T. T. LIE

REPRINTED FROM
JOURNAL OF THE STRUCTURAL DIVISION, ASCE,
VOL 99, NO. 575, PROC. PAPER 9719, MAY 1973
P. 837 - 852

RESEARCH PAPER NO. 577
OF THE
DIVISION OF BUILDING RESEARCH

OTTAWA

PRICE 25 CENTS

NRCC 18869

FOR INFORMATION
ONLY

FOR INFORMATION
ONLY

Page 29

M-138 REV-1
ATTACH: I

LA RESISTANCE AU FEU DES POUTRES D'ACIER
NON PROTEGEES

SOMMAIRE

Les auteurs étudient la résistance au feu des poutres d'acier non protégées au moyen d'essais d'incendie standards et de l'analyse numérique. On a découvert que la durée de la résistance au feu varie selon le facteur forme du poids de la poutre divisé par le périmètre chauffé. Les auteurs ont établi deux équations simples pour calculer les durées de résistance au feu des poutres d'acier non protégées et ils recommandent de les utiliser dans les normes du bâtiment.

FOR INFORMATION
ONLY

FOR INFORMATION
ONLY

JOURNAL OF THE STRUCTURAL DIVISION

PP 7/29
M-198 REV-1
ATTACH. I

FIRE RESISTANCE OF UNPROTECTED STEEL COLUMNS

By W. W. Stanzak¹ and T. T. Lie²

In the past the fire resistance of unprotected steel columns has been considered so small a quantity that it could be ignored. Fire experience and controlled fire tests on structural steel columns of small cross-sectional area showed that unprotected steel columns could not survive the effects of fire exposure for more than 10 min to 20 min. However, it will now be shown that the heavier columns required to carry the vertical loads in modern high-rise buildings are capable of much better fire performance than had previously been realized, and that some can attain fire resistance classifications of 1 hr or better.

Fire fatality statistics (1) show that the number of deaths attributable to structural collapse during a building fire is negligible. The main causes of life loss have been shown to be asphyxiation and burns (1,3,7). Therefore, to provide life safety to occupants, enough fire resistance to allow people time to escape must be provided. Except where escape routes are extremely long or the number of occupants is very large, 10 min to 20 min is usually assumed to be sufficient. However, with very tall buildings it has become evident that evacuation by stairs can be so time consuming that complete evacuation is impractical (4). In such buildings sufficient fire resistance to withstand a burnout of the contents must be provided.

Provision of fire resistance beyond that required to prevent life loss is determined largely by economic considerations. A recent study on the optimum fire resistance of structures (11) has shown that for buildings with a small-loss poten-

Note.—Discussion open until October 1, 1973. To extend the closing date one month, a written request must be filed with the Editor of Technical Publications, ASCE. This paper is part of the copyrighted Journal of the Structural Division, Proceedings of the American Society of Civil Engineers, Vol. 99, No. ST5, May 1973. Manuscript was submitted for review for possible publication on June 9, 1972.

¹Steel Industries Fellow, Fire Research Sect., Div. of Building Research, National Research Council of Canada, Ottawa, Canada.

²Research Officer, Fire Research Sect., Div. of Building Research, National Research Council of Canada, Ottawa, Canada.

that it would be uneconomical to provide any fire protection beyond that inherent in the structure, provided such fire resistance is sufficient to allow evacuation by the occupants. Buildings representing a small-loss expectation are those that are small in size and not valuable; those with no valuable contents; those for which the probability of a serious fire is low (e.g., completely sprinklered buildings); or those having a low fire load. The use of unprotected steel columns in such buildings is generally justified if these elements have the minimal fire resistance required to prevent loss of life.

Accordingly, the writers have investigated the fire resistance of unprotected steel columns by methods of numerical calculation and by full-scale fire tests in their laboratory, with a view to developing simple expressions for calculating the fire resistance of these building elements.

TEST METHODS AND CRITICAL TEMPERATURE

On this continent, two test methods are acceptable. The most recent ASTM Standard prescribing these is E119-71 (16).

The older load test requires a sample at least 9 ft in length to be tested under an applied load calculated to develop theoretical working stresses contemplated by the design. The column is required to sustain the applied load for a period of fire exposure equal to that for which classification is desired.

The newer alternate test of protection for structural steel columns requires that a sample at least 8 ft in length be tested in a vertical position without applied load. This test is applicable when the protection is not required by design to carry any part of the column load. The applied protection must be restrained against longitudinal thermal expansion greater than that of the steel column. Temperatures are measured by at least three thermocouples located at each of four levels (cross sections). The upper and lower levels are 2 ft from the ends of the steel column, and the two intermediate levels are equally spaced. The test is considered successful if the transmission of heat through the protection, during the period of fire exposure for which classification is desired, does not raise the average (arithmetical) temperature of the steel to any level above 1,000° F (538° C), or above 1,200° F (649° C) at any one of the measured points.

The 1,000° F average allowable temperature that usually determines the fire endurance time in a test may be regarded as a critical temperature for structural failure established for protected columns as a result of many fire tests on axially loaded column sections. Thus, for the analysis in this paper, it has been assumed that structural failure is imminent when the steel cross section attains an average temperature of 1,000° F as all calculations and fire tests were made on the basis of heat conduction alone.

While complete theoretical justification for the use of temperature criteria is beyond the scope of this paper, it can readily be shown that 1,000° F is a reasonable value. For long columns, assuming that the member is uniformly heated, the buckling stress is given by Euler's formula:

$$\sigma_{cr} = \frac{\pi^2 E I}{\lambda^2} \dots \dots \dots (1)$$

and the allowable design stress for long columns is given by CSA S16-1969 (17) as:

$$\sigma_n = \frac{\pi^2 E_n}{1.92 \lambda^2} \dots \dots \dots (2)$$

in which 1.92 is a safety factor prescribed by the Code and $\sqrt{286,000 / \sigma_n}$, $= 13 < \lambda \leq 200$.




FIG. 1.—Average Compressive Properties of ASTM A36 Structural Steel

At elevated temperatures failure is due to occur when the left-hand sides of the equations are equal, i.e.:

$$E_n = \frac{E_n}{1.92} \dots \dots \dots (3)$$

Accepting the commonly assumed value for carbon steels of $E_n = 29 \times 10^3$ ksi, then

$$E_n = 15.1 \times 10^3 \text{ ksi } (104 \times 10^9 \text{ N/m}^2) \dots \dots \dots (4)$$

Using Fig. 1, based on data reported by Ingberg and Sale (10), it is found that the temperature at buckling is approximately 1000° F (537° C). Fire tests of loaded columns (9) have shown that the point of maximum expansion (approximately the point at which the column buckles) is followed by a further 100° F-150°

F (55° C-83° C) rise in temperature before complete failure of the column occurs. Thus failure of columns can be expected at cross-sectional temperatures of from 950° F-1,050° F, (510° C-565° C), depending on the design method and slenderness ratio. A value of 1,000° F has been assumed as a reasonable average for any column, as has been indicated by the ASTM fire test standard.

TEMPERATURE RISE IN UNPROTECTED STEEL COLUMNS

The column is exposed on four sides to the heat of a fire that follows approximately the temperature-time course prescribed in ASTM E119 for the standard fire of "controlled extent and severity." Heat is transferred from the flames in the furnace and from the furnace walls to the specimen by convection and radiation, with radiation as the primary mechanism when the flames have sufficient thickness (18). The coefficient of heat transfer (the quantity of heat received per unit area of the column, per unit time, and temperature difference between the column surface and fire) depends on many factors. The most significant are: emissivity of the flames; thickness of the flames between furnace walls and column; size of specimen; and thermal properties of the furnace walls. Experimental data (5) have indicated that the heat transfer to the specimen in test furnaces approximates the radiative heat transfer from a black body at the so-called "furnace temperature." Similar heat transfer may also be expected in most building fires because the flames are luminous and usually have considerable thickness, giving them a correspondingly high emissivity.

The coefficient of heat transfer can vary significantly, however, for different individual conditions, and the effect of varying this quantity will be examined later herein.

CALCULATION OF TEMPERATURE RISE

Two-Dimensional Numerical Procedure.—To determine the temperature distribution in massive square steel columns, a number of calculations based on a two-dimensional procedure (12) were carried out. In these tests black body radiation at the prescribed furnace temperature was assumed as the only mechanism of heat transfer. The two equations used for the calculation are:

T_{i,n}^{t+1} = T_{i,n}^t + \frac{\Delta t}{(\rho c)_{i,n}^t (\Delta \xi)^2} \{ [k_{2,2n-1}^t + k_{i,n}^t] [T_{2,2n-1}^t - T_{i,n}^t] + [k_{2,2n-1}^t + k_{i,n}^t] [T_{2,2n-1}^t - T_{i,n}^t] + 2 \sqrt{2} \Delta \xi \sigma \epsilon_s [(T_f^t)^4 - (T_{i,n}^t)^4] \} \dots (5)

for the temperature of an elementary surface element of the column, and

T_{o,n}^{t+1} = T_{o,n}^t + \frac{1}{2} \frac{\Delta t}{(\rho c)_{o,n}^t (\Delta \xi)^2} \{ [k_{i,m-1,2n-1}^t + k_{o,n}^t] [T_{i,m-1,2n-1}^t - T_{o,n}^t] - T_{o,n}^t + [k_{i,m-1,2n-1}^t + k_{o,n}^t] [T_{i,m-1,2n-1}^t - T_{o,n}^t] [k_{i,m-1,2n-1}^t] + k_{o,n}^t [T_{i,m-1,2n-1}^t - T_{o,n}^t] + [k_{i,m-1,2n-1}^t + k_{o,n}^t] [T_{i,m-1,2n-1}^t - T_{o,n}^t] \} \dots (6)

for the temperature at any point inside the steel cross section, in which T is expressed in degrees Rankine and t in hours. It should be noted that the

M-198 REV-1
ATTACH - I

term, ϵ , in Eq. 5 is, strictly speaking, a material and temperature dependent quantity, but it is sufficiently accurate, for the purpose of this study, to be regarded as a constant. Also, since most building materials have emissivities in the range of 0.85 to 0.95 (13) a value of 0.9 was used, although the results indicated that a value of 0.95 would have been more appropriate.

The dependence of the thermal properties of steel on temperature was taken into account in the calculations. The material properties used were derived

TABLE 1.—Thermal Properties of Steel

Temperature, in degrees Fahrenheit (1)	Volumetric heat capacity, in British thermal units per cubic foot-degrees Fahrenheit (2)	Thermal conductivity, in British thermal units per foot-hour-degrees Fahrenheit (3)
70	54.30	26.60
100	54.86	26.60
200	56.36	26.82
300	58.27	26.43
400	60.35	25.87
500	62.44	25.34
600	64.90	24.71
700	67.52	23.72
800	70.56	22.80
900	74.59	21.86
1,000	80.32	21.06
1,100	85.72	20.07
1,200	90.52	18.98
1,250	94.29	18.55
1,300	127.85	18.16
1,350	164.15	17.87
1,400	117.75	17.60
1,450	84.58	17.34
1,500	66.16	16.78
1,550	62.23	15.69
1,600	60.74	15.26
1,650	62.01	15.45
1,700	66.09	15.48
1,800	67.96	16.03
2,100	69.65	16.85
2,350	70.97	17.56


from available data (15) and are reproduced in Table 1. As is apparent, the involved nature of the calculation makes utilization of a high speed digital computer almost mandatory.

Calculated temperature profiles for a 6-in. (0.152-m) square unprotected steel column are shown in Fig. 2 at 40-min intervals. Similar profiles for a 12-in. (0.304-m) square column are shown in Fig. 3 after 50-min and 60 min of fire exposure. Fig. 3(b) shows that at 60 min the maximum temperature difference between the surface and the core was 225° F (125° C) and the temperature at


FOR INFORMATION
ONLY

FOR INFORMATION
ONLY

MA-198 REV-1
ATTACH. I



(a) 10 MIN




(b) 20 MIN


FIG. 2.—Temperature Rise in Unprotected Steel Square Column (6 in.)

FOR INFORMATION
ONLY

FOR INFORMATION
ONLY



(c) 30 MIN



(d) 40 MIN.

FIG. 2—Continued

the point midway between the surface and core was about 1,000° F. From Figs 2(c) and 2(d) it is seen that the maximum temperature difference between the surface of the 6-in. column and the core is about 100° F. This can be regarded as a reasonable maximum for most steel columns likely to be encountered in building practice. For the purpose of determining fire endurance time by temperature rise, the temperature at the point halfway between the surface and core of the cross section (or flange in the case of a wide flange section) may be regarded as representing the average temperature of the cross section. For all but very thick sections this temperature will be almost equal to the temperature at the column surface.

Fig. 4 shows temperature rise curves for a 6-in. square column (calculated or measured as was just described). As is seen, the assumption of radiative heat transfer only does not adequately represent the conditions prevailing in




FIG. 3.—Temperature Rise in Unprotected Steel Column (12 in.)

M-198 REV-1
ATTACH. I

the DRR/NCR furnace when short fire endurance times are involved. The curve labeled (2) in Fig. 4 was calculated by assuming that 20% of the heat transfer is due to convection and produces good agreement with the experimental result. Unfortunately, this finding is of no general value because the convective heat transfer varies with each individual situation. With most fires of short duration the convection component of heat transfer can be in the order of 10% to 20%. In the calculation the effect of convective heat transfer was simulated by raising ϵ from 0.9 to the fictitious value of 1.1.

The heat transfer coefficients to columns of square cross section were calculated based on an emissivity (ϵ) of 0.9 using results obtained by Eqs. 5 and 6. The results are shown in Fig. 5, where the coefficient of heat transfer has been plotted as a function of the duration of standard fire exposure. As is seen, the heat transfer coefficient rises almost linearly with time, and the smaller

h
1.1

1.0
1.0

6
nc
4

1327	1276	1237	1207	1188	1179	1179	1188	1207	1237	1276	1327
1244	1207	1188	1156	1132	1137	1142	1156	1181	1217	1264	1327
1207	1155	1117	1091	1078	1070	1079	1091	1117	1153	1207	1276
1217	1155	1109	1076	1055	1041	1041	1055	1076	1109	1155	1217
1237	1184	1109	1069	1042	1026	1021	1026	1042	1069	1109	1184
1181	1117	1069	1035	1013	1003	1003	1013	1035	1069	1117	1181
1207	1133	1076	1035	1007	981	985	981	1007	1035	1076	1133
1156	1091	1042	1007	980	974	974	980	1007	1042	1091	1156
1188	1112	1055	1013	985	968	963	968	985	1013	1055	1112
1142	1075	1026	991	968	957	957	968	991	1026	1075	1142
1179	1103	1041	1003	974	957	952	957	974	1003	1041	1103
1137	1070	1021	985	963	952	952	963	985	1021	1070	1137
1179	1103	1041	1003	974	957	952	957	974	1003	1041	1103
1142	1075	1026	991	968	957	957	968	991	1026	1075	1142
1188	1112	1055	1013	985	968	963	968	985	1013	1055	1112
1207	1133	1076	1035	1007	981	985	981	1007	1035	1076	1133
1181	1117	1069	1035	1013	1003	1003	1013	1035	1069	1117	1181
1237	1184	1109	1069	1042	1026	1021	1026	1042	1069	1109	1184
1217	1155	1109	1076	1055	1041	1041	1055	1076	1109	1155	1217
1276	1207	1155	1117	1091	1078	1070	1079	1091	1117	1155	1207
1244	1207	1184	1153	1132	1137	1142	1153	1184	1207	1244	
1327	1244	1217	1181	1156	1142	1142	1156	1181	1217	1244	1327

(b) 60 MIN

FIG. 3—Continued

FOR INFORMATION ONLY

FOR INFORMATION ONLY

M-198 REV-1
ATTACH. I

the column the higher the coefficient of heat transfer.

One-Dimensional Numerical Procedure.—The temperature distributions, determined by the two-dimensional calculation method described previously, show




FIG. 4—Temperature Rise Curves, 6 x 6 Solid Column




FIG. 5—Coefficients of Heat Transfer for Unprotected Columns During Exposure to Standard Fire

that the temperature differences in the steel are relatively small, except for very thick sections. Most columns used in buildings have sections less than 10 in. (0.25 m) thick. In such cases detailed calculation of temperature distribution in the steel cross section is unnecessary, and a one-dimensional model of the

M-198 REV-1
ATTACH. I

heated column can be usefully employed. The model consists of a steel plate having the same cross-sectional and surface areas per unit height as the four sides of the heated column, with the edges and exposed side perfectly insulated. This model permits use of a one-dimensional numerical procedure by which

TABLE 2.—Sample Calculation for 10-in. Square Column

t (1)	T _s (2)	T _c (3)	(T _s - T _c) (4)	ΔT _s (5)	T _c (6)
0	70	533	465	58	70
5	1,000	1,150	1,022	128	128
10	1,300	1,350	1,044	137	256
15	1,399	1,431	1,038	130	393
20	1,462	1,486	963	120	523
25	1,510	1,530	887	111	643
30	1,550	1,567	813	102	754
35	1,584	1,599	743	93	856
40	1,613	1,626	677	85	949
45	1,638				1,034

Note: α = 18.45; c = 0.12; D = 3.33; W = 340; ΔT_s = 0.125 (T_s - T_c) for Δt = 1/12 hr.




FIG. 6.—Temperature Rise of Square Solid Steel Columns (Calculated, α = 18.65)

the temperature of the steel cross section can be calculated with only a desk calculator or slide rule. In the calculation, with each interval of time, Δt, the rise in steel temperature, ΔT_s, is given by:

$$\Delta T_s = \frac{\alpha}{c} \frac{D}{W} (T_s - T_c) \Delta t \dots \dots \dots (7)$$

PP 18/29
M-198 REV-1
ATTACH. I




FIG. 8.—Fire Endurance of Square Columns (Experimental)




FIG. 7.—Temperature Rise of Square Solid Steel Columns (Experimental data)

FOR INFORMATION ONLY

FOR INFORMATION ONLY

M-198 REV-1
ATTACH. I

in which Δt is expressed in hours. The results of sample calculation for a 10-in. square column with $a = 18.45$ (104.8) and $c = 0.12$ (502) are shown in Table 2. A family of temperature rise curves obtained by similar calculations is shown by the solid lines in Fig. 6.

Experimental Results.—To obtain information on the temperature rise of unprotected steel columns in the DBR/NRC floor furnace, five fire tests were carried out on square solid columns of various cross section. The temperatures measured at the point halfway between the surface and the core at mid-height of the columns are plotted in Fig. 7. Fig. 8 shows a plot of fire endurance time versus the dimensional parameter, W/D , on logarithmic scales. As is seen, the relationship is linear and, from the graph, it is possible to obtain the following relation directly:

$$t = 10.3 \left(\frac{W}{D} \right)^{29.5} \dots \dots \dots (8)$$

in which $W/D < 10$. To obtain a relation for columns whose $W/D \geq 10$,




FIG. 9.—Built-up Column—3 Plates

a straight line temperature rise for the 16-in. square column is assumed, as shown by the dashed line in Fig. 7. From this it is possible to obtain the relation:

$$T_c = 120 \left(\frac{D}{W} \right)^{0.2} \dots \dots \dots (9)$$

and by setting T_c equal to the critical temperature of 3,000° F:

$$t = 8.3 \left(\frac{W}{D} \right)^{0.2} \dots \dots \dots (10)$$

The lines resulting from Eq. 9 are plotted in Figs. 6 and 7 (dashed lines). The line resulting from Eq. 10 is plotted in Fig. 8 and that equation should be used for columns having $W/D \geq 10$. However, as is seen from Fig. 7,

M-198 REV-1
ATTACH. I

it can be conservatively applied to any column section, and provides a relation that could readily be incorporated into a building by-law. (Although the experimental data are confined to solid square columns, numerical analyses show that Eqs. 9 and 10 can apply to any shape of cross section.)

As an example of the fire resistance typical in columns of very tall buildings, a calculation for the section shown in Fig. 9, one of several massive sections used in Toronto's 56-story Toronto Dominion Centre, is worked out:

$$D = 2(30 + 16) + 2(30 - 7) + 2(10) = 174 \text{ in.} \quad (11)$$

$$W = 1.870 \text{ lb per ft.} \quad \frac{W}{D} = 10.75 \quad (12)$$

Eq. 10 yields a fire endurance time of:

$$t = 8.3(10.75)^{0.8} = 56 \text{ min} \quad (13)$$

As is seen, these massive sections can have fire endurance times approaching 1 hr. even when unprotected.

Recent North American practice has seen increased installation of sprinkler systems in large (especially tall) buildings, including some that are not considered to have a very high fire load (2,6). Once complete sprinklering of high buildings becomes more common, the use of unprotected massive column sections with a fire resistance capability of about 1 hr should prove adequate for fire safety, provided that the fire load is no more than 5 lb/sq ft to 10 lb/sq ft, which should not result in a fire of severity greater than a 1-hr standard fire (8). (Fire load is the heat of combustion of the combustible contents expressed in equivalent pounds of wood per unit floor area.) It can be reasonably deduced from Refs. 4 and 14 that no safety factor need be applied to the actual fire load if the building is fully sprinklered, although such a safety factor is implied by all current North American building regulations now in force.

ACKNOWLEDGMENTS

This paper is a contribution from the Division of Building Research, National Research Council of Canada, and is published with the approval of the Director of the Division.

APPENDIX I.—REFERENCES

1. Chandler, S. E., "Deaths in Fires Attended by Fire Brigades in 1969," *Fire Research Technical Paper No. 26*, H. M. Stationery Office, London, England, 1970.
2. "Fire Protection for High-Rise Buildings," *Building Systems Design*, Sept., 1971.
3. Gaultbreath, M., "Fire in High Buildings," *Fire Study No. 21*, Division of Building Research, National Research Council of Canada, Ottawa, Canada, 1968.
4. Gaultbreath, M., "Time of Evacuation by Stairs in High Buildings," *Fire Fighting in Canada*, Feb., 1969.
5. Harnathy, T. Z., "Thermal Performance of Concrete Masonry Walls in Fire," *Special Technical Publication No. 464*, American Society for Testing and Materials, 1970, pp. 20N-243.
6. "High Rise, Tall Dilemma," *News Bulletin*, Canadian Automatic Sprinkler Association, May-Aug., 1971.
7. Hutcheon, N. B., and Shorter, G. W., "Smoke Problems in Highrise Buildings."

FOR INFORMATION
ONLY

FOR INFORMATION
ONLY

M-198 REV-1
ATTACH. I

ST5

FIRE RESISTANCE

pg 21/ ~~22~~
851 29

- ASHRAE *Journal*, American Society of Heating Refrigerating and Air Conditioning Engineers, Vol. 10, No. 9, 1968, pp. 57-61.
8. Ingberg, S. H., "Tests of Severity of Building Fires," *Quarterly*, National Fire Protection Association, Vol. 22, No. 43, 1928.
 9. Ingberg, S. H., et al., "Fire Tests of Building Columns," *Technologic Papers of the Bureau of Standards*, No. 184, 1921.
 10. Ingberg, S. H., and Sale, P. D., "Compressive Strength and Deformation of Structural Steel and Cast-Iron Shapes at Temperatures up to 900° C (1742° F)," *Proceedings of the American Society for Testing and Materials*, Vol. 26, No. 11, 1926.
 11. Lee, I. T., "Optimum Fire Resistance of Structures," *Journal of the Structural Division*, ASCE, Vol. 98, No. ST1, Proc. Paper 8638, Jan., 1972, pp. 215-232.
 12. Lee, I. T., and Harmathy, T. Z., "A Numerical Procedure to Calculate the Temperature of Protected Steel Columns Exposed to Fire," NRCC 12535, National Research Council of Canada, Division of Building Research, Mar., 1972.
 13. Lee, I. T., Touloukian, Y. S., and Lambill, W. R., "Physical and Chemical Data," Sect. 3, *Chemical Engineers Handbook*, J. H. Perry, ed., McGraw-Hill Book Co., Inc., New York, N.Y., 1963.
 14. "Norme di sicurezza per la protezione contro il fuoco dei fabbricati a struttura in acciaio destinati ad uso civile" ("Safety Standards for the Fire Protection of Structural Steel Buildings Intended for Civilian Use"), *Circolare N. 91*, Ministero dell'Interno, Direzione Generale dei Servizi Antincendi, Rome, Italy, 1961. (Available as NRC Technical Translation TT-1347, Ottawa, Canada, 1968).
 15. *Physical Constants of Some Commercial Steels at Elevated Temperatures*, British Iron and Steel Research Association, Butterworths Scientific Publications, London, England, 1953.
 16. "Standard Methods of Fire Tests of Building Construction and Materials," *ASTM Designation E119-71*, Pt. 14, *1971 Book of ASTM Standards*, American Society for Testing and Materials, 1971.
 17. *Steel Structures for Building*, CSA S16-1969, Canadian Standards Association, Ottawa, Canada, 1969.
 18. Trinks, W., and Mawhinney, M. W., *Industrial Furnaces*, Carnegie Institute of Technology, John Wiley and Sons, Inc., New York, N.Y., 1961.

APPENDIX II.—NOTATION

The following symbols are used in this paper:

- c = specific heat of steel, in British thermal units per pound—degrees Fahrenheit (or degrees Rankine) (joules per kilogram—degrees Kelvin);
- D = heated perimeter, in inches (meters);
- E = modulus of elasticity of steel, in kips per square inch (newtons per square meter);
- FE = fire endurance time, in minutes;
- k = thermal conductivity, in British thermal units per foot-hour-degrees Fahrenheit (watts per meter-degrees Kelvin);
- T = temperature, in degrees Fahrenheit (degrees Celsius);
- t = time, in minutes (unless specified otherwise);
- W = mass of steel section, in pounds per foot (kilograms per meter);
- α = coefficient of heat transfer, in British thermal units per foot-hour-degrees Fahrenheit (watts per meter-degrees Kelvin);
- Δ = increment;
- $\Delta \xi$ = mesh width, in feet (meters);
- e = emissivity;
- λ = slenderness ratio;

FOR INFORMATION
ONLY

FOR INFORMATION
ONLY

M198 REV-1
ATTACH. I

852

MAY 1973

pg 22/ STS 29

ρ = density of steel, in pounds per cubic foot (kilograms per cubic meter);
and
 σ = stress, ksi (N/m^2); Stefan-Boltzmann constant, 0.1713×10^{-8} , in British
thermal units per hour-square foot-degrees Rankine to the fourth power
(watts per square meter—degrees Kelvin to the fourth power).

Subscripts

a = allowable, average;
 cr = critical;
 f = of furnace;
 m = at or around mesh point in m th row;
 n = at or around mesh point in n th column;
 o = at room temperature;
 s = of steel cross section;
 T = at temperature T ; and
 y = at yield stress.

Superscripts

j = at $t = j\Delta t$.

FOR INFORMATION
ONLY

FOR INFORMATION
ONLY

M198 REV-1
ATTACH. I

9719 FIRE RESISTANCE OF UNPROTECTED STEEL COLUMNS

KEY WORDS: Buildings (codes); Columns; Fire protection; Fire resistance; Heat transfer; Steel; Structural engineering; Temperature

ABSTRACT: Fire resistance of unprotected steel columns is examined by standard fire test and numerical analyses based on a 1,000 D F (538 D C) critical temperature for failure. It is shown that fire resistance time varies with the shape factor of column weight divided by the heated perimeter, and two simple equations for calculating the fire resistance times of unprotected steel columns are established. A practical example shows that large columns used in high-rise buildings can have fire resistance times of up to one hr. The more conservative of the two equations is recommended for use in building standards.

REFERENCE: "Fire Resistance of Unprotected Steel Columns," *Journal of the Structural Division, ASCE*, Vol. 99, No. ST5, Proc. Paper 9719, May, 1973, pp. 837-852

FOR INFORMATION
ONLY

FOR INFORMATION
ONLY

Pg 24 / ~~28~~
29

M198-REV-1
ATTACH. I

This publication is being distributed by the Division of Building Research of the National Research Council of Canada. It should not be reproduced in whole or in part without permission of the original publisher. The Division would be glad to be of assistance in obtaining such permission.

Publications of the Division may be obtained by mailing the appropriate remittance (a Bank Express, or Post Office Money Order, or a cheque, made payable to the Receiver General of Canada, credit NRC) to the National Research Council of Canada, Ottawa, K1A 0R6. Stamps are not acceptable.

A list of all publications of the Division is available and may be obtained from the Publications Section, Division of Building Research, National Research Council of Canada, Ottawa, K1A 0R6.

FOR INFORMATION
ONLY

FOR INFORMATION
ONLY

Assessment of Fire Resistance Requirements

J. R. MEHAFFEY and T. Z. HARMATHY

National Research Council of Canada

Division of Building Research

The calculation of normalized heat load, a succinct quantifier of the potential of compartment fires to spread by destruction, is greatly simplified by the introduction of two semi-empirical equations. These afford direct insight into the relation between the destructive potential of fire and the principal characteristics of the fire compartment and its contents of combustibles.

ALTHOUGH the bases on which code writers bring down their decisions on fire resistance requirements have changed over the years, the influence of Ingberg's fire load concept¹ is still recognizable. That concept, developed some 40 years ago, claims that the destructive potential of compartment fires is proportional to the specific fire load (mass of combustibles per unit floor area), and that the fire resistance requirement for compartment boundaries should also be allocated in proportion to the specific fire load.

Although still widely used, the concept was soundly disproved by the results of subsequent experimental research. The outlines of a rational way of assigning fire resistance requirements had recently emerged, following the identification of a parameter as a unique quantifier of the potential of enclosure fires for destructive spread.² With this new understanding, decisions regarding fire resistance requirements are a matter of matching the values of the parameter calculated for real-world situations with those developed for test conditions.

The calculation of the parameter quantifying the destructive potential of fires under real-world conditions is quite straightforward, but involves an expertise technique. It may prove somewhat time-consuming for those who attempt to perform it without a programmable calculator. To eliminate the need for calculation, the feasibility of expressing the parameter by an approximate empirical equation has been examined. The results of the examination are reported in this paper.

FOR INFORMATION ONLY

requirements concerning same. Conversely, specifying the same fire resistance requirement for all boundaries of an enclosure is a practice that relies on the validity of the theorem of uniformity of normalized heat load.

SEMI-EMPIRICAL EXPRESSION FOR THE NORMALIZED HEAT LOAD

According to statistical data, the fire load in modern buildings, despite the increasing use of plastics, consists predominantly of cellulose. Since, in addition, fires of cellulose excel in their destructive potential, it appears to be a safe practice to assume that the fire load consists fully of cellulose.

By reflecting on the meaning of Ingberg's fire load concept, one recognizes that it has been built on the implicit assumption that the bulk of the fuel energy is eventually absorbed by the compartment boundaries. The normalized heat load pertaining to the assumption that all heat release by the fuel is absorbed within the compartment is

$$H_m = \frac{1}{\sqrt{kqc}} \frac{G\Delta H}{A} \quad (6)$$

where the subscript m has been affixed to H to indicate that it represents the conceivable absolute maximum, G is the total fire load (total fuel mass), and ΔH is the heat of combustion of the fuel.

Fortunately it has been found that the normalized heat load on the compartment boundaries is only 10 to 40 percent of H_m . Some of the fuel energy is released outside the compartment, but even of the portion released inside some energy will leave the compartment with the fire gases as sensible heat and some will be lost by radiation through the ventilation opening. A multitude of calculations performed by the detailed iterative technique mentioned earlier indicates that the normalized heat load, in other words the potential of fire for destructive spread,

- increases less than in proportion to the fire load,
- decreases as the ventilation of the compartment increases, and
- decreases as the thermal inertia of the boundaries increases.

Numerical results of these calculations formed the basis for an equation that resulted in the following semi-empirical equation:

$$H = 10^4 \frac{(11.0 \delta + 1.6) G}{A \sqrt{kqc} + 935 \sqrt{\phi G}} \quad (7)$$

counts for the fact that the fire load is released inside the compartment. It is to be estimated from the following equation:

$$\delta = \begin{cases} 0.79 \sqrt{h_c} / \phi \\ 1 \end{cases} \quad \text{whichever is less} \quad (8)$$

where h_c is the height of the compartment.

ϕ is a variable that characterizes the ventilation of the compartment. It is defined as

$$\phi = \rho_e A_v \sqrt{gh} \quad (9)$$

where ρ_e is the density of environmental atmosphere, A_v is the area of ventilation opening (window or door), h is the height of the ventilation opening, and g is the acceleration due to gravity. The considerations that have led to the development of Equation 7 are discussed in the Appendix.

As the specific fire load G/A , (where A is the floor area of the compartment) may vary rather markedly from compartment to compartment, the selection of the value of G for the fire safety design must be based on an analysis of statistical data. If the compartment boundaries are simple "dividing elements" without essential structural functions, the design value for G/A , is usually taken as the 80th percentile in the cumulative plot for the applicable occupancy. If, on the other hand, the compartment boundaries are "key elements" that play an important part in the structural performance of the building as a whole, some extra degree of safety is justified. The selection of G may be based on considerations propounded by Lie and outlined later by Harmathy.

The ventilation parameter, ϕ , is a measure of the minimum ventilation of the compartment. This occurs under "classic" draft-free conditions. As discussed by Harmathy, the presence of drafts causes the value of ϕ to increase over that calculated from Equation 9 and thus (by virtue of Equation 7) to reduce the value of the normalized heat load, a value for ϕ obtained from Equation 9 may be used in assessing the potential of fires for destructive spread.

It is of interest to examine the normalized heat load in relation to its limiting value, as expressed by Equation 6. Combining Equations 6 and 7 and using $\Delta H = 18.8 \times 10^4 \text{ J kg}^{-1}$ in the former (because the fire load is assumed to be cellulose), the following equation is obtained:

$$\frac{H}{H_m} = \frac{0.585 \delta + 0.085}{1 + 935 \frac{\sqrt{G\phi}}{A \sqrt{kqc}}}$$

FOR INFORMATION ONLY
 M 198 REV-1
 Pg 26/29
 ATTACH. I

FOR INFORMATION ONLY

M-198 REV-1

RET-3

PP 27/29
ATTACH. I

**HEAT, MASS,
AND
MOMENTUM TRANSFER**

Warren M. Rohsenow

PROFESSOR OF MECHANICAL ENGINEERING
MASSACHUSETTS INSTITUTE OF TECHNOLOGY

Harry Y. Choi

ASSOCIATE PROFESSOR OF MECHANICAL ENGINEERING
TUFTS UNIVERSITY

Prentice-Hall, Inc.

ENGLEWOOD CLIFFS, NEW JERSEY

**FOR INFORMATION
ONLY**

REV #3

M-198 REV-1
~~CONFIDENTIAL~~ PP 28/29
 ATTACH. I
 APPENDIX E 517

TABLE E.1—Continued

(2) Nonmetals	T (°F)	ρ (lb _m /ft ³)	c_p (Btu/lb _m F)	k (Btu/hr ft F)	α (ft ² /hr)
Aerogel, silica	100	5.3	0.205	0.013	0.012
Asbestos	32	36	0.25	0.087	0.010
	800	36		0.130	
Brick, common	68	100	0.20	0.20-0.10	0.01-0.02
	fire clay	1472	145	0.23	0.79
Bakelite	68	79.5	0.38	0.134	0.0044
Concrete	68	119-144	0.21	0.47-0.81	0.019-0.027
Corkboard	100	10	0.4	0.025	0.008
Diatomaceous earth, powdered	100	14	0.21	0.030	0.01
	Fiber insulating board	100	14.3	0.024	
Glass, window	68	162	0.16	0.51	0.030
Glass wool, fine	100	1.5		0.031	
	packed	100	6.0	0.022	
Ice	32	57	0.46	1.28	0.038
Magnesia, 85%	100	17		0.039	
Marble	68	156-160	0.193	1.6	0.064
Paper				0.075	
Rock wool	100	12		0.023	
Rubber, hard	32	74.8	0.48	0.087	0.0034
Wood, oak, to grain	70	51	0.67	0.12	0.004
Wood, oak, ⊥ to grain	70	51	0.67	0.23	0.0009

erties

k (Btu/hr ft F)	α (ft ² /hr)
(212 F)	(1112 F)
(68 F)	(68 F)
119	3.665
74	1.322
13	---
219	4.353
39	0.785
	0.606
33	0.634
19.3	0.924
97	3.702
68	2.074
48	0.882
37	0.677
240	6.601
25	0.452
1.4	0.172
10	1.505
34	2.430
87	1.591
4.8	63

FOR INFORMATION
 ONLY

D CONVECTION

600	800	1000
0.0266	0.0303	0.0337
0.0238	0.0292	0.0345

is
(1)
 $q_x = -k(\partial t/\partial x)$, and if
This states that the
cross-sectional $A(x)$ nor-
 $\partial t/\partial x$ along the conduc-
" thermal conductivity

h temperature, and the

is t' value of k at the

$(A_2 - A_1)/\ln(A_2/A_1)$;
apes, Eq. (1) must be
procedure (Awbery and
0) or by the relaxation

REFERENCE #3 CONCEPTS M198REV-1

CONDUCTION

4-95 ATTACH-I

PP 29/29

Table 3. Thermal Conductivities of Miscellaneous Solid Substances*
(Values of k are to be regarded as rough average values for the temperature range indicated)

Material	Bulk density, lb per cu ft	Temp. deg F	k	Material	Bulk density, lb per cu ft	Temp. deg F	k
Asbestos board, compressed asbestos and cement	123.	86.	0.225	Quartz, crystal, parallel to C-axis	...	-300.	25.0
Asbestos millboard	60.5	86.	0.070			0.	8.3
Asbestos wool	25.	212.	0.058	Rubber, hard	74.3	300.	4.2
Ashes, soft wood	12.5	65.	0.018	Rubber, soft, vulcanized	68.6	180.	0.092
Ashes, volcanic	51.	300.	0.123			68.6	86.
Carbon black	12.	133.	0.312	Sand, dry	94.8	68.	0.188
Cardboard, corrugated	0.037	Sawdust, dry	13.4	68.	0.042
Celluloid	87.5	86.	0.12	Silica, fused	280.	...	0.43
Cellulose sponge, du Pont	3.4	82.	0.033	Silica gel, powder	32.5	131.	0.049
Concrete, sand and gravel	142.	75.	1.05	Soil, dry	68.	...	0.075
Concrete, cinder	97.	75.	0.41	Soil, dry, including stones	127.	68.	0.30
Charcoal, powder	11.5	63.	0.029	Soow	7-31	32.	0.54-1.3
Cork, granulated	5.4	23.	0.028	Titanium oxide, finely ground	52.	1000.	0.041
Cotton wool	5.0	180.	0.035	Wool, pure	5.6	86.	0.021
Diamond	151.	70.	320.	Euroonia grain	113.	600.	0.11
Earth plus 42% water	108.	0.	0.62	Woods, oven dry, across grain†:			
Fiber, red	80.5	68.	0.27	Aspen	26	85	0.069
"Flotofom" (U.S. Rubber Co.)	1.6	92.	0.017	Bald cypress	36	85	0.065
Glass pyrex	139	200.	0.59	Balsa	40	85	0.034
Glass soda lime	...	200.	0.59	Basswood	34	85	0.050
Graphite, solid	93.5	122.	87.	Douglas Fir	39	85	0.043
Gravel	116.	68.	0.22	Fir, rock	40	85	0.047
Gypsum board	51.	99.	0.062	Fir, white	36	85	0.049
Ice	57.5	...	1.26	Hemlock	37	85	0.046
Kaolin wool	10.6	800.	0.050	Larch, western	34	85	0.072
Leather, sole	62.4	...	0.092	Maple, sugar	43	85	0.094
Mica	122.	...	0.25	Oak, red	42	85	0.099
Pearlite, Arizona, spherical shell of siliceous material	9.1	112.	0.035	Pine, southern yellow	37	85	0.047
Polystyrene, expanded "Styrofoam"	1.7	...	0.021	Pine, white	36	85	0.047
Pumice, powdered	49.	300.	0.41	Red cedar, western	21	85	0.047
Quartz, crystal, perpendicular to C-axis	...	-300.	12.5	Redwood	35	85	0.047
		0.	4.5	Spruce	27	85	0.047
		300.	2.3				

* The thermal conductivity of different materials varies greatly with the temperature, but in the case of metals, the variation is relatively small. In some instances, k increases with rising temperatures, but in the case of many crystalline materials, it decreases. † With heat flow parallel to the grain, k may be 2 to 3 times that with heat flow perpendicular to the grain; the values for wood are taken chiefly from J. D. Maclean, *Trans. ASME*, 57, 1935.

FOR INFORMATION ONLY

M-198 REV. 1

Attachment II - Independent Verification Statement (CIVIL/STRUCTURAL)
M-198 Calculation # _____, Revision # 1 *(SEE NOTES BELOW) has been independently verified by the following method(s), as noted below:

- Design Review including verification that:
- * Design inputs were correctly selected and included in the calculation.
 - * Assumptions are adequately described and are reasonable.
 - * Input or assumptions requiring confirmation are identified, and if any exist, the calculation has been identified as "Preliminary" and a "Finalization Due Date" has been specified.
 - * Design requirements from applicable codes, standards and regulatory documents are identified and reflected in the design.
 - * Applicable construction and operating experience was considered in the design.
 - * The calculation number has been properly obtained and entered.
 - * An appropriate design method or computer code was used.
 - o A mathematical check has been performed.
 - o The output is reasonable compared to the input.

Alternate Calculation including verification of asterisked items noted above. The alternate calculation (_____ pages) is attached.

- Qualification Testing for design feature _____ including verification of asterisked items noted above and the following:
- o The test was performed in accordance with written test procedures.
 - o Most adverse design conditions were used in the test.
 - o Scaling laws were established and verified and error analyses were performed, if applicable.
 - o Test acceptance criteria were clearly related to the design calculation.
 - o Test results (documented in _____) were reviewed by the calculation Preparer or other cognizant engineer.

* NOTES:
Independent Verifier Comments: THE SCOPE OF THIS INDEPENDENT VERIFICATION IS LIMITED TO THE REVIEW OF THE CONCRETE AND STEEL SURFACE AREA CALCULATIONS ON PAGES 12 THROUGH 15.

See NED Procedure 3.05, Sec. 7.1.1 (s) John Z. Jery 9/23/86
Independent Verifier Date

Preparer concurrence with findings and comment resolution John J. Prawlucki 9/23/86
Preparer or other cognizant engineer Date

Exhibit 3.05-Q Rev. 5

2. REFER TO INDEPENDENT REVIEW STATEMENT ATTACHMENT II TO CALCULATION NO. FP 26 REV. 1 DATED 9-23-86 EAR "DOCUMENTATION OF STRUCTURAL PERFORMANCE OF STEEL ELEVATED TEMPERATURES" BY J. PRAWLUCKI DATED ~~9-23-86~~ THIS PROVIDES FURTHER JUSTIFICATION FOR THE USE OF 1000 F AS A TEMPERATURE LIMIT FOR UNPROTECTED STRUCTURAL STEEL. FOR INFORMATION ONLY

M198

III

Attachment - Independent Verification Statement (FS & MC)

Calculation # 04198 Revision # 1 has been independently verified by the following method(s), as noted below:

Design Review including verification that:

- * Design inputs were correctly selected and included in the calculation.
- * Assumptions are adequately described and are reasonable.
- * Input or assumptions requiring confirmation are identified, and if any exist, the calculation has been identified as "Preliminary" and a "Finalization Due Date" has been specified.
- * Design requirements from applicable codes, standards and regulatory documents are identified and reflected in the design.
- * Applicable construction and operating experience was considered in the design.
- * The calculation number has been properly obtained and entered.
- * An appropriate design method or computer code was used.
- o A mathematical check has been performed.
- o The output is reasonable compared to the input.

Alternate Calculation including verification of asterisked items noted above. The alternate calculation (___ pages) is attached.

Qualification Testing for design feature _____ including verification of asterisked items noted above and the following:

- o The test was performed in accordance with written test procedures.
- o Most adverse design conditions were used in the test.
- o Scaling laws were established and verified and error analyses were performed, if applicable.
- o Test acceptance criteria were clearly related to the design calculation.
- o Test results (documented in _____) were reviewed by the calculation Preparer or other cognizant engineer.

Independent Verifier Comments:

see attached sheet - comment resolved

See NED Procedure 3.05, Sec. 7.1.1

Independent Verifier

Date

Joseph J. Roberts 9/2/86

Preparer concurrence with findings and comment resolution

Preparer or other cognizant engineer

Date

J.F. Brienky 10/3/86

ATTACHMENT III - INDEPENDENT VERIFICATION
ESEM

QUESTIONS/COMMENTS

CALC M198
PAGE 2 OF 4

Q1 SHOULD THE STANDARD TIME TEMPERATURE CURVE (ASTM-E-119) BE INCLUDED AS AN ATTACHMENT TO THE CALCULATION?

Q2 HOW WERE THE TEMPERATURES DETERMINED FOR TIME INCREMENTS FOR THE CALCULATION?

Q3 CLARIFY TABLE 6.5. WHY IS TABLE DEVELOPED FOR COMBUSTIBLE LOADINGS GREATER THAN FOUND IN AREAS ANALYSED?

Q4 WHAT IS THE RELATIONSHIP BETWEEN FIRE LOADING AND HEAT FLUX? DOES FIRE LOADING EQUAL HEAT FLUX AT EQUILIBRIUM?

Q5 WHAT IS THICKNESS OF THE CONCRETE FIRE BARRIERS?

Q6 SHOULD THE TEMPERATURE COMPUTATION BE IN UNITS OF OR?

Q7 CLEARLY IDENTIFY THE NEW SURFACE TEMPERATURE IN CALCULATION.

Q8 DOES ASSUMPTION 9 APPLY TO THIS CALCULATION?

FOR INFORMATION
ONLY

ATTACHMENT III - INDEPENDENT VERIFICATION
FS&MC

ANSWERS/COMMENTS

CALC M198
PAGE 3 OF 4

A1. THE STANDARD-TIME-TEMPERATURE CURVE IS FROM A NATIONAL STANDARD (ASTM) AND WAS NOT INCLUDED IN THE CALCULATION TEXT. THE "STT" CURVE DOES, HOWEVER, APPEAR IN ATTACHMENT II, pg 8 OF 22.

A2. THE TEMPERATURES FOR THIS CALCULATION WERE TAKEN FROM APPENDIX "B" OF THE NATIONAL FIRE CODES; VOLUME 10; 1981; SECTION 251. APPENDIX "B" IS ACTUALLY THE ASTM-E-119 CURVE IN TABULAR FORM.

A3. TABLE 6.5 HAS BEEN MARKED-UP TO CLEARLY IDENTIFY STEEL TEMPERATURES. PORTIONS OF THE TABLE, WHICH EXCEED THE COMBUSTIBLE HEAT LOAD WHICH IS APPLIED TO THE AREA BOUNDARY, HAVE BEEN ELIMINATED.

A4. THE HEAT FLUX IS DETERMINED BY COLUMNS 1 THRU 6 (TABLE A). IT IS A FUNCTION OF ΔT AND THE COMBINED CONVECTION AND RADIATION COEFFICIENTS. THE HEAT FLUX IS USED TO DETERMINE THE GROSS HEAT APPLIED TO THE

FOR INFORMATION ONLY

ATTACHMENT III - INDEPENDENT VERIFICATION

FS&MC

CALCM198

ANSWERS/COMMENTS

PAGE 4 OF 4

A4.(CONT) BOUNDARIES. WHEN THE TOTAL GROSS HEAT APPLIED ($\sum Q_s + \sum Q_c$) IS EQUAL TO 40% OF THE THEORITICAL FIRE LOAD, THE TEMPERATURE OF THE STEEL IS IDENTIFIED.

A5. THE THICKNESS OF THE CONCRETE FIRE BARRIERS IS NOT REQUIRED FOR THIS CALCULATION. THE CONCRETE THICKNESS MEETS OR EXCEEDS THE THICKNESS REQUIRED FOR THE FIRE BARRIER RATING.

A6. THE TEMPERATURE COMPUTATION, IN DEGREES FAHRENHEIT, IS ACCEPTABLE;

$$a) F_o = \Delta T h$$

$$b) T_w = T_{w_1} + 2 \left(\frac{F_o}{k} \right) \left(\frac{\Delta b}{3.14} \right)^{\frac{1}{2}}$$

ABOVE FORMULA UTILIZES A ΔT FOR
 ΔT $\therefore \Delta T$ OF $1^\circ F = \Delta T$ OF $1^\circ R$

A7. DONE

A8. ASSUMPTION 9 HAS BEEN DELETED FROM THE CALCULATION ASSUMPTIONS. THIS IS NOT REQUIRED.

FOR INFORMATION ONLY

ATTACHMENT 4 TO BECO LETTER 88-010

APPLICATION OF M197/M198 CALCULATION METHODOLOGY

- TORUS AREA (See calculation M197, Rev. 2)

Plan View Area = 10,658 SF (P18)

Proposed Maximum = 14,000 BTU/SF X 10,658 SF
= 149.21 X 10⁶ BTU

From Table B (P21), the total BTU's absorbed (as a function of time) during a standard ASTM E-119 fire, and the corresponding steel temperature:

<u>t</u>	<u>Sigma (Qs) + Sigma (Qc)</u>	<u>TN (steel)</u>
.05hrs	52.85 X 10 ⁶ BTU	137°F
.10hrs	150.82 X 10 ⁶ BTU	255°F

Since 149.21 X 10⁶ BTU is essentially equivalent to the heat required to raise the steel to only 255°F, the associated proposed maximum loading of 14,000 BTU/SF is safe.

- STEAM TUNNEL (See Calculation M198, Rev. 1)

Plan View Area = 784 SF (P13)

Proposed Maximum = 8200 BTU/SF X 784 SF
= 6.43 X 10⁶ BTU

From Table B (P17), the total BTU's absorbed (as a function of time) during a standard ASTM E-119 fire, and the corresponding steel temperature:

<u>t</u>	<u>Sigma (Qs) + Sigma (Qc)</u>	<u>TN (steel)</u>
.05hrs	2.0 X 10 ⁶ BTU	137°F
.10hrs	6.4 X 10 ⁶ BTU	255°F

Since 6.43 X 10⁶ BTU is essentially equivalent to the heat required to raise the steel to only 255°F, the associated proposed maximum loading of 8,200 BTU/SF is safe.