

March 24, 1988

Docket No. 50-346
Serial No. DB-88-014

Distribution

Docket File
NRC & Local PDRs
PDIII-3 r/f
GHolahan
PKreutzer
Ade Agazio

OGC-WF1
E. Jordan
JPartlow
KEPerkins
ACRS (1)
PDIII-3 g/f

Mr. Donald C. Shelton
Vice President - Nuclear
Toledo Edison Company
Edison Plaza - Stop 712
300 Madison Avenue
Toledo, Ohio 43652

Dear Mr. Shelton:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION (TAC 65685)

We have received and are reviewing your letter dated March 21, 1988 (No. 1500), containing supplemental information related to your application for license amendment dated August 7, 1987 (No. 1400). This information was submitted in response to our March 3, 1988, conference call. Subsequent to that conference call, we have determined the need for further additional information. The attachment to this letter identifies the information required.

The information requested affects fewer than ten respondents; therefore, OMB clearance pursuant to PL 95-511 is not required. Please provide your response to this request not later than April 30, 1988.

Sincerely,

151

Albert W. De Agazio, Project Manager
Project Directorate III-3
Division of Reactor Projects - III,
IV, V & Special Projects

Enclosure:
As stated

cc: See next page

OFFICE
Office: LA/PDIII-3
Surname: PKreutzer
Date: 03/ /87

PM/PDIII-3
Ade Agazio/rl
03/24/87

for PD/PDIII-3
KEPerkins
03/24/87

8803300356 880324
PDR ADDCK 05000346
PDR

Mr. Donald C. Shelton
Toledo Edison Company

Davis-Besse Nuclear Power Station
Unit No. 1

cc:

Donald H. Hauser, Esq.
The Cleveland Electric
Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Radiological Health Program
Ohio Department of Health
1224 Kinnear Road
Columbus, Ohio 43212

Mr. Robert W. Schrauder
Manager, Nuclear Licensing
Toledo Edison Company
Edison Plaza
300 Madison Avenue
Toledo, Ohio 43652

Attorney General
Department of Attorney
General
30 East Broad Street
Columbus, Ohio 43215

Gerald Charnoff, Esq.
Shaw, Pittman, Potts
and Trowbridge
2300 N Street N.W.
Washington, D.C. 20037

Mr. James W. Harris, Director
(Addressee Only)
Division of Power Generation
Ohio Department of Industrial Relations
2323 West 5th Avenue
P. O. Box 825
Columbus, Ohio 43216

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois

Ohio Environmental Protection Agency
361 East Broad Street
Columbus, Ohio 43266-0558

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 525, 1700 Rockville Pike
Rockville, Maryland 20852

President, Board of
County Commissioners of
Ottawa County
Port Clinton, Ohio 43452

Resident Inspector
U.S. Nuclear Regulatory Commission
5503 N. State Route 2
Oak Harbor, Ohio 43449

State of Ohio
Public Utilities Commission
180 East Broad Street
Columbus, Ohio 43266-0573

REQUEST FOR ADDITIONAL INFORMATION
PLANT SYSTEMS BRANCH
DAVIS BESSE PROPOSED TECHNICAL SPECIFICATION CHNAGE
TO DELETE SFAS TO CERTAIN VALVES (TAC NO. 65685)

The following information is required in order for the staff to complete its review of the submittal by the Toledo Edison Company, dated August 7, 1987:

1. The proposed changes to the plant Technical Specifications (TS) in the licensee's letter dated August 7, 1988 will revise Table 3.3-5, Safety Features System Response Times to delete reference to the main steam warmup drain valves and atmospheric vent valves (AVV) receiving a high containment pressure or low reactor coolant system pressure SFAS automatic signal. It was indicated that the purpose of this change was to improve reliability and availability of the Main Feedwater System by reducing the chance of plant trips resulting from an inadvertent SFAS. The primary justification for this change was that those valves are normally closed during power operations. The SFAS signal serves to provide only a backup to procedural requirements for maintaining the valves in a closed position.

The staff has two concerns with the above proposed TS change:

- (1) These valves are normally closed, and an automatic closure of these valves does not isolate the feedwater system. Therefore, how can the elimination of the SFAS automatic signal for MS warmup drain valves and AVVs improve reliability of the main feedwater system?
 - (2) It is required in NUREG-0737, Item II.E.4.2 that following an accident all nonessential systems penetrating containment be automatically isolated. No credit can be given for operator action. By eliminating the SFAS state how this requirement is satisfied, or justify why those containment isolation valves can be granted a deviation from this requirement.
2. The proposed TS change will revise TS 3/4.3.2, Table 3.3-5 to delete reference to the atmospheric vent valves, main steam warmup drain valves, main steam isolation valves, main feedwater stop valves, and main steam line warmup valves receiving a manual SFAS. It was indicated in a telecon of March 3, 1988 between the licensee and staff that those valves were also listed in Table 3.6-2, Containment Isolation Valves, under TS section 3/4.6.3. Therefore, the licensee considered it redundant and unnecessary to list those valves in Table 3.3-5.

The staff finds that the surveillance requirements under TS 3/4.3.2 are not the same as the requirements under TS 3/4.6.3. For example a monthly CHANNEL FUNCTIONAL TEST is required by TS 3/4.3.2 but not required by TS 3/4.6.3. Identify the differences between these TS requirements and justify your proposed TS for the above valves.

3. The proposed change will revise TS section 3/4.3.6, Table 3.6-2 to delete isolation time requirements for the MSIV, MS warmup valves, MFW stop valves, AVV, MS warmup drain valves, and steam generator blowdown valves, along with the deletion of SFAS actuation. The licensee's evaluation of unreviewed safety question has been focused on large break LOCA and MSLB. The licensee should verify whether there are any other unidentified safety concerns or accident analyses that may be impacted by the proposed changes? For example, confirm the dose consequences for a steam generator tube rupture accident are within acceptable limits. Confirm that the environmental effects for a small MSLB inside or outside containment are not adversely affected. Verify that the small break LOCA accident analysis is not adversely affected by the proposed change. Provide additional discussion and/or analysis to justify that there is no unreviewed safety question resulting from the proposed change.