

June 16, 1997

Mr. John R. McGaha, Jr.  
Vice President - Operations  
Entergy Operations, Inc.  
River Bend Station  
P. O. Box 220  
St. Francisville, LA 70775

SUBJECT: RIVER BEND STATION, UNIT 1 - REQUEST FOR DEVIATION FROM 10 CFR  
PART 50, APPENDIX R, REQUEST FOR ADDITIONAL INFORMATION (TAC NO.  
M97241)

Dear Mr. McGaha:

By letter dated November 6, 1996, Entergy Operations, Inc. requested a deviation from its commitment to the requirements of Section III.G.2 of Appendix R to 10 CFR Part 50 of the Code of Federal Regulations for the use of a partial area automatic suppression system in lieu of a full area automatic suppression system in fire area C-16.

We have identified additional information that we will need to complete our review. Enclosed is our request for additional information. Please respond within 45 days so that we may complete our review. If you have any questions on our request, please let us know.

Sincerely,

ORIGINAL SIGNED BY:  
David L. Wigginton, Senior Project Manager  
Project Directorate IV-1  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

Docket No. 50-458

Enclosure: Request for Additional Information

cc w/encl: See next page

DISTRIBUTION:

Docket File	PUBLIC	PD4-1 r/f
C. Hawes	J. Roe	D. Wigginton
T. Gwynn, RIV	ACRS	OGC (15B18)
E. Adensam (EGA1)	MSalley	

1/1  
DF01

Document Name: RB97241.RAI

OFC	PM/PD4-1	LA/PD4-1
NAME	DWigginton/vw	CHawes <i>cg for</i>
DATE	6/16/97	6/16/97
COPY	YES/NO	YES/NO

OFFICIAL RECORD COPY

**NRC FILE CENTER COPY**

170036

9706170262 970616  
PDR ADDCK 05000458  
F PDR



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

June 16, 1997

Mr. John R. McGaha, Jr.  
Vice President - Operations  
Entergy Operations, Inc.  
River Bend Station  
P. O. Box 220  
St. Francisville, LA 70775

SUBJECT: RIVER BEND STATION, UNIT 1 - REQUEST FOR DEVIATION FROM 10 CFR  
PART 50, APPENDIX R, REQUEST FOR ADDITIONAL INFORMATION (TAC NO.  
M97241)

Dear Mr. McGaha:

By letter dated November 6, 1996, Entergy Operations, Inc. requested a deviation from its commitment to the requirements of Section III.G.2 of Appendix R to 10 CFR Part 50 of the Code of Federal Regulations for the use of a partial area automatic suppression system in lieu of a full area automatic suppression system in fire area C-16.

We have identified additional information that we will need to complete our review. Enclosed is our request for additional information. Please respond within 45 days so that we may complete our review. If you have any questions on our request, please let us know.

Sincerely,

A handwritten signature in cursive script, appearing to read "D. Wigginton".

David L. Wigginton, Senior Project Manager  
Project Directorate IV-1  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

Docket No. 50-458

Enclosure: Request for Additional Information

cc w/encl: See next page

Mr. John R. McGaha  
Entergy Operations, Inc.

River Bend Station

cc:

Winston & Strawn  
1400 L Street, N.W.  
Washington, DC 20005-3502

Manager - Licensing  
Entergy Operations, Inc.  
River Bend Station  
P. O. Box 220  
St. Francisville, LA 70775

Director  
Joint Operations Cajun  
10719 Airline Highway  
P. O. Box 15540  
Baton Rouge, LA 70895

Senior Resident Inspector  
P. O. Box 1050  
St. Francisville, LA 70775

President of West Feliciana  
Police Jury  
P. O. Box 1921  
St. Francisville, LA 70775

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, TX 76011

Ms. H. Anne Plettinger  
3456 Villa Rose Drive  
Baton Rouge, LA 70806

Administrator  
Louisiana Radiation Protection Division  
P. O. Box 82135  
Baton Rouge, LA 70884-2135

Executive Vice President and  
Chief Operating Officer  
Entergy Operations, Inc.  
P. O. Box 31995  
Jackson, MS 39286

General Manager - Plant Operations  
Entergy Operations, Inc.  
River Bend Station  
P. O. Box 220  
St. Francisville, LA 70775

Director - Nuclear Safety  
Entergy Operations, Inc.  
River Bend Station  
P. O. Box 220  
St. Francisville, LA 70775

Vice President - Operations Support  
Entergy Operations, Inc.  
P. O. Box 31995  
Jackson, MS 39286-1995

Attorney General  
State of Louisiana  
P. O. Box 94095  
Baton Rouge, LA 70804-9095

Wise, Carter, Child & Caraway  
P. O. Box 651  
Jackson, MS 39205

Vice President & Controller  
Cajun Electric Power Cooperative  
10719 Airline Highway  
P.O. Box 15540  
Baton Rouge, LA 70895

REQUEST FOR INFORMATION BY THE  
OFFICE OF NUCLEAR REACTOR REGULATION  
DIVISION OF SYSTEMS SAFETY AND ANALYSIS  
PLANT SYSTEMS BRANCH  
REQUEST FOR DEVIATION FROM SECTION III.G.2 OF  
APPENDIX R TO 10 CFR PART 50  
RIVER BEND STATION - UNIT 1  
DOCKET NO. 50-458

1. BACKGROUND

By letter dated November 6, 1996, Entergy Operations, Inc. (EOI), the licensee for River Bend Station, Unit 1, requested a deviation from its commitment to meet the requirements of Section III.G to Appendix R of 10 CFR Part 50. The requested deviation is for the use of a partial automatic suppression system in lieu of a full area suppression system in Fire Area C-16. This fire area contains both Division I and Division II post-fire safe shutdown cables. Automatic fire detection capability is provided for the fire area. In lieu of providing a 3-hour fire barrier for one division of the required post-fire safe shutdown cables, the licensee is proposing to provide a 1-hour fire barrier with a partial area automatic sprinkler system.

The staff has reviewed the licensee's deviation request and has concluded that it needs additional information in order to complete its review. The following is the staff's request for additional information:

2. REQUEST FOR ADDITIONAL INFORMATION

- a. Justify why a full area automatic suppression system cannot be installed in Fire Area C-16.
- b. Justify why a rated three hour fire barrier cannot be installed to protect the required Division II cables.
- c. The request for deviation states: "Automatic smoke detection is already provided in the area (Fire Area C-16)." The request for deviation also states: "Area wide zone detection is provided by six ionization detectors and three photo-electric detectors located in the fire area and arranged to alarm locally in the Main Control Room." Provide an engineering evaluation which demonstrates that the fire detection system meets the applicable fire protection industry codes and standards (e.g., National Fire Protection Association Fire Codes). This engineering evaluation should specifically address detector placement, detector selection criteria, type and classification of detection and alarm circuit supervision.

ENCLOSURE

- d. Provide design details regarding the partial area suppression system. Include the design basis and an engineering evaluation which demonstrates that this system conforms with applicable fire protection industry codes and standards. In addition, the engineering evaluation should demonstrate that the system design and its distribution of sprinkler heads is adequate to control all potential fires that could occur in the area of concern.
- e. The RBS Calculation G13.18.12.2-22 "River Bend Station Combustible Loading" determines an average fuel loading that produces a "worst case theoretical fire duration of 31 minutes." The calculation also uses the term "unidentified combustibles". Explain what these combustibles are and how they impact the accuracy of the calculation. Based on this Fire Hazard Analysis average fuel loading justify how the partial area sprinkler coverage will provide the same level of fire safety as that of full sprinkler protection through out the fire area or area of concern.