

MAR 24 1988

Docket Nos. 50-327/50-328

MEMORANDUM FOR: Kenneth P. Barr, Acting Assistant Director  
 for Inspection Programs  
 TVA Projects Division  
 Office of Special Projects

FROM: B. D. Liaw, Assistant Director  
 for Technical Programs  
 TVA Projects Division  
 Office of Special Projects

SUBJECT: EVALUATION OF TVA RESOLUTION FOR CAQR SQT 870626

Per your request, enclosed is a copy of our evaluation on TVA's resolution for CAQR SQT 870626. If any additional information is needed, please contact me.

Original signed by  
 B. D. Liaw

B. D. Liaw, Assistant Director  
 for Technical Programs  
 TVA Projects Division  
 Office of Special Projects

Enclosure:  
 As stated

CONTACT: T. Cheng  
 FTS 492-0710

DISTRIBUTION:  
 TVA TP R/F BDLiaw  
 Docket Files RHermann  
 Local PDR TCheng  
 NRC PDR  
 SEbnetter  
 JAxelrad  
 SRichardson

8803300401 880324  
 PDR ADDCK 05000327  
 P PDR

OFC	:EB:TPD	:BC/EB:TPD	:AD/TP:TPD	:	:	:	:
NAME	:TCheng:sam	:RHermann	:BDLiaw	:	:	:	:
DATE	:3/23/88	:3/24/88	:3/24/88	:	:	:	:

OFFICIAL RECORD COPY

## EVALUATION OF TVA RESOLUTION FOR CAQR SQT 870626

### Background

The Startup Action List (SAL) Item 0982 has been signed off as complete based on TVA's resolution for CAQR SQT 870626 concerning the adequacy of conduit support design and installation at Sequoyah Nuclear Power Plant Unit 2. This evaluation is to address the appropriateness of TVA's decision that the subject CAQR was resolved adequately for the restart.

### Evaluation

TVA's restart resolution for CAQR SQT 870626 has been evaluated under Item CEB 16 of the Design Calculation Review Program for SQN, "Conduit and HVAC Duct Support Calculations." The staff's findings were summarized in NRC Inspection Report No. 50-328/88-12, which concluded that TVA's restart resolution for CAQR SQT 870626 is acceptable. Therefore, TVA's decision that CAQR SQT 870626 was resolved adequately for restart at SQN is appropriate.