

POWER AUTHORITY OF THE STATE OF NEW YORK

10 COLUMBUS CIRCLE NEW YORK, N. Y. 10019

(212) 397-6200

TRUSTEES

FREDERICK R. CLARK
CHAIRMAN

GEORGE L. INGALLS
VICE CHAIRMAN

RICHARD M. FLYNN

ROBERT I. MILLONZI

WILLIAM F. LUDDY



November 14, 1978
JNRC-78-57

GEORGE T. BERRY
GENERAL MANAGER
AND CHIEF ENGINEER

LEWIS R. BENNETT
ASSISTANT GENERAL
MANAGER-GENERAL
COUNSEL

WILBUR L. GRONBERG
ASSISTANT GENERAL
MANAGER-ENGINEERING

JOHN W. BOSTON
DIRECTOR OF
POWER OPERATIONS

THOMAS F. MCCRANN, JR.
CONTROLLER

Director of Nuclear Reactor Regulation
United States Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. Thomas A. Ippolito
Operating Reactors Branch No. 3
Division of Operating Reactors

Subject: James A. FitzPatrick Nuclear Power Plant
Multiple Consecutive S/RV Actuation Evaluation
Docket No. 50-333


Dear Sir:

Transmitted herewith is an analysis performed by Teledyne Engineering Services for the Authority concerning multiple consecutive safety relief valve actuation evaluation.

On September 28, 1978 the Authority transmitted information concerning the subject matter summarizing the results of the analysis and describing the methods and assumptions used. The results of the analysis supported upcoming operation of the FitzPatrick Plant during Cycle 3 by assuring that the structural capability of the torus satisfies acceptance criteria established by the Short Term Mark I Containment Program.

Subsequently, the Commission requested by telephone on October 18, 1978 that the Authority submit the analysis done by Teledyne Engineering Services.

Very truly yours,


Paul J. Early
Assistant Chief Engineer-Projects

7811170110


A013
5/11

October 19, 1978
2386-62
Page 1 of 10

James A. Fitzpatrick Nuclear Power Plant

Multiple Consecutive S/RV Actuation Evaluation

- 11 SRV Lines
- Assume multiple consecutive actuation of valves L, K, E and D.
- Assume multiple initial actuation of valves L and K and multiple consecutive actuation of valves E and D.
- Determination and evaluation of the maximum shell stress and support column load.



October 19, 1978

2386-62

Page 2 of 10

Support Column Evaluation

Consecutive Actuation Factor = 1.96

From Monticello S/RV Test - Single Cold Actuation of Valve D:

Reference Outside Column Load = 196.7 kips

Midbay to Ring Girder Factor = .84

Plant Unique Column Load Multiplier = .71

Outer Column, Single Hot Pop = $(1.96)(.71)(.84)(196.7) = 230$ kips

Outer Column Deadweight = 270 kips

October 19, 1978
2386-62
Page 3 of 10

4 Valves Hot - L, K, E and D

Factors for Multiple Actuation - Columns - Outer

<u>Column Location</u>	<u>Actuated Valve</u>					<u>P_{SRV} (kips)</u>	<u>P_{SRV} + Deadweight (kips)</u>
	<u>L</u>	<u>K</u>	<u>E</u>	<u>D</u>	<u>ε</u>		
1	.08	.7	.11	.	1.04	239	509
C	.09	.15	.12	.12	.48	110	380
A	.10	.15	.15	.11	.51	117	387
H	.11	.12	.15	.10	.48	110	380
2	.12	.11	.7	.09	1.02	235	505
Ⓔ	.15	.10	1.0	.08	1.33	306	576
3	.15	.09	.7	.09	1.03	237	507
G	.7	.08	.15	.10	1.03	237	507
Ⓕ	1.0	.09	.15	.11	1.35	311	581
F	.7	.10	.12	.12	1.04	239	509
J	.15	.11	.11	.15	.52	120	390
B	.15	.12	.10	.15	.52	120	390
4	.12	.15	.09	.7	1.06	244	514
Ⓖ	.11	.15	.08	1.0	1.34	308	578
5	.10	.7	.09	.7	1.59	366	636
Ⓚ	.09	1.0	.10	.15	1.34	308	578

October 19, 1978
2386-62
Page 4 of 10

STP Evaluation of Outside Column - Location 5

$$f_a = \frac{636}{47.4} = 13.418 \text{ ksi} \quad \text{factor} = \frac{636}{631.8} = 1.0066$$

$$f_{bx} = \frac{(636 \times .117 \times 1.0066) + (49.58 \times 1.0066)}{222} = .562 \text{ ksi}$$

$$f_{by} = \frac{(636 \times .057 \times 1.0066) + (9.2874 \times 1.0066)}{78} = .588 \text{ ksi}$$

$$\frac{13.418}{44.0} + \frac{(.85)(.562)}{\left[1 - \frac{13.418}{121.0}\right]^{36}} + \frac{(.85)(.588)}{\left[1 - \frac{13.418}{38.2}\right]^{36}} \leq 0.5$$

$$.305 + .0149 + .0214 \leq 0.5$$

$$.3413 \leq 0.5$$

Weld Joint SEC = 1,961 kips (includes ultimate capacity of web weld and yield capacity of flange welds)

$$\text{Weld Joint S.R.} = \frac{636}{1961} = .32$$

October 19, 1978

2386-62

Page 5 of 10

Valves E & D - Hot Pop

Valves L & K - Cold Pop

Factors for Multiple Actuation - Columns - Outer

Column Location	E + D	① P _{SRV} Hot (kips)	L + K	② P _{SRV} Cold (kips)	① + ② + Deadweight (kips)
1	.26	60	.78	92	422
C	.24	55	.74	28	353
A	.26	60	.25	29	359
H	.25	58	.23	27	355
2	.79	182	.23	27	479
Ⓔ	1.08	248	.25	29	547
3	.79	182	.24	28	480
G	.25	58	.78	92	420
Ⓕ	.26	60	1.09	128	458
F	.24	55	.80	94	419
J	.26	60	.26	31	361
B	.25	58	.27	32	360
4	.79	182	.27	32	484
Ⓖ	1.08	248	.26	31	549
5	.79	182	.80	94	546
Ⓗ	.25	58	1.09	128	456

October 19, 1978
2386-62
Page 6 of 10

Code Evaluation of Outside Column - Location D

$$\text{factor} = \frac{549}{631.8} = 0.869$$

$$f_{bx} = \frac{(549 \times .117 \times .869) + (49.58 \times 0.869)}{222} = .446 \text{ ksi}$$

$$f_{by} = \frac{(549 \times .057 \times .869) + (9.2874 \times 0.869)}{78} = .452 \text{ ksi}$$

$$f_a = \frac{549}{47.4} = 11.582 \text{ ksi}$$

$$\frac{11.582}{14.61} + \frac{(.85)(.446)}{\left[1 - \frac{11.582}{63.1}\right] 23.8} + \frac{(.85)(.452)}{\left[1 - \frac{11.582}{19.9}\right] 27.0} \leq 1.0$$

$$.793 + .0195 + .034 \leq 1.0$$

$$.847 \leq 1.0$$

STP Evaluation of Outside Column - Location D

$$\frac{11.582}{44.0} + \frac{(.85)(.446)}{\left[1 - \frac{11.582}{121.0}\right] 36} + \frac{(.85)(.452)}{\left[1 - \frac{11.582}{38.2}\right] 36} \leq 0.5$$

$$.263 + .0116 + .0153 \leq 0.5$$

$$.29 \leq 0.5$$

$$\text{Weld Joint S.R.} = \frac{549}{1961} = .28$$

Shell Evaluation

Factors for Multiple Actuation - Shell - Midbay

<u>Shell Location</u>	<u>Actuated Valve</u>				<u>①</u>	<u>②</u>	<u>③</u>
	<u>L</u>	<u>K</u>	<u>E</u>	<u>D</u>			
1	.11	.39	.11	.13	.53	.204	.486
2	.11	.17	.13	.11	.32	.204	.243
3	.11	.13	.17	.11	.32	.243	.204
4	.11	.11	.39	.11	.52	.486	.187
5	.13	.11	.8	.11	.99	.969	.204
6	.17	.11	.8	.11	1.0	.969	.243
7	.39	.11	.39	.11	.69	.486	.486
8	.8	.11	.17	.11	1.0	.243	.969
9	.8	.11	.13	.11	.99	.204	.969
10	.39	.11	.11	.11	.52	.187	.486
11	.17	.11	.11	.17	.34	.243	.243
12	.13	.13	.11	.39	.53	.486	.221
13	.11	.17	.11	.8	1.0	.969	.243
14	.11	.39	.11	.8	1.084	.969	.486
15	.11	.8	.11	.39	1.084	.486	.969
16	.11	.8	.11	.17	1.0	.243	.969

$$\textcircled{1} = 1.2 \sqrt{\epsilon(L^2 + K^2 + E^2 + D^2)}$$

$$\textcircled{2} = 1.2 \sqrt{\epsilon(E^2 + D^2)}$$

$$\textcircled{3} = 1.2 \sqrt{\epsilon(L^2 + K^2)}$$

Factors for Multiple Actuation -

Shell - Ring Girder Location

<u>Location</u>	<u>L</u>	<u>Actuated Valve</u>			<u>①</u>	<u>②</u>	<u>③</u>
		<u>K</u>	<u>E</u>	<u>D</u>			
1	.11	.59	.11	.15	.754	.223	.720
2	.11	.19	.11	.11	.323	.187	.263
3	.11	.15	.15	.11	.316	.223	.223
4	.11	.11	.19	.11	.323	.263	.187
5	.11	.11	.59	.11	.744	.720	.187
6	.15	.11	1.0	.11	1.228	1.207	.223
7	.19	.11	.59	.11	.767	.720	.263
8	.59	.11	.19	.11	.767	.263	.720
9	1.0	.11	.15	.11	1.228	.223	1.207
10	.59	.11	.11	.11	.744	.187	.720
11	.19	.11	.11	.15	.345	.223	.263
12	.15	.11	.11	.19	.345	.263	.223
13	.11	.15	.11	.59	.754	.720	.223
14	.11	.19	.11	1.0	1.236	1.207	.263
15	.11	.59	.11	.59	1.019	.720	.720
16	.11	1.0	.11	.19	1.236	.263	1.207

$$\textcircled{1} = 1.2 \sqrt{\epsilon(L^2 + K^2 + E^2 + D^2)}$$

$$\textcircled{2} = 1.2 \sqrt{\epsilon(E^2 + D^2)}$$

$$\textcircled{3} = 1.2 \sqrt{\epsilon(L^2 + K^2)}$$

October 19, 1978
2386-62
Page 9 of 10

Shell Stresses

- Consecutive Actuation Factor = 2.37
- From Monticello S/RV Test - Single Cold Actuation of Valve D.
 Extreme Fiber Shell Stress at Midbay, 45° up from bottom toward
 inside columns = 3400 psi
- Factor relating stress at bottom midbay to stress 45° up from bottom
 midbay = 1.49
- Factor from extreme fiber to membrane stress = .86
- Plant unique shell stress multiplier = .63

Thickness of Monticello Shell = 0.584 in.

Thickness of Fitzpatrick Shell = 0.632 in.

Radius of Monticello Torus = 166 in.

Radius of Fitzpatrick Torus = 177 in.

$$\begin{aligned} \text{Single Hot Actuation} &= (1.49)(3400)(.63)(2.37) \frac{(.584)(177)}{(.632)(166)} \\ &= 7453 \text{ psi} \end{aligned}$$

Hydrostatic Pressure Stress = 1708 psi

Valves L, K, E & D Hot

$$(38\% \text{ of Code}) P_1 + P_b = (1.236)(7453) + 1708 = 10,920 \text{ psi}$$

$$(50\% \text{ of Code}) P_m = (.86)(1.236)(7453) + 1708 = 9,630 \text{ psi}$$

Valves E & D Hot, Valves L & K Cold (Bay 14)

$$\begin{aligned} P_1 + P_b &= \sqrt{[(1.207)(7453)]^2 + [(.263)(3145)]^2} + 1708 \\ &= 10,742 \text{ psi (37\% of Code)} \end{aligned}$$

October 19, 1978
2386-62
Page 10 of 10

$$P_m = \sqrt{[(.86)(1.207)(7453)]^2 + [(.86)(.263)(3145)]^2} + 1708$$

$$= 9,477 \text{ psi (49\% of Code)}$$

Valves E & D Hot, Valves L & K Cold (Bay 15)

$$P_1 + P_b = \sqrt{[(.720)(7453)]^2 + [(.720)(3145)]^2} + 1708$$

$$= 7532 \text{ psi (26\% of Code)}$$

$$P_m = \sqrt{[(.86)(.720)(7453)]^2 + [(.86)(.720)(3145)]^2} + 1708$$

$$= 6717 \text{ psi (35\% of Code)}$$

Material: A516 Gr. 70

$$S_m = 19,300 \text{ psi}$$

$$1.5 S_m = 28,950 \text{ psi}$$

Following references have been used in the preparation of this analysis.

1. G. E. Letter MI-G-179, "Mark I Containment Program - Multiple Consecutive SRV Actuation Evaluation-Task 7.1.3" dated June 16, 1978.
2. TES Report TR-2386(a), "Plant Unique Analysis Report for Torus Support System and Attached Piping for James A. FitzPatrick Nuclear Power Plant" dated August 25, 1976.