

# UNITED STATES NUCLEAR REGULATORY COMMISSION

---

In the Matter of:

MEETING: NRC & TVA  
re: 10 C.F.R. Part 50,  
Appendix R Issues

Pages: 1 through 120

Place: Rockville, Maryland

Date: March 9, 1988

---

## HERITAGE REPORTING CORPORATION

*Official Reporters*  
1220 L Street, N.W., Suite 600  
Washington, D.C. 20005  
(202) 628-4288

8804010078 880309  
PDR ALUCK 05000327  
F PDR

1 UNITED STATES NUCLEAR REGULATORY COMMISSION

2 In the Matter of:

3 MEETING: NRC & TVA  
4 re: 10 C.F.R. Part 50,  
5 Appendix R Issues

6 Wednesday,  
7 March 9, 1988

8 Room 8-B-11  
9 11555 Rockville Pike  
10 Rockville, Maryland

11 The above-entitled matter came on for hearing,  
12 pursuant to notice.

13 MEETING ATTENDANCE:

14 From the NRC:

15 T.P. Gwynn  
16 C.L. Miller  
17 George Hubbard  
18 David Notley  
19 Dennis Kubicki  
20 B.D. Liaw  
21 E.C. Marinos  
22 Charles Ader  
23 George Felgate  
24 E.C. Gilbert  
25 C.E. Mullins  
S.D. Ebnetter  
Pete Hearn  
Jack Scarborough  
Steven West  
R. Aulnek  
Steven Richardson  
Rex G. Wescott  
Robert C. Pierson  
Thomas S. Rotella  
Barry Zalaman  
Hukam Gary  
Jane Axelrad

1 MEETING ATTENDANCE (Continued):

2 From TVA:

- 3 R.P. Levi
- 4 N.D. Black
- 5 R. Gridley
- 6 R.W. Bass
- 7 R.J. Hansen
- 8 H. George
- 9 T.A. Keys
- 10 Nick Fioravante
- 11 Robert C. Williams
- 12 Jimmy J. Pierce
- 13 Edward A. Connell
- 14 R.H. Bryan
- 15 James T. Springfield
- 16 P.J. Polk
- 17 C.H. Fox
- 18 John Hosmer
- 19 John Henry Sullivan
- 20 Frank A. Koontz, Jr.

21 From Knoxville News-Sentinel:

- 22 Richard Powelson

23 From Bishop, Cook:

- 24 Dan Stenger

25 From Impell:

- 26 Steven Whitsert

27 From House Interior Committee:

- 28 Richard H. King

29 Others:

- 30 Andrew Bartlik
- 31 Lynne Bernabei
- 32 M. McGarry
- 33 Kevin Elle

P R O C E E D I N G S

1  
2 MR. RICHARDSON: Good afternoon, I apologize for  
3 the crowded conditions of the meeting room here.

4 This is a meeting between the NRC and TVA to  
5 discuss various issues related to fire protection compliance  
6 at the Sequoyah facility. It is a public meeting. A  
7 transcript is being taken. I would ask that speakers other  
8 than those at the table when you speak or give a comment give  
9 a name and get close to a microphone so the conversation can  
10 be picked up and transcribed.

11 There is an agenda for the meeting that has been  
12 put together which lists the various technical issues that  
13 the staff feels there are still some questions on. The  
14 protocol of the meeting is that the staff is going to go  
15 through the TVA responses, each of the individual 26  
16 questions that were sent out on February 26th and the  
17 answers to those. We are going to go through those in  
18 sequential order. There will be a frequent break  
19 periodically for members of the public to interact with the  
20 staff, any additional questions that they think need to be  
21 answered. At the end of the technical discussion there will  
22 be a 20 minute period that members of the public will be able  
23 to address various concerns for the record.

24 Any additional comments or questions we need t  
25 cover?

1 MR. ROTELLA: There is attendance list going  
2 around.

3 MR. RICHARDSON: There is an attendance list coming  
4 around and everybody needs to sign that.

5 With that, I'd like the members at the table to  
6 introduce themselves.

7 MS. AXELROD: He essentially just laid out the  
8 ground rules with regard to public participation, that this  
9 is a meeting between the staff and TVA. Members of the  
10 public will have an opportunity, a 20 minute period at the  
11 end of the meeting to voice their comments or questions.  
12 Questions should be directed to the staff.

13 MR. RICHARDSON: I'd like to take a minute and go  
14 around the room and introduce everybody. I am Steve  
15 Richardson, Director of the TVA Project Division.

16 MR. WESCOTT: I'm Rex Wescott, Office of Special  
17 Projects.

18 MR. PIERSON: I'm Bob Pierson, Plant Systems Branch  
19 Chief.

20 MS. HANSEN: Rebecca Hansen, TVA Manager Staff.

21 MR. FOX: Charles Fox, TVA Office of Nuclear Power.

22 MR. HOSMER: I'm John Hosmer, Project Engineer, TVA  
23 Sequoyah.

24 MS. AXELROD: Jane Axelrod, Deputy Director, Office  
25 of Special Projects.

1 MR. GARG: -- Garg, Office of the Special Project.

2 MR. ROTELLA: Tom Rotella, Sequoyah Project Manager  
3 for Unit 2.

4 MR. MARINOS: Angelo Marinos, Chief of Reactor  
5 Operations Branch, TVA Projects.

6 (Whereupon, others in the room gave their name and  
7 affiliation)

8 MR. RICHARDSON: Thank you. I'd like to turn the  
9 meeting over to Bob Pierson who will start through the  
10 questions and TVA responses.

11 MR. PIERSON: The agenda we would like to follow  
12 today is to work through question by question the request  
13 for additional information which we sent to TVA on  
14 February 26, 1988. TVA replied on March 2nd. It is not my  
15 intention to cover every question, but only those questions  
16 which the staff has questions about.

17 What I would like to do is start with number one,  
18 which discussed providing calculations for the reactor  
19 coolant system, water and containment. I don't want to  
20 discuss that question now. I want to come back to it later,  
21 depending on what your answers are to subsequent questions.

22 Question number two, which is the question  
23 concerning the task group's conclusion of boiling of the  
24 spent fuel pool is not a technical concern. I don't have  
25 any questions for that.

1           Mr. Wescott, do you have any questions concerning  
2 this issue?

3           (No response.)

4           MR. PIERSON: The next question is question number  
5 three. Question number three concerns procedure review. And  
6 again, I don't have any questions for that. I would like for  
7 you to understand that we are reserving the right to come  
8 back to some of these questions because it really depends on  
9 subsequent answers.

10           The first question I would like to discuss in  
11 detail is question number four, which describes the standard  
12 operating instruction 26.3, revision one, and provides  
13 adequate boron concentration for cold shutdown condition  
14 after a worst case appendix R fire.

15           Our ledger talked about a concept called  
16 pressurizer level fluctuation as a methodology for  
17 depressurizing. TVA replied in their response that  
18 pressurizer level fluctuation was not used in 30I 26.3  
19 Region 1. However, the response that I am looking for more  
20 than that is do you use a concept of pressurizer level  
21 fluctuation? Is there such a concept? What is it? Do you  
22 use it in your procedures?

23           Who in TVA addresses question number four?

24           MR. FOX: Our speaker on that question is John  
25 Henry Sullivan. John Henry is the Supervisor of the Plant

1 Operations Review Staff at Sequoyah. He is our former  
2 Appendix R project manager at Sequoyah also.

3 MR. PIERSON: The first thing is this concept of  
4 pressurizer level fluctuation. Then how does that work, and  
5 how do you accomplish the depressurization sequence to get on  
6 RHR?

7 The point that we're trying to bring out here is  
8 that you need to have your Appendix R protected  
9 depressurization mechanism. I am not quite sure by your  
10 answer that that is addressed.

11 MR. SULLIVAN: To directly address the question on  
12 pressurizer level fluctuations, it is not taken credit for in  
13 any of the procedures or analysis for depressurization of the  
14 RCS.

15 MR. PIERSON: What does that mean?

16 MR. SULLIVAN: I am assuming what is meant by  
17 pressurizer level fluctuations is you somehow try to cool the  
18 vapor space in the pressurizer to decrease pressure.

19 MR. PIERSON: But you don't use that as a  
20 depressurization method?

21 MR. SULLIVAN: That is not a proceduralized method  
22 and there is no credit taken for that.

23 MR. PIERSON: Do you take credit for one trail of  
24 RHR to cool the plant to less than 200 degrees fahrenheit?

25 MR. SULLIVAN: Yes.



1           MR. PIERSON: Your response indicates that you've  
2 requested an update on an analysis that Westinghouse  
3 performed on July 21, 1975, and you will provide those  
4 results as soon as possible. Could you discuss why you feel  
5 it's appropriate to use one train of RHR cooldown if you  
6 don't, what information do you use to substantiate that? Why  
7 do you think it's a viable method of cooldown? What I'm  
8 reading here says to me that it doesn't look like you have an  
9 analysis to support that.

10           MR. PIERSON: We do have an analysis from  
11 Westinghouse that supports shutdown in the plant, cold  
12 shutdown using one train. If you back up into the old single  
13 failure criteria and get out of the R space, you're  
14 guaranteed to be able to shut the plant down with one train  
15 of RHR. It just takes a little longer than the normal two  
16 trains do.

17           We have an updated Westinghouse analysis which I  
18 believe has been supplied to you. I don't know if you  
19 received it and had a chance to review it.

20           MR. FOX: TVA provided at your request a list of  
21 all pertinent documents and calculations and so on that were  
22 germane to this issue that were referenced in our response.  
23 You should have gotten that earlier this week.

24           MR. PIERSON: We got two binders this morning and  
25 we got some last week. We haven't completed our review of

1 that.

2 MR. FOX: John Henry, why don't you give them the  
3 reference. It is in your package. I'll confirm that.

4 MR. ROTELLA: That's the March 8th submittal or the  
5 earlier submittal?

6 MR. FOX: There were three submittals. I think  
7 this package should have come to you yesterday.

8 MR. PIERSON: It was delivered this morning. We  
9 have just completed a preliminary review of the package  
10 delivered this morning.

11 MR. SULLIVAN: There is a Westinghouse letter to  
12 TVA dated March 4th, TVA-88-561, and it deals with the one  
13 RHR pump to two RCS co-legs at a tech spec minimum required  
14 flow rate of 2500 GPM and gives us performance curves on RHR  
15 cooldown to cold shutdown.

16 MR. PIERSON: The last statement in the response on  
17 the March 2nd says that pressurizer heaters, auxiliary spray,  
18 and normal spray are not required to support safe shutdown.  
19 Could you describe how you accomplish safe shutdown without  
20 pressurizer heaters, auxiliary spray, and normal spray?

21 MR. SULLIVAN: Pressurizer heaters is really  
22 addressed in a different question. Basically there is, who  
23 has the question on pressurizer heaters?

24 MR. PIERSON: The question is an operational  
25 concern. You have the statement, pressurizer heaters,

1 auxiliary spray, and normal spray are not required to support  
2 safe shutdown, so presumably you have some shutdown scenario  
3 whereby you can accomplish it without those three items, and  
4 I would just be interested in your discussing that.

5 MR. SULLIVAN: The safe shutdown logic does not  
6 require pressurizer heaters. It was in the original analysis  
7 and there were I believe three locations, two locations,  
8 where you lost pressurizer heaters. We based our response to  
9 the question I believe in the Task Force Resolution Report  
10 that loss of the pressurizer heaters does not mean you have  
11 lost your bubble. You still have a bubble in the top of the  
12 pressurizer. There are special tests that were run during  
13 the startup phase of Sequoyah. There are other St. Lucie  
14 vents that Westinghouse Owners Group I believe has documented  
15 that shows the relationship, RCS pressure and decay of  
16 pressure versus time and loss of heaters.

17 MR. PIERSON: That assumes that you don't have a  
18 spurious actuation of the pressurizer port, is that correct?

19 MR. SULLIVAN: Yes. I think all the analysis did  
20 not assume any sort of transient going on at the same time.

21 MR. PIERSON: I'd like to have it noted, we'll have  
22 to come back to that because we do have some questions  
23 concerning spurious actuation of your pressurizer port which  
24 may impact on the response that you gave to question number  
25 four.

1 Does anyone from the staff have anything to say?

2 MR. MARINOS: I have a question, clarification on  
3 these three items. You said you don't need the heaters, you  
4 don't need the emergency spray, and you don't need the normal  
5 spray for the pressurizer. How do you maintain pressure  
6 control? The pressurizer is not utilized at all for pressure  
7 control?

8 MR. SULLIVAN: Yes. The vapor space in the  
9 pressurizer is still utilized for pressure control. It has a  
10 certain amount of internal energy and will be there for a  
11 certain finite period of time.

12 MR. MARINOS: But you are using no sprays and no  
13 heaters to maintain that control. How are you going to do  
14 that? Are you going to pop the PORV?

15 MR. SULLIVAN: We prefer not to pop PORVs, safety  
16 valves, or do anything like that to challenge the system.  
17 Charging pumps are used for charging. The steam is steam  
18 from the generator to maintain a certain cooldown rate.  
19 Without going into a lot of detail on it, you make up to the  
20 plant, you maintain your pressurizer levels, you can bring  
21 the pressurizer level up to help collapse, help compress your  
22 bubble a little bit more. I think it was something like a  
23 ten percent increase in level gave you 100 PSI. Don't quote  
24 me on that one but I believe that is about a correlation  
25 where you can increase the level to help get pressure back up

1 should you lose pressure. That was all documented in our  
2 resolution of the issue of the interactions where we lost  
3 pressurizer heaters.

4 MR. ROTELLA: In other words, you use CBCS?

5 MR. SULLIVAN: Yes. Charging pumps.

6 MR. ROTELLA: Charging pumps and letdown.

7 MR. MARINOS: It is not clear to me how you are  
8 going to maintain the bubble in the pressurizer without any  
9 of the control systems associated with the pressurizer.

10 MR. ROTELLA: What he is saying is he's going to  
11 lower the level by increasing letdown.

12 MR. SULLIVAN: We'll lower level by cooling the  
13 plant down and shrinking the plant. Adding water through a  
14 CBCS.

15 MR. BARTLIK: You mean not using letdown, just to  
16 correct that statement.

17 MR. ROTELLA: You mean it's not necessary to use  
18 letdown.

19 MR. BARTLIK: I didn't say that.

20 MR. PIERSON: One point here. The staff is allowed  
21 to ask the questions. We are not set up to allow the public  
22 to address questions. The public can address questions of  
23 the staff at the intermissions or following the meeting. We  
24 will address them at that point.

25 The next question is question number five, and the

1 question, to paraphrase, asks you about taking credit for  
2 pneumatic systems for control during Appendix R events. You  
3 reply that you don't take credit for pneumatic systems except  
4 for one key. We asked for clarification on that and you  
5 stated that you took manual control of some HVAC dampers.

6 My question with respect to that is, if you're  
7 taking manual control of these HVAC dampers, are they covered  
8 in procedures, are they accessible?

9 MR. FOX: Bob Bryan is the Staff Specialist,  
10 Accident Evaluation as it deals with containment systems in  
11 the Nuclear Technology Branch, in the Division of Nuclear  
12 Engineering.

13 MR. BRYAN: The answer is yes, specifically in our  
14 procedure SOI 26.2. These dampers are provided and discussed  
15 and the operator is informed that if he loses automatic  
16 control of them he can go out and manually take control of  
17 them.

18 MR. PIERSON: And you substantiated that as opposed  
19 to some plants I've seen that they are in fact accessible and  
20 he doesn't have to carry a step ladder with him?

21 MR. SULLIVAN: The main control room HVAC dampers  
22 are all located in the mechanical equipment room adjacent to  
23 the control room and they are accessible.

24 MR. PIERSON: Thank you.

25 To continue on with question five, this touches on

1 another issue. You stated that a preliminary separation  
2 analysis on Unit 2 indicates that either a head vent or  
3 pressurizer port letdown path is available for all scenarios  
4 that may require water solid operations.

5 We have done a preliminary review of the submittal  
6 this morning and we are going to take some issue with that  
7 statement. I'll be coming back to that later.

8 But the question I have with respect to this, is  
9 TVA taking credit for using pressurizer 4 where a reactor  
10 event, as a means of recovering from an Appendix R event?

11 MR. RYAN: At the current time, no.

12 MR. PIERSON: The answer to that question is no?

13 MR. RYAN: That is correct.

14 MR. PIERSON: Thank you.

15 Then I think we can go on to question six. I have  
16 some subsequent questions with respect to that answer.

17 Does anybody on the staff have a question about  
18 number five?

19 MR. HUBBARD: George Hubbard, OSP. I guess if that  
20 preliminary separation analysis you are not taking credit for  
21 then, we wouldn't be expecting to see a final analysis on  
22 that?

23 MR. RYAN: Not at the present time, no.

24 MR. PIERSON: Okay, we'll move on to question six.  
25 Question number six concerned why the primary plant will not

1 lose a pressurizer bubble in a fire scenario such that 19  
2 hours is the conservative value for requiring the  
3 availability of RHR.

4 We in the staff have discussed this, and we  
5 understand how you came up with 19 hours and why you consider  
6 it a conservative value. We don't have any argument with  
7 that per se. But we do question whether you will be able to  
8 maintain primary plant pressure in light of the fact that  
9 it's not clear to us that the pressurizer PORVs are  
10 protected. I don't need to address it under this question  
11 because it's going to be addressed in other questions later,  
12 but we do have some questions concerning whether you are  
13 going to end up in a solid plant condition and what you're  
14 going to do, and why you can take 19 hours credit for that.

15 So with respect to that I'd like to move on to  
16 number seven.

17 Number seven, TVA states that, we asked TVA to  
18 provide justification for repair times of flow control valve  
19 74-1 and 74-2. Those are the series valves for your RHR. We  
20 asked why these valves are considered operable for fires  
21 inside containment, and TVA replied they consider them  
22 operable because they can utilize 72 hours to go in and  
23 repair these valves.

24 I don't have a question per se based on that,  
25 however, I do have a concern that if you stated earlier you



1 didn't use the pressurizer PORVs or the reactor head vent  
2 valves as a cooldown mechanism, which seems to me  
3 contradictory to some of the replies you made later. Maybe  
4 they were questions that you used that as a possible means  
5 but you didn't take credit for it. But if you do use reactor  
6 head vents or pressurizer PORVs and you do end up in a  
7 situation where you are blowing down RCS into the  
8 containment, we are concerned as to how you could access the  
9 containment. What calculations are used to justify that the  
10 containment is accessible to repair, among other things,  
11 these valves, or else show to us that these valves, it's not  
12 credible to have a fire in those areas where you could have a  
13 blowdown, say if a pressurize PORV reactor head vent valve,  
14 and as such the one event excludes the possibility of the  
15 other.

16           It's not clear to me, going back to your first  
17 question, as to how you could justify access to the  
18 containment if you took credit for that. Since you didn't  
19 take credit for it I'll move on, but I think there are other  
20 statements where it implies to me, at any rate, that you did  
21 take credit for it.

22           MR. ROTELLA: During a phone call a couple of days  
23 ago, we had understood TVA Licensing and Engineering to tell  
24 us that indeed you do protect PORVs and block valves. You  
25 separate where necessary, you wrap where necessary. Why

1 would you do that if you don't need them for fire? Why isn't  
2 that inconsistent with the submittal we got today?

3 MR. FOX: I'm not sure what the conversation was.  
4 Who was the conversation with, Tom?

5 MR. ROTELLA. Licensing was Mark Burzynski, and  
6 Engineering was, was it Frank?

7 MR. KOONTZ: This is Frank Koontz. I think I can  
8 address that.

9 MR. FOX: Frank Koontz is our Assistant Branch  
10 Chief in Nuclear Technology Branch. He's also our Safe  
11 Shutdown Specialist.

12 MR. KOCNTZ: We were doing a preliminary analysis  
13 to see if we did have the availability of the reactor head  
14 vents or the pressurizer PORVs. That analysis at the time we  
15 were discussing it was still in its preliminary stage and it  
16 was being finalized. Since that time the analysis has been  
17 finalized and it's been documented. We do not have a problem  
18 that I'm aware of, providing that analysis to the staff if  
19 they would like to review it. However, our position today is  
20 we still do not take credit for the use of the head vents or  
21 the PORVs to cool down the plant. I need to emphasize that.

22 MR. ROTELLA: Is that a change in the design basis  
23 then?

24 MR. KOONTZ: No, we did not credit the use of the  
25 head vents or the PORVs before.

1 MR. ROTELLA: So Rev 6 of the calculation doesn't  
2 have PORVs?

3 MR. KOONTZ: Right.

4 MR. ROTELLA: Rev 8 does not either?

5 MR. KOONTZ: That's correct. It does not.

6 MR. PIERSON: If I could interject, Jane Axelrod  
7 has come up with a very good suggestion. She says we have a  
8 bigger room. I want to break and move. I suggest that's a  
9 good idea. The question is, where is the room.

10 (Whereupon, a brief recess is taken)

11 MR. PIERSON: The meeting will continue.

12 We were on question seven and I'd like to continue  
13 with question seven.

14 We were discussing the RHR valves, FCV 74-1 and  
15 74-2, and their accessibility with respect to a fire inside  
16 containment.

17 The question I have is are the RHR valves  
18 protected? Are they considered Appendix R equipment? Do  
19 they have separation, a one hour barrier, detectors, or  
20 whatever?

21 MR. SULLIVAN: Please ask your questions one at a  
22 time.

23 MR. PIERSON: Are the RHR valves Appendix R  
24 protected equipment? That's 74-1 and 74-2?

25 MR. SULLIVAN: Yes. They are cold shutdown

1 required equipment.

2 MR. PIERSON: How is that Appendix R protection  
3 provided?

4 MR. SULLIVAN: It's provided by using the 3G  
5 requirements for cold shutdown. Basically for a fire outside  
6 containment we have a couching procedure that will repair the  
7 valve and can get 74-1 and 74-2 open without entering  
8 containment.

9 For a fire inside containment there is no  
10 significant fire loading around the valves. One of the  
11 valves is located in accumulator room four, and one is under  
12 steam generator four. Fire hazard analysis has been done.  
13 So a fire inside containment will not damage the valve unless  
14 the fire is in the valve or the control circuitry to the  
15 valve, in which case that fire will be limited to within that  
16 valve and will not damage other equipment. Containment  
17 access, normal letdown, everything else would be available.  
18 No spurious PORV or head vent operation is considered.

19 The conclusion is cold shutdown is achievable for  
20 our shutdown logic with those valves protected the way we  
21 have.

22 MR. PIERSON: So you base that on a fire hazards  
23 analysis then?

24 MR. SULLIVAN: Yes sir.

25 MR. PIERSON: We have that fire hazards analysis?

1 MR. SULLIVAN: Yes sir. I should also point out  
2 that the valves, there was I believe a question at one point  
3 on the EQ qualification of these valves.

4 MR. PIERSON: Yes.

5 MR. SULLIVAN: The valves are qualified on a  
6 temperature profile that peaks at about 300 and then  
7 maintains about 200 for 30 days.

8 MR. PIERSON: So the valves are essentially  
9 qualified for end containment local conditions?

10 MR. SULLIVAN: Yes.

11 MR. PIERSON: Thank you.

12 Does anyone from the staff have any further  
13 questions on question number seven?

14 (No response)

15 MR. PIERSON: Now I'd like to discuss quickly  
16 number eight, which discusses the possibility of lubrication  
17 oil from the main coolant system pumps being thrown beyond  
18 the oil collection system.

19 I don't have any questions concerning this. Does  
20 anyone from the staff have any questions?

21 (No response)

22 MR. PIERSON: We'll move on to question nine.  
23 Describe the protection and provide a copy of the fire hazard  
24 analysis for steam generator PORV controls.

25 From the response from March 2nd it appears that

1 you have done what you need to do. I don't have any  
2 questions on number nine. Does anyone from the staff have a  
3 question on nine?

4 (No response)

5 MR. PIERSON: We'll move on to question number ten.  
6 Describe the effects of a main steamline break and the  
7 resulting steam generator PORV opening spuriously. Describe  
8 the environmental qualification of PORV including seismic.  
9 Is the PORV single failure proof? Discuss whether Appendix R  
10 functional criteria specifically call for no bore down of any  
11 steam generator.

12 I'd like for TVA to start with describing what your  
13 single failure criteria is.

14 MR. BRYAN: Bob Bryan. In addressing what our  
15 single failure criteria is, basically we feel we follow  
16 standard industry practice. Specifically for seismic events,  
17 our safety-related equipment is designed to be seismic so we  
18 don't expect it to fail in seismic events. We also do not  
19 consider multiple failures of non-seismic components during a  
20 seismic event.

21 Specifically for the case of the main steamline  
22 break that we were talking about in question ten, we consider  
23 that an independent initiating event. We take a loss of off-  
24 site power if that is the worst assumption. We take a single  
25 failure, either one active failure immediately or a passive

1 failure 24 hours later, and for this event we do not couple a  
2 seismic event with the MSLV since we consider those  
3 independent events.

4 MR. PIERSON: I see. So what you're saying then is  
5 from your response, that the actuating circuit, the closing  
6 solenoid is environmentally and seismically qualified, and  
7 the valve is not seismically qualified and it's not a problem  
8 in your single failure criteria?

9 Mr. BRYAN: The actuating circuit is not  
10 environmentally qualified. A portion of the controller's  
11 circuit has been moved out of the vault, but the closing  
12 circuits have been environmentally and seismically qualified,  
13 and they are provided for remote manual actuation from the  
14 control room. The operator can override all the automatic  
15 control functions and can run that valve closed if it should  
16 spuriously open.

17 MR. PIERSON: I don't have any more questions on  
18 number ten. Does anyone from the staff have questions on  
19 number ten?

20 MR. FOX: Was that answer satisfactory? Do you  
21 have a question about standard industry practice? I have  
22 consultants lined up to speak to that if there is a further  
23 question.

24 MR. PIERSON: No, I don't.

25 The next question, number 11 was very straight

1 forward. Provide assurance of the pressurizer block valve  
2 when closed against full reactor coolant system pressure. I  
3 think Mr. Hubbard requested a completed maintenance  
4 instruction. Did you get that complete instruction?

5 MR. HUBBARD: Yes, I did, Bob.

6 MR. PIERSON: Then I have no questions about number  
7 11.

8 MR. FOX: Have you had an opportunity to review  
9 that instruction, and do you find it satisfactory?

10 MR. HUBBARD: I briefly looked at it and it appears  
11 that it will be satisfactory.

12 MR. PIERSON: Now we come to really what I consider  
13 the crux of the meeting which is question 12, which is  
14 provide an explanation of how Appendix R related cables are  
15 provided protection from spurious actuations, and  
16 particularly define the grounding mechanisms of these cables;  
17 do cables of a train for various required components share a  
18 common ground? If so, is spurious actuation from a wire to  
19 wire short between different cables prevented? Were credible  
20 faults considered between individual conductors within a  
21 cable, or cable to cable?

22 You have since revised your response on this. We  
23 have conducted a preliminary review on it this morning. We  
24 got the response this morning. I think the staff has several  
25 questions regarding that submittal.



1           I think what I'd like to do is let Mr. Garg ask  
2 some questions if he has some, and then I have some  
3 additional questions following his.

4           MR. GARG: The question I have is how do you  
5 justify not considering the cable to cable fire? I think you  
6 did an industrial study and I think most of the utility  
7 outlets have been this. I don't see what basis you have for  
8 not considering a cable to cable fire.

9           MR. PIERSON: Would TVA like to make a presentation  
10 on this question and then let us respond to it?

11          MR. FOX: We would like to present our response to  
12 this entire question, if we could, since it is the principal  
13 point of contention. Thank you.

14          Our speaker on this subject is John Henry Sullivan.

15          MR. SULLIVAN: Thank you, Charlie.

16          Spurious actuation of type two associated circuits  
17 is the concern here. These circuits required for safe  
18 shutdown and those not allowed to spuriously operate were all  
19 analyzed as required circuits. In general, required circuits  
20 and these type two associated circuits were protected by  
21 separation or fire barriers in accordance with G-2. Where  
22 separation did not exist, interactions were identified, we  
23 analyzed those interactions, and provided dispositions to  
24 each one of them.

25          Alternate shutdown capability is provided for areas

1 where we considered cable to cable faults credible, namely  
2 the main control room, the cable spring room, and the  
3 auxiliary instrument room. These areas have a large  
4 congestion of cables and cable to cable faults. Maybe  
5 credible.

6 Sequoyah utilizes an ungrounded DC control --

7 MR. MARINOS: Are you going to be able to explain  
8 to us later what you call credible and not credible faults?  
9 You just indicated whenever you decided that a cable to cable  
10 fault may be credible, or however you phrased it. Could you  
11 tell us how you made that judgment?

12 MR. SULLIVAN: Yes, I will try to get into that  
13 right now.

14 We utilized an underground DC control system. We  
15 also have an ungrounded AC control system off control  
16 transmitters on the 480 volt grounded AC system. This is  
17 unique in some respects that our AC control power system or  
18 essentially all of our motor operated valves and MOV boards  
19 are off controlled transformers and is ungrounded.

20 This means that spurious actuation from any device  
21 not fed from a common power source, would take multiple  
22 faults.

23 Additionally, we did a separate look back at the  
24 high/low pressure interfaces based upon the criteria in 531  
25 of Generic Letter 86-10. We relooked that reactor vessel

1 head vents, the RHR letdown path, the OCS normal and excess  
2 letdown, and also pressurizer relief pacts. In only three  
3 cases in this look back did we find that the cable to cable  
4 fault, had it been considered, would have resulted in a  
5 problem and therefore, we did not meet that. The literal  
6 guidance given is such in 531.

7 MS. AXELROD: When did you do this look back?

8 MR. SULLIVAN: This look back was completed over  
9 the weekend. These three cases deals with the pressurizer  
10 PORV, cable to cable fault, multiple faults such that you hot  
11 up on a separate cable. This assumes spurious operation.

12 MR. GARG: There are two issues here. One is the  
13 high/low interface, and the other is for any other subject.  
14 But high/low interface, you have to consider the multiple  
15 chart. For any of the separates, you have to consider if  
16 there is any --

17 MR. SULLIVAN: I point out here that we identified  
18 these interactions and our disposition of cable to cable  
19 shorts was submitted to the NRC. I think we brought that out  
20 in the submittal that you got this morning. This was  
21 reviewed by the NRC at the time of our reevaluation. NRC  
22 stated that we had taken appropriate corrective actions for  
23 these interactions. However, we did go back and reevaluate  
24 due to your additional request with respect to the high/low  
25 interfaces, and provided the results of that review this

1 morning.

2 MR. PIERSON: If I could interject, it sounds to me  
3 like you are saying that you have three cases where you have  
4 a cable to cable interaction problem. One is the pressurizer  
5 PORVs; one is the reactor head vent valves; and one is with  
6 respect to the RCS letdown path. Is that a correct  
7 statement?

8 MR. SULLIVAN: Would you repeat the first sentence  
9 of that question?

10 MR. PIERSON: I said it appears to me that you have  
11 three places in your containment where you apparently haven  
12 to considered where you have a problem with cable to cable  
13 faults.

14 MR. SULLIVAN: No. The three problems that I point  
15 out here in meeting the literal requirements of 531, all  
16 three of them deal with pressurizer PORVs in three separate  
17 locations.

18 MR. PIERSON: All three deal with pressurizer PORVs  
19 in three separate locations.

20 MR. SULLIVAN: Yes.

21 MR. PIERSON: I'd like you to turn to Attachment 5,  
22 a March 8, 1988 submittal. Could you elaborate on statement  
23 number four. "The reactor head vent valves are obviously not  
24 separated because they are physically located together near  
25 the reactor vessel head to satisfy reactor pressure vessel

1 boundary considerations." What have you done to prevent  
2 spurious actuation to reactor head vent valves?

3 MR. FOX: You're going to need to rephrase your  
4 question.

5 MR. PIERSON: Have you found Attachment 5?

6 MR. SULLIVAN: I've got it now. Will you repeat  
7 your question?

8 MR. PIERSON: On question four you said that the  
9 "reactor head vent valves are obviously not separated because  
10 they are physically located together near the reactor vessel  
11 head to satisfy reactor pressure vessel boundary  
12 considerations."

13 What does that mean? Does that mean that you  
14 provided the cable wrapping? You provided the separation  
15 criteria? Obviously it didn't meet the separation criteria,  
16 so what have you done?

17 MR. SULLIVAN: There is another attachment in here  
18 if you give me just a minute. Attachment 2, Roman Numeral I  
19 readdresses in a very similar fashion how we initially  
20 addressed this issue in December 2, 1982, which I believe  
21 that letter was provided as enclosure Attachment 1.

22 MR. PIERSON: Okay, now there is a problem with  
23 that response based on what you said earlier in the meeting,  
24 because you said you didn't take credit for reactor head vent  
25 valves operating spuriously or operating in a fire for

1 pressure control. Yet in the second paragraph here you say  
2 "Even if spurious operation did occur, it will not result in  
3 depressurization of the RCS because a shutdown logic  
4 separation analysis ensures a CCP is available for makeup.  
5 Because two valves are in series, a single set of two on this  
6 ungrounded DC circuit from an external cable will not result  
7 in a loss of the high pressure interface."

8 So what it's telling me, if I'm reading this  
9 correctly, is you're saying we don't care if the valve is  
10 open. We've got the centrifugal charging pump to provide  
11 makeup. Is that what you're saying there?

12 MR. SULLIVAN: What we're saying, to address the  
13 earlier response that we gave you, is that we do not take  
14 credit for reactor head vent system as a letdown path or a  
15 depressurization path.

16 MR. KOONTZ: This is Frank Koontz. I think there  
17 is a confusion about whether we worry about the thing  
18 spuriously opening when we don't want it to be open versus  
19 whether we take credit for it as a letdown path so that we  
20 can open it and can close it when we want to.

21 MR. PIERSON: I guess I am confused then, because  
22 Appendix R says that essentially if something can spuriously  
23 actuate, you've got to provide some sort of protection  
24 against it. That's what a high/low pressure interface is all  
25 about. That's what generic letter 8610 considers. So if

1 you're telling me in one place that you don't consider it and  
2 then the other place you're saying if it happens we can  
3 provide makeup, there is a problem.

4 MR. FIORAVANTE: Nick Fioravante. He's saying that  
5 they don't utilize the head vents for the PORV as letdown  
6 path. That doesn't mean they don't consider it. They don't  
7 utilize it as part of their shutdown equipment. They have  
8 reviewed it as part of the spurious actuation parts, part of  
9 the associated circuits.

10 MR. ROTELLA: So it is protected against.

11 MR. FIORAVANTE: It is addressed, but it's not  
12 utilized.

13 MR. PIERSON: You're saying it's addressed but it's  
14 not protected. You don't take credit for it in your  
15 analysis, is that right? If you take credit for it it has to  
16 be protected.

17 MR. SULLIVAN: We do not take credit for head vents  
18 as a required circuit.

19 MR. FIORAVANTE: Protection is beyond just cable  
20 right. Protection can be provided that you looked at it and  
21 it doesn't spuriously actuate. Protection can be defined as  
22 you looked at it, it spuriously actuates, it opens, but it's  
23 not a problem. Try to separate in your mind something that  
24 needs to open and close and the type of protection you  
25 provide for that and something you are only worried about if

1 it spuriously actuates.

2 MS. AXELROD: What kind of protection did you  
3 provide here, I think, is the other part of Bob's question.  
4 What did you do to prevent a spurious actuation?

5 MR. SULLIVAN: To summarize what we've said in  
6 Attachment 2 here, there are fuses that can be pulled by the  
7 operator should the thing spuriously operate and the valves  
8 will go closed. That is from an internal cable fault.  
9 External cable faults were dispositioned here as not being  
10 credible, well the hot/short being credible from an external  
11 cable, but since it had to happen to two valves it would take  
12 multiple combinations of the two hot/shorts and therefore  
13 that was not credible.

14 MR. GARG: That's what I have a problem with. If  
15 we look at 8610 for high/low interfaces, you have to consider  
16 the short for all the high/low defenses. But anything beyond  
17 the high/low defense you have to consider a single short.

18 MR. WILLIAMS: This is Bob Williams, TVA. We  
19 looked at those valves and the basis for our conclusion was  
20 if you pull those fuses, it takes multiple shorts on two  
21 different valves. It will take at least four shorts of the  
22 proper polarity to actuate two valves and give you a path.  
23 With the random laying cable, we considered that to be an  
24 incredible event. You've got to get four off the same  
25 instrument bus or transformer together in the same tray and



1 short them with the proper polarity to have that event occur.

2 MR. GARG: I'm not sure why you would need four.

3 MR. WILLIAMS: You have to have the positive and  
4 negative of two different circuits together to actuate two  
5 vessels.

6 MR. GARG: That's the two shorts.

7 MR. WILLIAMS: That's four conductor shorts of the  
8 proper polarity.

9 MR. GARG: Yes, but that is considered --

10 MR. WESCOTT: But that is in addition to the one  
11 we've already mitigated.

12 MR. MARINOS: Do you know how many shorts or faults  
13 are required for low to high pressure interface? Is there  
14 more than one, less than four, what is the number?

15 MR. WILLIAMS: In this particular case we're  
16 discussing, the original short can be, it would take a short  
17 to the positive side which is a single event. We can  
18 mitigate that by pulling the fuses. In addition to that, we  
19 would have to short additionally two more cables, both  
20 positive to positive and negative to negative, to initiate  
21 that event. So there is a minimum, it would take a minimum  
22 of three.

23 MR. MARINOS: If you have two or less it will be  
24 unacceptable.

25 MR. WILLIAMS: No.

1 MR. GARG: Your comment about three, that's  
2 considered for the high/low defense. My question is, -- I'm  
3 not sure how you can operate this.

4 MR. WILLIAMS: No, we did not remove the fuses.  
5 What we said was that if it does spuriously actuate we can  
6 pull the fuses and mitigate that event. If we pull the  
7 fuses, then it takes two additional shorts on two valves to  
8 cause them to spuriously open again. What we said in the  
9 analysis was that having those valves spuriously actuate is  
10 within the design basis of the plant.

11 MR. GARG: So you indicated that three is a  
12 credible, three independent faults you are talking about, or  
13 more. You say four.

14 MR. WILLIAMS: If you pull the fuses it would take  
15 four conductor to conductor shorts with proper polarity. It  
16 could be two cables to cables.

17 MR. GARG: Pulling the fuse is in your procedure?

18 MR. SULLIVAN: The form on the fuses is in the  
19 procedure for the backup control room, abandonment of the  
20 main control room, single procedure for the plant fires  
21 outside the control room at this time.

22 MR. PIERSON: I'm sorry. I missed something there.  
23 Can you repeat that please?

24 MR. FOX: Repeat the question, please.

25 MR. PIERSON: I heard something about something

1 wasn't in a procedure, and I'm not sure what that referred  
2 to.

3 MR. FOX: What was your question?

4 MR. GARG: My question is pulling the fuses out in  
5 the procedure, the norm, and he is supposed to take out the  
6 fuses. I mean if you take the credit for that.

7 MR. SULLIVAN: We'll put in that in SOI 26.2 right  
8 now is currently in AOI 27 on abandonment of main control  
9 room.

10 MR. PIERSON: So in effect you're saying that's a  
11 fix as a result of what you've done in the past few days?

12 MR. SULLIVAN: No, it's an enhancement based upon a  
13 relook at what we told you December 2, 1982, based upon our  
14 relook. Our disposition in December 2, 1982 basically said,  
15 and I'd like to put this on the record, is that there is a  
16 three-eighths inch flow restrictor during this line, that  
17 charging pump can maintain RCS pressure with that flow  
18 restrictor, and it's not defined as a loca in accordance with  
19 10 CFR 50 because we can provide the makeup and do a normal  
20 shutdown in accordance with --

21 MR. PIERSON: And you can assure me that since it  
22 has nothing to do with your flow control valves for your RHR  
23 system, the RHR system is independent of this so you can  
24 always access your RHR valves even if you did have some  
25 leakage?

1           MR. SULLIVAN: We think that appropriate mitigative  
2 action would have been taken to stop this spurious actuation  
3 of the valves once the operator had found it, and there would  
4 never have been any adverse effect on 74-1 or 74-2.

5           MR. PIERSON: I'd like to talk more, are we  
6 finished with this question now?

7           MR. GARG: No, I have some more questions.

8           MR. SULLIVAN: We had an open question I believe  
9 that you said we were to get back to on number, dealing with  
10 the RHR valves. We didn't address that at the time. You  
11 said we would discuss it later in the presentation. Would  
12 you like to discuss that?

13           MR. KOONTZ: I believe that was question seven,  
14 Bob.

15           MR. SULLIVAN: Were you satisfied with our response  
16 on seven?

17           MR. PIERSON: Let's go ahead and talk more about  
18 spurious actuates. We've still got pressurizer PORVs to talk  
19 about and we've still got RCS letdown. When we finish that  
20 then we can come back to that.

21           MR. GARG: Okay. I think the question I still have  
22 is that you pull the fuses for all the high/low interfaces?  
23 Is that what you are doing?

24           MR. WILLIAMS: We're only pulling the fuses if that  
25 valve spuriously actuates.

1 MR. GARG: That has to be that.

2 MR. WILLIAMS: What I want to make clear is we're  
3 not pulling the fuses in advance of the event. They are not  
4 being pulled now.

5 MR. GARG: No, but you have a procedure before --  
6 You will have the instructions for the operator that if he  
7 detects -- that he will pull the fuse, for all high/low  
8 differences.

9 MR. WILLIAMS: For the reactor head vent.

10 MR. GARG: No, I'm talking about all high/low  
11 differences. There are four or five identified, right?

12 MR. SULLIVAN: Only on the reactor head vents. The  
13 internal letdown, if you go through Attachment 2 in the  
14 submittal that you received this morning, it goes through in  
15 detail all four of those and what we've done. The reactor  
16 vessel head vents we stated in Attachment 2 that the operator  
17 could pull the fuses, and that is what, we already had an  
18 AOI, abnormal operating procedure for the operator to verify  
19 the valves closed. We'll go on and enhance that one step  
20 further and tell them if it doesn't close we'll pull the  
21 fuses. We'll go ahead and put in an SOI 26.2 and identify  
22 that those fuses need to be pulled in the event of a  
23 confirmed fire to protect the plant and equipment.

24 MR. PIERSON: How long does it take for the  
25 operator to do that?

1           MR. SULLIVAN: The fuses are two doors away from  
2 the control room, about 100 feet. When he knows they're  
3 spuriously opened and he has pulled out his procedure and is  
4 ready to go, ten minutes would be a very conservative  
5 estimate.

6           MR. GARG: If you look at it, two shorts are  
7 incredible. Again, I have a problem there.

8           MR. MARINOS: Are you modifying the statement to  
9 say by applying the removal of fuses you will increase the  
10 need for failures to cause you the inadvertent actuation?  
11 The statements say two shorts are incredible. But what I  
12 have heard here, it will require more than two shorts in  
13 order to cause the inadvertent situation.

14          MR. WILLIAMS: No sir. It takes one short to  
15 inadvertently actuate. Pulling the fuses causes at least two  
16 more.

17          MR. MARINOS: That makes it three.

18          MR. WILLIAMS: Right. But it only takes one to  
19 initially make it actuate, and then it takes two more to  
20 bring it back open again.

21          MR. PIERSON: If I could interject here, you're  
22 saying then that it takes one short to spuriously actuate the  
23 reactor head vent valves?

24          MR. SULLIVAN: That's due to an internal cable  
25 fault. The same power force. You pull the fuses in that

1 event.

2 MR. PIERSON: How does that meet generic letter  
3 8610?

4 MR. SULLIVAN: We performed the further evaluation  
5 and documented that evaluation to you that said that that  
6 line being restricted by a three-eighths inch orifice which  
7 separates reactor coolant system piping from non-reactor  
8 coolant system piping, was not a loca, was within the makeup  
9 capability of the centrifugal charging pump, so we could  
10 proceed with a normal --

11 MR. PIERSON: So I can infer from that that your  
12 centrifugal charging pump is in your Appendix R safe shutdown  
13 evaluation, and all the control circuitry, and you've  
14 established that that is going to be operable in the event  
15 you have this spurious actuation?

16 MR. SULLIVAN: We will always have a centrifugal  
17 charging pump that satisfies the shutdown logic requirements.

18 MR. GARG: I think I'm still looking for an answer  
19 on Item 3, RCS is nominal and accessibly done.

20 MR. SULLIVAN: In Attachment 2?

21 MR. GARG: Yes. Here you make a statement that it  
22 would take two shorts of the proper polarity without  
23 grounding, and each of these --

24 MR. SULLIVAN: Let me explain this. There are two  
25 pipe and flow paths--normal and excess letdown. In similar

1 ways, head vents, you have two flow paths, an A train and a B  
2 train. Head vents have two valves in series. We just went  
3 through all that. That's why it takes the four hot/shorts of  
4 the proper polarity to get those things open. In this line  
5 you have three valves in series in each of the two paths. So  
6 it would take three hot/shorts, two hot/shorts of the proper  
7 polarity, to get all three of those valves open.

8 MR. GARG: Is it three, or three paths?

9 MR. SULLIVAN: There are two paths, three boundary  
10 valves in each path.

11 MR. GARG: Three in each path. And they have no  
12 problem.

13 MR. SULLIVAN: Right. They are normally fail close  
14 valves, and you would have to hot them up and have air  
15 supplied to them at the same time to get all three valves up.

16 MR. PIERSON: You're talking about the RCS letdown  
17 path?

18 MR. SULLIVAN: And excess letdown.

19 MR. PIERSON: One other question I've got is in  
20 terms of availability of RCS letdown. Have you considered  
21 all your spurious actuation circuits to verify that in all  
22 conditions you're going to have RCS letdown available?

23 MR. SULLIVAN: RCS letdown availability is not  
24 guaranteed by the shutdown logic and Appendix R analysis.

25 MR. PIERSON: We talked earlier about the



1     pressurizer PORV and these interactions that you consider on  
2     the pressurizer PORV. Could you elaborate on where they are  
3     and what they are?

4             MR. SULLIVAN: This is from memory. Two locations  
5     in the annulus of Unit 2, Unit 1 has not been looked at; two  
6     locations in the Unit 1 annulus, one involves each of the  
7     PORVs. A PORV may spuriously open there, considering the  
8     hot/shorts from the cable. No internal cable hot/shorts  
9     would cause the valve to open.

10            MR. PIERSON: Cable to cable fault you're talking  
11     about?

12            MR. SULLIVAN: Yes, it has to be a cable to cable  
13     fault.

14            MR. BLACK: Norman Black, Electrical Group at  
15     Sequoyah. That's correct. The three interactions or  
16     identified concerns, two of them are in the reactor building  
17     Unit 2 annulus, and one is in the emergency gas treatment  
18     area where we have a situation where the PORV cable is tray  
19     routed in close proximity to a block valve which we have  
20     identified. It happens to be the train B block valve  
21     associated with that train A PORV valve.

22            MR. PIERSON: Do you consider this cable to cable  
23     interaction a problem?

24            MR. BLACK: On that particular circuit?

25            MR. PIERSON: Are you planning on doing anything

1 about it, or are you just telling us it exists? What is your  
2 answer with respect to that?

3 MR. SULLIVAN: Let me try to address that.

4 We're currently relooking at both the spurious  
5 cable to cable concern and also the letdown concern. We have  
6 not decided what to do about them or made any decisions. In  
7 this particular case Norm's talking about, it's emergency  
8 power supplying the block valve that's in question. If  
9 you're sending the cable to cable fault, the emergency power  
10 from the diesels to that valve may not be available. If off-  
11 site power was available the block valve would be available  
12 to close. That was our problem.

13 MR. PIERSON: It sounds to me like there's a  
14 problem there that we need some additional information before  
15 we can resolve. Is that a correct assumption on my part?

16 MR. FOX: Can we take a five minute caucus? I'm  
17 not sure, we've got too many people speaking to the issue.  
18 Could we take a few minutes to caucus and then give you a  
19 coherent answer to your question?

20 MR. PIERSON: Yes. Make it ten minutes.

21 (Whereupon, a brief recess was taken)

22 MR. HOSMER: Let me answer the question by first  
23 starting with a little bit of history.

24 The majority of the Appendix R work on Sequoyah we  
25 reconvened a team and did our, well let me go back even

1 further.

2 The NRC confirmation letter was sent to us in 8/84  
3 saying "confirm you meet Appendix R 3GJLL." We formed a  
4 team, we completed our work, and we completed that work with  
5 the submittal to NRC in December 1984. So the history is we  
6 had completed our work and submitted that to you the end of  
7 December 1984. Generic letter 8610 obviously was issued  
8 after that.

9 I would like to read from the cover letter of the  
10 generic letter a couple of sentences. "This package  
11 represents recent staff assessments of these questions and  
12 provides guidance as to acceptable methods of satisfying  
13 commission regulatory requirements." Attention to the next  
14 sentence. "Other methods proposed by a licensee for  
15 complying with commission regulations may also be satisfied  
16 and will be considered on their own merits." We proposed,  
17 and we feel you have accepted, other methods.

18 Our basis that we presented to you for other  
19 methods of compliance with 8610 and particularly this issue  
20 of cable to cable interaction, were low probability of  
21 interaction for ungrounded DC systems, and the fact that we  
22 had ungrounded AC systems and had low probability of  
23 interaction. That was our basis and that is what we believe  
24 you have accepted. It is documented in a December 21, 1984  
25 letter to the commission. Your acceptance enclosure of that

1 is documented by at least three inspection reports; at least  
2 two that I have access to today, 8741 and 8640.

3 In conclusion, we meet 8610. We meet it by  
4 approved alternate exceptions.

5 MR. PIERSON: I've looked at the inspection reports  
6 and I'm not sure that I can agree with what you say. This is  
7 probably the wrong forum to take that up. What we'll do is  
8 we will understand what you have done with respect to  
9 spurious actuation cable to cable. I think we can understand  
10 that you essentially have not done it in accordance with 8610  
11 literally, but you feel like the exceptions that you do have  
12 have been evaluated by the NRC and accepted by the NRC. Is  
13 that a correct synopsis?

14 MR. FOX: Again, I want to make the statement that  
15 8610 is not a set of requirements. It is merely guidelines  
16 and it allows alternate means.

17 MR. PIERSON: I understand that.

18 MR. FOX: We feel like we meet it per the alternate  
19 means.

20 MR. PIERSON: I understand what you're saying, but  
21 I am not telling you that I am accepting what you're saying.

22 Are there any more questions with respect to  
23 spurious actuation?

24 MR. GARG: Just for the record, I want to know, we  
25 have talked about high/low interface, and we haven't talked

1 about any other subjects. Have you considered any other  
2 subjects besides high/low interface for this?

3 MR. WILLIAMS: Let me try to address that.  
4 Specifically to address cable to cable, the answer is no.  
5 But much of the analysis that we did with Appendix R and our  
6 calculations bounded the cable to cable case.

7 For instance, in the main control room, the  
8 spreading room, the auxiliary instrument room, we looked to  
9 see if we had an alternate path for any device that faulted.  
10 We didn't consider the mechanical means for the basis for  
11 that fault, we just said that we had a faulty device and do  
12 we have an alternate.

13 If you look at things like the short circuit  
14 calculation and some of the coordination studies, basically  
15 they did the same thing. They considered like a three phase  
16 fault, regardless of how they got it, whether it was  
17 conductor to conductor or cable to cable. So there is much  
18 in the analysis we feel is bounded the cable to cable case,  
19 even though specifically we did not address it that way.

20 MR. PIERSON: Could you discuss the RCS letdown  
21 path in terms of reactor coolant system letdown in the event  
22 of an Appendix R event? It says on your Attachment 5,  
23 "Further analysis being performed that will result in an RCS  
24 letdown path." Can you amplify on that statement and explain  
25 what you mean by that?

1 MR. SULLIVAN: You're referring to the preliminary  
2 work that had been done?

3 MR. PIERSON: On Attachment 5 of your submittal  
4 today.

5 MR. FOX: Give us just a minute. Attachment 5?

6 MR. PIERSON: Attachment 5 to the submittal you  
7 gave us. It's on the same page that we talked about with  
8 respect to pressurizer PORVs and also the reactor head vent  
9 valves. He said, "Further analysis is being performed that  
10 will result in an RCS letdown path."

11 MR. SULLIVAN: That analysis is in its preliminary  
12 stage right now. I think it's being reviewed and checked, is  
13 that right Norm?

14 MR. KOONTZ: No, we have the analysis right here.

15 MR. PIERSON: May I ask what does that mean? What  
16 is that analysis to accomplish?

17 MR. SULLIVAN: That analysis ensures that a  
18 pressurizer PORV or a head vent path is available for letdown  
19 from the RCS.

20 MR. PIERSON: I'm confused then. Is that strictly  
21 for a fire, or is that --

22 MR. SULLIVAN: This was done for a fire. It's not  
23 a current requirement of our shutdown logic or safe shutdown  
24 to have a letdown path. This evaluation was done to see if  
25 the plant in its physical layout had any problems in it where

1 you would not have a letdown path.

2 MR. PIERSON: What does that mean with respect to  
3 the statement you said earlier that you didn't take Appendix  
4 R approved path for letdown then for vent valves or PORVs?

5 MR. SULLIVAN: As I stated, in the current shutdown  
6 logic for safe shutdown, letdown is not identified and we do  
7 not take credit for it.

8 MR. PIERSON: Then why are you doing this letdown  
9 analysis?

10 MR. SULLIVAN: A question was asked to us  
11 concerning letdown and we went off and looked at the cables  
12 that we already had plotted because we had to ensure letdown  
13 would isolate. This was sort of the flip question, now can  
14 you ensure a letdown path is available. So we had all the  
15 cables plotted. We just went out and looked at what they  
16 were.

17 MR. PIERSON: So you're telling me that in all  
18 cases you've got an RCS letdown path available?

19 MR. SULLIVAN: No, I'm not telling you that.

20 MR. PIERSON: Okay. You're telling me as a result  
21 of that that you've done an analysis to show that your  
22 pressurizer PORV and your reactor coolant system vents can be  
23 used as a letdown, is that correct?

24 MR. SULLIVAN: No. We're saying we've done an  
25 analysis to see if they can be used as a letdown path.

1 MR. PIERSON: So what is the conclusion? Do you  
2 have a letdown path?

3 MR. SULLIVAN: In all but two locations which are  
4 in the annulus area for Unit 2. I don't know about Unit 1.  
5 We could have a letdown path.

6 MR. PIERSON: And you're going to address those two  
7 locations to provide to us with this analysis you've got  
8 here? Is that what you're doing?

9 MR. FOX: Yes, we will.

10 MR. PIERSON: Are there any other questions with  
11 respect to question number 12?

12 (No response)

13 MR. PIERSON: I'm going to move on then, to  
14 question 13. I don't have any questions about question  
15 number 13. Does anyone in the staff have a question about  
16 number 13?

17 (No response)

18 MR. PIERSON: Question number 14.

19 MR. GARG: I want to ask one question on question  
20 number 12 again. You have not considered the internal  
21 circuits for the cable to cable interaction?

22 MR. WILLIAMS: Yes, we have considered internal.

23 MR. GARG: I mean the two cables. I mean the  
24 circuits connected to the common bus could be shorted by one  
25 single short. Have you considered that?



1 MR. MARINOS: This is in connection with your  
2 statement earlier about the ungrounded AC and DC which is a  
3 legitimate electrical engineering argument, but if you had,  
4 that is true perhaps, for circuits that come from independent  
5 sources. If they are ungrounded, yes, it is a legitimate  
6 argument. But if the circuits are coming from the same  
7 common bus, have you addressed that? It will not be.

8 MR. WILLIAMS: In the original analysis, the cable  
9 to cable short was not considered. The basis for not  
10 considering the cable to cable short was the fact with the  
11 ungrounded system and the kind of the random arrangement  
12 we've got in cables and trays, the fact that it does take  
13 something on a common bus or a common transformer to cause  
14 that short, that we considered that a much less likely event  
15 to happen than having conductor to conductor shorts within a  
16 cable. For the case that you brought up for the high/low  
17 pressure interfaces, we did in fact go back and evaluate  
18 those four cable to cable shorts.

19 MR. GARG: No, but for the circuits besides  
20 high/low, you have to consider single short and if it can  
21 cause a spurious acuations.

22 MR. WILLIAMS: The way the analysis was done within  
23 the main control room, the spreading room, and the auxiliary  
24 instrument room, we bounded that analysis by making sure we  
25 always had an alternate path. Outside the high/low pressure

1 interfaces and outside those three areas we have not  
2 specifically looked at cable to cable shorts. But we do not  
3 think from the basis of our system that that's really a  
4 credible event.

5 MR. GARG: Well, you are not in compliance with  
6 8610.

7 MR. ROTELLA: Have you responded to 8610?

8 MR. HOSMER: We have never been asked to.

9 MR. GARG: Aren't you supposed to respond to  
10 generic letter?

11 MR. FIORAVANTE: Could you just please explain why  
12 you are interpreting them as not in compliance with 8610?

13 MR. GARG: Because 8610 requires that for any, --  
14 high/low interface you have to consider if a single short can  
15 create those --

16 MR. FIORAVANTE: Isn't it also in 8610 that it says  
17 for ungrounded DC you do 't have to consider --

18 MR. GARG: If you are a common bus then there is a  
19 case. If you are ungrounded, separate circuit then you  
20 don't. Then you don't have a scenario.

21 MR. FIORAVANTE: I guess I'm a little confused.  
22 Where in 8610 does it say anything about a common bus?

23 MR. GARG: In 8610, I think that was referenced to  
24 the separate circuit.

25 MR. MARINOS: You can only take credit for

1 ungrounded system if it will be two separate sources. If it  
2 is the same one it doesn't matter whether it's grounded or  
3 ungrounded, if it is the same circuit.

4 MR. PIERSON: We will discuss this later.

5 MR. MCGARRY: This is Mike McGarry. I just want to  
6 make one comment.

7 8610, so there is no confusion, did not require  
8 that a utility respond to 8610. It was put on the street to  
9 assist utilities and provide guidance. In this situation  
10 Sequoyah had already formed its fire hazards analysis in  
11 advance, prior to the issuance of 8610.

12 MR. PIERSON: I understand that.

13 Has everyone signed the attendance sheet? If you  
14 haven't I'll pass it down.

15 I'd like to continue on with question 14 if that  
16 takes care of the questions on number 12.

17 MR. WESCOTT: I would like to speak to someone on  
18 question 14 if they would be willing to address it.

19 MR. PIERSON: What is your question?

20 MR. WESCOTT: I spoke on the phone with Jimmy  
21 Pierce and we discussed the various situations where you  
22 actually have a non-ducted damper between wall, and there  
23 was one item here that I can't remember us talking about and  
24 that was where you had fire detection on both sides and  
25 automatic suppression on only one side. That may have been

1 mentioned, but I didn't hear it at the time.

2 I'm a little bit concerned about this particular  
3 situation and I'd like to ask two questions about areas where  
4 you have this particular type of setup.

5 First of all is the manual suppression. Can one  
6 get to that without going through the room where the fire is  
7 in all cases?

8 MR. PIERCE: Yes. The manual suppression is in  
9 some auxiliary instrument rooms, I believe, aux shutdown  
10 boards, and the actuation of those circuits are in another  
11 room.

12 MR. WESCOTT: The room where the major fuel load  
13 is, the significant fuel load, that has an automatic  
14 suppression I assume in all cases?

15 MR. PIERCE: Yes.

16 MR. WESCOTT: And the rooms that do not have  
17 automatic suppression have very limited fuel load.

18 MR. PIERCE: The only fuel load in there is the  
19 insulation on the cables in the trays, and those trays are  
20 coated with pneumastic. We've got ionization smoke detection  
21 in that room and manually actuated suppression.

22 MR. WESCOTT: Thank you.

23 MR. PIERSON: Any other questions with respect to  
24 14?

25 (No response)

1           MR. PIERSON: Let's go on to question 15. Provide  
2 the fire interaction study for a fire in the immediate  
3 vicinity of the pressurizer. That comes back to the  
4 questions we discussed earlier in question 12, and I think  
5 we're going to have to address that in some other format. We  
6 understand what your position is, and we'll have to come  
7 back to you later.

8           So I'd like to go on to question 16. TVA has  
9 provided us this list which is requested in question number  
10 16. I'll go on to question 17.

11           Question number 17 is with respect to passing of  
12 liquid through a pressurized or code safety valve and the  
13 resultant erosion and subsequent ability of the valve to  
14 reseal. This question and many of the questions that we've  
15 covered seem at face value to be outside the context of  
16 Appendix R, but the way some of these questions were  
17 developed was on the assumption that some of the scenarios  
18 would be applicable, and in that event these questions  
19 necessarily would follow through. This is, of course, coming  
20 from where the pressurizer, your system becomes solid and you  
21 use a code safety valve as a pressure control mechanism. It  
22 wasn't clear to us, and may not still be clear to us, that  
23 that doesn't occur.

24           You've provided a list here that talks about the  
25 EPRI test, and I understand that code safeties are not

1 necessarily designed to pass water, although some of them  
2 will up to a point. But I don't think there is anything more  
3 to be gained by asking you any more questions with respect to  
4 that one, so I'd like to go on to question 18.

5 MR. HOSMER: Can I ask a question?

6 MR. PIERSON: Sure.

7 MR. HOSMER: Would it help if we explain to you why  
8 we do not believe it will go solid?

9 MR. PIERSON: Yes, but let's wait until we go  
10 through the questions. I think there is another question  
11 that addresses that specifically.

12 Number 18 is provide rationale for protection of  
13 centrifugal charging pump cavitation from a spurious  
14 actuation in the volume control tank isolation valve.

15 I'd like to talk to you a little bit about that.  
16 I'm not quite sure from talking to Mr. Koontz and Mr.  
17 Burzynski, it's my understanding that if you do have a  
18 spurious actuation of that isolation valve, that you still  
19 have the ultimate charging pump available, is that correct?

20 MR. SULLIVAN: The approach to the charging pump  
21 suction is to either remove power by opening the breaker on  
22 the board, transferring suction to the RWST and removing  
23 power from its breaker so you don't have the same problem  
24 again, or stopping the pump by the operator in the control  
25 room. This is all proceduralized in the SOI 26.2 to be done.

1           MR. PIERSON: Do you have any sense of how long  
2 you've got before the charging pump cavitation results in  
3 inoperability of the charging pump?

4           MR. SULLIVAN: I'd like to address that question by  
5 making the statement that we have done an evaluation and  
6 determined that for a fire in the area we should have at  
7 least ten minutes to perform these actions before the valves  
8 go closed.

9           MR. PIERSON: Ten minutes before the VCT isolation  
10 valve goes closed?

11          MR. SULLIVAN: Yes.

12          MR. PIERSON: How would the operator know that a  
13 fire started? Why would he know there was a fire in that  
14 area?

15          MR. SULLIVAN: Fire detection, fire suppression  
16 actuation, the fire alarm system.

17          MR. PIERSON: So when a fire occurs in that area he  
18 secures that charging pump and volume control tank and shifts  
19 the suction to the RWST tank?

20          MR. SULLIVAN: Yes.

21          MR. PIERSON: Is there any credibility or any  
22 possibility that the same fire that would affect that volume  
23 control tank isolation valve could also affect the standby  
24 charging pump?

25          MR. SULLIVAN: I believe when you get to some of

1 your end devices such as your MOV boards where power to the  
2 valves comes from, that's a possibility. Down locally at the  
3 valves and throughout most of the plant, no, that is not  
4 credible because the valves are in a room by themselves,  
5 charging pump cables don't go in that room, and to address a  
6 little further about the MOV boards for the valves to go  
7 closed, it would almost have to be a fire internal to those  
8 boards.

9 MR. PIERSON: Which wouldn't affect the power to  
10 the charging pump?

11 MR. SULLIVAN: Which wouldn't affect the cable  
12 trays in the area. That's not the approach we took. We  
13 looked at that. We took the approach of getting the operator  
14 to get power off the valves which was consistent with what  
15 the rest of the industry has done to address this generic  
16 Westinghouse type question.

17 MR. PIERSON: Did you provide that analysis to us  
18 in one of your submittals?

19 MR. SULLIVAN: Which analysis?

20 MR. PIERSON: What you're talking about, this  
21 approach you're talking about here.

22 MR. SULLIVAN: I think you've got a copy in SOI  
23 26.2.

24 MR. PIERSON: All right.

25 MR. WESCOTT: What type of fire detection do you



1 have in that area, do you know?

2 MR. SULLIVAN: Just ionization alone.

3 MR. PIERSON: One other question. The tripping  
4 mechanism of the centrifugal charging pump, is that protected  
5 so the same fire couldn't wipe out the volume control tank  
6 isolation valve and the tripping mechanism to the pump?  
7 Would it be a case where you couldn't isolate the pump?

8 MR. SULLIVAN: There are three alternates involved.  
9 He can move power from the VCT outlet valve, such that they  
10 will not go closed. He can transfer suction, or basically  
11 open the RWST valves and remove power from them so they will  
12 not go closed. Or he can trip the pump. So there are two  
13 backups in case he cannot trip the pump. I cannot address  
14 that. I'm sure you can build a fire in a certain place and  
15 you couldn't trip a pump, but I cannot address if that's the  
16 same fire that would cause a problem with these valves.

17 MR. PIERSON: But you're sure that you still have  
18 at least one remaining pump operable, the standby pump?

19 MR. SULLIVAN: What I'm trying to say is we have  
20 two other methods that the operator has in a situation that  
21 should he not be able to stop the pump he can remove power  
22 from the VCT outlet valves or he can go ahead and open an  
23 RWST supply valve and remove power from her.

24 MR. PIERSON: Any more questions about question  
25 number 18?

1 MR. NOTLEY: This is Dave Notley.

2 A couple of weeks ago we had a fire protection  
3 engineers meeting in Atlanta. One of the questions that came  
4 up was sending out a fire brigade immediately upon receipt of  
5 fire alarms. The response was that most plants send a runner  
6 down to establish that there is a fire before they call the  
7 fire brigade and dispatch them.

8 Do you do the same thing, and what you were just  
9 talking about? You have ten minutes to take action and  
10 prevent damage to the pump, and you were asked does the  
11 operator perform this action immediately upon receipt of the  
12 fire alarm. I think I heard you say yes, but I want to make  
13 sure you don't send a runner down to establish that there is  
14 a fire before you start this kind of action.

15 MR. ROTELLA: If there's a fire you're going to  
16 shut the plant down with boron coming from the RWST.

17 MR. SULLIVAN: The way we normally do it is if  
18 someone calls in on 6299 which is the plant fire alarm, all  
19 the fire brigade will respond. I know that for a fact. The  
20 fire brigade leader is the man responsible for notifying the  
21 control room when there is a fire affecting plant equipment.  
22 If it's a cigarette smoldering in a corner in a turbine  
23 building somewhere and the fire alarm comes in, we're not  
24 going to go through this scenario. The fire brigade leader  
25 is responsible for notifying the shift supervisor in the

1 control room who is in the command function when there is a  
2 fire affecting plant equipment, he knows the location of the  
3 fire, we go to our fire interaction manual, you open it up  
4 for that location, and it will tell you for that location  
5 what might happen and what action he needs to take.

6 MR. NOTLEY: I think your answer is yes, that you  
7 do send someone down on receipt of automatic fire alarm to  
8 establish that there is a fire.

9 MR. SULLIVAN: True.

10 MR. PIERSON: You need all the ten minutes, right.

11 MR. SULLIVAN: I'd like to add a concluding  
12 comment. Our response to this condition which is generic to  
13 a lot of other Westinghouse PWR's is consistent with what  
14 they're doing, and we think we've taken the appropriate  
15 action in this area consistent with other safety requirements  
16 to protect the charging pump from loss of suction.

17 MR. PIERSON: And you're sure that you have the  
18 remaining charging pump. There is nothing in your procedure  
19 that tells the guy to secure the one charging pump and then  
20 turn on the B charging pump on the same suction and destroy  
21 it as well, is that correct?

22 MR. SULLIVAN: There is nothing in the instruction  
23 for that.

24 MR. PIERSON: Good.

25 The next question is question number 19. The basis

1 for fire protection of Appendix R shutdown systems inside the  
2 containment. We addressed most of the questions with respect  
3 to this in question number 12, spurious actuation. I don't  
4 have anything else to add to this. Does anyone else have  
5 something they want to talk about with respect to question  
6 19?

7 (No response)

8 MR. PIERSON: If not, I'll go on to question number  
9 20. Question 20 discusses the possibility of two low  
10 pressure signals causing an actuation of the safety injection  
11 system. Sequoyah says safety injection is not required for  
12 safe shutdown at Sequoyah. I don't have any questions with  
13 respect to your response here. Does anyone on the staff have  
14 anything they want to address?

15 MR. ROTELLA: I have a question back on 19. for  
16 the RHR valves that we talked earlier, on 74-2, you stated  
17 that you've done a review of the area and have determined  
18 that you can't have a fire that is going to propagate from  
19 the motor on that valve, and that there are no surrounding or  
20 intervening combustibles. I guess I need to ask the question  
21 then, do you intend to submit a deviation for that condition?

22 MR. PIERCE: No, we had not planned on submitting a  
23 deviation on that. What we were looking at is the guidance  
24 you had given in 8610 said we could do a fire hazard  
25 evaluation in the area as long as it's done by appropriate

1 people, i.e., fire protection engineer and systems engineer,  
2 and provide that information to you for review. If you  
3 agree, and it's intuitively obvious that conditions we  
4 describe are as they state so we don't have to submit a  
5 deviation.

6 MR. ROTELLA: I'd like to ask the staff, Dennis  
7 Kubicki, if he could respond to that. Is that true?

8 MR. KUBICKI: This is Dennis Kubicki. Do I  
9 understand your question that you're asking me whether they  
10 have to submit a deviation for this condition? If 8610, the  
11 premise that I'm going to be basing my answer on is that if  
12 8610 establishes means for satisfying 3GJ LNO of Appendix R,  
13 and if they don't conform with that guidance, then a  
14 deviation is appropriate. I think in this particular case we  
15 should avoid the semantical distinction and say that if  
16 they've got a condition that doesn't literally conform with  
17 the explicit guidance in 8610, then they should provide the  
18 justification to us and we should review it without really  
19 calling it a deviation or whatever.

20 MR. GEORGE: This is Hank George. The condition  
21 we're talking about here is one where what was evaluated was  
22 whether these are components that would be susceptible to  
23 fire damage. Where the evaluation says that, basically  
24 concluding that you can still get in there and manually  
25 operate these valves, it's not an engineering evaluation to

1 justify adequacy of separation which is the 3G item that  
2 Dennis is referring to. So this engineering evaluation is  
3 not one that relates to a demonstration of meeting 3G. It's  
4 just whether these components could be damaged by a fire.  
5 Since they couldn't, these are valves that have manual  
6 operators on them. Even though they are motor operated,  
7 there are still hand wheels on them. That function is what  
8 was concluded as still being operable for fires in that area.

9 So under that, I think our interpretation would be  
10 that that is not an item requiring an engineering evaluation  
11 per 8610, or a deviation request.

12 MR. MCGARRY: I want to agree with Dennis Kubicki  
13 in that let's put the semantics aside and get down to what is  
14 really the substantive issue. But 8610 does state in page 14  
15 the question, if a utility determines that a deviation from a  
16 guidance document exists, then an exemption request needs to  
17 be filed. If so, what is the legal basis for this  
18 requirement? The response is no. In other words, you can  
19 have a deviation from 8610 and you don't have to file an  
20 exemption.

21 MR. PIERCE: Let me just say, we have provided you  
22 with that evaluation. If you've got any questions concerning  
23 that evaluation we'll be glad to talk to you.

24 MR. ROTELLA: That was the March 8th submittal, the  
25 one we just got?

1 MR. PIERCE: Yes.

2 MR. ROTELLA: Thank you.

3 MR. PIERSON: Okay, we'll go on. I think we're on  
4 question 20. I don't have any questions on question 20.  
5 Does anyone in the staff wish to address question number 20?

6 (No response)

7 MR. PIERSON: Question number 21, has TVA evaluated  
8 effects of fire on instrument sense lines? Provide the  
9 results of the evaluation on the functional analysis report.

10 We have some information from TVA with respect to  
11 fire effects on instrument sense lines, and I think we still  
12 have a few remaining questions. Mr. Garg, do you have  
13 questions still with respect to instrument sense lines?

14 MR. GARG: Yes, I have a couple of questions. One  
15 is I think on your document QYR SQP SQN 38, on Item 4 and 5,  
16 there is a statement that -- nothing inside -- I think we  
17 talked to somebody in here to explain why it wasn't done. I  
18 would like that information to be put in the record.

19 MR. PIERCE: I'd like for Ed Connell, one of our  
20 fire protection engineers to address that for you.

21 MR. CONNELL: The basis of the question was  
22 regarding whether or not a fire inside containment would make  
23 the containment untenable for manual operation of the valve.  
24 The evaluation in the areas of these penetration boxes  
25 concluded that a fire inside the penetration box could damage

1 the cables inside that box and therefore we would not be able  
2 to operate the valve outside containment. A fire in this box  
3 would certainly be a small fire, would not cause the spurious  
4 operation or release of any kind of RCS volume into the  
5 containment, and the manual operation of the valve could  
6 still be achieved.

7 MR. GARG: Okay. Another question I have is, I  
8 think the analysis you gave on the document SQN 00D052 EPM  
9 ESC 011888 did address only the pressurizer and --  
10 instruments. My question is, have you considered all other  
11 instruments for which you take a credit in the Appendix R?

12 MR. CONNELL: This particular analysis dealt only  
13 with steam generator and pressurizer level instrumentation.

14 MR. PIERCE: Let me interrupt right here and give  
15 you a little background on that. We wrote a CAQ back in  
16 early 1987 that said instrumentation sense lines had not been  
17 adequately reviewed for fire fix. As a result of that CAQ we  
18 did an Appendix R separation analysis on instrumentation  
19 sense lines. The result of that CAQ was another condition  
20 adverse to quality that identified four areas where we had  
21 interactions in which the sense lines did not meet Appendix R  
22 separation criteria. The fire hazard analysis evaluation was  
23 done to address those four areas where adequate Appendix R  
24 separation did not exist for those sense line instruments  
25 that were identified in that CAQ.



1 MR. CONNELL: The conclusion regarding the level  
2 indication for pressurizer and steam generator concluded that  
3 we would have at least one level indicator for each steam  
4 generator and we would retain one level instrument for the  
5 pressurizer, for any fire inside the containment.

6 MR. GARG: My question is not with your analysis on  
7 this. My question is do you have any document that you don't  
8 have any of that problem with the instrument lines?

9 MR. PIERCE: We documented where we had problems.  
10 I don't think we have to document where we don't have  
11 problems. We did an evaluation and found out where we did  
12 have problems, and then addressed them.

13 MR. GARG: You are saying, where you have addressed  
14 your evaluation, where can I find your evaluation on the  
15 instrument lines?

16 MR. PIERSON: What Mr. Garg is asking for is where  
17 do you have the evaluation that says the only point in  
18 containment where you have a problem is with respect to the  
19 steam generator level and the pressurizer levels?

20 MR. PIERCE: The corrective action CAQRASQP 870857.

21 MR. PIERSON: Do we have a copy of that?

22 MR. PIERCE: We gave you that CAQ. Then CAQR  
23 870151 identified where we had interaction specifically.

24 MR. PIERSON: We'll look at that. I have one other  
25 question. Did you discuss pressurizer or steam generator

1 pressures? I heard levels. Is a pressure required?

2 MR. SULLIVAN: Steam generator pressure is outside  
3 containment. It was provided separation by the original --  
4 saw a reevaluation of the 84-85 time frame.

5 RCS pressure was your second part of that, is that  
6 correct?

7 MR. PIERSON: Yes.

8 MR. SULLIVAN: There are three RCS pressure  
9 channels, two of them are pan instrumentation that are routed  
10 outside to the auxiliary building, and the other one is off  
11 which is wide range RCS, the other one is off the  
12 pressurizer.

13 MR. PIERSON: So you have three instruments, is  
14 what you're saying?

15 MR. SULLIVAN: Three instruments.

16 MR. PIERSON: You're confident that --

17 MR. SULLIVAN: We're confident we have separation  
18 between the two pans and the one over on the pressurizer.

19 MR. PIERSON: I'm sorry, I missed something there.

20 MR. SULLIVAN: The requirement being a 20 foot  
21 separation inside containment.

22 MR. PIERSON: So you met that 20 foot separation is  
23 what you're saying?

24 MR. SULLIVAN: Yes.

25 MR. GARG: How about instrument line outside the

1       containment? Did you consider those?

2               MR. SULLIVAN: Yes, by the electrical engineering  
3 branch, and I am not sure we submitted that calculation, but  
4 we will give you that information. We don't have it with us  
5 right now.

6               MR. LIAW: This is B. D. Liaw.

7               With regard to what you said, Mr. Sullivan, about  
8 CAQR and another, have they been closed for restart?

9               MR. PIERCE: Yes, they were determined to be  
10 restart, and they are already complete. Corrective action of  
11 those has been complete.

12              MR. PIERSON: Do we have any other questions on  
13 number 21?

14              MR. HUBBARD: George Hubbard. I have one quick  
15 question on that. He referenced a CAQR 870151. In looking  
16 through the documentation this morning, I didn't find that  
17 particular CAQR.

18              MR. FOX: We'll get it to you.

19              MR. PIERCE: I apologize for that. I thought we  
20 had sent that to you.

21              MR. PIERSON: Any other questions on sense lines,  
22 number 21?

23              MR. GARG: No, I don't have any.

24              MR. PIERSON: The next question I'd like to talk  
25 about is question 22. I'd like to point out something.

1 Within the response with the exception of number 12, the  
2 response to number 22 is very difficult. It dances around  
3 the issue, and I think I understand what you're trying to  
4 say, but it's misleading. Explain why the fire in  
5 containment would not affect the instrumentation as discussed  
6 in the task group deposition of issues in B2 used by the  
7 operator. Distinguish between a fire and a loca. You talk  
8 about what you take credit for here, and then you go into a  
9 list of instruments there without differentiating which of  
10 those instruments are Appendix R instruments, which of them  
11 are safety grade instruments, it's just a list of  
12 instruments. It's difficult to make any sense of that. But  
13 I talked to your staff and I think I understand where I can  
14 expect an answer from you with respect to that question. So  
15 I don't have anything to address on that, but I did want to  
16 make a comment there.

17 Would you like to say anything?

18 MR. HOSMER: We apologize for confusing you.

19 MR. SULLIVAN: Do we owe you something on this one?

20 MR. PIERSON: You told me you were going to take  
21 this list of instruments and tell me which were EQ and which  
22 were safety related and which were fire protection  
23 instruments.

24 MR. SULLIVAN: Okay. We have a list of those that  
25 are EQ. As far as addressing the safety related and

1 distinguishing between a fire and a loca, we can explain that  
2 to you also.

3 MR. PIERSON: We'll listen.

4 MR. SULLIVAN: This question is tied into 20 and 26  
5 as well. It is possible for two low pressure signals to  
6 cause a spurious SI in this plant, we believe, but SI is not  
7 required for safe shutdown.

8 Narrow range RCS pressure is also not required by  
9 our analysis. The fire that's inside containment, we have  
10 wide range RCS pressure which is located in the auxiliary  
11 building, elevation 690; and some outside containment  
12 radiation monitors, 9106 and 112 which sample inside  
13 containment. Also containment pressure differential  
14 transmitters which measure containment pressure that are  
15 located in the annulus. All these things are principally  
16 outside the reactor building itself where we believe they  
17 would be available post-fire.

18 Additionally, as we have mentioned earlier, we'll  
19 have pressurizer level available and we'll have steam  
20 generator level, one for each of the steam generators. Thus  
21 the SI termination criteria that's specified for the operator  
22 to use which states that sub-coolant has to be greater than  
23 40 degrees since he has RCS pressure and since he has  
24 temperature in two of the four loops, he can satisfy that  
25 point of the four point termination criteria.

1           The second point being RCS pressure stable and  
2     increasing. He can satisfy that for his spurious SI. And  
3     with steam generator level greater than a 10 percent narrow  
4     range in at least one steam generator, he can verify that as  
5     well.

6           The last item is pressurizer level being greater  
7     than 20 percent. Since pressurizer level is guaranteed, he  
8     can check that.

9           The operators have the appropriate training to know  
10    and apply this SI termination criteria. Additionally,  
11    simulator exercises are planned to start I believe next week.  
12    That's going to address fire scenarios. We're going to take  
13    this fire interaction manual that I've talked about, and  
14    we're going to start failing instruments for a fire in a  
15    given area and see if the operator can respond to it  
16    properly.

17           MR. PIERSON: That's a good idea.

18           MR. SULLIVAN: In conclusion, the operator's got  
19    sufficient information to check the SI termination criteria.  
20    He'll be able to distinguish between a loca and a fire,  
21    identify spurious SI, and terminate the spurious SI and  
22    proceed with mitigating the effects of the fire.

23           MR. PIERSON: Thank you. I don't think you need to  
24    say anything more on that particular question.

25           I'm ready to move on to question number 23 unless

1 someone has other comments.

2 On question 23, discuss how steam generator  
3 overflow from the main feedwater system is protected against  
4 fire in the control building. In particular, address  
5 response times for feeder line isolation following loss of  
6 control building.

7 The question that we're really asking here is in  
8 the event that you have a, how do you guarantee that you can  
9 complete this response here? You say that AOI 27 provides  
10 that before the main control room is abandoned the reactor is  
11 tripped and the MSIV's are closed. Have you provided some  
12 evaluation of your control power to MSIV's to state that they  
13 can or cannot be operated? Could you elaborate on that?

14 MR. SULLIVAN: Yes, I can.

15 For a fire in the control building that affects  
16 plant equipment and that requires control room abandonment,  
17 operators are going to be automatically dispatched out to the  
18 auxiliary control room to start their process. AOI 27 is the  
19 plant procedure for abandonment of the main control room and  
20 it requires the operator to do these two things before he  
21 abandons the control room.

22 MR. PIERSON: Are you sure the circuits would be  
23 available to accomplish that?

24 MR. SULLIVAN: Let me get to that, please.

25 He's going to trip the reactor and close the MSIV's

1 prior to leaving the main control room. Note that closing  
2 the MSIV's isolates steam flow to the main feed pump turbine  
3 which is going to terminate your feed water flow and avoid  
4 steam generator overfill.

5 Normally there is a manning overlap between the aux  
6 control room and the main control room, and when we get to  
7 the aux control room which is only two doors away, about 150  
8 feet, so it's less than two minutes we think he's going to  
9 get there, once the aux control room is manned, the operator  
10 places a transfer switch in auxiliary which removes the  
11 damaged circuits in the control building complex and ensures  
12 the MSIV is closed.

13 MR. PIERSON: Could you repeat the last please?

14 MR. SULLIVAN: Once the operator is in the  
15 auxiliary control room and he takes the transfer switches and  
16 puts them in auxiliary, the damaged circuits that are in the  
17 control building complex are then removed from the circuit.  
18 Should there have been a spurious signal over there, the  
19 MSIV, that will be isolated from the circuit and the MSIV  
20 will close.

21 MR. PIERSON: You're saying that's accomplished in  
22 two minutes?

23 MR. SULLIVAN: Less than two minutes.

24 MR. PIERSON: You've actually tested that two  
25 minutes?



1           MR. SULLIVAN: No sir. I'd like to add a little  
2 bit more to this.

3           The MSIV's are fail close valve. They have dual  
4 train solenoids. They have an A train solenoid and a B train  
5 solenoid. There is diverse isolation mechanisms provided in  
6 the safe shutdown logic for fires outside the control  
7 building. That diverse mechanism is basically steam load  
8 isolation in the turbine building, i.e., the trip valves,  
9 throttle valves from the main turbine, the reheat valves.  
10 The trip valves on the turbines to the main feed pumps.

11           On the feedwater isolation signal it's 60 percent  
12 steam generator leveled. Feedwater reg valves are going to  
13 go closed. There would have to also be some sort of spurious  
14 signal that causes the feedwater reg valve to stay open. In  
15 addition to the spurious signal that you've already assumed  
16 that keeps the MSIV open with dual trained solenoids.

17           Additionally, when a steam generator level gets to  
18 75 percent, you get the engineering safety feature actuation  
19 which closes all four steam generator feedwater isolation  
20 valves and trips the main feed pump circuit.

21           One third signal that could come in, since we've  
22 already tripped the reactor, if you get the low TI, which you  
23 will because you're steaming the power to the main feed pump  
24 to feed the steam generators at 554 degrees, you'll pick up  
25 another feedwater isolation signal.

1 MR. PIERSON: Thank you. I don't have any more  
2 questions about that issue.

3 MR. FOX: We have the CAQR with us, 870151. We'll  
4 be happy to provide this to you now and follow it with  
5 official docketing, if you so choose.

6 MR. PIERSON: I would appreciate that. We received  
7 a copy of this document that Mr. Fox just mentioned.

8 The next issue is question 24 which talks about  
9 reactor coolant pump seal integrity. The concern here was  
10 that during a fire you couldn't maintain your reactor coolant  
11 pump seal integrity and you could possibly end up with a loss  
12 of coolant accident to your reactor coolant pump seals.

13 You implied that you had talked to Westinghouse  
14 personnel and they indicated that a one hour value applies to  
15 both qualified and non-qualified elastomers within your  
16 reactor coolant pumps, and that you have in your procedure  
17 that you isolate that in an event that it's lost.

18 I'd like you to comment on that. In particular  
19 with respect to this qualified and non-qualified elastomers.  
20 I'm not sure I understand. It's my understanding from  
21 looking at that that it talks about high temperature  
22 elastomers. I'm not sure whether that's a qualified or  
23 whether that's a qualified and a non-qualified elastomer.

24 MR. KOONTZ: We have really reviewed the WCAP in  
25 question and also talked to Westinghouse personnel. There

1 are two basic types of elastomers that are discussed in that  
2 document and they are both called high temperature  
3 elastomers. One is called a qualified high temperature  
4 elastomer, and the other one is called an unqualified high  
5 temperature elastomer. Basically they are different  
6 manufacturer model numbers.

7           What we have at Sequoyah is equivalent to or better  
8 than the Parker E515-80 elastomer which is called a high  
9 temperature unqualified elastomer. Both cases in the WCAP,  
10 and this was confirmed by talking to Westinghouse personnel,  
11 both of those type of elastomers, both whether they're  
12 qualified or unqualified, will last for the first hour. They  
13 do degrade differently later on, though, if seal cooling is  
14 not available.

15           MR. PIERSON: Do you have something you're willing  
16 to provide to us to substantiate that? A letter or something  
17 like that?

18           MR. KOONTZ: I think what we provided was a  
19 reference to the WCAP. Would you like us to provide a  
20 letter? We can get Westinghouse to write a letter to TVA  
21 which we could provide to you if that would help.

22           MR. PIERSON: That would be better than what we've  
23 got here, because we've got something that's confusing to me  
24 with respect to what's a high temperature and what isn't a  
25 high temperature elastomer.

1 MR. KOONTZ: We'll take that as an action item.

2 MR. PIERSON: So your contention then is that your  
3 procedure tells you to isolate the reactor coolant pump? Are  
4 you assured that the circuits that are available to isolate  
5 that, you can do that in these fire scenarios?

6 MR. KOONTZ: I'm sorry, could you repeat that?

7 MR. PIERSON: This one hour time frame that you've  
8 got for your reactor coolant pumps, you say that's a  
9 windmilling pump as I understand it, is that correct? The  
10 pump is de-energized, is that correct?

11 MR. KOONTZ: The pump is de-energized for one hour,  
12 a one hour interval, yes.

13 MR. PIERSON: From your procedure you say that  
14 you're going to secure the pump. My question is, are you  
15 assured that the power that's required to secure the pump, to  
16 operate the control circuits or whatever, is available?

17 MR. SULLIVAN: The trip breakers for the reactor  
18 coolant pumps are located in the turbine building in a  
19 separate environment and a different direction from where the  
20 fire is that takes out the charging pumps.

21 MR. PIERSON: How long would it take you to operate  
22 the trip breaker there? How long would it take you to do  
23 that?

24 MR. SULLIVAN: An ASE is stationed in the turbine  
25 building and he's called our turbine building ASE and he's

1 about 50 feet from the pump, from the breaker, from the  
2 board. A couple of minutes.

3 MR. PIERSON: That's to rack out the breaker or  
4 trip the breaker? What are you talking about doing there?

5 MR. SULLIVAN: Trip the breaker locally at the 6900  
6 volt board.

7 MR. PIERSON: That's just a switch to operate. You  
8 don't have to rack it out is what you're saying.

9 MR. SULLIVAN: It's a switch on the board, on the  
10 compartment.

11 MR. PIERSON: Does anyone else have any questions  
12 about this issue?

13 Number 25. This considers spurious opening of the  
14 pressurizer PORV and that's the same thing we talked about  
15 earlier. We really probably are not going to get anything  
16 additional from this question. It's just essentially with a  
17 different nuance. I don't have anything with respect to this  
18 question I need to ask. Does anyone have anything they want  
19 to talk about?

20 (No response)

21 MR. PIERSON: We'll go on to question 26. Question  
22 26 is a narrow range reactor coolant system pressure sensors,  
23 all the narrow range reactor coolant pressure systems are  
24 included in the Appendix R analysis. I think you've already  
25 addressed that earlier. We'd ask additional questions about

1 spurious actuation possibly causing an operator to think a  
2 loca was in progress. We talked about that earlier. RCS  
3 depressurization from a fire, spurious failures, and that's  
4 been addressed in question 12.

5 I don't have any direct questions with respect to  
6 that. Does anyone have any items they want to address with  
7 respect to question 26 from the staff?

8 (No response)

9 MR. PIERSON: In that case, why don't we take a  
10 short break, say a ten minute break, and then we'll come back  
11 for public comments or TVA comments or both.

12 (Whereupon, a brief recess was taken.)

13 MR. PIERSON: We have a few issues we want to talk  
14 about, and then we'd like for TVA to talk, and then we're  
15 going to let the public have a comment.

16 Mr. Kubicki has indicated that he'd like to clarify  
17 one statement that he made earlier in the meeting, and I'll  
18 let him start out with that.

19 MR. KUBICKI: I'd like to preface my statement by  
20 saying that the issue concerns when TVA would have to request  
21 approval for a deviation from the criteria of GJ&O. What I  
22 was trying to say earlier is that when it comes to a  
23 particular condition in the plant, if that condition is not  
24 in conformance with 3GJ&O as identified in the supplemental  
25 guidance document of 8610, then that condition should be

1 identified as a deviation and a request for approval sought.

2 For example, if you have a situation within  
3 containment where you have certain cables that you're claiming  
4 are not going to be fire damaged, if the basis for claiming  
5 that no damage is going to exist is not in conformance with  
6 the separation criteria of 3G, then that's a deviation from 3G  
7 and should be so identified.

8 What we have here is we have a couple of situations  
9 where you are taking credit for an internal analysis that  
10 purports to demonstrate that certain components were not going  
11 to be damaged by fire, and yet the basis for such is not the  
12 separation criteria of 3G, so therefore that is a deviation  
13 and you should be proposing a deviation for that.

14 Is that clear? There are certain conditions that  
15 represent deviations and should be so identified.

16 MR. PIERSON: Would TVA like to comment on that now?  
17 I don't think that is consistent with what we were talking  
18 earlier.

19 MR. EBNETER: We don't need to comment on it.  
20 That's staff's interpretation right now, and we'll get back  
21 with you on it.

22 MR. PIERSON: I'd like to move on then.

23 We skipped over a couple of issues in the questions.  
24 One concerned solid plant operations; one was letdown; and one  
25 was this question number one which has to do with the

1 contamination in containment. What I'd like to do is talk a  
2 little bit about SOI 26.3 which allows, is your shutdown  
3 procedure. It says there that you need to be within 200  
4 degrees of, is it 15 hours? T=15 hours? Is there someone  
5 that can comment on that?

6 I have this document that was given to me earlier by  
7 Mr. Fox that says 200 degrees in 21 hours. I'm just a little  
8 bit confused about what the situation is.

9 MR. SULLIVAN: Is that the Westinghouse motor?

10 MR. PIERSON: Yes it is.

11 MR. SULLIVAN: Your question again?

12 MR. PIERSON: It's got a graph and it shows about  
13 200 degrees in 20 hours, 21 hours. I remember earlier that  
14 you took credit for 19 hours and some place it's 16 hours.  
15 I'm confused about your cooldown sequence for SOI 26.3. How  
16 long is it going to take you to get to that point? And how  
17 are you going to accomplish letdown to do that if you possibly  
18 don't have pressurizer heaters or sprays? In other words, to  
19 provide boration to the core.

20 MR. SULLIVAN: There are three or four questions  
21 embedded in that, I believe. I'll try to sort them out.

22 I would like to go through a little bit about  
23 depressurization first, and how we would expect to  
24 depressurize the system, and then get to the second part of  
25 the question.



1           When we're cooling down the plant, feeding off the  
2 feedwater to the steam generators and steaming, steam from the  
3 steam generators, the primary side energy is being removed and  
4 the primary side is shrinking. RCS temperature obviously  
5 decreases and cold RWST water is provided as makeup. There is  
6 going to be a certain amount of thermal losses from the  
7 pressurizer during this period of time. Thermal losses from  
8 the pressurizer vapor space would be expected.

9           Should pressure not come down, the SDA can determine  
10 that if with the current RCS temperature and boron  
11 concentrations, if sufficient boron is in the core to just sit  
12 there until pressure decays on down. A realistic approach,  
13 there are many ways to remove that excessive amount of energy,  
14 pressure in the core. Obviously the technical support center  
15 and operational support center is going to be manned post-  
16 fire. It's affected the plant in this way. We made some real  
17 unlikely assumptions through all of this that the boric acid  
18 transfer system, the letdown system, is all not available;  
19 that we've not been able to supply the 20,000 PPM boron from  
20 the boric acid tanks; that the only water supplied is the  
21 25,000 gallons that you normally make up when the RCS shrinks  
22 to a normal cold shutdown condition.

23           Only if all those cases are required and also the  
24 worst case conditions for the reactivity analysis that we've  
25 done, and I'd like to go through some of those worst case

1 reactivity assumptions. I think this was quoted as the worst  
2 case Appendix R fire. It has done all the things I have just  
3 mentioned, plus it assumes this scenario.

4 The plant had been at 100 percent power. There is a  
5 reactor trip. There is a post-trip review conducted and a  
6 fast restart decision made. Maximum delusion is started in  
7 order to try to fast restart the plant, at the same time xenon  
8 is peaking. Xenon peaks somewhere between nine and ten hours  
9 after a 100 percent trip. This analysis assumes we're  
10 reaching 100 percent power with boron reaching its peak, which  
11 is obviously not possible. This gives you the minimum boron  
12 concentration in the core, and that will give you the initial  
13 condition for the worst case Appendix R fire.

14 In reality, in today's world, if you have a trip and  
15 you go through and do a post-trip review, you're not going to  
16 get it done and get the plant restart decision made prior to  
17 xenon peaking. You're not going to be reaching, even if you  
18 tried to go back into core, you're sure not going to be  
19 getting significant power levels up to get to 100 percent  
20 power with xenon peaking.

21 Additionally, should all of that happen, in four  
22 hours you've brought xenon out. Your reactor flux has already  
23 burned that xenon out and you're back down to equilibrium  
24 xenon. So we're only talking about a four hour period after  
25 all these initial conditions have occurred on all this matter

1 that we don't consider to be a realistic assumption for a --  
2 which I think quite in the beginning of -- you're supposed to  
3 look at the probability and consequences of the fire. We've  
4 taken such an improbable initial condition and then tried to  
5 design a plant for it after a fire that it's just not  
6 consistent with other safety requirements. We've gone beyond  
7 what we do for other Chapter 15 -- accidents. We don't go  
8 into that amount of depth.

9 This was also done for the worst point in the fuel  
10 cycle. In other words, for different cycles BOL, EOL, or  
11 whatever point in between, you had to be at that point in the  
12 fuel cycle, that one point in the fuel cycle.

13 Again to summarize, boric acid makeup and boric acid  
14 tanks are unavailable, normal RCS letdown is unavailable,  
15 excess RCS letdown is unavailable, reactor head vents are  
16 unavailable and didn't spuriously open or anything,  
17 pressurizer PORVs are unavailable, and boric acid makeup and  
18 the refueling water storage tank is your only boration source.  
19 We're relooking at that scenario to see if it's appropriate to  
20 be part of the design of the worst case Appendix P fire.

21 MR. PIERSON: So can I infer from that that you  
22 assure letdown?

23 MR. SULLIVAN: No. Letdown, again, is not a  
24 requirement in the current shutdown logic.

25 MR. PIERSON: The reason it's not is because you

1 feel you still envelope whatever consideration you'd be in  
2 because of what you just said.

3 MR. SULLIVAN: Right.

4 To address the second point about depressurization a  
5 little bit more, there are lots of ways to get that energy out  
6 of the core. Like I said, the technical support center and  
7 the operational support center is staffed. We've gone through  
8 various drills at Sequoyah. An accident never happens,  
9 especially a fire, the way you predict and think it's going to  
10 happen, so we're going to take credit for the people, the  
11 staff that's there, and we're going to assess the consequences  
12 and make the best decision at that time.

13 For example, with portable nitrogen bottles we could  
14 go in and get auxiliary spray reestablished to the pressurizer  
15 if that method is the most desirable.

16 Another example, a pressurizer PORV could be opened  
17 by wiring in a temporary 125 volt DC power source at the  
18 containment penetration such that you could open the PORV with  
19 that method for a short period of time to depressurize, to get  
20 RHR cut on.

21 MR. PIERSON: Does anyone have any more comments  
22 from the staff about this matter?

23 (No response)

24 MR. PIERSON: I'd like to go on and ask a couple of  
25 other things.

1           You don't need to address it right now, but in your  
2 water solid condition I do want you to talk about the  
3 likelihood of a pressurized PORV opening and putting it in a  
4 solid plant condition and how you plan to respond to that  
5 solid plant condition when you come to your discussion.

6           MR. KOONTZ: I can address that a little bit. I  
7 can't address it from the operating procedures standpoint.  
8 But if you were to spuriously open a pressurizer PORV, what  
9 would happen to the reactor coolant system is you'd lose mass  
10 and inventory through that PORV.

11          MR. PIERSON: Right.

12          MR. KOONTZ: Once the operator took action, and I  
13 think you had us consider two cases in here. One was if you  
14 took action in the control room, then that action would take  
15 place fairly quickly and he would move to close the block  
16 valve and terminate the event.

17          There was a second case that was questioned, and  
18 that was if the fire was in the control room, what would the  
19 operator do? And for that event, the operator would have to  
20 go down to the auxiliary control room and/or the MOV boards  
21 and cause the block valve to be closed.

22          In both of those events, though, what you end up  
23 with is an RCS that has somewhat less inventory in it once the  
24 vent is closed.

25          As you continue to cool the system down on the steam

1 generator, and you use natural circulation or whatever means  
2 of cooldown, the bubble in the pressurizer should reform  
3 because the RCS is connected to itself in the steam  
4 generators. The pressurizer is over there essentially at a  
5 dead end leg at that point, so the bubble should reform.

6 MR. PIERSON: Do you have an engineering evaluation  
7 of this, or is this just engineering judgment?

8 MR. KOONTZ: No, that's engineering reasoning,  
9 analysis.

10 The second thing, the only way we could determine  
11 that you might lose a pressurizer bubble was if you had a  
12 spurious safety injection which would then fill the  
13 pressurizer up with water.

14 What we looked at there was the charging flow rate,  
15 because our safety injection pumps don't pump in at 2250 psi  
16 which is normal RCS conditions. So you'd have charging flow  
17 at approximately 100 to say if both trains were on maybe 300  
18 GPN, and you'd have approximately 10-20 minutes before you'd  
19 eliminate the pressurizer bubble. So the operator would have  
20 time to go take action and terminate that spurious safety  
21 injection.

22 MR. PIERSON: What sort of actions would he take?

23 MR. KOONTZ: He would just have to go down and  
24 secure the charging pumps and turn them off temporarily.  
25 We've got that in, have we got some operating procedures?

1           MR. SULLIVAN: E-0 contains, or one of the emergency  
2 procedures, I think E-0 refers you to it, contains the SI  
3 termination criteria and also the steps the operator goes  
4 through to terminate the SI. It tells them what to do if the  
5 response is not obtained.

6           MR. BRYAN: This is Bob Bryan. The other thing that  
7 is important is we have assured the instrumentation necessary  
8 for him to know that he has a spurious SI and terminate the  
9 event quickly.

10          MR. KOONTZ: As a minimum, remember that we assured  
11 pressurizer level so that would be available.

12          MR. PIERSON: Okay. Rick Wescott has got a question  
13 about your HVAC systems and some of the performed calculations  
14 he'd like to ask.

15          MR. WESCOTT: When we asked you question 14, at the  
16 time basically our concerns were regarding heat transfer due  
17 to a fire through open dampers, walls, and that type of thing  
18 and possibly affecting required equipment in adjacent rooms.  
19 We have expanded the concern to include equipment that would  
20 require for a safe shutdown any place in the plant.

21                 In other words, could a fire take out the HVAC in  
22 such a manner that you would have equipment required for safe  
23 shutdown exceeding their qualified temperatures and therefore,  
24 would be inoperable?

25          MR. PIERCE: I want to make sure I understand what

1 you're saying. We've got a fire in say room 8, and circuits  
2 for the room coolers, for room B are in there. Will the  
3 equipment that we were relying on in room B continue to  
4 operate?

5 MR. SULLIVAN: That's correct. That would be one  
6 scenario, yes.

7 MR. PIERCE: Okay, and correct me if I'm wrong, John  
8 Henry, but we have gone through and any place we required room  
9 cooling we made sure that that room cooler was available.

10 MR. SULLIVAN: The shutdown logic already contains  
11 the HVAC that is currently necessary and has provided a  
12 separation for that HVAC.

13 MR. WESCOTT: Okay, and I assume when you say room  
14 coolers you're talking about area coolers as well, cooling a  
15 large area like I think in the vicinity of the auxiliary  
16 feedwater pumps as I recall, that's one place that's area  
17 cooled, I believe.

18 MR. SULLIVAN: I'm not sure what the HVAC  
19 requirements are in that area, but right now the current  
20 shutdown logic does not include HVAC for that area as being  
21 qualified. It's not in the current shutdown logic.

22 MR. WESCOTT: So does this imply that you made  
23 calculations that show that even under worst case conditions  
24 you do not need those coolers? Is that what you mean when  
25 you're saying your HVAC system is not qualified for that area?



1           MR. KOONTZ: Generally what we do is they take a  
2 look at the electrical heat loads in a given area, and if it  
3 turns out that you can fail the HVAC in that area due to a  
4 fire and still not exceed reasonable qualifiable temperatures,  
5 again we don't EQ qualify for fires, but if you look at the  
6 temperatures that that room goes to and it stays within  
7 reason, then we assume that the cooling is not necessary for  
8 that room.

9           If the temperature goes on up and continues past a  
10 reasonable temperature for equipment in that room, what that  
11 indicates is that the cooling must be available in that room  
12 and we have to provide HVAC separated cooling or some other  
13 alternate means of getting cooling into that room. Maybe  
14 portable fans, whatever.

15           MR. ROTELLA: Did you document that analysis?

16           MR. KOONTZ: Yes. That's documented and it goes  
17 into the safe shutdown logic calculation as an input.

18           MR. WESCOTT: Could we get a calculation number for  
19 that?

20           MR. KOONTZ: I think it's 195. I'm not sure. I'd  
21 have to get back with you on the number.

22           MR. FOX: Has that information been provided to  
23 them in this package we sent?

24           MR. KOONTZ: No, that is a separate package.

25           MR. FOX: Are you also asking us to provide this

1 calculation?

2 MR. PIERSON: Do you need that, Rex?

3 MR. WESCOTT: Yes, if we could have it we'd like to  
4 have it.

5 MR. KOONTZ: We'll take that as an action item.

6 MR. PIERSON: Is that all you have on that, Rex?

7 (Pause)

8 MR. PIERSON: Mr. Wescott wants to continue on with  
9 questions on the HVAC.

10 MR. KOONTZ: Let me clarify one thing too, Rex. Let  
11 me tie up a loose end. As you're probably aware if you read  
12 the previous final report from the task team, the HVAC issue  
13 related to the calculations was one of the open issues that we  
14 were dealing with as a free restart issue. That is still  
15 ongoing. What we will provide for you is the current version  
16 of the calculation that goes with Rev 6 and then as soon as  
17 the new one is out we'll provide that one also for you to look  
18 at.

19 What may come out of the new calculation is some  
20 portable blowers may be required in certain areas, and that  
21 will be incorporated at that time into SOI 26.2.

22 MR. WESCOTT: I do have a question.

23 Have you in fact found, using the existing  
24 calculations, that some of the room coolers as presently  
25 designed, failure of these would in fact result in

1 temperatures exceeding the qualification limits of required  
2 equipment?

3 MR. KOONTZ: There are several room areas and I  
4 didn't bring the calculation with me today, but I remember one  
5 room area went to approximately 118 degrees, I believe, after  
6 a fire, which was above the previous temperature for that  
7 room. It was an aux instrument room, I believe.

8 For that area we've asked the electricals to go back  
9 and look at the equipment in the area and see what temperature  
10 the equipment was qualified to or purchased to to see if it  
11 could be reasonably expected to survive that event. We found  
12 that the temperature was something like 120 degrees, I  
13 believe, in that area, so we would expect the instrumentation  
14 and the components in there to survive.

15 Now some areas would exceed the room temperature  
16 after 72 hours, so what we've got to do is we've got to go in  
17 for those areas and put in somewhere in the operating  
18 procedure, specifically the fire procedure, for the operators  
19 to take action to assure that those rooms stay in a reasonable  
20 temperature range after 72 hours.

21 MR. WESCOTT: This would be equipment then that was  
22 required to bring the plant into shutdown, but not required  
23 for fire chart cooling.

24 MR. KOONTZ: Yes.

25 MR. WESCOTT: When you're saying heated up, you mean

1 actually exceeded the qualification temperatures on the  
2 equipment, is that what you're saying?

3 MR. KOONTZ: It would have heated up in some areas  
4 above say 130 degrees after 72 hours, which we would consider  
5 unacceptable and we would need to go in and do something.

6 Beyond that, I don't have enough knowledge of the  
7 calculation with me here today to go into the specifics, but I  
8 can provide it to you and I can provide the new calculation  
9 and you can review those.

10 MR. WESCOTT: Will we be notified as to the findings  
11 of your review and the calculations?

12 MR. KOONTZ: Yes.

13 MR. WESCOTT: Thank you.

14 MR. PIERSON: I'd like to go on and talk about one  
15 other thing. I'm a little bit confused about SOI 26.2 and I'd  
16 like you to reiterate I think what you've already said, that  
17 in the event that you have a situation that you lose one  
18 centrifugal charging pump, say from a VCP isolation valve  
19 shutting spuriously, do you have the other pump available? Is  
20 the additional pump there available? Do you know that for a  
21 fact? Have you looked at the interaction study or whatever to  
22 say that?

23 MR. SULLIVAN: We have not looked at the interaction  
24 study with the objective of making sure the other pump was not  
25 damaged in the fire area. We went through the interaction

1 study with the intent of ensuring that the existing pump that  
2 was sitting there operating at the time did not get damaged.

3 MR. PIERSON: If you essentially say that the  
4 existing pump was not damaged, then you're telling me that if  
5 the bond control tank isolation valve shuts the pump can sit  
6 there and spin?

7 MR. SULLIVAN: No sir, I'm not. The operating  
8 charging pump will not be damaged by spurious closure of the  
9 VCT outlet valves because we will take appropriate action  
10 before those valves close.

11 MR. PIERSON: I'm afraid I'm having a hard time  
12 agreeing with that for the simple reason that you told us  
13 earlier that you don't consider the fire to exist until you  
14 send a runner down to identify the fire. So we could have the  
15 valves shut during the time a man goes down, looks, verifies  
16 the fire, and comes back. I don't think that a charging pump  
17 will operate without a suction.

18 MR. SULLIVAN: I hear you. The charging pump will  
19 not operate with the suction valve closed. We know that, the  
20 vendor has told us that. Our whole intent is to ensure that  
21 the appropriate action is taken prior to spurious closure of  
22 these valves. It takes a finite amount of time to get cable  
23 damage.

24 We have an analysis of that.

25 MR. PIERSON: Have you provided an analysis to us?

1 MR. SULLIVAN: We will, if we have not provided it.

2 MR. PIERSON: I'd like to look at that because I'm  
3 concerned about that.

4 MR. SULLIVAN: I'd like to emphasize again, in case  
5 I wasn't clear before, there are three things the operator can  
6 do. He can open the AC breakers on the DCT outlet valves, so  
7 they won't spuriously close. He can open the RWST supply  
8 valve and open its breaker so it doesn't spuriously close, a  
9 similar problem to the one that had ben previously identified  
10 on the VCT. He can trip the centrifugal charging pump until  
11 one of the above is completed. So he has three things in  
12 there he can do to ensure that the operating pump is not  
13 damaged.

14 MR. PIERSON: I understand what you're saying. I'd  
15 like to see the analysis or calculations you've got that shows  
16 the expected amount of time before the fire is detected and  
17 the action is taken to isolate that pump.

18 Does anyone else on the staff have any questions we  
19 want to ask? We still need to talk about solid pressure,  
20 solid plant ops.

21 George Hubbard?

22 MR. HUBBARD: I've got just one point for  
23 clarification was earlier they had mentioned the CAQR 8700857.  
24 I looked at the data which they listed out the information  
25 they provided us, and that CAQR has not been provided, so that

1 would need to be provided to us. That was relative to  
2 question 21, CAQR 870857. That along with the 870151 which  
3 you have given us now.

4 MR. FOX: Yes.

5 MR. HUBBARD: The one other question with regard to  
6 question 22, in your response you indicated that for  
7 information notice 8409 that you were in compliance or had  
8 approved deviations. I think in telephone conversations we  
9 asked that you identify the specific equipment which you  
10 utilized to be in compliance with the 8409, and also to  
11 identify what the approved deviations are. I think there are  
12 a couple on there, I've run across a few. Also, which of the  
13 equipment was environmentally qualified.

14 MR. FOX: Okay. We have taken a copy of the  
15 appendix to the shutdown logic calculations, and we have  
16 checked those items which are 5049 EQ'd and I'll provide that  
17 to you now for information, and we'll put it on the docket of  
18 forms coming back.

19 MR. KOONTZ: George, I think the approved deviations  
20 are in an NRC letter, and we can provide the reference for  
21 that.

22 MR. HUBBARD: I do have one letter on approval of  
23 deviations. I have a May 29, 1986 which gives some  
24 deviations.

25 MR. PIERCE: There was another one I believe in

1       October of '86 that was on lack of TECo instrumentation in the  
2       auxiliary control room.

3               MR. FOX:   October of '86?

4               MR. PIERCE:  I believe that was the date.

5               MR. FOX:   We will confirm that.

6               MR. KOONTZ:  I believe those two constitute the  
7       approved deviations for instrumentation.

8               MR. HUBBARD:  So any deviation that would have been  
9       approved by the NRC.

10              MR. KOONTZ:  Yes.

11              MR. PIERSON:  Is that all?

12              I'd like you to speak about solid plant operations  
13       for a minute as we discussed earlier.

14              MR. FOX:   Okay, I would like to review the bidding  
15       right now because there are several things we want to do to  
16       close out our part of this presentation today.  We will cover  
17       depressurization, we'll cover the water solid, we also want to  
18       run through the action items to make sure we have a clear  
19       understanding of everything you've asked for here today.  I've  
20       tried to keep up with it, but I'd like at some point before we  
21       turn the meeting over to public comment to run through those.

22              MR. PIERSON:  That's fine.

23              MR. FOX:   We'd now like to have John Henry Sullivan  
24       talk about depressurization.

25              MR. HOSMER:  Before we do, I'd like to add a comment



1 on the charging pump question we brought up. I asked for  
2 this, as project engineer in Sequoyah I asked for this task  
3 force to be formed to look at these issues. One of the things  
4 I asked be done was an industry survey in particular on the  
5 charging pump issue because this is a Westinghouse plant with  
6 charging pumps of the type provided by Westinghouse.

7 What we found on this issue is what Sequoyah is the  
8 doing is the norm for Westinghouse plants. It is in NTOL's as  
9 well as older vintage plants. Our approach is consistent with  
10 what they are doing, and more conservative than some.

11 MR. PIERSON: Could you supply, we need something,  
12 that's not in the submittal that you gave us.

13 MR. HOSMER: I don't know how to name plants, give  
14 you a list of plants.

15 MR. GARG: I think it's in Appendix A.

16 MR. HOSMER: I believe it's in an attachment.

17 MR. KOONTZ: The industry survey on issue A-15 in  
18 the testing report.

19 MR. PIERSON: Thank you.

20 MR. FOX: Okay. We'll go ahead and cover water  
21 solid now then.

22 MR. KOONTZ: I think we've covered water solid from  
23 the standpoint of spurious safety injection being one clause;  
24 opening of the PORV being another clause; and I think we've  
25 gone into the depressurization a little bit. If you've got

1 some further questions, for example, on issue A1 on the dose  
2 or any of that, we can cover that.

3 MR. PIERSON: It appeared to me from your earlier  
4 submittals that you were taking credit for pressurizer PORV  
5 operation for reactor head vent valves in event of a solid  
6 plant operation, and as such I was interested in what would  
7 happen in terms of contamination inside the containment and  
8 how that would affect your accessibility to operate the RHR  
9 valves.

10 You told me in the meeting that you don't take  
11 credit for pressurizer PORV valves opening or reactor head  
12 vent valves opening, and presumably you've got the flow  
13 control valve or the RHR valve adequately protected such that  
14 a fire isn't going to destroy it such that you can't repair it  
15 within 72 hours. I don't see access to the containment as a  
16 problem per se, provided that you're not going to be leaking  
17 reactor coolant system coolant into the containment. If  
18 that's true, I think we can probably get around question  
19 number one.

20 I need some response rather than shaking your heads  
21 here.

22 MR. BRYAN: That's correct. We do not need access  
23 to the containment when we would have a release from the RCS.

24 MR. PIERSON: So what you're saying is when you have  
25 a release from the RCS you're in a loca and your hot shutdown

1 sense?

2 MR. KOONTZ: No, remember the reason that we would  
3 need access to the containment was to go in and repair, to  
4 manually open the valve door to repair the wiring or the motor  
5 on the valve. A study was done to show that there was not a  
6 fire loading in there that would cause those valves to be  
7 damaged other than the wiring or the motor itself. If the  
8 wiring or the motor to that valve was damaged, then we would  
9 not have had a spurious SI and we would not have had  
10 contamination inside the containment. That's the argument.

11 MR. BRYAN: And normal letdown would be available.

12 MR. PIERSON: We think you're going to have to  
13 supply us a deviation on that analysis for those flow control  
14 valves, because you're not taking the normal 20 foot  
15 separation on that.

16 MR. KOONTZ: We provided the drawings on those  
17 valves I think in the last submittal.

18 MR. PIERSON: Is there a 20 foot separation?

19 MR. KOONTZ: That I don't recall. One is inside the  
20 crane wall on the floor and the other is up in an accumulator  
21 room.

22 MR. PIERSON: We can address that later.

23 MR. PIERCE: Can I get a clarification? Are you  
24 saying the separation between the 74-1 and 74-2?

25 MR. PIERSON: Yes.

1 MR. PIERCE: Are you saying the separation between  
2 740-1 and 74-2 and --

3 MR. PIERSON: What I'm talking about is you're  
4 saying that the only fire there in terms of 74-1 and 74-2 is  
5 going to affect the motor operator of the valve as well as I  
6 remember, so it can only affect that valve. But I thought I  
7 understood from that that as a result of that fire hazard  
8 analysis you did, that you didn't meet some of the separation  
9 criteria that you would normally have to meet for Appendix R.  
10 If that's the case, then we need to have some sort of a  
11 deviation or something on that. I may have misunderstood that,  
12 but that was my understanding earlier in the meeting.

13 MR. HOSMER: We'd like a couple of minutes here just  
14 to caucus on that a second.

15 (Pause)

16 MR. BRYAN: What we want to clarify is, we don't  
17 see, it appears that you're asking us for a deviation request  
18 because you say we don't have 20 foot separation.

19 MR. EBNETER: Let me cut that off. We'll tell you  
20 formally whether we want a deviation on anything at all, but I  
21 don't want to debate it in this meeting.

22 MR. PIERSON: Is that acceptable? We'll take it up  
23 in a later issue.

24 MR. BRYAN: Okay, that's acceptable.

25 MR. PIERSON: Any other questions?

1 (No response)

2 MR. PIERSON: Does TVA have anything else to say in  
3 their response with respect to some of the other issues?

4 MR. KOONTZ: Let me ask if you had any further  
5 questions on number one, the off-site dose calculation?

6 MR. PIERSON: Possibly. It depends on something to  
7 do with the RHR valve, but I think we can work around that  
8 later. I don't think that's worth discussing now.

9 I'm ready to close the NRC's portion of this  
10 meeting.

11 MR. FOX: I would like to run through the action  
12 items as I have them identified, and if NRC staff has one  
13 that's not on the list, please call it out.

14 The first one is the docket CAQ 870151. Also we've  
15 been asked to docket CAQ 0857 in reference to question 21.  
16 870151 was, I guess, one of the others.

17 We've also been asked to docket the list of Appendix  
18 R equipment that's 5049 AQ'd. I handed George Hubbard a  
19 marked up appendix to the calc that was provided opposite  
20 question 22. We will formally docket that.

21 Also we need to provide you with, relative to  
22 question 24, the reactor coolant pump seal, we'll get a letter  
23 from Westinghouse and we'll provide that to you. It has to do  
24 with elastomer seal integrity.

25 We also will provide you the revised procedure to

1 pull fuses. That's SOI 26.2.

2 We will also provide you the HVAC calculation, both  
3 the old calculation and the new calculation when it's finished  
4 and we'll advise you of any actions we feel are appropriate to  
5 take with regard to providing localized cooling.

6 We also need to provide you an analysis assuring the  
7 operating charging pumps integrity, survivability.

8 Are there any other items?

9 Instrument lines outside the tank.

10 MR. PIERSON: We may have some other requests with  
11 respect to the pressurizer PORVs, the assured letdown, and the  
12 protection for your flow control valves, your RHR flow control  
13 valves.

14 MR. FOX: Okay. You haven't made your mind up on  
15 those yet?

16 MR. PIERSON: Well, I have to look at the transcript  
17 and discuss it with the staff.

18 MR. FOX: Okay.

19 MR. PIERSON: The second thing we need to reiterate  
20 is, I was a little bit remiss, and I wasn't keeping track of  
21 the items and there may be other items in the transcript and  
22 we'll ask for them.

23 MR. FOX: We'll scan the transcript. These were  
24 things that, with one exception, that we felt like you wanted  
25 fairly quickly and we're going to go ahead and initiate action

1 immediately to get those in and get them on the docket.

2 MR. PIERSON: We appreciate that.

3 MR. EBNETER: Before we close I'd like to make one  
4 comment. I'm somewhat concerned in looking at the chronology  
5 of events that TVA identified a problem with these  
6 calculations some time ago and the NRC wasn't aware of it  
7 until December. Is that true? In looking at your chronology,  
8 DNE calculation programs, identification documentation in  
9 December of '86. Should we have been notified?

10 MR. FOX: You're referring to the second --

11 MR. EBNETER: Part of your presentation.

12 MR. FOX: Well part of the handout we gave you.

13 MR. EBNETER: Right.

14 (Pause)

15 MR. HOSMER: Are you referring to the 12-86 date?

16 MR. EBNETER: Yes.

17 MR. HOSMER: That came out of the calc regeneration  
18 effort, a concern about unverified assumptions. I think we  
19 made it visible and apparent to you in Knoxville as part of  
20 audits. Can you help me, Mr. Koontz?

21 MR. KOONTZ: Yes. That whole program was audited by  
22 the NRC.

23 MR. EBNETER: Who was that, do you recall?

24 MR. KOONTZ: Gene Embro was in charge of that audit  
25 on calculations, and I believe the NRC reviewers took a copy

1 with them of the CAQR that reported that calculation was in  
2 error.

3 MR. EBNETER: Okay. I'll retract my remark.  
4 That must have been one of Gene's first DVBP inspections, is  
5 that right?

6 MR. FOX: I think part of the problem is that 86  
7 should be 87.

8 MR. KOONTZ: Maybe that's part of the problem.  
9 There's a typo in there.

10 MR. FOX: No, that's out of sequence again.

11 MS. AXELROD: Are you talking about a recent  
12 inspection by Gene Embro?

13 MR. KOONTZ: This is the whole calculation  
14 verification program where they came in and they audited the  
15 civil, electrical, mechanical, nuclear calculations and they  
16 closed out the issues on the nuclear and mechanical  
17 calculations. The review team consisted of Embro, Ron  
18 Parkhill, and others.

19 MR. EBNETER: That slide is in sequence and it says  
20 12-86.

21 MR. KOONTZ: That's correct.

22 MS. AXELROD: When did Mr. Embro do his inspection?

23 MR. FOX: I guess the best thing for us to do is to  
24 get with the people that were involved and we will take that  
25 as an action item to provide an explanation.



1 MR. EBNETER: If that is the case when it was  
2 identified, and particularly an Appendix R error, that thing  
3 should have been reportable, I believe. If it was not, and we  
4 didn't discover it until a year later, whether through an  
5 inspection or through an allegor, I still have some concerns  
6 about it. That's all I want to comment about it. But I will  
7 check back with you on that.

8 MR. HOSMER: Let me provide one piece of  
9 information. I think you're aware as part of a very massive  
10 calculation regeneration effort one of the things that TVA  
11 identified were numerous unverified assumptions. This was one  
12 of hundreds of unverified assumptions that were being  
13 monitored, tracked to closure. It was viewed as not a  
14 technical issue or a safety issue. It was viewed as needing  
15 to establish as built documentation. It was tracked and  
16 monitored as part of a program to close all of those issues  
17 prior to restart.

18 MR. EBNETER: Okay. I just wanted to let you know I  
19 have a concern about it.

20 MR. FOX: We'll get you the explanation of the  
21 events.

22 MS. AXELROD: I'd like to ask one question. What is  
23 the status of Rev 8 of the calculation? I've heard you might  
24 be working on a Rev 9, is that true?

25 MR. PIERSON: We have Rev 8.

1 MS. AXELROD: Are you working on a Rev 9?

2 MR. KOCNTZ: Yes. Revision 9 will be out, I don't  
3 know what the date scheduled for it is, and it will  
4 incorporate the new results of the HVAC analysis and these  
5 other issues.

6 MS. AXELROD: Can you give me an approximate date,  
7 when you expect it to be out?

8 MR. KOONTZ: I can't at this time, but we can get  
9 the date for you.

10 MS. AXELROD: Do you expect it to be out prior to  
11 restart?

12 MR. KOONTZ: I would expect the HVAC issue and the  
13 new revision out prior to restart, yes.

14 MR. PIERSON: Unless someone on the staff has some  
15 additional comments, I'm going to turn the meeting back over  
16 to Mr. Richardson, and Mr. Richardson will close it out to  
17 public comment.

18 Any questions?

19 MR. RICHARDSON: This is the portion of the meeting  
20 on the agenda that has been reserved for public comment  
21 period. Are there any members of the public that wish to make  
22 a statement?

23 MS. BERNABEI: My name is Lynn Bernabei. I'm  
24 attorney for Andrew Bartlik who has raised many of the  
25 concerns that are being discussed here today.

1           I'd like to make two comments that I think are  
2 integrally related to the technical issues that have been  
3 discussed. One has to do with Mr. Bartlik's charges of  
4 harassment and intimidation. Essentially he has charged that  
5 his contract was terminated because he identified these safety  
6 issues which cite management and upper level TVA management  
7 attempted to suppress. I think the NRC staff has to address  
8 that issue because the Commission has stated in no uncertain  
9 terms that if there has been intimidation of engineers and  
10 employees it is a very serious bar to the flow of safety  
11 information to upper TVA management and to the NRC.

12           The second issue that I think the staff should  
13 address is why we're all here today on the eve of restart days  
14 or weeks before the Commission is about to vote on restart,  
15 debating very serious safety issues. I think the only  
16 conclusion you can come to is that basically these problems  
17 which have been identified in internal memoranda in August of  
18 this year were withheld from the NRC so the staff could not  
19 complete a complete review at that time.

20           I think the reason people are scrambling right now  
21 is because that information was withheld. And given the  
22 seriousness of the problems and the likely reportability under  
23 NRC regulations, I think the staff should explore what  
24 happened that these issues were reported to you not by TVA but  
25 by a former TVA engineer.

1           Mr. Bartlik has a number of concerns that he wanted  
2 to talk about in terms of the technical issues, but I would  
3 urge the staff to review those two things before coming to any  
4 recommendation on the technical issues or on restart.

5           MR. RICHARDSON: Thank you.

6           MR. BARTLIK: My name is David Bartlik. I'd like to  
7 talk about a few things.

8           First I'd like to read a statement. I think the  
9 discussions here have shown that there are many unresolved  
10 problems pertaining to Appendix R of TVA's program. I would  
11 like to focus on a few of the areas. I believe it's clear  
12 that TVA does not meet NRC Appendix R requirements, and this  
13 has not been discussed in sufficient detail in all the areas I  
14 am concerned with, although the staff has made a reasonable  
15 attempt to do so.

16           First I'd like to talk about SOI 26.3. Mr. Sullivan  
17 today was alluding to all the excess conservatism they have  
18 used in this calculation. I wish to point out that that SOI  
19 26.3 is TVA's basis for establishing long term reactivity  
20 control, and that is what their calculations for ensuring the  
21 core will be maintained in some critical conditions is based  
22 on. It is based on the establishment of a letdown path  
23 through the RHR system at T=15 hours or 16 hours. If TVA  
24 intends to use this procedure, it also requires the RCS be  
25 cooled to 200 degrees F. If they intend to have the RCS

1 cooled to 200 degrees at T=15 hours, I would suspect the RHR  
2 valves would have to be opened well before eight hours.

3 TVA is relying on repair procedures, but by their  
4 own admission it takes up to 19 hours to get the valves fixed.  
5 Clearly these valves have to be fixed for periods as early as  
6 eight hours.

7 In addition to that, TVA has had previously not had  
8 any information from Westinghouse regarding how long it would  
9 take to cool the plant with a single train of RHR coolers  
10 available.

11 As it turns out, when this analysis came in from  
12 Westinghouse, they have determined that it takes over 20  
13 hours, I think it was 25 hours if we look at that graph, to  
14 cool the plant from hot standby conditions to 200 degrees. So  
15 it's essentially that calculation from Westinghouse that shows  
16 that TVA is not able to cool the plant down to 200 degrees  
17 within the allotted time. Therefore, they cannot meet the  
18 reactivity control requirements as specified in SOI 26.3.

19 In addition to that, TVA is relying on seal  
20 integrity for, it's relying on seal injection for seal  
21 integrity in a large number of fire areas. As a matter of  
22 fact, according to their safety position statements there is  
23 only one plant area in which they're relying on CCW to the  
24 thermal barriers as a means of maintaining seal integrity.  
25 Ultimately seal injection will result in the overflow of the

1 RCS and you must establish a letdown path. TVA's own  
2 calculations have shown that this establishment of letdown  
3 path for providing control is required at T=19 hours. That's  
4 where the original 19 hours came from. Again, they have not  
5 ensured this ability.

6 Again, at T=19 hours, they are not able to have  
7 opened up the RHR valves and cooled it down sufficiently to  
8 use TVA's own designated method of letdown.

9 In addition, there has been some debate whether  
10 these part 100 limits are accurate, or part 20 limits. I wish  
11 to point out that this Appendix R is not an accident and part  
12 100 limits are only applicable to accident scenarios. TVA  
13 submitted calculations showing they are within their part 100  
14 limits, as opposed to part 20.

15 TVA's letdown scenarios also dump water either to  
16 the floor, to the reactor building floor, or sometimes the  
17 auxiliary building floor. It is not clear to me that the part  
18 20 limits can be maintained with dumping water to the floor as  
19 they are currently planning, especially considering that the  
20 necessary HVAC systems that normally clean up such radioactive  
21 spills are not included in the analysis.

22 TVA also makes an interesting statement regarding  
23 water solid operations. They say that under water solid  
24 operations they will slow their cooldown rate. I guess they  
25 don't have to minimize any transients. It's interesting to

1 note that if you're cooling slowly that is clearly not in  
2 accordance with SOI 26 which requires a prompt cooldown.

3 Also TVA used the justification for not training  
4 operators on water solid operations that it's a low  
5 probability event. It is not necessarily such a low  
6 probability event. Also, loca, steam generator tube ruptures  
7 are also low probability events, and we certainly train  
8 operators on these. It's been noted that one of the most  
9 likely current concerns for core melt accidents is a fire-  
10 initiated event, so that they don't train to ensure they don't  
11 do something to endanger the public is beyond me.

12 It's also interesting to note, Bob Bryant, I know I  
13 talked to Bob many times about the issue concerning the steam  
14 generator PORV and blowdown of multiple generators. I was  
15 essentially the author of the CAQR that TVA references  
16 allegedly resolving the problem, they distributed the CAQR and  
17 said therefore, we don't have a problem.

18 It turns out that before I issued that CAQR, TVA's,  
19 I guess what I consider TVA's leading expert on single failure  
20 criteria, Harry O'Brien, had been fully consulted on that  
21 matter and was in full concurrence with me. Harry O'Brien is  
22 documented, saying that in a memo. Also I feel Doug Wilson  
23 considers him as expert because when I raised the CAQR, TVA,  
24 the first thing is Doug Wilson disagreed with my  
25 interpretation of the rules and the first person Doug Wilson

1 ran to was Harry O'Brien. He advised me that I should talk to  
2 Harry because I obviously don't know what I'm talking about.  
3 I responded I had fully coordinated with Harry O'Brien, and it  
4 has been supported.

5 I kind of wonder why TVA hasn't brought Harry  
6 O'Brien to discuss this matter, because I know he has a little  
7 bit different opinion than Mr. Bryant.

8 One interesting point, I don't want to get into all  
9 the technical details contained within that CAQR because it  
10 would really take more than 20 minutes to adequately discuss  
11 it, but I understand TVA has made some statements that they  
12 could always close that pressurizer PORV. I want to point out  
13 that if you have a steam generator tube rupture and that PORV  
14 is open and you take the failure of that closing solenoid as  
15 your single active failure, that PORV will not close. That  
16 will most clearly increase the significance of a steam  
17 generator tube rupture because TVA's current analysis assumes  
18 that that PORV is promptly closed. They will not be able to  
19 do that and it will delay operator action, and therefore, it  
20 will increase the amount of RCS that gets into the steam  
21 generator because it will be lower, steam generator pressures.  
22 It will also increase the amount of release because the valve  
23 will be open longer.

24 Again, it just shows how the failure of the PORV  
25 creates a beyond design basis event. A failure of this



1 control circuitry the way they have these non-qualified  
2 circuits influencing the position of the PORV.

3 I also wish to point out that from my understanding  
4 from John Henry Sullivan's discussion is that they are relying  
5 on a factor, they're saying that a VCT isolation valve will  
6 not close before ten minutes and give the operators time to do  
7 things like rack out the breakers so the valve will not close,  
8 or open the RWST. There is one other thing he was relying on.  
9 None of these methods being assured available from a fire.

10 I also wish to point out that an analysis of that  
11 nature is not currently allowed by Appendix R and would  
12 require a deviation request in my estimation. I understand  
13 TVA has not submitted the same, also.

14 Another concern that was not really thoroughly  
15 touched on is if we have a spurious safety injection signal as  
16 TVA has admitted may occur, that will start both charging  
17 pumps. TVA has not ensured that the RWST will be properly  
18 aligned and this may result in the charging pumps being left  
19 drawing suction from the VCT. That will promptly deplete it  
20 and this will result in the charging pump sucking on hydrogen  
21 which will also promptly destroy both charging pumps as well  
22 as the SI pumps which are also aligned at that time.

23 In addition, TVA has not ensured the prompt  
24 availability of RHR. They rely on repair procedures. This  
25 will also mean that it may very well be that the RHR pumps are

1 disabled. They may be left with absolutely no way to get water  
2 in the core in this event. I think we should examine this a  
3 little bit more closely.

4 I'm also pointing out, it was demonstrated in  
5 discussion today that there is no method assured by TVA to  
6 terminate feedwater flow, main feedwater flow to the steam  
7 generators in a control building fire and they are ultimately  
8 relying on action in the auxiliary control room. I am unaware  
9 of any calculations to determine how much or whether these  
10 generators won't back to overflow before they get down there.

11 Also, I understand TVA is taking credit for very  
12 short operator responses. Normally speaking, the NRC allows  
13 ten minute operator response for actions within the control  
14 room. I think a two minute operator responses currently  
15 called for might be over-stretching the operator's  
16 capabilities, especially considering he may not exactly  
17 appreciate what if anything is happening. I'll get into that  
18 a little more with regard to spurious SI a little later.

19 Also similar problems with the pressurizer PORV in  
20 the aux control building fire. Obviously, if you made your  
21 mind up and you say to the control room "Go, close that  
22 valve." You can get there in two minutes. I think that's  
23 about the extent of the analysis. However, you've got to keep  
24 in mind the operator may not really know what he has. I'm  
25 going to ask these things in question form because that's how

1 they're written to save time, but I'm really not expecting a  
2 response at this time.

3           How does TVA know in fact that the PORV is open? Do  
4 they have any position indications assured that they're going  
5 to receive that the PORV is in fact open? Any pressure  
6 indication that they know they're going to receive that the  
7 RCS pressure is dropping?

8           If the operator receives indication that the RCS is  
9 depressurizing and it receives a fire alarm, does he use his  
10 EOIs and follow them until he reaches the appropriate exit  
11 point? Or does he go to an AOI for control room abandonment?  
12 How are these procedures coordinated?

13           Will it take longer than two minutes to exit the  
14 EOI? How could they close the block valve before this time?  
15 If it takes ten minutes to close the block valve, what will  
16 the RCS conditions be? Is the situation currently analyzed?

17           Obviously if the PORV is only open for two minutes,  
18 the RCS conditions are not going to degrade that much.  
19 Normally safety injection comes on in a minute or thereabouts.  
20 Two minutes, I will acknowledge that there won't be much  
21 change in the RCS conditions, and I agree with Frank Koontz if  
22 they get there in two minutes it's not too much of a problem.  
23 Unfortunately, I believe it may take 10 minutes or 15 minutes  
24 to really figure out what happened. Ten or 15 minutes, you've  
25 lost substantial inventory and you are beyond your design

1 basis. You've gone into degrading of steam generator loops.

2 I believe this is unanalyzed at this time. I think  
3 the NRC staff should be very careful before they allow TVA to  
4 take credit for two minute operator response on an event of  
5 this nature.

6 In an actual loca if the operator receives a fire  
7 signal, this is not a real fire, by the way, just something  
8 caused as a consequential failure that occurred due to the  
9 loca. Maybe the diesels didn't start properly, maybe it was a  
10 voltage spike like we were talking about. I understand some  
11 people have raised that concern. That might have done  
12 something funny to the fire detection system that a false  
13 alarm comes in. Does the operator go into his loca procedures  
14 or does he go to his ALI's? Obviously, fire protection takes  
15 lower priority and the operator is going to stick with his  
16 EOIs first until he's absolutely positive he does not have a  
17 loca before he starts thinking about fires.

18 TVA also made statements today that they don't care  
19 if safety injection signals actuate. I want to point out that  
20 this is different than their 1984 position where they say it  
21 will not occur. I refer staff to the safety position  
22 statements. I can't put my finger on it exactly, but Mr.  
23 Pierce, I'm sure, could confirm that. We discussed that item  
24 at one point or another.

25 I've got questions with this spurious SI again. If

1 the operator really isn't sure what he's got, I believe the  
2 prudent thing would be to keep that SI flow going, and it may  
3 take all of 20 minutes to figure out that he doesn't have a  
4 loca and has a fire. Keep in mind, although TVA has said they  
5 have ensured a pressurizer level sensor available, the failure  
6 mechanisms of these pressurizer level sensors could be that  
7 you would have some of them failing on scale in intermediate  
8 values. The operator may be faced with two pressurizer level  
9 sensors, off scale load, the majority of his pressure sensors  
10 including his narrow range and some of his wide range  
11 indicating low pressures, pressurizer level indicating low,  
12 and then he sees one lone pressurizer level set lifting up  
13 kind of slow looking like it might be failing. What's he  
14 going to listen to? The weight of the indication that may  
15 indicate a loca and it may take him substantially longer than  
16 20 minutes.

17 I also want to point out that TVA responded in the  
18 recent correspondence to the NRC that an analysis on Bellafont  
19 was done and showed that the operators would in fact respond.  
20 I wish to just for the record state that I performed that  
21 analysis and I realize what the flaws are, not that they're  
22 flaws, but what the limitations are, I should add. That  
23 analysis also showed that in some areas it would be likely for  
24 the reactor to be driven more to solid. In those particular  
25 scenarios around Bellafont, we assured that we didn't have to

1 go into containment, that we didn't mess up the environment.  
2 I don't think we've done that at Sequoyah.

3 Also, TVA makes statements that they believe there  
4 will be sufficient indication available. Again, before we  
5 made those statements on Bellafont, we made specific looks at  
6 what instrumentation were lost, we made judgments as to  
7 whether it would be sufficient indication left over, and then  
8 we tested the operators. Per discussions with Ed Sheehy at  
9 TVA, we went over some scenarios where we lost tremendous  
10 amount of indication with a 20 foot Appendix R fire. With  
11 that indication in our opinion, it may be survivable, but it  
12 would certainly require some special operator training which  
13 is contrary to what TVA is currently considering to do.

14 (Pause)

15 Also I would like to talk about the main steam  
16 isolation valves. I know we talked about so much redundancy  
17 in separation. I'm not sure about TVA's specific design, but  
18 all the other plants I worked on, the main steam isolation  
19 valves, this is pro-Westinghouse, generally requires power to  
20 trip those valves although they are fail-close valves. The  
21 closing solenoids are usually, generally, this could be  
22 verified with Mr. Hosmer shaking his head no, but my  
23 understanding is the circuits that actually close the  
24 solenoid, that actually bleed the air require power. There  
25 are multiple solenoids, granted, but they do require power.

1 Again, I may be incorrect at TVA because I have not reviewed  
2 those specific circuits.

3 MR. RICHARDSON: You have a couple of minutes left  
4 in your allotted time.

5 MR. BARTLIK: Yes sir.

6 TVA mentioned they will trip the breakers, they  
7 would just hit a switch at the local control center. I wonder,  
8 hitting that switch, is that possible that the control power  
9 has been disabled? Has TVA shown that control power is  
10 available to trip the RCP breakers, or is TVA going to have to  
11 rely on winding up those breakers with the reach rods? I'm  
12 not sure what exactly TVA has to do to trip those RCP motor  
13 control centers.

14 I'd like to talk a little bit to RCS  
15 depressurization. John Henry Sullivan mentioned a lot of  
16 methods in which to depressurize the RCS. I wish to point out  
17 none of them are currently in the Appendix R shutdown logic.  
18 That was originally one of my concerns in that it wasn't there  
19 and it was unclear if the RCS would be able to be  
20 depressurized in a reasonable time frame, in the time frame  
21 required for SOI 26.3.

22 Although we may be able to get in there and put air  
23 bottles and do a number of different things, those are  
24 currently not reflected in procedures as required by the law.

25 MR. RICHARDSON: Do you have any closing comments,

1 Mr. Bartlik? You've come to the end of the allotted time.

2 MR. BARTLIK: You said you might give me a little  
3 more time. If you can give me about two more minutes --

4 MR. RICHARDSON: Please wrap up within that time.

5 MR. BARTLIK: Yes sir.

6 AOI 27 which deals with pulling control fuses for  
7 the pressurizer head vents, I mean the RCS head vents, the  
8 head vents may open for numerous other fire areas and AOI 27 I  
9 believe pertains strictly to the control room, so this  
10 procedure currently does not reflect the need to disable power  
11 to these valves.

12 I have no further comments. Thank you.

13 MR. RICHARDSON: Thank you very much.

14 MR. BARTLIK: I would like to say if any of the  
15 staff needs my help to discuss any of these items, for further  
16 clarification, I will be available.

17 MR. RICHARDSON: Thank you. Does TVA have any brief  
18 comments?

19 MR. FOX: Yes. TVA does not agree with a lot of the  
20 statements that were made by Mr. Bartlik. We'll be happy to  
21 address any of the questions that NRC staff feels are  
22 appropriate and need to be addressed after reviewing the  
23 transcript.

24 MR. RICHARDSON: Thank you, we appreciate that.

25 MR. PIERSON: Thank you for your participation.



1

(Whereupon, at 5:16 p.m. the meeting was adjourned.)

REPORTER'S CERTIFICATE

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

DOCKET NUMBER:

CASE TITLE: MEETING: NRC & TVA re: 10 C.F.R. Part 50,  
Appendix R Issues

HEARING DATE: March 9, 1988

LOCATION: Rockville, Maryland

I hereby certify that the proceedings and evidence  
are contained fully and accurately on the tapes and notes  
reported by me at the hearing in the above case before the  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS.

Date: 3/9/88

*Margaret Daley*  
\_\_\_\_\_  
Official Reporter

HERITAGE REPORTING CORPORATION  
1220 L Street, N.W.  
Washington, D.C. 20005

MARCH 9, 1988 MEETING  
AGENDA FOR APPENDIX R DISCUSSION  
BETWEEN NRC AND TVA FOR SEQUOYAH UNIT 2

OPENING REMARKS (MEETING FORMAT) S. Richardson/S. Ebnetter

BACKGROUND R. Pierson

DISCUSSION Staff/TVA

TVA will be asked to address staff questions on various Appendix R issues including the following:

- ° Spurious actuation
  - HI/LO pressure interface
  - Associated circuits
  - Ungrounded DC circuits
- ° Effect of fire on instrument sense lines
- ° RHR cooldown with one train
- ° Spurious actuation of specific components (PORV's, Reactor Head Vents, etc.)
- ° Solid plant operations
- ° Single failure criteria
- ° Instrumentation requirements of IN 84-09

PUBLIC COMMENT 20 Minutes

CLOSING REMARKS S. Richardson

Relative to Q-22     Sinterbury  
 400'L INFO     Calc

✓ - END DEVICE IS IN THE EQ PROGRAM (e.g., PT, LT, TE etc.)

OTHER ITEMS MARKED "NOT IN EQ PROGRAM" ARE NOT IN PROGRAM FOR VARIOUS REASONS: (EXAMPLES)

- a) MILD ENVIRONMENT
- b) ESSENTIALLY MILD
- c) CATEGORY "C"
- d) NON-SAFETY RELATED LOOPS ETC

THIS JUST INDICATES SOME EQUIPMENT DIFFERENCES EXIST BETWEEN EQ AND APP R AND SHOULD NOT BE A BIG SURPRISE.

EQUIPMENT REQUIRED FOR SAFE SHUTDOWN  
DURING A DESIGN BASIS FIRE

SQE-SQ84-0127

Prepared by/Date R. J. Clark 2/1

Checked by/Date R. J. Clark 3/10/8

APPENDIX D

APPENDIX D - INSTRUMENTATION LIST FOR MAIN CONTROL ROOM

Indicator	Description
✓ LI-68-339	Pressurizer Water Level
✓ LI-68-320 One of three	Pressurizer Water Level
✓ LI-68-335A (UB-335)	Pressurizer Water Level
PI-68-342A - not in eqn.	ECS WR Pressure
✓ PI-68-66A One of three	ECS WR Pressure
✓ PR-68-69	ECS WR Pressure
<div style="border: 1px solid black; padding: 5px;">                     ✓ PI-1-2A Either one                      ✓ PI-1-2B                 </div>	SG-1 Steam Press SG-1 Steam Press
<div style="border: 1px solid black; padding: 5px;">                     PI-1-9A Either one                      PI-1-9B                 </div>	SG-2 Steam Press SG-2 Steam Press
<div style="border: 1px solid black; padding: 5px;">                     PI-1-20A Either one                      PI-1-20B                 </div>	SG-3 Steam Press SG-3 Steam Press
<div style="border: 1px solid black; padding: 5px;">                     ✓ PI-1-27A Either one                      ✓ PI-1-27B                 </div>	SG-4 Steam Press SG-4 Steam Press
<div style="border: 1px solid black; padding: 5px;">                     ✓ LR-3-43                      ✓ LI-3-17A                      ✓ LI-3-164                      ✓ LI-3-38*                      ✓ LI-3-39                 </div>	SG-1 NR Level SG-1 NR Level
<div style="border: 1px solid black; padding: 5px;">                     ✓ LR-3-46 43                      ✓ LI-3-156                      ✓ LI-3-173                      ✓ LI-3-51*                      ✓ LI-3-52                 </div>	SG-2 NR Level SG-2 NR Level
<div style="border: 1px solid black; padding: 5px;">                     ✓ LR-3-98                      ✓ LI-3-172                      ✓ LI-3-148                      ✓ LI-3-93*                      ✓ LI-3-94                 </div>	SG-3 NR Level SG-3 NR Level
<div style="border: 1px solid black; padding: 5px;">                     ✓ LR-3-98                      ✓ LI-3-175                      ✓ LI-3-171                      ✓ LI-3-106*                      ✓ LI-3-107                 </div>	SG-4 NR Level SG-4 NR Level

PSS  
LT's

not in  
eqn.

Two  
Loops  
Required

should  
be 43

✓ means 50.49 EQ'd

EQUIPMENT REQUIRED FOR SAFE SHUTDOWN  
DURING A DESIGN BASIS FIRE

808-8084-0127

Prepared by/Date RA [Signature]

Checked by/Date RL Clark 2/19/81

APPENDIX D

APPENDIX D - INSTRUMENTATION LIST FOR MAIN CONTROL ROOM

Indicator

Description

TE's {  
 ✓ TR-68-1 (Pen 1)  
 ✓ TR-68-1 (Pen 2)  
 ✓ TR-68-24 (Pen 1)  
 ✓ TR-68-24 (Pen 2)  
 ✓ TR-68-43 (Pen 1)  
 ✓ TR-68-43 (Pen 2)  
 ✓ TR-68-65 (Pen 1)  
 ✓ TR-68-65 (Pen 2)

Two loops required

SCS Loop 1 Hot Leg  
 SCS Loop 1 Cold Leg  
 SCS Loop 2 Hot Leg  
 SCS Loop 2 Cold Leg  
 SCS Loop 3 Hot Leg  
 SCS Loop 3 Cold Leg  
 SCS Loop 4 Hot Leg  
 SCS Loop 4 Cold Leg

Source Range Flow Monitor

not  
 2/19/81  
 NI-92-31B      Either one  
 NI-92-32B

Condensate Storage Tank Level

not  
 2/19/81  
 1. LI-2-230A      Either one for Tank A (Note 1)  
 2. LI-2-230D  
 3. LI-2-233A      Either one for Tank B (Note 1)  
 4. LI-2-233D

Chemical and Volume Control

not  
 2/19/81  
 1. LI-62-129 (Tank Level-VCT)      Note 2  
 2. FI-62-93A (Charging Flow)      Note 3

Note 1: If MCR indication is not available, local monitoring of tank level or APW suction pressure is acceptable

Note 2: Refer to key 4 for actions if this level indication is not available.

Note 3: This indicator is only required if the path ~~using 40V 62-93~~ <sup>normal charging 2/19/81</sup> is chosen in key 2.

not  
 2/19/81  
 \*Denotes steam generator level transmitters whose sense lines have been verified as ~~having adequate separation~~ being unaffected by a fire inside containment (B29 880120 001). Only the sense lines are Appendix R equipment (i.e., the cabling was not evaluated).

Source: Xerox, Xerox Monitor

APPENDIX B

E1

1560F/JMS

SQN-SQS4-0127

APPENDIX E

Appendix E - Instrumentation List for Auxiliary Control Room:

Pressurizer Pressure and Level

Level

- not in eq. pg. 5
- 1. LI-68-325C Either one
  - 2. LI-68-326C

Pressure

- not in eq. pg. 5
- 1. PI-68-336C
  - 2. PI-68-337C One of three
  - 3. PI-68-342C

Reactor Coolant Hot Leg Temperature

- ✓ 1. TI-68-1C (Loop 1)
  - ✓ 2. TI-68-24C (Loop 2)
  - ✓ 3. TI-68-43C (Loop 3)
  - ✓ 4. TI-68-63C (Loop 4)
- All four loops  
~~Any two loops used for cooldown~~ RA 2/11/88

Steam Generator Pressure and Level

Pressure

- not in eq. pg. 5
- 1. PI-1-1C (Loop 1)
  - 2. PI-1-8C (Loop 2)
  - 3. PI-1-19C (Loop 3)
  - 4. PI-1-26C (Loop 4)
- All four loops  
~~Any two loops used for cooldown~~ RA 2/11/88

Level

- ✓ 1. LI-3-164C (Loop 1)
  - ✓ 2. LI-3-156C (Loop 2)
  - ✓ 3. LI-3-148C (Loop 3)
  - ✓ 4. LI-3-171C (Loop 4)
- All four loops  
~~Any two loops used for cooldown~~ RA 2/11/88

Source Range Flux Monitor

- not in eq. pg. 5
- 1. RI-90-210

Level Indication for Tanks

Volume Control Tank

- not in eq. pg. 5
- 1. LI-62-129C



SGN-5084-0127

APPENDIX B

Appendix B - Instrumentation List for Auxiliary Control Room:

Diagnostic Instrumentation for Shutdown Systems

Auxiliary Feedwater System

- ✓ 1. FI-3-163C (Loop 1)
- ✓ 2. FI-3-155C (Loop 2)
- ✓ 3. FI-3-147C (Loop 3)
- ✓ 4. FI-3-170C (Loop 4)
- 5. FI-3-142C (Aux FPT Disch)

All four loops  
~~Any two loops used for shutdown~~ *Rev 5/11/87*

EM NOT IN EQ TEM

Chemical and Volume Control Tank

- 1. TI-62-80C (Ltdn Ht Exch Outlet)
- 2. FI-62-92C (Chg Hdr Press)
- 3. FI-62-93C (Chg Hdr Flow)
- 4. FI-62-137C (Emet Boration)

not in EQ TEM

Safety Injection System

- 1. FI-63-91C (RHR Pmp A-A to RCS 243 CL)
  - 2. FI-63-92C (RHR Pmp B-B to RCS 164 CL)
- Either one

not in EQ TEM

Essential Raw Cooling Water

- 1. FI-67-61C (ERCW Supply Hdr A)
  - 2. FI-67-62C (ERCW Supply Hdr B)
- Either one

not in EQ TEM

Residual Heat Removal

- 1. TI-74-38C (RHR Htx A Outlet Temp)
  - 2. TI-74-40C (RHR Htx B Outlet Temp)
- Either one

not in EQ TEM



# QA Record

## CAQR <sup>1/2</sup> 1/87 AUG 21 1987

REV 12RIMS ACCESSION NUMBER 805 '87 0021 306 CAQR NO. 

S	Q	F	B	7	0	1	5	1
---	---	---	---	---	---	---	---	---

PART A DESCRIPTION OF THE CAQ 805 '87 1109 307

PLANT/PROJECT SON UNIT 2 VENDOR \_\_\_\_\_  
 SYSTEM G33 VENDOR'S ADDRESS \_\_\_\_\_  
 COMPONENT Instrumentation Assx with the RCS and S&S CONTRACT NO. \_\_\_\_\_  
 ASME? YES  NO  REFERENCES \_\_\_\_\_

REQUIREMENT VIOLATED SEPARATION OF ESSENTIAL SHUTDOWN SYSTEMS FROM THE EFFECTS OF FIRESOURCE OF REQUIREMENT VIOLATED APPENDIX R TO 10CFR PART 50

DESCRIPTION OF CONDITION  
 ADEQUATE SEPARATION OF INSTRUMENTATION ESSENTIAL TO SAFE SHUTDOWN IN THE EVENT OF FIRE HAS NOT BEEN ACCOMPLISHED. THIS CONCERN IS DETAILED IN THE ATTACHED SHEETS.

RECOMMENDED CORRECTIVE ACTION (OPTIONAL)  
 RELOCATE AND/OR PROTECT THE AFFECTED INSTRUMENTATION CABLES AND SENSE LINES SUCH THAT COMPLIANCE WITH THE FUNCTIONAL CRITERIA IS ACHIEVED

CAQR INITIATED BY ASBARTLIK DATE 8/21/87 TEL. NO. KNOX-6822  
 INITIATOR'S ORGANIZATION MEB DATE/TIME CAQ DISCOVERED 8/10/87  
 MANAGEMENT REVIEWER SDCOK DATE 8/21/87 TITLE DNG SPEL (FP)  
 RESPONSIBLE ORGANIZATION MEB COORDINATED WITH R McLELL AND F. TANNER 8/20/87

POTENTIAL AFFECT ON OPERABILITY  
 OPERABILITY OF NUCLEAR UNIT IS  IS NOT  AFFECTED.  
 IF 'YES', INDICATE AFFECTED UNITS.

BFN	<input type="checkbox"/> 1	<input type="checkbox"/> 2	<input type="checkbox"/> 3	COMMON	<input type="checkbox"/>	SON	<input type="checkbox"/> 1	<input checked="" type="checkbox"/> 2	COMMON	<input type="checkbox"/>
WBN	<input type="checkbox"/> 1	<input type="checkbox"/> 2	COMMON	<input type="checkbox"/>	BLN	<input type="checkbox"/> 1	<input type="checkbox"/> 2	COMMON	<input type="checkbox"/>	

CAQ COORDINATOR \_\_\_\_\_  
 DATE RECEIVED 8-21-87  
 PROCESSED BY W. P. Estep DATE 8-21-87

TRENDING CODES  
 CALL ... ACTIVITY ...  
 DETAIL DESCRIPTION ... ROOT CAUSE ...  
 APPR ... CAUSE ORG ...  
 EQUIP IDENT PLANT UNIT FUNCTION SYSTEM ADDRESS SEPARATOR  
 ION WBN BFN - - - - -  
 BLN PLANT UNIT/SYSTEM COMPONENT ADDRESS SEPARATOR  
 PROCEDURE VIOLATED \_\_\_\_\_  
 MANUFACTURER \_\_\_\_\_  
 REGISTRATION \_\_\_\_\_ ONE EQUIPMENT \_\_\_\_\_

DISTRIBUTION		PLANT			
ORGANIZATION/GR.		BF	BLS	SO	WE
DNQA, DIR	<input type="checkbox"/> SITE DIR.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
DNE, DIR	<input type="checkbox"/> PMO	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
DNC, DIR	<input type="checkbox"/> SITE QA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
DNS, DIR	<input type="checkbox"/> DNE-PE	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
DNSL, DIR	<input type="checkbox"/> DNC-CE	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
NSRB	<input type="checkbox"/> DNC-MOD	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
ONP, MGR	<input type="checkbox"/> DNSL	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
RIMS	<input type="checkbox"/> NRC RES	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
ORIGINATOR _____					
OTHER _____					
RIMS ACCESSION NUMBER _____					

RIMS ACCESSION NUMBER **805 '87 0812 303** CAOR NO. **SQF870151**

**PART A DESCRIPTION OF THE CAQ**

PLANT/PROJECT SON UNIT 2 VENDOR N/A

SYSTEM GB3 VENDOR'S ADDRESS N/A

COMPONENT INSTRUMENTATION ASSX WITH THE RCS AND SG CONTRACT NO. N/A

ASME? YES  NO  REFERENCES SQP 870857

REQUIREMENT VIOLATED SEPARATION OF ESSENTIAL SHUTDOWN SYSTEMS FROM THE EFFECTS OF FIRE

SOURCE OF REQUIREMENT VIOLATED APPENDIX R TO 10CFR PART 50

**DESCRIPTION OF CONDITION**

ADEQUATE SEPARATION OF INSTRUMENTATION ESSENTIAL TO SAFE SHUTDOWN IN THE EVENT OF FIRE HAS NOT BEEN ACCOMPLISHED. THIS CONCERN IS DETAILED IN THE ATTACHED SHEETS

**RECOMMENDED CORRECTIVE ACTION (OPTIONAL)**

CAQR INITIATED BY A.J. BARTLE DATE 8/12/87 TEL. NO. 6822-KMX

INITIATOR'S ORGANIZATION MEB DATE/TIME CAQ DISCOVERED 8/10/87

MANAGEMENT REVIEWER S.D. COOK DATE 8/12/87 TITLE ENR. SPEC (E.P.)

RESPONSIBLE ORGANIZATION MEB-GPC/SSP COORDINATED WITH R. MCCOLL ON 8/12/87

**POTENTIAL AFFECT ON OPERABILITY**

OPERABILITY OF NUCLEAR UNIT IS  IS NOT  AFFECTED. IF 'YES', INDICATE AFFECTED UNITS.

BFN 1  2  3  COMMON  SON 1  2  COMMON

WBN 1  2  COMMON  BLN 1  2  COMMON

**CAQ COORDINATOR**

DATE RECEIVED 8-12-87

PROCESSED BY W.D. ESTEP DATE 8-12-87

**TRENDING CODES**

SAFETY ACTIVITY

DETAIL DESCRIPTION ROOT CAUSE

APP. CAUSE ORG.

EQUIP IDENT PLANT UNIT FUNCTION SYSTEM ADDRESS SEPARATOR

PLANT UNIT/SYSTEM COMPONENT ADDRESS SEPARATOR

PROCEDURE VIOLATED

MANUFACTURER

REQUISITION ONE EQUIPMENT

ORGANIZATION/GR.		PLANT			
		BF	BL	SQ	WI
DNQA, DIR	<input type="checkbox"/> SITE DIR.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
DNE, DIR	<input type="checkbox"/> FMO	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
DNC, DIR	<input type="checkbox"/> SITE QA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
DNS, DIR	<input type="checkbox"/> DNE-PE	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
DNSL, DIR	<input type="checkbox"/> DNC-CE	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
NSRB	<input type="checkbox"/> DNC-MOD	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
ONP, MGR	<input type="checkbox"/> DNSL	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
RIMS	<input type="checkbox"/> NRC RES	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

ORIGINATOR \_\_\_\_\_

OTHER \_\_\_\_\_

RIMS ACCESSION NUMBER



# CAQR

REV C

RIMS ACCESSION NUMBER **805 '87 1109 307** CAQR NO 50 FEB 7 9/5/87

## PART B EVALUATION

### AFFECT ON OPERABILITY

DOES THIS CAQ IMPACT UNIT OPERABILITY? YES  NO

IF 'YES' NOTIFIED PLT. MGR. AND/OR OPERATIONS AT \_\_\_\_\_ TIME \_\_\_\_\_ ON \_\_\_\_\_ DATE \_\_\_\_\_

### SIGNIFICANCE/REPORTABILITY

PORS	SIGNIFICANT CAQ	REPORTABILITY	REVIEWED BY	DATE
RESPONSIBLE ORGANIZATION	YES <input type="checkbox"/> NO <input type="checkbox"/>	YES <input type="checkbox"/> NO <input type="checkbox"/>	<u>Alan M. Mator</u>	<u>11/5/87</u>
	YES <input checked="" type="checkbox"/> NO <input checked="" type="checkbox"/>	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>		

IF REPORTABILITY BLOCK IS CHECKED 'YES' IN ITEM 3B, GIVE A COPY TO THE ORGANIZATION RESPONSIBLE FOR DETERMINING REPORTABILITY IMMEDIATELY: SENT TO \_\_\_\_\_ DATE \_\_\_\_\_ TIME \_\_\_\_\_

### GENERIC REVIEW

A REVIEW FOR POTENTIAL GENERIC IMPLICATIONS IS  IS NOT  REQUIRED. (ALWAYS REQUIRED FOR SIGNIFICANT CAQ'S AND CAQ'S AFFECTING OPERABILITY)

COPY OF CAQR SENT TO \_\_\_\_\_ ON \_\_\_\_\_ FOR PERFORMANCE OF A GENERIC REVIEW.

### EVALUATED BY

Alan M. Mator 11/5/87  
 NAME DATE  
DNE-MEB  
 ORGANIZATION

### APPROVED BY

[Signature] Nov 8  
 NAME DATE  
Principal Engineer  
 TITLE

### ROOT CAUSE ANALYSIS/RECURRENCE CONTROL

ROOT CAUSE ANALYSIS REQUIRED? YES  NO

RECURRENCE CONTROL REQUIRED? YES  NO

(ALWAYS REQUIRED FOR SIGNIFICANT CAQ'S, NRC VIOLATIONS, AUDIT FINDINGS, CAQ'S AFFECTING OPERABILITY.)

IF EITHER ARE REQUIRED, FILL OUT PART D OF THIS CAQR.

## PART C REMEDIAL CORRECTIVE ACTION

DISPOSITION METHOD	DESCRIPTION OF PROPOSED DISPOSITION
RETURN TO VENDOR <input type="checkbox"/> REWORK <input type="checkbox"/> REPAIR <input type="checkbox"/> <u>11/1/88</u> ACCEPT-AS-IS <input checked="" type="checkbox"/> SCRAP <input type="checkbox"/> OTHER (DESCRIBE) <input checked="" type="checkbox"/> <u>See C/A</u>	<i>See attachment</i>
OTHER INFORMATION	
NO TAGS PLACED <u>None</u>	
REPAIR/REWORK PROCEDURE NO. _____	
WAS ENGINEERING REQ'T VIOLATED YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> REFERRED TO ONE/DNS TO DETERMINE DISPOSITION YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	ORGAN RESPONSIBLE FOR C/A <u>DNE-SEEP-M3</u> SCHEDULED COMPLETION DATE <u>2-10-88</u>

VERIFICATION REQUIREMENTS: RETEST  REINSPECT  AUDITOR FOLLOW-UP  QA REVIEW  SUPV. REVIEW

OTHER (DESCRIBE)

APPROVALS	NAME	DATE	NAME	DATE	APPROVAL
PROPOSED BY	<u>David A. Boyd</u>	<u>1-11-88</u>			<u>N/A</u>
SUPV. APPROVAL	<u>[Signature]</u>	<u>11/2/88</u>			PORC REVIEW DATE
ONE/DNS APPROVAL	<u>R. E. Davis</u>	<u>1/11/88</u>			<u>N/A</u>
AIA ACCEPTANCE					PLANT MANAGER DATE
QA APPROVAL					<u>88 0114 001</u>
OTHER APPROVAL					RIMS ACCESSION NO.

VERIFICATION OF REMEDIAL C/A

APPROVED CORRECTIVE ACTION HAS BEEN COMPLETED AND IS READY FOR VERIFICATION	NAME	DATE
VERIFICATION COMPLETE		
ALL TAGS REMOVED		
CAQR SHEET 2 CLOSED		

RIMS ACCESSION NUMBER

B29 '88 0114 001

CAAR, GCF-870151

PART "C"

DESCRIPTION OF PROPOSED DISPOSITION

A fire hazards analysis walkdown has been performed by a fire protection engineer to determine if the minimum required number of instrument sense lines required for appendix R will survive any creditable fire without adverse effects on instrument indications. The sense lines involved are for the steam generator level indicators and for the pressurizer level indicators. It has been determined that at least one steam generator level indicator per steam generator loop will survive any creditable fire. These are level indicator loops 2-LT-3-38, 51, 93, and 106. These instruments are to be added to the NEB calculation SQN-SQS4-0127 on revision 8 which is to be issued by 2-5-88. At least one of the three sense lines for the pressurizer level indicators will survive any creditable fire. This will be documented in a formal fire hazards analysis calculation and in a Safety Function Position Statement scheduled to be issued by 1-20-88. No field work is required and the sense lines are acceptable for use "as is". Calculation SQN-SQS4-0127 revision 8 is not required for restart.

NRC was provided this

SQN-CO-D052, EPM-EAC-0011888  
as referenced in response to Question  
15.



# CAQR

RIMS ACCESSION NUMBER

CAQR NO. 50A87015111 REV. \_\_\_\_\_

PART D ROOT CAUSE ANALYSIS/RECURRENCE CONTROL

### ROOT CAUSE OF THE CAQ

Design criteria and appendix R documentation did not consider sense lines to vulnerable to fire damage because they are essentially noncombustible tubing or pipe. The effects of a fire on the fluid inside the sense lines was not considered, and thus is the root cause of this CAQR.

### PROPOSED RECURRENCE CONTROL ACTIONS

NEB calculation SQN-SQS4-0127 revision 8 is being prepared for issue by 2-5-88 and includes a requirement that all sense lines be evaluated for fire effects.

ORGANIZATION RESPONSIBLE FOR RECURRENCE CONTROL NEB

SCHEDULED COMPLETION DATE 2-10-88

VERIFICATION REQUIREMENTS SUPERVISOR REVIEW  QC INSPECTION  TEST  AUDITOR FOLLOWUP  QA REVIEW  OTHER (DESCRIBE)

APPROVALS	NAME	DATE	NAME	DATE	APPROVAL
PROPOSED BY	<i>David A. Boyle</i>	<i>1-11-88</i>			<i>N/A</i>
SUPV. APPROVAL	<i>[Signature]</i>	<i>1/11/88</i>			
ONE/DNS APPROVAL	<i>R. S. [Signature]</i>	<i>1/11/88</i>			
QA APPROVAL					
OTHER APPROVAL					

**B29** PLANT MANAGER 88 0114 007 DATE

VERIFICATION OF RECURRENCE CONTROL NAME DATE

APPROVED RECURRENCE CONTROL COMPLETE-READY FOR VERIFICATION

VERIFICATION CAQR SHEET 3 CLOSED

RIMS ACCESSION NUMBER

) A FIRE IN THE VICINITY OF STEAM GENERATOR 4

A FIRE IN THE AREA SHOWN ON ATTACHED SKETCH 1 MAY CAUSE THE LOSS OF RCS TEMPERATURE SENSORS TE-6B-43 & 53 (LOOP 3) AND TE-6B-65 AND 83 (LOOP 4) AND STEAM GENERATOR LEVEL SENSORS LT-3-39, 42, 43, 104 AND 174 (LOOP 1), LT-3-55, 56 AND 175 (LOOP 2), LT-3-97, 98 AND 148 (LOOP 3) AND LT-3-107, 110, 111, 17 AND 175 (LOOP 4).

ALLOWING CREDIT FOR APPENDIX R INSTRUMENTATION LOOP TWO IS THE ONLY LOOP WITH INTACT STEAM GENERATOR LEVEL SENSORS AND RCS TEMPERATURE SENSORS. THE FUNCTIONAL CRITERIA REQUIRES 2 LOOPS WITH INTACT STEAM GENERATOR LEVEL SENSORS AND RCS TEMPERATURE SENSORS. THEREFORE, THE PLANT CONFIGURATION IS NOT IN COMPLIANCE WITH THE FUNCTIONAL CRITERIA IN THIS AS SIMILAR UNACCEPTABLE INTERACTIONS (SOMETIMES INVOLVING FEWER INSTRUMENTS) EXIST IN THE VICINITY OF SG 4 UP TO  $A=15^\circ$ . ALSO, SIMILAR INTERACTIONS MAY EXIST BETWEEN CABLES IN FAN ROOM #1 AND SENSE LINES LOCATED WITHIN THE CRANE WALL IF THE CRANE WALL IS ASSUMED TO BE AN EFFECTIVE RADIANT ENERGY SHIELD.

## 2) FIRE IN THE VICINITY OF THE PRESSURIZER

A FIRE IN THE AREA SHOWN ON ATTACHED SKETCH 2 MAY CAUSE THE LOSS OF PRESSURIZER LEVEL SENSORS LT-68-320, 3 AND 339, RCS TEMPERATURE SENSORS TE-68-1A AND 1B (LOOP 1) AND STEAM GENERATOR LEVEL SENSORS LT-3-42, 43 AND 174 (LOOP 1), LT-3-94 AND 172 (LOOP 3) AND LT-3-107 AND 175 (LOOP 4).

THE LOSS OF THE ABOVE MENTIONED RCS TEMPERATURE SENSORS AND STEAM GENERATOR LEVEL SENSORS ARE NOT A CONCERN BECAUSE SUFFICIENT INSTRUMENTATION IS AVAILABLE ON LOOPS 2 AND 4. ALLOWING CREDIT FOR APPENDIX R INSTRUMENTATION ONLY, ALL PRESSURIZER LEVEL INSTRUMENTATION WOULD BE LOST. THIS IS IN VIOLATION OF THE FUNCTIONAL CRITERIA.

SIMILAR INTERACTIONS EXIST IN THE GENERAL VICINITY OF THE INTERACTION DESCRIBED ABOVE.



## 3) A FIRE IN THE VICINITY OF RCP 2

A FIRE IN THE AREA SHOWN ON ATTACHED SKETCH 3 MAY CAUSE THE LOSS OF PRESSURIZER LEVEL SENSOR LT-GB-320 RCS TEMPERATURE SENSORS TE-GB-1 AND 1B (LOOP 1) AND TE-GB-2 (LOOP 2), STEAM GENERATOR LEVEL SENSORS LT-3-55, 56 AND 173 (LOOP 2), LT-3-94, 97, 98, 14B AND 172 (LOOP 3) AND LT-3-107 AND 175 (LOOP 4) AND ~~SOURCE 2 AND NEUTRON MONITOR~~ ~~XS-92~~ <sup>Q13</sup> 3/12/87

THE LOSS OF LT-GB-320 IS NOT CRITICAL BECAUSE ITS REDUNDANT COUNTERPART (LT-GB-339) IS NOT AFFECTED.

ALLOWING CREDIT FOR APPENDIX R INSTRUMENTATION ONLY, LOOP 4 IS THE ONLY LOOP WITH INTACT STEAM GENERATOR LEVEL SENSORS AND RCS TEMPERATURE SENSORS. THE FUNCTIONAL CRITERIA REQUIRES 2 LOOPS WITH INTACT STEAM GENERATOR LEVEL SENSORS AND RCS TEMPERATURE SENSORS. THEREFORE, THE PLANT CONFIGURATION IS NOT IN COMPLIANCE WITH THE FUNCTIONAL CRITERIA.

SIMILAR INTERACTIONS EXIST IN THE GENERAL VICINITY OF THE INTERACTION DESCRIBED ABOVE.

IT SHOULD BE NOTED THE ABOVE ANALYSIS ASSUMES THAT LT-3-97, 98, 14B AND TE-GB-1 AND 1B CAN BE AFFECTED BY THE SAME FIRE. PRELIMINARY INFORMATION INDICATES THESE INSTRUMENTS MAY HAVE SUFFICIENT SEPARATION. HOWEVER, DUE TO UNCERTAINTIES CONCERNING THE EXACT INSTRUMENT LOCATION IT HAS BEEN ASSUMED THAT THESE INSTRUMENTS INTERACT UNTIL EXACT LOCATIONS HAVE BEEN DETERMINED.

4) FIRE IN THE AREA BETWEEN STEAM GENERATOR 2 AND 3

A FIRE IN THE AREA SHOWN ON ATTACHED SKETCH 4 MAY CAUSE THE LOSS OF PRESSURIZER LEVEL SENSOR LT-GB-320, RCS TEMPERATURE SENSORS TE-GB-1 AND 10 (LOOP 1) AND TE-GB-24 AND 42 (LOOP 2), SOURCE RANGE NEUTRON MONITOR XE-92-2 AND STEAM GENERATOR LEVEL SENSORS LT-3-51, 52, 53, 56, 156 AND 173 (LOOP LT-3-93, 94, 97, 98, 143 AND 172 (LOOP 3) AND LT-3-106, 107 AND 175 (LOOP

THE LOSS OF LT-GB-320 AND XE-92-2 IS NOT CRITICAL BECAUSE THEIR REDUNDANT COUNTERPARTS (LT-GB-339 AND XE-92-1 RESPECTIVELY) ARE NOT AFFECTED. LOOP 4 IS THE ONLY LOOP WITH INTACT STEAM GENERATOR LEVEL SENSORS AND RCS TEMPERATURE SENSORS. THE FUNCTIONAL CRITERIA REQUIRES 2 LOOPS WITH INTACT STEAM GENERATOR LEVEL SENSORS AND RCS TEMPERATURE SENSORS. THEREFORE THE PLANT CONFIGURATION IS NOT IN COMPLIANCE WITH THE FUNCTIONAL CRITERIA IN THIS AREA.

SIMILAR INTERACTIONS EXIST IN THE GENERAL VICINITY OF THE INTERACTION DESCRIBED ABOVE

NOTE: THE INSTRUMENT SENSE LINE ROUTING INFORMATION ON WHICH THIS CAOR IS BASED WAS TRANSMITTED TO MEB IN A PRELIMINARY FORM. SOME ERRORS WERE DETECTED AND CORRECTED BASED ON DISCUSSIONS WITH THE ELECTRICAL DESIGNERS INVOLVED. IN ADDITION, THE ROUTING OF RCS PRESSURE SENSORS PT-GB-66 AND GA (THESE ARE THE RCS PRESSURIZER PRESSURE SENSORS CALLED FOR BY THE FUNCTIONAL CRITERIA) WERE NOT INCLUDED IN THIS PACKAGE. PRIOR TO CLOSE OUT OF THIS CAOR FINAL INSTRUMENT ROUTING INFORMATION WILL HAVE TO BE TRANSMITTED TO MEB IN A "QUALITY FORM" INCLUDING THE ROUTING OF PT-GB-66 AND GA. THIS INFORMATION WILL THEN BE COMPARED AGAINST THE PREVIOUS ISSUED INFORMATION TO ENSURE THE INTERACTIONS IDENTIFIED BY THIS CAOR ARE VALID AND NO NEW INTERACTIONS EXIST.

SKETCH

SKETCH 1

2NM37-IC  
2NM1384-I (XE-92-115)

20 ft DIA FIRE  
(LOOP 4)

2PM690-  
ITE-68-65

2PM875-  
ITE-68-83

20 ft DIA FIRE

LT-3-11,10,FR  
LT-3-17,10

LT-3-81

LT-3-81,15

LT-3-81,15

LT-3-90

LT-3-90,117

LT-3-90,117

LT-3-90,117

LT-3-90,117

LT-3-90,117

LT-3-90,117

LT-3-90,117

LT-3-90,117

LT-3-90,117

LT-3-90,117


LT-3-90,117

LT-3-90,117

LT-3-90,117

LT-3-90,117

SCFB70151



SOF 870151

SEE NOTE 3  
(LOOP 1)

### SKETCH 2

PNL 2-L-178

△ 2PM777-I (TE-68-18)

△ 2PM590-I (TE-68-11)

LF5-94

LT-68-325 20 ft


LT-3-107, 175


TE-68-1, 18


LT-3-222, 05

□ 2PM870-I (TE-68-41)

IN ADDITION TO THE INSTRUMENT  
SHOWN ABOVE, THIS AREA  
CONTAINS PRESSURE  
LEVEL SENSORS LT-68-325  
AND LT-68-329 IN  
CLOSE PROXIMITY







SEQUOYAE NUCLEAR PLANT

FIRE PROTECTION

NRC MEETING

MARCH 9, 1988



MEETING AGENDA


- |  |                |
|--|----------------|
| I. INTRODUCTION                                    | C. H. Fox      |
| II. SQN FIRE PROTECTION HISTORY                    | J. B. Hosmer   |
| III. RESPONSE TO QUESTIONS                         |                |
| 1, 17, 24, 6, 25                                   | F. Koontz      |
| 2, 5, 10   | B. Bryan       |
| 8, 9, 13, 14, 15, 21                               | J. Pierce      |
| 3, 4, 16, 7, 11, 12, 18,<br>19, 20, 22, 23, and 26 | J. H. Sullivan |
| IV. SUMMARY  |                |

FIRE PROTECTION HISTORY

- 2/80 - 9/81
  - Operating license
  - SRP, APCSB 9.5-1
  - Unit 2 condition Appendix R  
III G, J, L, and O
- 6/84 - 7/84
  - Watts Bar Appendix R  
inspection
- 8/84
  - NRC confirmation letter
- 8/84 - 1/85
  - Operations and DNE team
    - Industry issue plus  
Watts Bar
    - Team used evolving  
guidelines generic  
letter 83-33 and IEN 84-09
    - Generic letters 85-01  
and 86-10 not issued
    - 121 interactions  
21 deviation requests

- 1/85 - 7/87
    - NRC audits of corrective actions
    - Last audit action closed 7/87
- 12/86 DNE calculation program identifies documentation concern with R6 (shutdown logic)
- 7/87 DNE assumes long-term compliance role  
R7 issued with no operations review
- 10/87 DNE concludes R8 required
- 12/87 Review team formed to address all known concerns
- 1/88 Team issues final report and meets with NRC
- 2/88 NRC identifies 26 questions
- 3/2/88 TVA response to 26 questions
- 3/8/88 Question 12 amplification


### 2-Hour SQN Site Boundry Dose For Various Amounts of Coolant Lost (Normal Operation)



(10 CFR 100 Limit = 26 rem)

Figure 1

### 2-Hour SQN Site Boundry Dose For Various Amounts of Coolant Lost (Normal Operation)



(10 CFR 100 Limit = 300 rem)

Figure 2

QUESTION 1

ISSUE: Containment integrity following a fire

RESPONSE: Calculation shows offsite dose within 10CFR100 guidelines

- 0-100% RCS release
- ANSI 18.1 - 1984 activity
- 0.28 REM gamma site boundary (25 limit)
- 18 REM thyroid site boundary (300 limit)

Defense-in-depth

Only practical release path via containment purge

- Connects containment to environment
- Infrequently used at power
- Exhaust line has three fail close valves in series
- HEPA filters and charcoal beds in exhaust line
- Supply line has three fail close valves
- Additional four fail closed dampers in supply line
- Valves and dampers close automatically on radiation signal

Appendix R, Section III.L, does not require containment integrity

CONCLUSION:

- Highly improbable
- Dose within 10CFR100 limits
- Not Appendix R required

QUESTION 2

ISSUE: Fuel pool boiling effects on auxiliary building

- RESPONSE:
- \* No safe shutdown equipment in area except for cables and surge tank
  - \* Cable type qualified to MSLB temperature and humidity
  - \* Nine hours for pool to boil (worst fuel load)
  - \* Boiloff rate - 48 gpm
  - \* Refuel floor volume - 1,000,000 ft.<sup>3</sup>
  - \* Refuel floor exhaust flow - 28,000 cfm
  - \* General building exhaust - 80,000 cfm
  - \* Auxiliary building general spaces volume - 2,000,000 ft.<sup>3</sup>
  - \* No fuel failures result - radiation effects from pool boiling not a safe shutdown concern

CONCLUSIONS:

- \* Significant time for pool to boil
- \* Minimal impact on environment
- \* Not Appendix R issue

QUESTION 3

ISSUE: Procedure coordination

- RESPONSE:
- \* Utilize all plant equipment
  - \* Operator trained and experienced
  - \* Procedure hierarchy
    - \* Emerged procedure
    - \* Fire-specific procedures
  - \* Operation and training to review procedures
  - \* Not Appendix R requirement

CONCLUSION:

- \* No significant conflicts identified
- \* Operator will handle most important event



QUESTIONS 4 AND 16

ISSUE: Adequate Boron concentration

- RESPONSE:
- Reactivity calculations
  - Attempt normal boration (BAT/letdown)
  - RHR letdown to floor drain collection tank with makeup from charging pumps from the RWST
  - Equipment list in safe shutdown logic
  - Pressurizer level fluctuations not used
  - Westinghouse calculation shows single RHR heat exchanger cooldown in 26 hours
  - Credit for pressurizer spray, auxiliary spray, letdown and excess letdown not taken

CONCLUSION: The STA will perform reactivity calculations and operators will take appropriate actions to maintain subcriticality

QUESTION 5

ISSUE: Is control air required?

- RESPONSE:
- Control air is not required to reach safe shutdown
  - Control air used if available
  - Manual actions used as backup specified in Procedure SOI 26.2
  - Water solid operation unlikely

Procedures and assured instrumentation prevent water solid operation

Takes over 10 hours to go solid without letdown and no RCS cooling

CONCLUSION:

- Plant can be shut down without control air
- Manual actions are supported by procedures

QUESTION 6

ISSUE: Water solid operation

RESPONSE: Unlikely event - loss of bubble does not make plant unsafe

- Pressurizer level assured

Operator would terminate spurious charging

Time available for action (10-20 minutes)

- Water solid backup

19 Hours earliest RHR needed (exception Question 4)

Casualty procedure assures valves ready in 15 hours

Cold shutdown not NRC requirement before 72 hours

Safety valve available if PORV/head vent not available

Procedures and training not needed

CONCLUSION:

- Low likelihood for need
- Means of assuring inventory if necessary

QUESTION 7

ISSUE: Ability to put RHR system into operation

RESPONSE: Valves (FCV-74-1,2) in question can be repaired

- Not needed for hot standby
- Fire outside containment casualty procedure ensures availability within 15 hours without containment entry
- No significant in situ fire load around valves
  - Fire inside containment will not damage valve
- For fire in valve will not damage other equipment
  - No spurious PORV, head vent, etc.
  - Normal access to containment

CONCLUSION: Cold shutdown condition is achievable

QUESTION 8

ISSUE: Reactor coolant pump oil collection system

RESPONSE: Appendix R, Section III.0, requires an oil collection system for reactor coolant pumps to collect oil leaks from the lubricating system

- \* Reviewed and accepted by NRC
- \* Recently reviewed by fire protection engineer and determined to be adequate
- \* Postulated low probability events such as broken shafts are not required by Section III.0 of Appendix R
- \* Sleeve around shaft would contain oil on the shaft

CONCLUSION: Reactor coolant pump oil collection system meets the requirements of Appendix R

QUESTION 9

ISSUE: Fire damage to SG atmosphere power-operated relief valve controls

- RESPONSE:
- \* Modification associated with SGs 1 and 4 ensure that no fire in the area of the PORV solenoids and controller can cause spurious opening of the PORVs.
  - \* Fire hazards evaluation performed for the area containing the solenoids for PORVs 2 and 3 determined there is insufficient fuel load to cause damage to the solenoids.
  - \* For a fire in the auxiliary control room cabinet, spurious action can be mitigated.
  - \* One PORV opening is within the design basis of the plant.
  - \* Boron injection tank and pump and safety injection pumps are not required nor assured for Appendix R safe shutdown.
  - \* Charging pump operability is assured with manual control.

CONCLUSION: Met Appendix R requirements and stayed within the design basis events of the plant.

QUESTION 10

ISSUE: Multiple steam generator blowdown

- RESPONSE:
- \* Not Appendix R - MSLE separate initiating event.
  - \* CAQR issued to document and track.
  - \* Bounded by FSAR analysis - 4.6 ft.<sup>2</sup> break
    - Flow limiter - 1.4 ft.<sup>2</sup>
    - 2 ADVs - 0.4 ft.<sup>2</sup>
    - Valve vault break and 2 ADVs - 1.8 ft.<sup>2</sup>
  - \* Westinghouse analysis of unisolated blowdown of 2 SG with 2 PORVs open (Catawba, Seabrook) bounds SQN.
  - \* Physical modifications have been made.
    - Moved controllers and solenoid out of valve vault.
    - Replaced mechanical positioner with more reliable model.
  - \* Operator can manually close ADVs.
    - ADVs and closing solenoid are environmentally and seismically qualified.
  - \* ADVs control design consistent with design for all Westinghouse PWRs.
  - \* CAQR postrestart.
  - \* Appendix R criteria do not exclude SG blowdown.

CONCLUSION:

- \* Plant is safe.
- \* CAQR postrestart.
- \* Long-term corrective actions to resolve CAQR being evaluated.
- \* Not Appendix R issue

QUESTION 10 (Continued)

ISSUE: Single failure criteria

RESPONSE: \* Standard industry practice

\* Seismic event

Safety-related equipment designed

Do not consider multiple failures of nonseismic components

\* Main steam line break

Independent initiating event

Loss of offsite power

Single failure

1 Active immediately or

1 Passive at 24 hours

Do not combine with seismic event



QUESTION 11

ISSUE: Closure of pressurizer block valve



- \* Closure at 2500 psid specified
- \* Tested using MOVATS system per MI 10.43
- \* Thrust meets or exceeds requirements

CONCLUSION: PRZ blocks closure verified

QUESTION 12

ISSUE: Spurious actuation

RESPONSE: Circuits required for safe shutdown and those not allowed to spuriously operate were analyzed as required circuits

- In general, required circuits protected by separation or fire barriers
- Where separation did not exist, interactions were identified, analyzed, and dispositioned
- Alternate shutdown provided for cable-to-cable areas
  - Main control room
  - Cable spreading room
  - Auxiliary instrument room
- Ungrounded DC control system
- Ungrounded AC off-control transformers
-  
- Separate look back at high/low pressure interfaces
  - Reactor vessel head vents
  - RHR letdown path
  - RCS normal and excess letdown
  - Pressurizer relief paths
- In 3 cases only is GL 86-10 Section 5.3.1 not met

CONCLUSION:

- Met Licensing basis for Appendix R
- Position submitted to NRC
- Reevaluated GL 86-10 5.3.1
- March 8, 1988 submittal

QUESTION 13

ISSUE: Baseline data - SQN-SQS4-127

RESPONSE: Baseline data provided

- ARSK drawings, block diagrams, interaction studies, safety function position statements, approved deviation requests, fire hazards evaluations, engineering change notices
- Task force performed review of selected issues and this was submitted to NRC
- Numerous audits on electrical calculations

CONCLUSION:

- R6 was the revision that reflected plant configuration
- Baseline data exists
- Sufficient number of audits have been performed and determined appropriate calculation methodology used

QUESTION 14

ISSUE: Fire effects on equipment in rooms adjacent to a fire

- RESPONSE:
- ° Fire dampers ensure physical separation
  - ° Fusible links ensure damper will close in a timely manner
  - ° Contain fire and products of combustion
  - ° Equipment qualifications not required for Appendix R or 50.49 requirements
  - ° Containment

Outside - Access not required

Inside - For fires inside containment there are no credible fires that create an adverse environment that requires containment entry to ensure safe shutdown

CONCLUSIONS:

- ° HVAC calculations are not required to demonstrate Appendix R compliance

QUESTION 15

ISSUE: Fire near pressurizer

RESPONSE: Fire Hazards Analysis

- o FHA determined that at least one train of pressurizer level and steam generator level will be available. Insufficient fire load or adequate separation exist for the required instrumentation.

CONCLUSION: Fire in vicinity of pressurizer will not prevent safe shutdown.

QUESTION 17

ISSUE: Validity of passing liquid through safety valve

RESPONSE: Short-term operability has been demonstrated

- EPRI test data supplied

- Crosby 6M6 valve
  - Water test
  - Some chattering/galling of surfaces
  - Summary noted valve closed

- Needed only if
  - pressurizer bubble lost
  - PORV unavailable
  - head vent unavailable
  - normal letdown unavailable
  - excess letdown unavailable
- Pressurizer level instrumentation assured for fire
  - Operator secures charging
- Few challenges anticipated

CONCLUSION:

- Valve will perform as intended
- Not Appendix R required

QUESTION 18

ISSUE: Assuring adequate suction to charging pumps

- Analyzed fire zones
- Identify VCT spurious isolation areas
- Procedurally controlled expeditiously
  - Open 400 Vac breakers
  - or
  - Open RWST supply and open its breaker
  - or
  - Trip CCP until above is completed
- Isolate VCT on VCT level observation

CONCLUSION: Our response to this condition is consistent with what other utilities have done and we have taken appropriate action, consistent with other safety requirements, to protect the CCP from loss of suction.

QUESTION 19

ISSUE: Basis for fire protection of shutdown systems inside containment

RESPONSE: Appendix R, Section III.G.2.a-f, is the basis

- Shutdown logic review
- Equipment identification
- Plant cables
- Evaluate separation
- Documentation

CONCLUSION: Inside containment has been evaluated consistent with our Licensing position on Appendix R.



QUESTIONS 20, 22, 26

ISSUE: Spurious safety injection, distinguish between LOCA and fire

RESPONSE: Spurious safety injection not prevented and instrumentation provided

- Safety injection not required for safe shutdown
- SI terminated criteria

CONCLUSION: Operator can diagnose event and terminate SI.

QUESTION 21

ISSUE: Fire effects on instrument sense lines

RESPONSE: Effects have been evaluated

- Fire Hazards Analysis done for Appendix R instrumentation
- Adequate separation exists or fire effects will not adversely affect both trains of Appendix R instrumentation

CONCLUSION: Adequate instrumentation available to the operator

QUESTION 24

ISSUE: Reactor coolant pump seal integrity

RESPONSE: Seal integrity assured

- SOI 68.2 operating procedure requires pump trip for loss-of-seal cooling (less than 2 minutes)
- WCAP applies to qualified high temperature and nonqualified high-temperature elastomers

Sequoyah uses Parker E515-80 or better elastomers

Immediate seal heatup not expected

Westinghouse tests indicate two-hour survival (one hour needed)

- Worst case is if seals fail

21 gpm/pump leak

CONCLUSION:

- Procedure requires pump trip
- Seals will survive

QUESTION 25

ISSUE: Spurious pressurizer PORV opening - block valve closure

RESPONSE: Operator action will mitigate event

- Fire in control building
- Operators dispatched to auxiliary control room
- Staff overlap between main/auxiliary control room
- AOI-27 checks hi/low interfaces  
Isolation as needed
- AOI-18 requires block valve closure if PORV open  
Attempt from main control room, MOV board  
2-5 minute action time
- Terminate SI per criteria
- Similar to stuck open PORV analysis WCAP-9600  
SI initiated if available  
Only charging would inject  
Additional 700 gallon loss (90,000 gallons RCS)
- Operators trained on AOIs

CONCLUSION:

- Operator mitigates event
- Similar RCS response to analyzed event

DISTRIBUTION FOR MEETING SUMMARY DATED: March 22, 1988

Facility: Sequoyah Nuclear Plant, Units 1 and 2\*

Docket File

NRC PDR

Local PDR

Projects Reading

S. Ebneter

J. Axelrad

S. Richardson

G. Zech

J. Clifford

T. Rotella

C. Jamerson

OGC

J. Rutberg

F. Miraglia

E. Jordan

J. Partlow

G. Hubbard

D. Notley

D. Kubicki

B. D. Liaw

E. Marinos

G. Felgate

E. Gilbert

C. Mullins

P. Hearn

S. West

R. Auluck

R. Wescott

R. Pierson

B. Zalcman

H. Garg

ACRS (10)

Hon. M. Lloyd

Hon. J. Cooper

Hon. D. Sundquist

Hon. A. Gore

Dr. Henry Myers

Mr. R. King, GAO

P. Gwynn

J. Scarborough

G. Marcus

C. Miller

T. Elsasser

C. Ader

TVA-Rockville

SQN Reading File

\*Copies sent to those persons on facility service list

3/30/48