



HELPING BUILD ARKANSAS

ARKANSAS POWER & LIGHT COMPANY

P.O. BOX 551 LITTLE ROCK, ARKANSAS 72203 • (501) 371-4000

November 6, 1978

1-118-3

Mr. K. V. Seyfrit, Director
Office of Inspection & Enforcement
Region IV
U. S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Subject: Arkansas Nuclear One-Unit 1
Docket No. 50-313
License No. DPR-51
Reportable Occurrence Report
No. 50-313/78-29
(File: 0520)

Gentlemen:

In accordance with Arkansas Nuclear One Technical Specification 6.12.3.2, we have attached the subject report concerning the failure of CRD "A" breaker to trip immediately on a trip signal.

Very truly yours, .

Daniel H. Williams
Manager, Licensing

DHW:REI:tw

Attachment

7811200176

*Acc 2
5/1
1/1*

