

MAR 29 1988

Docket No. 50-266
Docket No. 50-315


Wisconsin Electric Power Company
ATTN: Mr. C. W. Fay
Vice President
Nuclear Power Department
231 West Michigan, Room 308
Milwaukee, WI 53201

Gentlemen:

Thank you for your letter dated March 21, 1988, regarding your requested exception to the lifetime storage of radiographs contained in ANSI N45.2.9. We have reviewed your requested change and find that it conforms to the position described in NQA-1. Based on the results of our review, we consider your revised program acceptable. However, you should review all pertinent commitments to ensure that no conflicts exist. If there are changes to other operative QA commitments existing in docketed correspondence outside of the Quality Assurance Program, as described in Section 1.8 of the Point Beach Nuclear Plant (PBNP) Final Safety Analysis Report (FSAR), you are obligated to notify this office. Implementing such changes should be based on 10 CFR 50.54(a)(3) or 10 CFR 50.55 (f)(3) as appropriate.

Please contact Mr. Monte Phillips of my staff at 312/790-5530 with any questions you have regarding this matter.

Sincerely,



Geoffrey C. Wright, Chief
Operations Branch

cc: J. J. Zach, Plant Manager
DCD/DCB(RIDS)
Licensing Fee Management Branch
Resident Inspector, RIII
Virgil Kanable, Chief
Boiler Section
Charles Thompson, Chairman
Wisconsin Public Service
Commission

BB04060236 BB0329
PDR ADDOCK 05000266
P PDR

11
10-01

MAR 29 1988

Wisconsin Electric Power Company

2

Distribution (Con't)

R. I. Braund (SLO),
 WI Div. of Emergency Government
 Lawrence J. McDonnell, Chief
 Radiation Protection Section
 WI Department of Health and
 Social Services, Division
 of Health
 S. H. Weiss, LQAB, NRR
 D. H. Wagner, LPM, NRR

RIII
[Signature]
 Sutphin

RIII ^{NRR}
[Signature] ^{Phillips}
 Vandell ^{Hankins} Phillips

RIII ^{yes}
[Signature]
 DeFayette ^{Wright}